

CARG: INA POWER & LIGHT COMPANY

Brunswick Steam Electric Plant

Units 1 & 2

Low Voltage (208/120 Volt)


Electrical Distribution System Study

Safety Classification: Nuclear Safety Related (Q List)

Seismic Classification: N/A

Project Manager

A. M. Segrest



Revision 1

July, 1984

DUKE
POWER | **MATS**

3409060337 840830
PDR ADOCK 05000324
P PDR

REVISION DOCUMENTATION SHEET

REVISION NUMBER	REVISION DESCRIPTION
1	<p>U.E. & C. revised the 1X-LOCA load data for Panel 31A (Circuit 8) and Panel 32B (Circuit 14) from 1621 VA to 353 VA. Minor changes are noted on the following pages:</p> <p>Page 4 of 14</p> <p>Page 9 of 14</p> <p>Page 12 of 14</p> <p>Page 13 of 14</p> <p>Page A40 of 113</p> <p>Page A99 of 113</p> <p>Page B10 of 24</p> <p>Page B18 of 24</p> <p>Page 1.3 of 106</p> <p>Page 1.49 of 106</p> <p>Page 1.98 of 106</p>

CAROLINA POWER & LIGHT COMPANY

BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 & 2

LOW VOLTAGE (208/120 VOLT) ELECTRICAL DISTRIBUTION SYSTEM

DESIGN ENGINEERING CALCULATION NO. MTS-2076-1808.04-00-001

This is to certify that I, Aldean Bengé, have reviewed the above calculation, which was developed under my direction, and find it to be complete and in conformance with generally accepted engineering practice.

Signature: *Aldean Bengé*

Name: Aldean Bengé
Registered Professional Engineer

PE No. NC 6509

Date: 7/26/84



TABLE OF CONTENTS

	<u>Page</u>
1.0 <u>PURPOSE</u>	3
2.0 <u>SUMMARY</u>	4
3.0 <u>METHOD OF ANALYSIS</u>	5
3.1 <u>MODES OF OPERATION ANALYZED</u>	5
3.2 <u>COMPUTER PROGRAMS</u>	5
3.3 <u>HAND CALCULATIONS</u>	5
4.0 <u>EQUIPMENT VOLTAGE CRITERIA</u>	6
5.0 <u>ASSUMPTIONS</u>	7
6.0 <u>SOURCES OF INFORMATION</u>	8
6.1 <u>LOAD DATA, CABLE IMPEDANCE, AND TRANSFORMER DATA</u>	8
6.2 <u>EQUATIONS AND COMPUTER PROGRAMS</u>	8
7.0 <u>STUDY RESULTS</u>	9
8.0 <u>CONCLUSIONS AND RECOMMENDATIONS</u>	12
9.0 <u>CALCULATION DOCUMENTATION</u>	14
<u>Appendix A - Model One Lines, ASDOP Inputs and Outputs</u>	
<u>Appendix B - Hand Calculations</u>	
<u>Attachment I - Load Data, Transformer Data, and Cable Data Used In ASDOP Model Development</u>	

1.0 PURPOSE

The purpose of this study was to perform the electrical distribution system analyses for Carolina Power & Light (CP&L) Company's Brunswick Steam Electric Plant (BSEP), Units 1 and 2, as required to demonstrate the adequacy of the 208/120 VAC system to supply safety system loads. The objectives of this study were achieved by:

- Identifying voltage requirements (limits) at the load terminals.
- Defining modes of plant operation requiring analysis in order to demonstrate electrical distribution system adequacy.
- Modeling and analyzing the distribution system in order to determine distribution panel bus and load terminal voltages for each mode of operation.
- Comparing computed voltage values with the load requirements.

The above scope of work was performed by Duke Power Company as part of Request for Services Number 12 to the North Carolina Technical Services Agreement with CP&L.

2.0 SUMMARY

In its present configuration, the BSEP 208/120 VAC Distribution System provides acceptable voltage levels to all but three 120 VAC single phase circuits for both LOCA Run and Shutdown modes of operation. These three loads have terminal voltages which, under LOCA Run conditions, fall outside the range specified by study criteria. Cable additions and resizing recommendations are provided in Section 8.0 which will solve these problems. More detailed analyses of the actual load may show these terminal voltages to be within acceptance criteria. If so, no cable modifications would be necessary.

In addition, a slight overvoltage condition exists on certain panels during light load (Shutdown) periods. A tap change of the transformers feeding these panels is recommended, even though this overvoltage condition does not jeopardize the ability of this system to meet its design function.

3.0 METHOD OF ANALYSIS

3.1 MODES OF OPERATION ANALYZED

The 208/120 VAC system was analyzed for LOCA Run and Shutdown modes of operation. The LOCA Run mode represented the steady state condition after a LOCA with the safety loads running. The LOCA Run mode was selected in order to demonstrate the capability of the 208/120 VAC loads to operate with the minimum expected source voltage. The Shutdown mode represented the unit with minimum expected auxiliary load. This case was developed in order to demonstrate that the 208/120 VAC system voltage would be within equipment ratings with the source voltage at the maximum expected value.

3.2 COMPUTER PROGRAMS

The Auxiliary System Design Optimization Program (ASDOP) was used to compute voltages at the 208/120 VAC distribution panel buses. The distribution system was modeled considering the 480 VAC bus supplying the 208/120 VAC system as the source. Impedances of the 480 VAC feeder cable, 480/208/120 VAC transformer and 208/120 VAC feeder cable from the transformer were included in the model. The 208/120 VAC loads were modeled as lumped static (constant impedance) loads at each distribution panel.

3.3 HAND CALCULATIONS

The voltage at the terminals of selected loads was determined by hand calculations. The hand calculations were performed as follows:

- Load impedance was computed using the load KVA and load voltage rating.
- The load terminal voltage was computed by voltage division using the distribution panel voltage, feeder cable impedance and the load impedance.

For the LOCA Run condition, relay or solenoid circuits on each panel were selected for analysis for each of the criteria below:

- Longest cable supplying a single phase load.
- Maximum load on a single phase circuit.
- Single phase loads with cable length more than 50% of the longest cable and load more than 50% of the largest load.

During the Light Load (Shutdown) condition, calculations to determine load terminal voltage were not necessary when the distribution panel bus voltage was less than the load maximum rated voltages. If the distribution bus voltage was more than the load maximum rated voltage, then the circuit with the minimum feeder circuit impedance was examined for compliance with the criteria.

4.0 EQUIPMENT VOLTAGE CRITERIA

The voltage criteria used in this study are as follows:

- The voltage at the load terminal must be maintained at no less than 90% of the device's nominal voltage for the steady state condition after a LOCA on one unit with the other unit shutdown.
- The voltage at the load terminals must not exceed 110% of the device's nominal voltage during a Light Load (Shutdown) condition.

The source voltage was at the minimum expected value for the LOCA Run mode and at the maximum expected value for the Shutdown mode. The single phase loads are rated 115 volts. Thus, the acceptable terminal voltage criteria was 0.90 to 1.10 p.u. on a 115V base or 0.865 to 1.054 p.u. on a 120V base.

5.0 ASSUMPTIONS

The following assumptions were used in this analysis:

- Load on the 208/120 VAC distribution panels was balanced between phases.
- Operating power factor of solenoid and relay devices was 0.5. This assumption was based on a review of power factors of auxiliary relays which typically have a power factor of 0.5 or greater.
- Power factor of loads other than solenoids and relays was 0.85. This should be conservative since it included resistive heaters and other non-inductive type loads.
- The distribution panel load during shutdown was conservatively assumed to be 0.5 times the normal power operation load.

6.0 SOURCES OF INFORMATION

6.1 LOAD DATA, CABLE IMPEDANCE, AND TRANSFORMER DATA

All load, cable, and transformer data required to perform the study was developed by United Engineers and Contractors (U.E. & C.) for CP&L. The data sheets are included in Attachment I and provide a tabulation of the load for Normal and LOCA Run conditions. The distribution panel load during Light Load (Shutdown) operation was obtained by multiplying the Normal Load value by 0.5.

The cable impedance given on the load tabulation sheets is the impedance of one conductor between the distribution panel and the load. The total impedance of the single phase circuit is two times this value.

All cable impedance calculations by Duke Power Company personnel were performed with the aid of Table 1.20 and adjusted to 90°C using the correction factor provided by U.E. & C. Both Table 1.20 and the temperature correction factor can be found on Sheet 53 of U.E. & C. Calculation #7453-127-3-ED00-01 included in Attachment 1. Calculations for cable impedances not provided by U.E. & C. are included in Appendix B.

Worst case transformer data was used in all cases modeled. For LOCA Run models, the transformer impedance was assumed to be nominal plus the allowable tolerance, thereby producing the maximum voltage drop across the transformer and minimum panel voltage. For Light Load (Shutdown) models, the transformer impedance was assumed to be nominal minus the allowable tolerance, thereby producing the minimum voltage drop across the transformer and maximum panel voltage.

6.2 EQUATIONS AND COMPUTER PROGRAMS

Calculations of voltage at the distribution panels utilized the ASDOP 1 computer program developed by Duke Power Company.

Hand calculations were performed using standard textbook equations which are demonstrated in Appendix B.

7.0 STUDY RESULTS

Calculations were performed for the Shutdown and LOCA Run conditions in order to determine the distribution panel and load terminal voltages. ASDOP one-line models and program inputs and outputs for each case are provided in Appendix A. Hand calculations of load terminal voltage are included in Appendix B.

Initial Shutdown studies indicated a potential overvoltage situation on Unit 2 distribution panels supplied by transformers GF4 and GF6. With these transformers tapped at -2.5% (present tap setting), the voltage at some panels exceeded the overvoltage criterion (105.4% on a 120 VAC base) by as much as 0.80%. This voltage is not great enough to be a major concern since there will be some voltage drop in the cables and the time that the voltage would be at the maximum should be limited. The overvoltage can be easily prevented by changing the transformer taps to nominal. In the calculations, taps on these transformers were changed from -2.5% to nominal in order to resolve the overvoltage situation. Taps on the other 208/120 VAC transformers were not changed. The Shutdown case results for before and after the tap change are included in the ASDOP outputs in Appendix A. For the LOCA Run condition, the ASDOP outputs are also included in Appendix A for the tap change cases.

In the LOCA Run cases, three single phase loads were found to have terminal voltages outside the range specified by study criteria. Voltages at all other loads analyzed met the study criteria. The undervoltage condition at the three loads was caused by a combination of heavy load and long cable runs. In the analysis, this problem was corrected either by paralleling the existing cable with another of the same size or by replacing the original cable with a larger one. Details of the individual circuit modification are included in Table 8-1.

With the tap change and the recommended cable modifications, voltage at the load terminals was above the minimum allowable value (0.90 pu on a 115V base) for the LOCA Run case and below the maximum value (1.10 pu on a 115V base) for the Light Load (Shutdown) case. The results of the modifications are demonstrated by the summary of LOCA Run and Light Load study results in Table 7-1 for Unit 1 and Table 7-2 for Unit 2.

TABLE 7-1
BSEP - Unit #1

208/120 VAC Distribution System Bus and Load Terminal Voltages
(After Implementation of Recommendations)

PANEL	LOCA RUN VOLTAGES ¹ (p.u. on a 115V base)			Shutdown Voltages ² (p.u. on a 115V base)
	Panel Bus	Terminals of Load with Longest Cable	Terminals of Largest Load	Panel Bus
1A-TB	0.9699	0.9690	0.9493	1.0928
31AB	0.9718	0.9641	0.9641	1.0938
1C	0.9718	0.9428	0.9428	1.0938
1A	0.9716	0.9658	0.9508	1.0938
1AB-RX	0.9706	0.9685	0.9696	1.0937
1AB	0.9716	0.9555	0.9634	1.0938
1A-RX	0.9700	0.9671	0.9693	1.0928
1AB-TB	0.9658	0.9619	0.9023	1.0922
1B-TB	0.9712	0.9703	N/A	1.0950
1B-RX	0.9707	0.9694	N/A	1.0948
1D	0.9718	0.9113	N/A	1.0953
1B	0.9715	0.9600	0.9581	1.0951
31A	0.9549	0.9539	0.9543	1.0802
1A-DG	0.9554	0.9547	0.9532	1.0793
31B	0.9548	0.9005	0.9431	1.0863
1B-DG	0.9472	0.9460	0.9444	1.0823

Notes:

1. Acceptance Voltage \geq 0.90 p.u. on a 115V base
2. Acceptance Voltage \leq 1.10 p.u. on a 115V base

TABLE 7-2
BSEP - Unit #2

208/120 VAC Distribution System Bus and Load Terminal Voltages
(After Implementation of Recommendations)

PANEL	LOCA RUN VOLTAGES ¹ (p.u. on a 115V base)			Shutdown Voltages ² (p.u. on a 115V base)
	Panel Bus	Terminals of Load with Longest Cable	Terminals of Largest Load	Panel Bus
2A-TB	0.9607	0.9526	0.9499	1.0753
32AB	0.9639	0.9632	0.9552	1.0771
2C	0.9640	0.9489	0.9521	1.0771
2A	0.9639	0.9531	0.9431	1.0771
2AB-RX	0.9633	0.9622	N/A	1.0769
2AB	0.9637	0.9509	0.9510	1.0770
2A-RX	0.9632	0.9603	0.9617	1.0768
2AB-TB	0.9634	0.9183	0.9280	1.0783
2B-TB	0.9658	0.9649	N/A	1.0794
2B-RX	0.9654	0.9636	N/A	1.0792
2D	0.9676	0.9303	0.9589	1.0803
2B	0.9674	0.9560	0.9546	1.0802
32A	0.9789	0.9756	0.9785	1.0986
2A-DG	0.9711	0.9682	0.9682	1.0940
32B	0.9697	0.9551	0.9091	1.0971
2B-DG	0.9720	0.9666	0.9686	1.0964

Notes:

1. Acceptance Voltage \geq 0.90 p.u. on a 115V base
2. Acceptance Voltage \leq 1.10 p.u. on a 115V base

Page 11 of 14
 Performed by:
 Checked by: *CRP*
SC 6-6-84

8.0 CONCLUSIONS AND RECOMMENDATIONS

A potential for voltages slightly exceeding the voltage criteria exists on the Unit 2 Low Voltage (208/120 VAC) system when a unit is shutdown. Although the voltage is not great enough to present a significant concern, a tap change of transformers GF4 and GF6 from -2.5% to nominal is recommended to correct this situation. In addition, the cable changes shown in Table 8-1 are recommended to alleviate undervoltage conditions during LOCA Run operation unless detailed analysis based on the voltage drop of the individual circuit components show these modifications to be unnecessary. After implementation of these recommendations, adequate voltage should be maintained on the 208/120 VAC safety system during LOCA Run and Shutdown modes of operation.

TABLE 8-1
BSEP UNITS 1 & 2

Recommended Load Feeder Cable Modifications

Panel	Circuit #	Cable	Cable Length (Ft.)	Panel Voltage $ V_p $ @ 115 VAC (p. u.)	Load $ S $ (VA)	Load Terminal Voltage $ V_L $ @ 115 VAC (p. u.)
1AB-TB	18	As-built with one #12 cable	908	0.9658	882	0.8398
		Replace with two #12 cables	908	0.9658	882	0.9023
2AB-TB	16	As-built with one #12 cable	648	0.9634	882	0.8732
		Replace with two #12 cables	648	0.9634	882	0.9183
2D	12	As-built with one #12 cable	1961	0.9676	240	0.8929
		Replace with two #12 cables	1961	0.9676	240	0.9303

Page 13 of 14
 Performed by: CRP
 Checked by: SC
 7-27-84

9.0 CALCULATION DOCUMENTATION

- A. PROBLEM: See Section 1.0
- B. RELATIONSHIP TO QA CONDITION: Nuclear Safety Related (QA Condition 1)
- C. DESIGN METHODS: ASDOP computer program and standard engineering practices and techniques
- D. APPLICABLE CODES AND STANDARDS (Name, Number, Date, Revision): N/A
- E. OTHER DESIGN CRITERIA: None
- F. RELATED SAR CRITERIA (PSAR or FSAR, Page, Amendment) Updated FSAR dated 7/19/82
- G. CALCULATIONS ----- Appendix B
- H. ASSUMPTIONS ----- Section 5.0
- I. REFERENCES ----- N/A
- J. CONCLUSION ----- Section 8.0

APPENDIX A


Model One Lines

ASDOP Inputs and Outputs

Table of Contents

	<u>Page</u>
BSEP Unit 1 - ASDOP Model #1	A2
BSEP Unit 1 - ASDOP Model #2	A13
BSEP Unit 1 - ASDOP Model #3	A23
BSEP Unit 1 - ASDOP Model #4	A31
BSEP Unit 1 - ASDOP Model #5	A39
BSEP Unit 1 - ASDOP Model #6	A47
BSEP Unit 2 - ASDOP Model #1	A55
BSEP Unit 2 - ASDOP Model #2	A69
BSEP Unit 2 - ASDOP Model #3	A82
BSEP Unit 2 - ASDOP Model #4	A90
BSEP Unit 2 - ASDOP Model #5	A98
BSEP Unit 2 - ASDOP Model #6	A106

BSEP - Unit #1



ASDOP MODEL #1

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #1
Swgr. IE5

STATIC LOADS

DATA					
INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-5-1	.208	3.695	.85	LAG	LIGHTLY LOADED RUN
L-5-2	.208	0.566	.5	LAG	LIGHTLY LOADED RUN
L-6-1	.208	0.288	.85	LAG	LIGHTLY LOADED RUN
L-6-2	.208	0.250	.5	LAG	LIGHTLY LOADED RUN
L-7-1	.208	0.665	.85	LAG	LIGHTLY LOADED RUN
L-7-2	.208	0.090	.5	LAG	LIGHTLY LOADED RUN
L-8-1	.208	1.386	.85	LAG	LIGHTLY LOADED RUN
L-8-2	.208	1.219	.5	LAG	LIGHTLY LOADED RUN
L-9-1	.208	0.406	.85	LAG	LIGHTLY LOADED RUN
L-9-2	.208	0.040	.5	LAG	LIGHTLY LOADED RUN
L-10-1	.208	1.177	.85	LAG	LIGHTLY LOADED RUN
L-10-2	.208	0.780	.5	LAG	LIGHTLY LOADED RUN
L-11-1	.208	1.538	.85	LAG	LIGHTLY LOADED RUN
L-11-2	.208	0.078	.5	LAG	LIGHTLY LOADED RUN

Page A4 of 113
Performed by:
Checked by:

CRP
6-6-84
E.C. 84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #1
Swgr. 1E5

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE	RESISTANCE
		(OHMS) X	(OHMS) R
B1-2-1A	Cable	0.0238	0.0259
B3-4-1A	Cable	0.0010	0.0011
B4-5-1A	Cable	0.0051	0.0091
B4-6-1A	Cable	0.0040	0.0072
B4-7-1A	Cable	0.0026	0.0046
B4-8-1A	Cable	0.0021	0.0021
B4-9-1A	Cable	0.0130	0.0231
B4-10-1A	Cable	0.0018	0.0032
B4-11-1A	Cable	0.0130	0.0231

Page A6 of 113
Performed by: CRG 6-6-84
Checked by: SC E. E. S. L.

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

00000

DUKE POWER COMPANY

DATE = 05/10/84

CRC 5-10-84

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

RSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #1(SUBR 1E5) LOCA RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%

BUS VOLTAGES,CURRENTS,AND POWER FLOWS

00000

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 11 NO. OF LINES= 10

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000009 0.000005

SUMMARY OF TAPS

FROM-BUS 2 TO-BUS 3 XTAPS -2.50

LINE FLOWS

FROM-BUS	TO-BUS	KW	KVAR	KVA	LINE CURRENT MAG(KA)
1	2	16.326	13.429	21.140	0.028
2	1	-16.266	-13.375	21.059	0.028
2	3	16.266	13.374	21.058	0.028
3	2	-16.226	-13.262	20.956	0.062
3	4	16.238	13.266	20.968	0.062
4	3	-16.225	-13.255	20.951	0.062
4	5	5.929	4.218	7.276	0.022
4	6	0.419	0.501	0.653	0.002
4	7	0.770	0.788	1.102	0.003
4	8	3.089	3.155	4.415	0.013
4	9	1.521	0.981	1.810	0.005

AS-BUILT WITH XFMR TAPPED AT -2.5%

RSEP UNIT #1 208/120 VOLT LOAD STUDY

PAGE 2

05/10/84

4	10	2.148	2.084	2.992	0.009
4	11	2.339	1.524	2.792	0.008

5	4	-5.916	-4.211	7.262	0.022

6	4	-0.419	-0.501	0.653	0.002

7	4	-0.770	-0.788	1.102	0.003

8	4	-3.088	-3.154	4.414	0.013

9	4	-1.519	-0.980	1.807	0.005

10	4	-2.147	-2.083	2.992	0.009

11	4	-2.334	-1.521	2.786	0.008

-----BUS DATA-----

NO.	NAME	---VOLTAGE---		---GENERATION---		---MOTOR---		---STATIC---		---MISMATCH---		
		MAG(PU)	ANG(DEG)	BASE(KV)	KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	SMGR1E5	0.9168	-10.92	0.480	16.33	13.43	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	0.9133	-10.93	0.480	0.00	0.00	0.00	0.00	0.00	0.00	-0.0004	-0.0004
3	XFMR5	0.9322	-11.10	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.0117	0.0043
4	PNL1E5	0.9314	-11.10	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0104	-0.0042
5	PNL1ATB	0.9295	-11.09	0.208	0.00	0.00	0.00	0.00	5.92	4.21	-0.0000	0.0000
6	PNL31AB	0.9313	-11.10	0.208	0.00	0.00	0.00	0.00	0.42	0.50	-0.0000	-0.0001
7	PNL1C	0.9313	-11.10	0.208	0.00	0.00	0.00	0.00	0.77	0.79	-0.0001	0.0003
8	PNL1A	0.9311	-11.10	0.208	0.00	0.00	0.00	0.00	3.09	3.15	-0.0002	0.0004
9	PNL1ABRX	0.9302	-11.10	0.208	0.00	0.00	0.00	0.00	1.52	0.98	-0.0000	0.0000
10	PNL1AB	0.9311	-11.10	0.208	0.00	0.00	0.00	0.00	2.15	2.08	0.0000	-0.0002
11	PNL1ARX	0.9296	-11.09	0.208	0.00	0.00	0.00	0.00	2.33	1.52	0.0000	0.0000

RELEASE 9, 10/1/79
ENTER COMMAND

BRANCH ELEMENTS

-INPUT CODE-	TYPE	++++CABLE OR BUS++++		++++CABLE++++		++++BUS++++			++REACTOR OR CAPACITOR++			
		---X---	---R---	NO.-SIZE	--FT--	---X/FT--	---R/FT--	--FT--	--X(FU)--	--IR--	--KV--	
B 1-	2- 1A	CAB		2.38E-02	2.59E-02							
B 3-	4- 1A	CAB		1.00E-03	1.10E-03							
B 4-	5- 1A	CAB		5.10E-03	9.10E-03							

Page A8 of 113
 Performed by: CRB 6-6-84
 Checked by: SC 6-6-84

AS-BUILT WITH XFMR TAPPED AT -2.5%

BSEP UNIT #1 208/120 VOLT LOAD STUDY

PAGE 3

05/10/84

B	4-	6-	1A	CAB	4.00E-03	7.20E-03
B	4-	7-	1A	CAB	2.60E-03	4.60E-03
B	4-	8-	1A	CAB	2.10E-03	2.10E-03
B	4-	9-	1A	CAB	1.30E-02	2.31E-02
B	4-	10-	1A	CAB	1.80E-03	3.20E-03
B	4-	11-	1A	CAB	1.30E-02	2.31E-02

2-WINDING TRANSFORMERS

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAB-	-X/R-
T 2- 3- 1	0.0333	0.48	0.21	150.00	150.00*	2.82

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0- 5- 1	0.21	7.39	0.85	LAG
L 0- 5- 2	0.21	1.13	0.50	LAG
L 0- 6- 1	0.21	0.27	0.85	LAG
L 0- 6- 2	0.21	0.50	0.50	LAG
L 0- 7- 1	0.21	0.66	0.85	LAG
L 0- 7- 2	0.21	0.65	0.50	LAG
L 0- 8- 1	0.21	2.68	0.85	LAG
L 0- 8- 2	0.21	2.57	0.50	LAG
L 0- 9- 1	0.21	2.02	0.85	LAG
L 0- 9- 2	0.21	0.08	0.50	LAG
L 0- 10- 1	0.21	2.00	0.85	LAG
L 0- 10- 2	0.21	1.56	0.50	LAG
L 0- 11- 1	0.21	3.09	0.85	LAG
L 0- 11- 2	0.21	0.15	0.50	LAG

SYSTEM EQUIVALENT

-INPUT CODE-	--FNVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A9 of 113
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84

CRC 5-10-84

05/10/84

RSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #1(SWGR 1ES) LIGHTLY LOADED CASE WITH SWYD VO=1.017

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 11 NO. OF LINES= 10

00000

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000001 0.000007

SUMMARY OF TAPS

FROM-BUS TO-BUS ZTAPS
2 3 -2.50

LINE FLOWS

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	10.242	8.225	13.136	0.015
2	1	-10.224	-8.208	13.111	0.015
2	3	10.219	8.203	13.104	0.015
3	2	-10.209	-8.174	13.078	0.035
3	4	10.233	8.181	13.102	0.035
4	3	-10.229	-8.178	13.096	0.035
4	5	3.759	2.675	4.614	0.012
4	6	0.406	0.404	0.573	0.002
4	7	0.668	0.469	0.816	0.002
4	8	1.965	1.962	2.777	0.007
4	9	0.401	0.273	0.485	0.001

AS-BUILT WITH XFMR TAPPED AT -2.5%

RSEP UNIT #1 206/120 VOLT LOAD STUDY

PAGE 2

05/10/84

4	10	1.527	1.423	2.087	0.006
4	11	1.478	0.964	1.764	0.005

5	4	-3.755	-2.672	4.609	0.012

6	4	-0.406	-0.404	0.573	0.002

7	4	-0.667	-0.469	0.816	0.002

8	4	-1.965	-1.962	2.777	0.007

9	4	-0.401	-0.273	0.485	0.001

10	4	-1.527	-1.423	2.087	0.006

11	4	-1.477	-0.963	1.763	0.005

-----BUS DATA-----

NO.	NAME	---VOLTAGE---		BASE(KV)	---GENERATION---		---MOTOR---		---STATIC---		---MISMATCH---	
		MAG(PU)	ANG(DEG)		KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	SUGR1ES	1.0266	-4.81	0.480	10.24	8.22	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	1.0246	-4.82	0.480	0.00	0.00	0.00	0.00	0.00	0.00	-0.0042	-0.0046
3	XFMR5	1.0488	-4.89	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.0246	0.0078
4	PNL1ES	1.0483	-4.89	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0258	-0.0076
5	PNL1ATB	1.0473	-4.88	0.208	0.00	0.00	0.00	0.00	3.76	2.67	0.0002	0.0001
6	PNL31AB	1.0482	-4.89	0.208	0.00	0.00	0.00	0.00	0.41	0.40	0.0007	0.0003
7	PNL1C	1.0482	-4.89	0.208	0.00	0.00	0.00	0.00	0.67	0.47	0.0021	0.0009
8	PNL1A	1.0482	-4.89	0.208	0.00	0.00	0.00	0.00	1.96	1.96	-0.0009	-0.0001
9	PNL1ABRX	1.0481	-4.89	0.208	0.00	0.00	0.00	0.00	0.40	0.27	0.0001	0.0000
10	PNL1AB	1.0482	-4.89	0.208	0.00	0.00	0.00	0.00	1.53	1.42	0.0009	0.0006
11	PNL1ARX	1.0473	-4.89	0.208	0.00	0.00	0.00	0.00	1.48	0.96	0.0002	0.0001

RELEASE 9, 10/1/79
ENTER COMMAND

BRANCH ELEMENTS

-INPUT CODE-	TYPE	+++CABLE OR BUS+++		+++CABLE+++++		++++BUS+++++				++REACTOR OR CAPACITOR+++			
		---X---	---R---	NO.-	SIZE	--FT--	---X/FT--	---R/FT--	--FT--	--X(PU)--	--[R--	--[V--	
B 1-	2- 1A	CAP		2.38E-02	2.59E-02								
B 3-	4- 1A	CAP		1.00E-03	1.10E-03								
B 4-	5- 1A	CAP		5.10E-03	9.10E-03								

Page All of 113
 Performed by: CRG 6-6-84
 Checked by: SC 6-6-84

AS-BUILT XFMR TAPPED AT -2.5%

BSEP UNIT #1 208/120 VOLT LOAD STUDY

PAGE 3

05/10/84

B	4-	6-	1A	CAB	4.00E-03	7.20E-03
B	4-	7-	1A	CAB	2.60E-03	4.60E-03
B	4-	8-	1A	CAB	2.10E-03	2.10E-03
B	4-	9-	1A	CAB	1.30E-02	2.31E-02
B	4-	10-	1A	CAB	1.80E-03	3.20E-03
B	4-	11-	1A	CAB	1.30E-02	2.31E-02

2-WINDING TRANSFORMERS

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAR-	-X/R-
T 2- 3- 1	0.0287	0.48	0.21	150.00	150.00*	2.82

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0- 5- 1	0.21	3.69	0.85	LAG
L 0- 5- 2	0.21	0.57	0.50	LAG
L 0- 6- 1	0.21	0.29	0.85	LAG
L 0- 6- 2	0.21	0.25	0.50	LAG
L 0- 7- 1	0.21	0.66	0.85	LAG
L 0- 7- 2	0.21	0.09	0.50	LAG
L 0- 8- 1	0.21	1.39	0.85	LAG
L 0- 8- 2	0.21	1.22	0.50	LAG
L 0- 9- 1	0.21	0.41	0.85	LAG
L 0- 9- 2	0.21	0.04	0.50	LAG
L 0- 10- 1	0.21	1.18	0.85	LAG
L 0- 10- 2	0.21	0.78	0.50	LAG
L 0- 11- 1	0.21	1.54	0.85	LAG
L 0- 11- 2	0.21	0.08	0.50	LAG


SYSTEM EQUIVALENT

-INPUT CODE-	--FMVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A12 of 113
 Performed by: CRD 6-6-84
 Checked by: SC 6-6-84

BSEP - Unit #1



ASDOP MODEL #2

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #2
Swgr. 1E6

STATIC LOADS

DATA					
INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-5-1	0.208	11.388	.85	LAG	LOCA RUN
L-5-2	0.208	1.625	.5	LAG	LOCA RUN
L-6-1	0.208	2.455	.85	LAG	LOCA RUN
L-6-2	0.208	0.021	.5	LAG	LOCA RUN
L-7-1	0.208	4.896	.85	LAG	LOCA RUN
L-7-2	0.208	0.047	.5	LAG	LOCA RUN
L-8-1	0.208	0.776	.85	LAG	LOCA RUN
L-8-2	0.208	0.657	.5	LAG	LOCA RUN
L-9-1	0.208	5.274	.85	LAG	LOCA RUN
L-9-2	0.208	0.975	.5	LAG	LOCA RUN
L-5-1	0.208	5.214	.85	LAG	LIGHTLY LOADED RUN
L-5-2	0.208	0.867	.5	LAG	LIGHTLY LOADED RUN
L-6-1	0.208	1.228	.85	LAG	LIGHTLY LOADED RUN
L-6-2	0.208	0.011	.5	LAG	LIGHTLY LOADED RUN
L-7-1	0.208	2.395	.85	LAG	LIGHTLY LOADED RUN
L-7-2	0.208	0.024	.5	LAG	LIGHTLY LOADED RUN
L-8-1	0.208	0.657	.85	LAG	LIGHTLY LOADED RUN
L-8-2	0.208	0.056	.5	LAG	LIGHTLY LOADED RUN
L-9-1	0.208	2.790	.85	LAG	LIGHTLY LOADED RUN
L-9-2	0.208	0.488	.5	LAG	LIGHTLY LOADED RUN

Page A14 of 113
 Performed by: CRC 6-6-6
 Checked by: SC 6-6-6

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #2
Swgr. 1E6

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.0333	0.480	0.208	150	150	2.82	LOCA RUN
T2-3-1	0.0287	0.480	0.208	150	150	2.82	LIGHTLY LOADED RUN

Page A15 of 113
 Performed by: *CRL*
 Checked by: *SC*
 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #2
Swgr. 1E6

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE	RESISTANCE
		(OHMS) X	(OHMS) R
B1-2-1A	Cable	0.0159	0.0177
B3-4-1A	Cable	0.0007	0.0007
B4-5-1A	Cable	0.0103	0.0183
B4-6-1A	Cable	0.0059	0.0105
B4-7-1A	Cable	0.0050	0.0089
B4-8-1A	Cable	0.0018	0.0032
B4-9-1A	Cable	0.0019	0.0020

Page A16 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASPOP)

DATE = 05/10/84

CRC 5-10-84

SC 5/11/84 #1

BSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #2(SWGR 1E6) LOCA RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 9 NO. OF LINES= 8

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000006 0.000004

00000

SUMMARY OF TAPS

FROM-BUS TO-BUS XTAPS
2 3 -2.50

LINE FLOWS

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	19.779	13.983	24.222	0.032
2	1	-19.725	-13.935	24.151	0.032
2	3	19.725	13.934	24.150	0.032
3	2	-19.672	-13.787	24.023	0.072
3	4	19.682	13.787	24.031	0.072
4	3	-19.671	-13.776	24.016	0.072
4	5	9.051	6.380	11.074	0.033
4	6	1.818	1.137	2.144	0.006
4	7	3.626	2.270	4.278	0.013
4	8	0.857	0.848	1.206	0.004
4	9	4.310	3.142	5.333	0.016

Page A17 of 113
Performed by: *CRC 6-6-84*
Checked by: *SC 6-6-84*

AS-BUILT WITH XFMR TAPPED AT -2.5%

RSEF UNIT #1 208/120 VOL1 LOAD STUDY

PAGE 3

05/10/84

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAB-	-X/R-
T 2- 3- 1	0.0333	0.48	0.21	150.00	150.00*	2.82

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0- 5- 1	0.21	11.39	0.85	LAG
L 0- 5- 2	0.21	1.63	0.50	LAG
L 0- 6- 1	0.21	2.45	0.85	LAG
L 0- 6- 2	0.21	0.02	0.50	LAG
L 0- 7- 1	0.21	4.90	0.85	LAG
L 0- 7- 2	0.21	0.05	0.50	LAG
L 0- 8- 1	0.21	0.78	0.85	LAG
L 0- 8- 2	0.21	0.66	0.50	LAG
L 0- 9- 1	0.21	5.27	0.85	LAG
L 0- 9- 2	0.21	0.97	0.50	LAG

SYSTEM EQUIVALENT

-INPUT CODE-	--FMVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A19 of 113
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

05/10/84

PAGE 1

RSEP UNIT #1 208/120 VOLT LOAD STUDY

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES, 0=NO)
 GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS
 LOAD FLOW AND LIST ALL
 DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO, C=CHANGE)
 DO YOU WANT ALL BUSES OUTPUTTED? (0=NO, 1=YES, 2=DEFAULT)

00000

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
 OPTIMIZATION PROGRAM
 (ASDOP)

RSEP UNIT #1 208/120 VOLT LOAD STUDY
 MODEL #2(SMGR 1E6) LIGHTLY LOADED RUN WITH SMYD V0=1.017

DATE = 05/10/84

CRC 5-10-84
 SC 5/10/84 #3

AS-BUILT WITH XFMR TAPPED AT -2.5%

BUS VOLTAGES, CURRENTS, AND POWER FLOWS

00000

CASE TITLE: LOAD FLOW AND LIST ALL

NO. OF BUSES= 9 NO. OF LINES= 8
 SWING BUS NO.= 1
 NO. OF ITERATIONS= 4
 ABS VOLTAGE ERROR= 0.000000 0.000000

-----SUMMARY OF TAPS-----

FROM-BUS	TO-BUS	TAPS
2	3	-2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	KW	KVAR	KVA	LINE CURRENT MAG(KA)
1	2	12.319	8.554	14.998	0.018
2	1	-12.303	-8.539	14.976	0.018
2	3	12.304	8.541	14.978	0.018
3	2	-12.290	-8.503	14.945	0.040
3	4	12.298	8.499	14.949	0.040
4	3	-12.295	-8.495	14.945	0.040
4	5	5.346	3.841	6.583	0.017
4	6	1.156	0.723	1.364	0.004
4	7	2.253	1.411	2.658	0.007

05/10/84

8SEF UNIT #1 208/120 VOLT LOAD STUDY AS-BUILT WITH XFMR TAPPED AT -2/5%
PAGE 2

5	4	-5.329	-3.631	6.564	0.017
6	4	-1.156	-0.723	1.363	0.004
7	4	-2.251	-1.410	2.657	0.007
8	4	-0.645	-0.434	0.777	0.002
9	4	-2.878	-2.081	3.552	0.009

BUS DATA

NO.	NAME	VOLTAGE		GENERATION		MOTOR		LOAD		STATIC		MISHAHL	
		MAG(FU)	ANG(DEG)	BASE(KV)	KU	KVAR	KU	KVAR	KU	KVAR	KU	KVAR	KU
1	SUGRIE6	1.0276	-4.75	0.480	12.32	8.55	0.00	0.00	0.00	0.00	0.00	0.0009	0.0000
2	XFHRF	1.0261	-4.76	0.480	0.00	0.00	0.00	0.00	0.00	0.00	0.0007	0.0025	0.0007
3	XFHRS	1.0501	-4.85	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.0032	-0.0039	0.0007
4	FHLIE6	1.0497	-4.85	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0163	-0.0945	0.0007
5	FHLIATR	1.0467	-4.84	0.208	0.00	0.00	0.00	0.00	0.00	5.33	3.83	0.0013	0.0006
6	FHLIBR	1.0494	-4.85	0.208	0.00	0.00	0.00	0.00	0.00	1.16	0.72	-0.0905	-0.0902
7	FHLIPRX	1.0492	-4.85	0.208	0.00	0.00	0.00	0.00	0.00	2.25	1.41	0.0027	0.0013
8	FHLIB	1.0497	-4.85	0.208	0.00	0.00	0.00	0.00	0.00	0.65	0.43	0.0014	0.0007
9	FHLIR	1.0495	-4.86	0.208	0.00	0.00	0.00	0.00	0.00	2.88	2.08	0.0029	0.0051

RELEASE 9, 10/1/79
ENTER COMMAND

-INPT CODE-		TYPE	+++CABLE OR BUS+++	NO.-SIZE	---R---	+++CABLE+++++	NO.-SIZE	---R---	+++BUS+++++	---R/FT---	---FT---	+++REACTOR OR CAPACITOR+++	---R/FT---	---FT---	---R/FT---	---FT---	---R/FT---
B 1	2-1A	CAB	1.59E-02	1.77E-02													
B 3	4-1A	CAB	7.00E-04	7.00E-04													
B 4	5-1A	CAB	1.03E-02	1.83E-02													
B 4	6-1A	CAB	5.90E-03	1.05E-02													
B 4	7-1A	CAB	5.00E-03	8.90E-03													
B 4	8-1A	CAB	1.80E-03	3.20E-03													
B 4	9-1A	CAB	1.90E-03	2.00E-03													

2-WINDING TRANSFORMERS

BSEP UNIT #1 208/120 VOLT LOAD STUDY

AS-BUILT WITH XFMR TAPPED AT -2.5%
PAGE 3

05/19/84

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAB-	-X/R-
T 2- 3- 1	0.0287	0.48	0.21	150.00	150.00*	2.82

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0- 5- 1	0.21	5.21	0.85	LAG
L 0- 5- 2	0.21	0.87	0.50	LAG
L 0- 6- 1	0.21	1.23	0.85	LAG
L 0- 6- 2	0.21	0.01	0.50	LAG
L 0- 7- 1	0.21	2.39	0.85	LAG
L 0- 7- 2	0.21	0.02	0.50	LAG
L 0- 8- 1	0.21	0.66	0.85	LAG
L 0- 8- 2	0.21	0.06	0.50	LAG
L 0- 9- 1	0.21	2.79	0.85	LAG
L 0- 9- 2	0.21	0.49	0.50	LAG


SYSTEM EQUIVALENT

-INPUT CODE-	--FNVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A22 of 113
Performed by: CRC 6-6-8
Checked by: SC 6-6-84

BSEP - Unit #1



ASDOP MODEL #3

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #3
Pnl. 31A

STATIC LOADS

DATA					
INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-4-1	0.208	1.129	0.85	LAG	LOCA RUN
L-4-2	0.208	0.143	0.5	LAG	LOCA RUN
L-4-1	0.208	0.565	0.85	LAG	LIGHTLY LOADED RUN
L-4-2	0.208	0.074	0.5	LAG	LIGHTLY LOADED RUN

Page A24 of 113
 Performed by: *CRC* 6-6-88
 Checked by: *SC* C.C.C.

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #3
Pnl. 31A

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.0273	0.480	0.208	30	30	0.63	LOCA RUN
T2-3-1	0.0257	0.480	0.208	30	30	0.63	LIGHTLY LOADED RUN

Page A25 of 113
Performed by: *CPC*
Checked by: *SC* 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #3
Pnl. 31A

BRANCH ELEMENTS

INPUT CODE	BRANCH TYPE	BRANCH ELEMENTS	
		REACTANCE (OHMS) X	RESISTANCE (OHMS) R
B1-2-1A	Cable	0.0029	0.0387
B3-4-1A	Cable	0.0010	0.0031

ENTER COMMAND

HOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASOP)

RSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #3(PIL 31A) LOCA RUN

DATE = 05/10/84

CRC 5-10-84
SC 5/11/84

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000002 0.000003

00000

SUMMARY OF TAPS

FROM-BUS TO-BUS TAPS
2 3 -2.50

LINE FLOWS

FROM-BUS	TO-BUS	LINE POWER FLOW			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	0.866	0.603	1.055	0.001
2	1	-0.866	-0.603	1.055	0.001
2	3	0.865	0.603	1.055	0.001
3	2	-0.864	-0.602	1.053	0.003
3	4	0.864	0.601	1.053	0.003
4	3	-0.864	-0.601	1.053	0.003

BUS DATA

Page A27 of 113
Performed by: *CRC* 6-6-84
Checked by: *SC* 6-6-84

RSEF UNIT #1 208/120 VOLT LOAD STUDY AS-BUILT WITH XFMR TAPPED AT -2.5% PAGE 2 05/10/84

NO.	NAME	MAG(FU)	ANG(DEG)	BASE(KV)	---GENERATION---			---MOTOR---			---STATIC---			---MISMATCH---		
					KW	KVAR	KU	KW	KVAR	KU	KW	KVAR	KU	KW	KVAR	KU
1	MC1CA	0.8944	-11.25	0.460	0.87	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0000	0.0000	0.0000
2	XFMRP	0.8942	-11.24	0.480	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.0003	0.0000	0.0000
3	XFMR5	0.7152	-11.24	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0009	-0.0008	0.0000
4	PNL31A	0.9151	-11.23	0.208	0.00	0.00	0.00	0.00	0.00	0.86	0.60	0.00	0.00	-0.0008	0.0000	0.0007

RELEASE 9, 10/1/79
 ENTER COMMAND

BRANCH ELEMENTS	+++CABLE OR BUS+++	+++CABLE+++	NO.-SIZE	---R---	---X/FT---	---R/FT---	---X/FT---	---FT---	+++BUS+++++	---R/FT---	---X/FT---	---FT---	+++REACTOR OR CAPACITOR+++
-INPUT CODE-	TYPE	---											
B 1- 2- 1A	CAB	2.90E-03	3.87E-02										
B 3- 4- 1A	CAB	1.00E-03	3.10E-03										

2-WINDING TRANSFORMERS

-INPUT CODE-	---XT---	---KV1-	0.48	---KV2-	0.21	---KVAT-	30.00	---KVAB-	30.00*	---X/R-	0.63
T 2- 3- 1	0.0273										

STATIC LOADS

-INPUT CODE-	---KV---	---KVA---	---PFL-	LEAD/LAG
L 0- 4- 1	0.21	1.13	0.85	LAG
L 0- 4- 2	0.21	0.14	0.50	LAG

SYSTEM EQUIVALENT

-INPUT CODE-	---FMVA---	---KV---	---X/R---
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84

CRC 5-10-84

SC 5/10/84 J

BSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #3(PNL 31A) LIGHTLY LOADED RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 4 NO. OF LINES= 3

00000

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000001 0.000002

SUMMARY OF TAPS

FROM-BUS TO-BUS XTAPS
2 3 -2.50

LINE FLOWS

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	0.560	0.388	0.681	0.001
2	1	-0.560	-0.388	0.681	0.001
2	3	0.555	0.388	0.677	0.001
3	2	-0.554	-0.388	0.676	0.002
3	4	0.544	0.384	0.666	0.002
4	3	-0.544	-0.384	0.666	0.002

BUS DATA

Page A29 of 113
Performed by: *CRC 6-6-84*
Checked by: *SC 6-6-84*

05/10/84

AS-BUILT WITH XFMR TAPPED AT -2.5%

PAGE 2

RSEF UNIT #1 208/120 VOLT LOAD STUDY

NO.	NAME	VOLTAGE		GENERATION		MOTOR		STATIC		MISMATCH	
		MAG(PU)	ANG(DEG)	BASE(KV)	KU	KVAR	KU	KVAR	KU	KVAR	KU
1	MCL1CA	1.0105	-5.00	0.480	0.56	0.39	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	1.0104	-5.00	0.480	0.00	0.00	0.00	0.00	0.00	-0.0049	-0.0001
3	XFMRB	1.0353	-4.99	0.208	0.00	0.00	0.00	0.00	0.00	-0.0100	-0.0033
4	PNL31A	1.0352	-4.99	0.208	0.00	0.00	0.00	0.55	0.39	0.0100	0.0033

RELEASE 9, 10/1/79
 ENTER COMMAND

-INPUT CODE-		TYPE		+++CABLE OR BUS+++		BRANCH ELEMENTS		++REACTOR OR CAPACITOR++	
		---X---	---R---	---X---	---R---	---X/VI---	---R/VI---	---X(PU)---	---IR---
B 1-	2-1A	CAB	2.90E-03	3.87E-02	NO.-SIZE	---X/VI---	---R/VI---	---FI---	---IR---
B 3-	4-1A	CAB	1.00E-03	3.10E-03					

2-WINDING TRANSFORMERS

-INPUT CODE-	---XT---	---KV1-	---KV2-	---KVAT-	---KVAB-	---X/R-
T 2-	3-1	0.0257	0.48	0.21	30.00*	0.63

STATIC LOADS


-INPUT CODE-	---KV---	---KVA---	PFL-	LEAD/LAG
L 0-	4-1	0.21	0.56	LAG
L 0-	4-2	0.21	0.07	LAG

SYSTEM EQUIVALENT

-INPUT CODE-	---FVA---	---KV---	---X/R---
S 0-	1-1	18.00	0.48
			5.0

ENTER COMMAND

BSEP - Unit #1



ASDOP MODEL #4

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #4
Pnl. 1A-DG

STATIC LOADS

DATA					
INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-4-1	0.208	12.363	0.85	LAG	LOCA RUN
L-4-2	0.208	0.209	0.5	LAG	LOCA RUN
L-4-1	0.208	8.429	0.85	LAG	LIGHTLY LOADED RUN
L-4-2	0.208	0.018	0.5	LAG	LIGHTLY LOADED RUN

Page A32 of 113
 Performed by: *CRC*
 Checked by: *SC*
 6-6-84
 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #4
Pnl. 1A-DG

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.0273	0.480	0.208	30	30	0.63	LOCA RUN
T2-3-1	0.0257	0.480	0.208	30	30	0.63	LIGHTLY LOADED RUN

Page A33 of 113
 Performed by: CRC
 Checked by: SC
 6-6-84
 6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84

CRC 5-10-84
SC 5/10/84

BSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #4(PNL 1A-D6) LOCA RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

00000

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000003 0.000002

-----SUMMARY OF TAPS-----

FROM-BUS TO-BUS TAPS
2 3 -2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	9.143	5.737	10.794	0.014
2	1	-9.106	-5.734	10.761	0.014
2	3	9.106	5.734	10.760	0.014
3	2	-8.915	-5.614	10.535	0.032
3	4	8.915	5.614	10.535	0.032
4	3	-8.895	-5.610	10.517	0.032

-----BUS DATA-----

|||||DAR|||||

Page A35 of 113
Performed by: *CRC* 6-6-84
Checked by: *SC* 6-6-84

ENTER COMMAND

HOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84

CRC 5-10-84
SC 6-6-84

BSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #4(PNL 1A-DG) LOCA RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

00000

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000003 0.000002

-----SUMMARY OF TAPS-----

FROM-BUS TO-BUS TAPS
2 3 -2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	9.143	5.737	10.794	0.014
2	1	-9.106	-5.734	10.761	0.014
2	3	9.106	5.734	10.760	0.014
3	2	-8.915	-5.614	10.535	0.032
3	4	8.915	5.614	10.535	0.032
4	3	-8.895	-5.610	10.517	0.032

-----BUS DATA-----

Page A35 of 113
Performed by: *CRC 6-6-84*
Checked by: *SC 6-6-84*

ENTER COMMAND

HOW IN RUN MODE
 DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)
 GIVE TITLE OF RUN. IT HAS TO BE 80 CHARACTERS
 LOAD FLOW AND LIST ALL
 DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)
 DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

00000

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
 OPTIMIZATION PROGRAM
 (ASDOP)
 RSEP UNIT #1 208/120 VOLT LOAD STUDY
 MODEL #4(PNL 1A-DG) LIGHTLY LOADED RUN

DATE = 05/10/84

CRC 5-10-84
SC = 10/18/84

 AS-BUILT WITH XFMR TAPPED AT -2.5%
 BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL
 NO. OF BUSES= 4 NO. OF LINES= 3
 SWING BUS NO.= 1
 NO. OF ITERATIONS= 4
 ABS VOLTAGE ERROR= 0.000000 0.000001

00000

-----SUMMARY OF TAPS-----

FROM-BUS	TO-BUS	TAPS
2	3	-2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	7.813	4.836	9.158	0.011
2	1	-7.791	-4.834	9.169	0.011
2	3	7.790	4.834	9.168	0.011
3	2	-7.686	-4.769	9.045	0.024
3	4	7.685	4.769	9.044	0.024
4	3	-7.673	-4.767	9.033	0.024

-----BUS DATA-----

|||||LOAD|||||

Page A37 of 113
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

RSEP UNIT #1 208/120 VOLT LOAD STUDY AS-BUILT WITH XFMR TAPPED AT -2.5% PAGE 2 05/10/84

NO.	NAME	MAG(1PU)	ANG(1DEG)	BASE(KV)	GENERATION			MOTOR			STATIC			MISMATCH		
					KW	KVAR	KU	KW	KVAR	KU	KW	KVAR	KU	KW	KVAR	KU
1	MCCDGA	1.0255	-4.87	0.480	7.81	4.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0000	0.0000	0.0000
2	XFMRP	1.0234	-4.81	0.480	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.0015	-0.0000	-0.0000
3	XFMR3	1.0356	-4.81	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.0014	-0.0003	-0.0003
4	PNL1ADG	1.0343	-4.78	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.77	7.67	0.0014	0.0002	0.0002

RELEASE 9, 10/1/79
 ENTER COMMAND

INPUT CODE-	TYPE	+++CABLE OR BUS+++	+++CABLE+++++	NO.-SIZE	---R---	---X/FT---	---R/FT---	+++BUS+++++	+++REACTOR OR CAPACITOR+++
P 1- 2- 1A	CAB	4.70E-03	6.15E-02						
B 3- 4- 1A	CAB	1.10E-03	6.60E-03						

2-WINDING TRANSFORMERS

INPUT CODE-	---X---	---KV1-	---KV2-	---KVAT-	---KVAB-	---X/R-
T 2- 3- 1	0.0257	0.48	0.21	30.00	30.00*	0.63

STATIC LOADS


INPUT CODE-	---KVA--	-PFL-	LEAD/LAG
L 0- 4- 1	8.43	0.85	LAG
L 0- 4- 2	0.02	0.50	LAG

SYSTEM EQUIVALENT

INPUT CODE-	---FMVA--	---KV--	---X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

BSEP - Unit #1



ASDOP MODEL #5

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #5
Pnl. 31B

STATIC LOADS

INPUT CODE	DATA				Comments
	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	
	KV	KVA	PFL	LEAD/LAG	
L-4-1	0.208	0.785	0.85	LAG	LOCA RUN
L-4-2	0.208	3.358	0.5	LAG	LOCA RUN
L-4-1	0.208	0.888	0.85	LAG	LIGHTLY LOADED RUN
L-4-2	0.208	0.140	0.5	LAG	LIGHTLY LOADED RUN

Note: Revision 1 of this calculation reduced the LOCA run load value (L-4-2) given above. With this reduced load value, the actual panel voltage would be slightly greater than the value derived in this calculation. Since this was a more conservative treatment of the model, new ASDOP runs were not performed.

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #5
Pnl. 31B

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.0273	0.480	0.208	30	30	0.63	LOCA RUN
T2-3-1	0.0257	0.480	0.208	30	30	0.63	LIGHTLY LOADED RUN

Page A41 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #5
Pnl. 31B

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE	RESISTANCE
		(OHMS) X	(OHMS) R
B1-2-1A	Cable	0.0063	0.0827
B3-4-1A	Cable	0.0009	0.0051

Page A42 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
 OPTIMIZATION PROGRAM
 (ASDDP)
 BSEP UNIT #1 208/120 VOLT LOAD STUDY
 MODEL W5(PNL 31B) LOCA RUN

DATE = 05/10/84

CRC 5-10-84
SC 1/1/84 -1

AS-BUILT WITH XFMR TAPPED AT -2.5%

BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 4 NO. OF LINES= 3

00000

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000003 0.000003

-----SUMMARY OF TAPS-----

FROM-BUS	TO-BUS	TAPS
2	3	-2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	1.991	2.794	3.431	0.005
2	1	-1.986	-2.794	3.428	0.005
2	3	1.986	2.794	3.427	0.005
3	2	-1.966	-2.781	3.406	0.010
3	4	1.967	2.780	3.406	0.010
4	3	-1.965	-2.780	3.404	0.010

-----BUS DATA-----

Page A43 of 113
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

RSEP UNIT #1 208/120 VOLT LOAD STUDY PAGE 2 05/10/84
 AS-BUILT WITH XFMR TAPPED AT -2.5%

NO.	NAME	MAG(PU)	ANG(DEG)	BASE(KV)	---GENERATION---			---MOTOR---			---STATIC---			---MISMATCH---		
					KW	KVAR	KU	KW	KVAR	KU	KW	KVAR	KU	KW	KVAR	KU
1	MCC1CB	0.8990	-11.31	0.480	1.99	2.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0000	0.0000	0.0000
2	XFMRP	0.8981	-11.24	0.480	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.0001	-0.0001	-0.0001
3	XFMR3	0.9153	-11.09	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0008	-0.0006	-0.0006
4	PNL318	0.9150	-11.07	0.208	0.00	0.00	0.00	0.00	0.00	1.96	2.78	0.00	0.00	-0.0007	0.0006	0.0006

RELEASE 9, 10/1/79
 ENTER COMMAND

BRANCH ELEMENTS

---INPUT CODE---	TYPE	+++CABLE OR BUS+++	---R---	NO.-SIZE	---FI---	---X/FI---	---R/FI---	+++BUS+++++	+++FI---	---X(PU)---	---IR---	+++REACTOR OR CAPACITOR+++
B 1- 2- 1A	CAB	6.30E-03	8.27E-02									
B 3- 4- 1A	CAB	9.00E-04	5.10E-03									

2-WINDING TRANSFORMERS

---INPUT CODE---	---XI---	---KV1---	---KV2---	---KVAT---	---KVAB---	---X/R---
T 2- 3- 1	0.0273	0.48	0.21	30.00	30.00*	0.63

STATIC LOADS

---INPUT CODE---	---KV---	---KVA---	---PFL---	LEAD/LAG
L 0- 4- 1	0.21	0.78	0.85	LAG
L 0- 4- 2	0.21	3.36	0.50	LAG

SYSTEM EQUIVALENT

---INPUT CODE---	---FMVA---	---KV---	---X/R---
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84
CRC 5-10-84
05/10/84

BSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #5(PNL 31B) LIGHTLY LOADED RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 4 NO. OF LINES= 3

00000

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000001 0.000002

SUMMARY OF TAPS

FROM-BUS TO-BUS XTAPS
2 3 -2.50

LINE FLOWS


FROM-BUS		TO-BUS		LINE POWER FLOW			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)		
1	2	0.898	0.640	1.102	0.001		
2	1	-0.897	-0.639	1.102	0.001		
2	3	0.896	0.639	1.100	0.001		
3	2	-0.894	-0.638	1.099	0.003		
3	4	0.892	0.638	1.097	0.003		
4	3	-0.892	-0.638	1.096	0.003		

BUS DATA

|||||LOAD|||||

Page A45 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

BSEP - Unit #1



ASDOP MODEL #6

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #6
Pnl. 1B-DG

STATIC LOADS

DATA					
INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-4-1	0.208	12.630	0.85	LAG	LOCA RUN
L-4-2	0.208	0.198	0.5	LAG	LOCA RUN
L-4-1	0.208	6.765	0.85	LAG	LIGHTLY LOADED RUN
L-4-2	0.208	0.013	0.5	LAG	LIGHTLY LOADED RUN

Page A48 of 113
 Performed by: CRC 6-6-88
 Checked by: SC 6-6-88

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #6
Pnl. 1B-DG

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.0273	0.480	0.208	30	30	0.63	LCCA RUN
T2-3-1	0.0257	0.480	0.208	30	30	0.63	LIGHTLY LOADED RUN

Page A49 of 113
Performed by: CRP
Checked by: SC
6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-1

CASE TITLE: Model #6
Pnl. 1B-DG

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE	RESISTANCE
		(OHMS) X	(OHMS) R
B1-2-1A	Cable	0.0043	0.0573
B3-4-1A	Cable	0.0007	0.0043

Page A50 of 113
Performed by: CRP
Checked by: SC
6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE (80) CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

BSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #6(FNL 1B-DG) LOCA RUN

DATE = 05/08/84
CXC 5-10-84
06 5/1/84

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 4 NO. OF LINES= 3

00000

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000003 0.000002

-----SUMMARY OF TAPS-----

FROM-BUS	TO-BUS	TAPS
2	3	-2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	9.170	5.751	10.824	0.014
2	1	-9.135	-5.748	10.793	0.014
2	3	9.135	5.748	10.792	0.014
3	2	-8.939	-5.625	10.562	0.032
3	4	8.940	5.625	10.562	0.032
4	3	-8.926	-5.623	10.549	0.032

-----BUS DATA-----

Page A51 of 113
Performed by: CXC
Checked by: SC
6-6-84
6-6-84

BSEP UNIT #1 208/120 VOLT LOAD STUDY AS-BUILT WITH XFMR TAPPED AT -2.5% 05/08/84
 PAGE 2

NO.	NAME	MAG(PU)	ANG(DEG)	BASE(KV)	VOLTAGE		GENERATION		MOTOR		STATIC		MISMATCH	
					KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	MCC08B	0.9080	-11.16	0.480	9.17	5.75	0.00	0.00	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	0.9054	-11.07	0.480	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.0002	-0.0001
3	XFMR5	0.9087	-11.07	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0001	0.0001
4	PNL18DG	0.9077	-11.04	0.208	0.00	0.00	0.00	0.00	8.93	5.62	0.00	0.00	-0.0000	-0.0001

RELEASE 9, 10/1/79
 ENTER COMMAND

-INPUT CODE-		TYPE	NO.	SIZE	NO.	SIZE	BRANCH ELEMENTS	
B 1-	2-1A	CAB	4.30E-03	5.73E-02	+++++	+++++	BUS+++++	REACTOR OR CAPACITOR+++
B 3-	4-1A	CAB	7.00E-04	4.30E-03	----	----	X/FI--	X(PU)--- --IR-- --KV--

-INPUT CODE-		2-WINDING TRANSFORMERS	
		NO.	SIZE
T 2-	3-1	0.0273	0.48

-INPUT CODE-		STATIC LOADS	
		NO.	SIZE
L 0-	4-1	0.21	12.63
L 0-	4-2	0.21	0.20

-INPUT CODE-		SYSTEM EQUIVALENT	
		NO.	SIZE
S 0-	1-1	18.00	0.48

ENTER COMMAND

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASBOP)

DATE = 05/08/84
CRC 5-10-84

BSEP UNIT #1 208/120 VOLT LOAD STUDY
MODEL #6(PNL 1B-06) LIGHTLY LOADED RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

00000

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000000 0.000001

SUMMARY OF TAPS

FROM-BUS TO-BUS XTAPS
2 3 -2.50

LINE FLOWS

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	6.278	3.890	7.385	0.009
2	1	-6.265	-3.889	7.374	0.009
2	3	6.265	3.889	7.374	0.009
3	2	-6.198	-3.847	7.295	0.020
3	4	6.194	3.846	7.291	0.020
4	3	-6.189	-3.845	7.287	0.020

BUS DATA

Page AS3 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

AS-BUILT WITH XFMR TAPPED AT -2.5%

BSEP UNIT #1 208/120 VOLT LOAD STUDY

PAGE 2

05/08/84

NO.	NAME	-----VOLTAGE-----			-----GENERATION-----		-----MOTOR-----		-----STATIC-----		-----MISMATCH-----	
		MAG(PU)	ANG(DEG)	BASE(KV)	KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	MCCDGB	1.0245	-4.78	0.480	6.28	3.89	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMR5	1.0229	-4.73	0.480	0.00	0.00	0.00	0.00	0.00	0.00	0.0001	-0.0001
3	XFMR5	1.0378	-4.74	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0039	-0.0004
4	PNL1BDG	1.0372	-4.72	0.208	0.00	0.00	0.00	0.00	6.19	3.85	0.0037	0.0003

RELEASE 9, 10/1/79
ENTER COMMAND

BRANCH ELEMENTS

-INPUT CODE-	TYPE	++++CABLE OR BUS++++		++++CABLE+++++		++++BUS+++++			++REACTOR OR CAPACITOR++			
		---X---	---R---	NO.-SIZE	--FT--	---X/FT--	---R/FT--	--FT--	---X(PU)--	--IR--	--KV--	
B 1-	2- 1A	CAB	4.30E-03	5.73E-02								
B 3-	4- 1A	CAB	7.00E-04	4.30E-03								

2-WINDING TRANSFORMERS

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAB-	-X/R-	
T 2-	3- 1	0.0257	0.48	0.21	30.00	30.00*	0.63

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG	
L 0-	4- 1	0.21	6.76	0.85	LAG
L 0-	4- 2	0.21	0.01	0.50	LAG


SYSTEM EQUIVALENT

-INPUT CODE-	--FMVA--	--KV--	-X/R--	
S 0-	1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A54 of 113
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

BSEP - Unit #2



ASDOP MODEL #1

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #1
Swgr. 2E7

STATIC LOADS

DATA INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-5-1	0.208	9.348	0.85	LAG	LOCA RUN
L-5-2	0.208	2.974	0.5	LAG	LOCA RUN
L-6-1	0.208	0.324	0.85	LAG	LOCA RUN
L-6-2	0.208	0.552	0.5	LAG	LOCA RUN
L-7-1	0.208	0.863	0.85	LAG	LOCA RUN
L-7-2	0.208	1.434	0.5	LAG	LOCA RUN
L-8-1	0.208	4.577	0.85	LAG	LOCA RUN
L-8-2	0.208	0.574	0.5	LAG	LOCA RUN
L-9-1	0.208	2.436	0.85	LAG	LOCA RUN
L-9-2	0.208	0.059	0.5	LAG	LOCA RUN
L-10-1	0.208	3.808	0.85	LAG	LOCA RUN
L-10-2	0.208	1.560	0.5	LAG	LOCA RUN
L-11-1	0.208	3.193	0.85	LAG	LOCA RUN
L-11-2	0.208	0.165	0.5	LAG	LOCA RUN

Page A56 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #1
Swgr. 2E7

STATIC LOADS

DATA					
INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-5-1	0.208	4.674	0.85	LAG	LIGHTLY LOADED RUN
L-5-2	0.208	1.487	0.5	LAG	LIGHTLY LOADED RUN
L-6-1	0.208	0.314	0.85	LAG	LIGHTLY LOADED RUN
L-6-2	0.208	0.276	0.5	LAG	LIGHTLY LOADED RUN
L-7-1	0.208	0.811	0.85	LAG	LIGHTLY LOADED RUN
L-7-2	0.208	0.145	0.5	LAG	LIGHTLY LOADED RUN
L-8-1	0.208	2.321	0.85	LAG	LIGHTLY LOADED RUN
L-8-2	0.208	0.269	0.5	LAG	LIGHTLY LOADED RUN
L-9-1	0.208	0.738	0.85	LAG	LIGHTLY LOADED RUN
L-9-2	0.208	0.030	0.5	LAG	LIGHTLY LOADED RUN
L-10-1	0.208	2.055	0.85	LAG	LIGHTLY LOADED RUN
L-10-2	0.208	0.780	0.5	LAG	LIGHTLY LOADED RUN
L-11-1	0.208	1.588	0.85	LAG	LIGHTLY LOADED RUN
L-11-2	0.208	0.083	0.5	LAG	LIGHTLY LOADED RUN

Page A57 of 113
 Performed by: *CRC*
 Checked by: *SC* 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #1
Swgr. 2E7

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.0333	0.480	0.208	150	150	2.82	LOCA RUN
T2-3-1	0.0287	0.480	0.208	150	150	2.82	LIGHTLY LOADED RUN

Page A58 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP - Unit #2

CASE TITLE: Model #1
Swgr. 2E7

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE (OHMS)	RESISTANCE (OHMS)
		X	R
B1-2-1A	Cable	0.01822	0.01962
B3-4-1A	Cable	0.0010	0.0011
B4-5-1A	Cable	0.0060	0.0106
B4-6-1A	Cable	0.0040	0.0072
B4-7-1A	Cable	0.0007	0.0013
B4-8-1A	Cable	0.0009	0.0009
B4-9-1A	Cable	0.0058	0.0104
B4-10-1A	Cable	0.0014	0.0026
B4-11-1A	Cable	0.0049	0.0088

Page A59 of 113
 Performed By: CRC
 Checked By: SC
 6-7-84
 6-7-84

05/12/84

RSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 1

ENTER COMMAND
 EXECUTED NOTAP
 ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)
 GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS
 LOAD FLOW AND LIST ALL-----NO TAPS
 DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,1=CHANGE)
 DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

00000

DUKE POWER COMPANY

DATE = 05/12/84
 CRC 5-15-84

AUXILIARY SYSTEM DESIGN
 OPTIMIZATION PROGRAM
 (ASDOP)

RSEP UNIT #2 208/120 VOLT LOAD STUDY
 MODEL #1(SUGR 2E7) LOCA RUN

MODIFIED WITH XFMR TAPS AT NOMINAL

BUS VOLTAGES, CURRENTS, AND POWER FLOWS

00000

CASE TITLE:LOAD FLOW AND LIST ALL-----NO TAPS
 NO. OF BUSES= 11 NO. OF LINES= 10
 SWING BUS NO.= 1
 NO. OF ITERATIONS= 3
 ABS VOLTAGE ERROR= 0.000001 0.000005

LINE FLOWS

FROM-BUS	TO-BUS	KW	KVAR	KVA	LINE CURRENT MAG(KA)
1	2	21.119	16.722	26.938	0.035
2	1	-21.048	-16.657	26.841	0.035
2	3	21.047	16.656	26.841	0.035
3	2	-20.982	-16.472	26.675	0.080
3	4	20.981	16.471	26.674	0.080
4	3	-20.961	-16.451	26.645	0.080
4	5	8.027	6.375	10.251	0.031
4	6	0.471	0.554	0.727	0.002
4	7	1.238	1.452	1.908	0.006
4	8	3.564	2.487	4.346	0.013

MODIFIED WITH XFMR TAPS AT NOMINAL

BSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 2

NO.	NAME	MAG(PU)	ANG(DEG)	BASE(KV)	GENERATION-- KU	KVAR	MOTOR-- KW	LOAD----- KVAR	STATIC-- KW	MISMATCH-- KVAR
4	11	2.385	1.557	2.848	0.009					
5	4	-7.997	-6.358	10.216	0.031					
6	4	-0.470	-0.554	0.727	0.002					
7	4	-1.238	-1.452	1.908	0.006					
8	4	-3.564	-2.486	4.345	0.013					
9	4	-1.790	-1.138	2.121	0.006					
10	4	-3.484	-2.701	4.534	0.014					
11	4	-2.383	-1.556	2.846	0.009					

BUS DATA

NO.	NAME	MAG(PU)	ANG(DEG)	BASE(KV)	GENERATION-- KU	KVAR	MOTOR-- KW	LOAD----- KVAR	STATIC-- KW	MISMATCH-- KVAR
1	SUGRCE7	0.9339	-9.85	0.480	21.12	16.72	0.00	0.00	0.00	0.0000
2	XFMRP	0.9306	-9.86	0.480	0.00	0.00	0.00	0.00	0.00	-0.0004
3	XFMR5	0.9248	-10.09	0.208	0.00	0.00	0.00	0.00	0.00	-0.0008
4	PNL2E7	0.9236	-10.09	0.208	0.00	0.00	0.00	0.00	0.00	0.0110
5	PNL2ATR	0.9207	-10.06	0.208	0.00	0.00	0.00	0.00	0.00	0.0001
6	PNL2AR	0.9237	-10.09	0.208	0.00	0.00	0.00	0.00	0.00	0.0002
7	PNL2C	0.9238	-10.09	0.208	0.00	0.00	0.00	0.47	0.55	-0.0009
8	PNL2A	0.9237	-10.10	0.208	0.00	0.00	0.00	1.24	1.45	-0.0001
9	PNL2ARX	0.9232	-10.09	0.208	0.00	0.00	0.00	3.56	2.48	0.0001
10	PNL2AB	0.9235	-10.09	0.208	0.00	0.00	0.00	1.79	1.14	-0.0001
11	PNL2ARX	0.9231	-10.09	0.208	0.00	0.00	0.00	3.48	2.90	-0.0004
								2.38	1.56	-0.0001

RELEASE 9, 10/1/79

ENTER COMMAND

-INPUT CODE-		TYPE	+++CABLE OR BUS+++	NO.-SIZE	---X/FI--	+++X/FI--	---R/FI--	+++BUS+++++	---R/FI--	+++X(FU)---	---R/FI--	+++REACTOR OR CAPACITOR+++
R	1- 2- 1A	CAR	1.82E-02	1.96E-02								
R	3- 4- 1A	CAR	1.03E-03	1.07E-03								
R	4- 5- 1A	CAR	6.00E-03	1.06E-02								
R	4- 6- 1A	CAR	4.00E-03	7.70E-03								

MODIFIED WITH XFMR TAPS AT NOMINAL

BSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 3

05/12/84

R	4-	7-	1A	CAB	7.00E-04	1.30E-03
B	4-	8-	1A	CAB	9.00E-04	9.00E-04
B	4-	9-	1A	CAB	5.80E-03	1.04E-02
B	4-	10-	1A	CAB	1.40E-03	2.60E-03
B	4-	11-	1A	CAB	4.90E-03	8.80E-03

2-WINDING TRANSFORMERS

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAR-	-X/R-
T 2- 3- 1	0.0333	0.48	0.21	150.00	150.00*	2.82

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0- 5- 1	0.21	9.35	0.85	LAG
L 0- 5- 2	0.21	2.97	0.50	LAG
L 0- 6- 1	0.21	0.32	0.85	LAG
L 0- 6- 2	0.21	0.55	0.50	LAG
L 0- 7- 1	0.21	0.86	0.85	LAG
L 0- 7- 2	0.21	1.43	0.50	LAG
L 0- 8- 1	0.21	4.58	0.85	LAG
L 0- 8- 2	0.21	0.57	0.50	LAG
L 0- 9- 1	0.21	2.44	0.85	LAG
L 0- 9- 2	0.21	0.06	0.50	LAG
L 0- 10- 1	0.21	3.89	0.85	LAG
L 0- 10- 2	0.21	1.56	0.50	LAG
L 0- 11- 1	0.21	3.19	0.85	LAG
L 0- 11- 2	0.21	0.16	0.50	LAG

SYSTEM EQUIVALENT

-INPUT CODE-	--FMVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A62 of 113
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

ENTER COMMAND
 EXECUTED NOTAP
 ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL----NO TAPS

, 00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
 OPTIMIZATION PROGRAM
 (ASDOP)

DATE = 05/12/84

CRC 5-15-84

BSEP UNIT #2 208/120 VOLT LOAD STUDY

MODEL #1(SWGR 2E7) LIGHTLY LOADED WITH SUYD VO=1.017

 MODIFIED WITH XFMR TAPS AT NOMINAL

BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL----NO TAPS

00000

NO. OF BUSES= 11 NO. OF LINES= 10

SWING BUS NO.= 1

NO. OF ITERATIONS= 3

ABS VOLTAGE ERROR= 0.000002 0.000002

----- LINE FLOWS -----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	12.998	9.918	16.350	0.019
2	1	-12.977	-9.899	16.321	0.019
2	3	12.972	9.893	16.314	0.019
3	2	-12.955	-9.846	16.272	0.044
3	4	12.964	9.854	16.284	0.044
4	3	-12.958	-9.848	16.276	0.044
4	5	5.018	3.988	6.410	0.017
4	6	0.428	0.429	0.606	0.002
4	7	0.811	0.588	1.002	0.003
4	8	2.245	1.549	2.727	0.007
4	9	0.682	0.441	0.812	0.002
4	10	2.274	1.871	2.944	0.008

Page A63 of 113
 Performed by: *CRC 6-6-84*
 Checked by: *SC 6-6-84*

MODIFIED WITH XFMR TAPS AT NOMINAL

RSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 2

05/12/84

4	11	1.481	0.967	1.768	0.005
5	4	-5.009	-3.982	6.399	0.017
6	4	-0.428	-0.429	0.606	0.002
7	4	-0.811	-0.588	1.002	0.003
8	4	-2.245	-1.548	2.727	0.007
9	4	-0.682	-0.441	0.812	0.002
10	4	-2.273	-1.871	2.944	0.008
11	4	-1.480	-0.966	1.768	0.005

-----BUS DATA-----

NO.	NAME	-----VOLTAGE-----			-----GENERATION-----		-----MOTOR-----		-----STATIC-----		-----MISMATCH-----	
		MAG(PU)	ANG(DEG)	BASE(KV)	KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	SWGR2E7	1.0373	-3.95	0.480	13.00	9.92	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	1.0355	-3.96	0.480	0.00	0.00	0.00	0.00	0.00	0.00	-0.0052	-0.0054
3	XFMR5	1.0328	-4.06	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.0091	0.0082
4	PNL2E7	1.0323	-4.06	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0202	-0.0155
5	PNL2ATB	1.0305	-4.04	0.208	0.00	0.00	0.00	0.00	5.01	3.98	-0.0001	-0.0000
6	PNL32AB	1.0322	-4.06	0.208	0.00	0.00	0.00	0.00	0.43	0.43	0.0038	0.0019
7	PNL2C	1.0322	-4.06	0.208	0.00	0.00	0.00	0.00	0.81	0.59	0.0011	0.0006
8	PNL2A	1.0322	-4.06	0.208	0.00	0.00	0.00	0.00	2.25	1.55	0.0005	0.0024
9	PNL2ARX	1.0320	-4.06	0.208	0.00	0.00	0.00	0.00	0.68	0.44	0.0021	0.0010
10	PNL2AB	1.0321	-4.06	0.208	0.00	0.00	0.00	0.00	2.28	1.87	0.0029	0.0019
11	PNL2ARX	1.0319	-4.06	0.208	0.00	0.00	0.00	0.00	1.48	0.97	0.0014	0.0008

RELEASE 9, 10/1/79
ENTER COMMAND

BRANCH ELEMENTS

-INPUT CODE-	TYPE	++++CABLE OR BUS++++		++++CABLE++++				++++BUS++++				++REACTOR OR CAPACITOR++		
		---X---	---R---	NO.	SIZE	--FT--	---X/FT--	---R/FT--	--FT--	---X(PU)---	---IR---	---KV---		
B 1-	2- 1A	CAB	1.82E-02	1.96E-02										
B 3-	4- 1A	CAB	1.03E-03	1.07E-03										

Page A64 of 113
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

MODIFIED WITH XFMR TAPS AT NOMINAL

RSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 3

95/12/84

B	4-	7-	1A	CAB	7.06E-04	1.30E-03
B	4-	8-	1A	CAB	9.00E-04	9.00E-04
B	4-	9-	1A	CAB	5.80E-03	1.04E-02
B	4-	10-	1A	CAB	1.40E-03	2.60E-03
B	4-	11-	1A	CAB	4.90E-03	8.80E-03

2-WINDING TRANSFORMERS

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAR-	-X/R-
T 2- 3- 1	0.0267	0.48	0.21	150.00	150.00*	2.82

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0- 5- 1	0.21	4.67	0.85	LAG
L 0- 5- 2	0.21	1.49	0.50	LAG
L 0- 6- 1	0.21	0.31	0.85	LAG
L 0- 6- 2	0.21	0.28	0.50	LAG
L 0- 7- 1	0.21	0.81	0.85	LAG
L 0- 7- 2	0.21	0.14	0.50	LAG
L 0- 8- 1	0.21	2.32	0.85	LAG
L 0- 8- 2	0.21	0.27	0.50	LAG
L 0- 9- 1	0.21	0.74	0.85	LAG
L 0- 9- 2	0.21	0.03	0.50	LAG
L 0- 10- 1	0.21	2.05	0.85	LAG
L 0- 10- 2	0.21	0.78	0.50	LAG
L 0- 11- 1	0.21	1.59	0.85	LAG
L 0- 11- 2	0.21	0.08	0.50	LAG

SYSTEM EQUIVALENT

-INPUT CODE-	--FMVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A65 of 113
 Performed by: CRC
 Checked by: SC 6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

DATE = 05/12/84

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

CRC 5-15-84

BSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL #1(SVGR 2E) LIGHTLY LOADED RUN WITH SWD V0=1.017

AS-BUILT WITH XFMR TAPPED AT -2.5%

BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

00000

NO. OF BUSES= 11 NO. OF LINES= 10

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000001 0.000000

SUMMARY OF TAPS

FROM-BUS TO-BUS ZTAPS
2 3 -2.50

LINE FLOWS

		-----LINE POWER FLOW-----			LINE CURRENT
FROM-BUS	TO-BUS	KW	KVAR	KVA	MAG(KA)
1	2	13.668	10.430	17.193	0.020
2	1	-13.645	-10.408	17.161	0.020
2	3	13.644	10.408	17.160	0.020
3	2	-13.626	-10.358	17.116	0.045
3	4	13.627	10.350	17.112	0.045
4	3	-13.621	-10.343	17.103	0.045
4	5	5.279	4.795	6.743	0.018
4	6	0.455	0.454	0.643	0.002
4	7	0.856	0.621	1.057	0.003
4	8	2.358	1.628	2.866	0.008

Page A66 of 113
Performed by: *CRC 6-6-84*
Checked by: *SC 6-6-84*

05/12/84

AS-BUILT WITH XFMR TAPPED AT -2.5%

RSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 2

NO.	NAME	MAG(FU)	ANG(DEG)	BASE(KV)	GENERATION--	MOTOR--	STATIC--	MISMATCH--
1	SUGR2E7	1.0373	-3.95	0.480	KW 13.67	KVAR 10.43	KW 0.00	KVAR 0.00
2	XFMRP	1.0354	-3.96	0.480	0.00	0.00	0.00	0.00
3	XFMR5	1.0592	-4.06	0.208	0.00	0.00	0.00	0.00
4	PNL2E7	1.0586	-4.06	0.208	0.00	0.00	0.00	0.00
5	PNL2ATR	1.0569	-4.04	0.208	0.00	0.00	5.27	4.19
6	PNL32AR	1.0585	-4.06	0.208	0.00	0.00	0.45	0.45
7	PNL2C	1.0586	-4.06	0.208	0.00	0.00	0.85	0.62
8	PNL2A	1.0586	-4.06	0.208	0.00	0.00	2.36	1.63
9	PNL2ARRX	1.0584	-4.06	0.208	0.00	0.00	0.72	0.46
10	PNL2AR	1.0584	-4.06	0.208	0.00	0.00	2.39	1.97
11	PNL2ARX	1.0582	-4.06	0.208	0.00	0.00	1.56	1.02

---BUS DATA---

NO.	NAME	MAG(FU)	ANG(DEG)	BASE(KV)	GENERATION--	MOTOR--	STATIC--	MISMATCH--
1	SUGR2E7	1.0373	-3.95	0.480	KW 13.67	KVAR 10.43	KW 0.00	KVAR 0.00
2	XFMRP	1.0354	-3.96	0.480	0.00	0.00	0.00	0.00
3	XFMR5	1.0592	-4.06	0.208	0.00	0.00	0.00	0.00
4	PNL2E7	1.0586	-4.06	0.208	0.00	0.00	0.00	0.00
5	PNL2ATR	1.0569	-4.04	0.208	0.00	0.00	5.27	4.19
6	PNL32AR	1.0585	-4.06	0.208	0.00	0.00	0.45	0.45
7	PNL2C	1.0586	-4.06	0.208	0.00	0.00	0.85	0.62
8	PNL2A	1.0586	-4.06	0.208	0.00	0.00	2.36	1.63
9	PNL2ARRX	1.0584	-4.06	0.208	0.00	0.00	0.72	0.46
10	PNL2AR	1.0584	-4.06	0.208	0.00	0.00	2.39	1.97
11	PNL2ARX	1.0582	-4.06	0.208	0.00	0.00	1.56	1.02

RELEASE 9, 10/1/79

ENTER COMMAND

BRANCH ELEMENTS	+++CABLE OR BUS+++	+++CABLE++++	NO.-SIZE	---X/FI--	---R/FI--	---FI--	++REACTOR OF CAPACITOR+++
---X---	---	---					
R 1- 2- 1A CAB	1.82E-02	1.96E-02					
R 3- 4- 1A CAB	1.03E-03	1.07E-03					
R 4- 5- 1A CAB	6.00E-03	1.06E-02					

05/12/84

AS-BUILT WITH XFMR TAPPED AT -2.5%
 PAGE 3

RSEP UNIT #2 208/120 VOLT LOAD STUDY


B	4-6-1A	CAB	4.00E-03	7.20E-03
B	4-7-1A	CAB	7.00E-04	1.30E-03
B	4-8-1A	CAB	9.00E-04	9.00E-04
B	4-9-1A	CAB	5.80E-03	1.04E-02
B	4-10-1A	CAB	1.40E-03	2.60E-03
B	4-11-1A	CAB	4.90E-03	8.80E-03

2-WINDING TRANSFORMERS						
-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAB-	-X/R-
T 2-3-1	0.0287	0.48	0.21	150.00	150.00*	2.82

STATIC LOADS				LEAD/LAG
-INPUT CODE-	--KV--	---KVA--	--PFL-	
L 0-5-1	0.21	4.67	0.85	LAG
L 0-5-2	0.21	1.49	0.50	LAG
L 0-6-1	0.21	0.31	0.85	LAG
L 0-6-2	0.21	0.28	0.50	LAG
L 0-7-1	0.21	0.81	0.85	LAG
L 0-7-2	0.21	0.14	0.50	LAG
L 0-8-1	0.21	2.32	0.85	LAG
L 0-8-2	0.21	0.27	0.50	LAG
L 0-9-1	0.21	0.74	0.85	LAG
L 0-9-2	0.21	0.03	0.50	LAG
L 0-10-1	0.21	2.05	0.85	LAG
L 0-10-2	0.21	0.78	0.50	LAG
L 0-11-1	0.21	1.59	0.85	LAG
L 0-11-2	0.21	0.08	0.50	LAG

SYSTEM EQUIVALENT		
-INPUT CODE-	--FMVA--	--KV--
S 0-1-1	18.00	0.48
ENTER COMMAND		-X/R--
		5.0

BSEP - Unit #2



ASDOP MODEL #2

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #2
Swgr. 2E8

STATIC LOADS

DATA					
INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-5-1	0.208	5.430	0.85	LAG	LOCA RUN
L-5-2	0.208	1.625	0.5	LAG	LOCA RUN
L-6-1	0.208	2.455	0.85	LAG	LOCA RUN
L-6-2	0.208	0.021	0.5	LAG	LOCA RUN
L-7-1	0.208	4.068	0.85	LAG	LOCA RUN
L-7-2	0.208	0.042	0.5	LAG	LOCA RUN
L-8-1	0.208	0.776	0.85	LAG	LOCA RUN
L-8-2	0.208	0.822	0.5	LAG	LOCA RUN
L-9-1	0.208	5.875	0.85	LAG	LOCA RUN
L-9-2	0.208	0.975	0.5	LAG	LOCA RUN
L-5-1	0.208	2.235	0.85	LAG	LIGHTLY LOADED RUN
L-5-2	0.208	0.867	0.5	LAG	LIGHTLY LOADED RUN
L-6-1	0.208	1.228	0.85	LAG	LIGHTLY LOADED RUN
L-6-2	0.208	0.011	0.5	LAG	LIGHTLY LOADED RUN
L-7-1	0.208	1.981	0.85	LAG	LIGHTLY LOADED RUN
L-7-2	0.208	0.021	0.5	LAG	LIGHTLY LOADED RUN
L-8-1	0.208	0.656	0.85	LAG	LIGHTLY LOADED RUN
L-8-2	0.208	0.138	0.5	LAG	LIGHTLY LOADED RUN
L-9-1	0.208	3.129	0.85	LAG	LIGHTLY LOADED RUN
L-9-2	0.208	0.487	0.5	LAG	LIGHTLY LOADED RUN

Page A70 of 113
 Performed by: *CRC*
 Checked by: *SC*
 6-6-84
 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #2
Swgr. 2E8

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	X/MR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.0333	0.480	0.208	150	150	2.82	LOCA RUN
T2-3-1	0.0287	0.480	0.208	150	150	2.82	LIGHTLY LOADED RUN

Page A71 of 113
 Performed by: *CRP*
 Checked by: *SC*
 6-6-84
 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP - Unit #2

CASE TITLE: Model #2
Swgr. 2E8

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE	RESISTANCE
		(OHMS) X	(OHMS) R
B1-2-1A	Cable	0.02941	0.03235
B3-4-1A	Cable	0.0006785	0.0007038
B4-5-1A	Cable	0.0137	0.0244
B4-6-1A	Cable	0.0159	0.0284
B4-7-1A	Cable	0.0120	0.0213
B4-8-1A	Cable	0.0010	0.0017
B4-9-1A	Cable	0.0010	0.0011

Page A72 of 113
 Performed by: *CRC*
 Checked by: *SC*
 6-6-84

ENTER COMMAND
EXECUTED NOTAP
ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)
GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS
LOAD FLOW AND LIST ALL-----NO TAPS
DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)
DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

00000

DUKE POWER COMPANY

DATE = 05/12/84

CRC 5-14-84

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

RSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL #2(SUGR 2ES) LOCA RUN

MODIFIED WITH XFMR TAPS AT NOMINAL
BUS VOLTAGES, CURRENTS, AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL-----NO TAPS
NO. OF BUSES= 9 NO. OF LINES= 8
SWING BUS NO.= 1
NO. OF ITERATIONS= 4
ABS VOLTAGE ERROR= 0.00000 0.000000

00000

LINE FLOWS

FROM-BUS	TO-BUS	KW	KVAR	KVA	LINE CURRENT MAG(KA)
1	2	15.156	11.140	18.810	0.024
2	1	-15.099	-11.088	18.733	0.024
2	3	15.099	11.088	18.733	0.024
3	2	-15.067	-10.998	18.654	0.056
3	4	15.067	10.997	18.653	0.056
4	3	-15.060	-10.991	18.644	0.056
4	5	4.650	3.651	5.912	0.018
4	6	1.800	1.126	2.123	0.006
4	7	2.985	1.869	3.522	0.011
4	8	0.913	0.959	1.324	0.004
4	9	4.712	3.387	5.803	0.017

MODIFIED WITH XFMR TAPS AT NOMINAL

BSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 2

05/12/84

5	4	-4.627	-3.638	5.886	0.018
6	4	-1.797	-1.124	2.119	0.006
7	4	-2.978	-1.865	3.514	0.011
8	4	-0.913	-0.959	1.324	0.004
9	4	-4.711	-3.386	5.802	0.017

-----BUS DATA-----

*****LOAD*****

NO.	NAME	-----VOLTAGE-----			-----GENERATION-----		-----MOTOR-----		-----STATIC-----		-----MISMATCH-----	
		MAG(PU)	ANG(DEG)	BASE(KV)	KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	SWGR2EB	0.9355	-10.06	0.480	15.16	11.14	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	0.9317	-10.08	0.480	0.00	0.00	0.00	0.00	0.00	0.00	-0.0002	-0.0003
3	XFMR5	0.9278	-10.25	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0008	-0.0009
4	PNL2EB	0.9273	-10.25	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.0000	0.0010
5	PNL2ACTB	0.9233	-10.21	0.208	0.00	0.00	0.00	0.00	4.63	3.64	0.0000	-0.0000
6	PNL2BTB	0.9256	-10.25	0.208	0.00	0.00	0.00	0.00	1.80	1.12	-0.0000	-0.0000
7	PNL2BRX	0.9252	-10.24	0.208	0.00	0.00	0.00	0.00	2.98	1.87	0.0000	0.0000
8	PNL2B	0.9273	-10.25	0.208	0.00	0.00	0.00	0.00	0.91	0.96	0.0002	0.0001
9	PNL2B	0.9271	-10.25	0.208	0.00	0.00	0.00	0.00	4.71	3.39	0.0006	-0.0002

RELEASE 9, 10/1/79
ENTER COMMAND

BRANCH ELEMENTS

-INPUT CODE-	TYPE	++++CABLE OR BUS++++		++++CABLE++++				++++BUS++++				++REACTOR OR CAPACITOR++		
		---X---	---R---	NO.-	SIZE	--FT--	---X/FT--	---R/FT--	--FT--	---X(PU)--	---IR--	---KV--		
B 1-	2- 1A	CAB	2.94E-02	3.23E-02										
B 3-	4- 1A	CAB	6.78E-04	7.04E-04										
B 4-	5- 1A	CAB	1.37E-02	2.44E-02										
B 4-	6- 1A	CAB	1.59E-02	2.84E-02										
B 4-	7- 1A	CAB	1.20E-02	2.13E-02										
B 4-	8- 1A	CAB	1.00E-03	1.70E-03										
B 4-	9- 1A	CAB	1.00E-03	1.10E-03										

Page A74 of 113
Performed by: CRC
Checked by: SC C-6-84
6-6-84
84

MODIFIED WITH XFMR TAPS AT NOMINAL

RSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 3

05/12/84

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAB-	-X/R-
T 2- 3- 1	0.0333	0.48	0.21	150.00	150.00*	2.82

STATIC LOADS						
-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG		
L 0- 5- 1	0.21	5.43	0.85	LAG		
L 0- 5- 2	0.21	1.63	0.50	LAG		
L 0- 6- 1	0.21	2.45	0.85	LAG		
L 0- 6- 2	0.21	0.02	0.50	LAG		
L 0- 7- 1	0.21	4.07	0.85	LAG		
L 0- 7- 2	0.21	0.04	0.50	LAG		
L 0- 8- 1	0.21	0.77	0.83	LAG		
L 0- 8- 2	0.21	0.82	0.50	LAG		
L 0- 9- 1	0.21	5.88	0.85	LAG		
L 0- 9- 2	0.21	0.97	0.50	LAG		

SYSTEM EQUIVALENT			
-INPUT CODE-	--FAVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A75 of 113
 Performed by: CRC
 Checked by: SC
 6-6-84
 6-6-84

ENTER COMMAND
 EXECUTED NOTAP
 ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)
 GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS
 LOAD FLOW AND LIST ALL----NO TAPS
 DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)
 DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

00000

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
 OPTIMIZATION PROGRAM
 (ASDOP)

DATE = 05/12/84

CRC 5-14-84

RSEP UNIT #2 208/120 VOLT LOAD STUDY
 MODEL #2(SWGR 2E8) LIGHTLY LOADED RUN WITH SWYD V0=1.017

MODIFIED WITH XFMR TAPS AT NOMINAL
 BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL----NO TAPS
 NO. OF BUSES= 9 NO. OF LINES= 8
 SWING BUS NO.= 1
 NO. OF ITERATIONS= 3
 ABS VOLTAGE ERROR= 0.000002 0.000002

00000

----- LINE FLOWS -----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	9.249	6.662	11.399	0.013
2	1	-9.232	-6.647	11.376	0.013
2	3	9.229	6.644	11.372	0.013
3	2	-9.221	-6.621	11.352	0.030
3	4	9.218	6.620	11.349	0.030
4	3	-9.216	-6.618	11.346	0.030
4	5	2.497	2.062	3.238	0.009
4	6	1.123	0.703	1.325	0.004
4	7	1.814	1.136	2.140	0.006
4	8	0.132	0.188	0.232	0.002

Page A76 of 113
 Performed by: *CRC*
 Checked by: *SC*
6-6-84
C.C.S.V.

05/12/84

MODIFIED WITH XFMR TAPS AT NOMINAL

PSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 2

5	4	-2.491	-2.059	3.232	0.009
6	4	-1.122	-0.702	1.324	0.004
7	4	-1.812	-1.135	2.138	0.006
8	4	-0.672	-0.499	0.837	0.002
9	4	-3.114	-2.221	3.825	0.010

BUS DATA

*****LOAD*****

NO.	NAME	MAG(PU)	ANG(DEG)	BASE(KV)	GENERATION		MOTOR		STATIC		MISMATCH	
					KU	KVAR	KU	KVAR	KU	KVAR	KU	KVAR
1	SUGR2E8	1.0395	-4.14	0.480	9.25	6.66	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	1.0374	-4.15	0.480	0.00	0.00	0.00	0.00	0.00	0.00	-0.0032	-0.0027
3	XFMRB	1.0356	-4.22	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0029	-0.0013
4	PHL2E8	1.0354	-4.22	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.0045	0.0031
5	PHL2BTR	1.0334	-4.20	0.208	0.00	0.00	0.00	0.00	2.49	2.06	0.0002	0.0001
6	PHL2BTR	1.0344	-4.22	0.208	0.00	0.00	0.00	0.00	1.12	0.70	0.0005	0.0002
7	PHL2BRX	1.0342	-4.22	0.208	0.00	0.00	0.00	0.00	1.81	1.14	0.0007	0.0003
8	PHL2B	1.0353	-4.22	0.208	0.00	0.00	0.00	0.00	0.67	0.50	-0.0001	-0.0002
9	PHL2B	1.0352	-4.23	0.208	0.00	0.00	0.00	0.00	3.11	2.22	-0.0001	-0.0001

RELEASE 9, 10/1/79
 ENTER COMMAND

BRANCH ELEMENTS

INPUT CODE	TYPE	+++CABLE OR BUS+++	---R---	+++CABLE+++++	NO.-SIZE	---R/FT---	+++R/FT---	---X/FT---	+++R/FT---	---X/FT---	+++REACTOR OR CAPACITOR+++
B 1-	2-1A	CAB	2.94E-02	3.23E-02							
B 3-	4-1A	CAB	6.78E-04	7.04E-04							
B 4-	5-1A	CAB	1.37E-02	2.44E-02							
B 4-	6-1A	CAB	1.59E-02	2.84E-02							
B 4-	7-1A	CAB	1.20E-02	2.13E-02							
B 4-	8-1A	CAB	1.00E-03	1.70E-03							
B 4-	9-1A	CAB	1.00E-03	1.10E-03							

2-WINDING TRANSFORMERS

MODIFIED WITH XFMR TAPS AT NOMINAL

BSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 3

05/12/84

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAB-	-X/R-
T 2- 3- 1	0.0287	0.48	0.21	150.00	150.00+	2.82

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0- 5- 1	0.21	2.23	0.85	LAG
L 0- 5- 2	0.21	0.87	0.50	LAG
L 0- 6- 1	0.21	1.23	0.85	LAG
L 0- 6- 2	0.21	0.01	0.50	LAG
L 0- 7- 1	0.21	1.98	0.85	LAG
L 0- 7- 2	0.21	0.02	0.50	LAG
L 0- 8- 1	0.21	0.66	0.85	LAG
L 0- 8- 2	0.21	0.14	0.50	LAG
L 0- 9- 1	0.21	3.13	0.85	LAG
L 0- 9- 2	0.21	0.49	0.50	LAG

SYSTEM EQUIVALENT

-INPUT CODE-	--FMVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A78 of 113
 Performed by: *CRC*
 Checked by: *SC*
6-6-84

ENTER COMMAND

NOW IN RUN MODE
 DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)
 GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS
 LOAD FLOW AND LIST ALL
 DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)
 DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

00000

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
 OPTIMIZATION PROGRAM
 (ASDOP)

DATE = 05/12/84

CRC 5-14-84

RSEP UNIT #2 208/120 VOLT LOAD STUDY
 MODEL #2(SUGR 2EB) LIGHTLY LOADED RUN WITH SWVD VO=1.017

AS-BUILT WITH XFMR TAPPED AT -2.5%

BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL
 NO. OF BUSES= 9 NO. OF LINES= 8
 SWING BUS NO.= 1
 NO. OF ITERATIONS= 4
 ABS VOLTAGE ERROR= 0.000001 0.000000

00000

SUMMARY OF TAPS

FROM-BUS	TO-BUS	TAPS
2	3	-2.50

LINE FLOWS

FROM-BUS		TO-BUS		LINE POWER FLOW			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)		
1	2	9.728	7.008	11.989	0.014		
2	1	-9.709	-6.991	11.964	0.014		
2	3	9.704	6.987	11.957	0.014		
3	2	-9.695	-6.962	11.936	0.031		
3	4	9.721	6.957	11.954	0.031		
4	3	-9.719	-6.955	11.952	0.031		
4	5	2.625	2.168	3.405	0.009		
4	6	1.182	0.739	1.394	0.004		
4	7	1.907	1.195	2.251	0.006		
4	8	0.707	0.525	0.881	0.002		
4	9	3.266	2.329	4.012	0.010		

Page A79 of 113
 Performed by: *CRC 6-6-84*
 Checked by: *SC 6-6-84*

05/12/84

AS-BUILT WITH XFMR TAPPED AT -2.5%
 PSEP UNIT #2 208/120 VOLT LOAD STUDY PAGE 2

5	4	-2.620	-2.165	3.399	0.009
6	4	-1.181	-0.739	1.393	0.004
7	4	-1.905	-1.194	2.248	0.006
8	4	-0.707	-0.525	0.881	0.002
9	4	-3.266	-2.329	4.011	0.010

BUS DATA

NO.	NAME	MAG(FU)	ANG(DEG)	BASE(KV)	VOLTAGE		GENERATION		MOTOR		STATIC		MISMATCH	
					ANG(DEG)	BASE(KV)	KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	SUGR2E8	1.0375	-4.14	0.480	9.73	7.01	0.00	0.00	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	1.0373	-4.15	0.480	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.0054	-0.0048
3	XFMR5	1.0620	-4.22	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0261	-0.0052
4	FML2E8	1.0618	-4.23	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.0315	0.0023
5	FML2ANT8	1.0598	-4.21	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.17	0.0007
6	FML2G18	1.0608	-4.22	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.0009	0.0000
7	FML2BRX	1.0606	-4.22	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0008	0.0004
8	FML2B	1.0618	-4.22	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-0.0006	-0.0007
9	FML2B	1.0617	-4.23	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0064	0.0041

RELEASE 9, 10/1/79
 ENTER COMMAND

-INPUT CODE-	TYPE	CABLE OR BUS		CABLE		BUS		REACTOR OR CAPACITOR	
		NO.	SIZE	NO.	SIZE	NO.	SIZE	NO.	SIZE
B 1-	2-1A	CAB	2.94E-02	3.23E-02					
B 3-	4-1A	CAB	6.78E-04	7.04E-04					
B 4-	5-1A	CAB	1.37E-02	2.44E-02					
B 4-	6-1A	CAB	1.59E-02	2.84E-02					
B 4-	7-1A	CAB	1.20E-02	2.13E-02					
B 4-	8-1A	CAB	1.00E-03	1.70E-03					
B 4-	9-1A	CAB	1.00E-03	1.10E-03					

AS-BUILT WITH XFMR TAPPED AT -2.5%

BSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 3

05/12/84

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAB-	-X/R-
T 2- 3- 1	0.0287	0.48	0.21	150.00	150.00*	2.82

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0- 5- 1	0.21	2.23	0.85	LAG
L 0- 5- 2	0.21	0.87	0.50	LAG
L 0- 6- 1	0.21	1.23	0.85	LAG
L 0- 6- 2	0.21	0.01	0.50	LAG
L 0- 7- 1	0.21	1.98	0.85	LAG
L 0- 7- 2	0.21	0.02	0.50	LAG
L 0- 8- 1	0.21	0.66	0.85	LAG
L 0- 8- 2	0.21	0.14	0.50	LAG
L 0- 9- 1	0.21	3.13	0.85	LAG
L 0- 9- 2	0.21	0.49	0.50	LAG


SYSTEM EQUIVALENT

-INPUT CODE-	--FMVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A81 of 113
 Performed by: CRC 6-6-84
 Checked by: SC C-6-84

BSEP - Unit #2



ASDOP MODEL #3

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #3
Pnl. 32A

STATIC LOADS

DATA					
INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-4-1	0.208	0.959	0.85	LAG	LOCA RUN
L-4-2	0.208	0.693	0.5	LAG	LOCA RUN
L-4-1	0.208	0.480	0.85	LAG	LIGHTLY LOADED RUN
L-4-2	0.208	0.347	0.5	LAG	LIGHTLY LOADED RUN

Page A83 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #3
Pnl. 32A

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.02043	0.480	0.208	30	30	0.95	LOCA RUN
T2-3-1	0.01758	0.480	0.208	30	30	0.95	LIGHTLY LOADED RUN

Page A84 of 113
 Performed by: CRC
 Checked by: SC
 6-6-84
 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP - Unit #2

CASE TITLE: Model #3
Pnl. 32A

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE	RESISTANCE
		(OHMS) X	(OHMS) R
B1-2-1A	Cable	0.0018	0.0232
B3-4-1A	Cable	0.0017	0.0052

Page A85 of 113
Performed by: CRG 6-6-84
Checked By: SC 6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/04/84
CRC 5-6-84

BSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL W3(PNL 32A) LOCA RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 2 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000002 0.000003

00000

SUMMARY OF TAPS

FROM-BUS TO-BUS XTAPS
2 3 -2.50

LINE FLOWS

FROM-BUS	TO-BUS	LINE POWER FLOW			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	1.025	0.975	1.414	0.002
2	1	-1.024	-0.975	1.414	0.002
2	3	1.024	0.974	1.414	0.002
3	2	-1.023	-0.973	1.411	0.004
3	4	1.023	0.972	1.411	0.004
4	3	-1.022	-0.972	1.411	0.004

BUS DATA

*****LOAD*****

Page A86 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

05/04/84

RSEP UNIT #2 208/120 VOLT LOAD STUDY
 AS-BUILT WITH XFMR TAPPED AT -2/5%
 PAGE 2

NO.	NAME	MAG(PU)	ANG(DEG)	BASE(KV)	---GENERATION---		---MOTOR---		---STATIC---		---MISMATCH---	
					KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	MCC2CA	0.9164	-10.08	0.480	1.02	0.97	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	0.9163	-10.07	0.480	0.00	0.00	0.00	0.00	0.00	0.00	-0.0003	-0.0003
3	XFHRS	0.9383	-10.07	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.0002	-0.0005
4	PHL32A	0.9381	-10.07	0.208	0.00	0.00	0.00	0.00	1.02	0.97	-0.0001	0.0004

RELEASE 9, 10/1/79
 ENTER COMMAND

BRANCH ELEMENTS

---CABLE OR BUS---	+++CABLE+++	+++R---	NO.-SIZE	---X/FT---	---R/FT---	---FT---	+++REACTOR OR CAPACITOR+++
B 1- 2- 1A	CAB	1.80E-03	2.33E-02				
B 3- 4- 1A	CAB	1.70E-03	5.20E-03				

2-WINDING TRANSFORMERS

---X---	---KV1---	---KV2---	---KVAT---	---KVAR---	---X/R---
T 2- 3- 1	0.0204	0.48	0.21	30.00	30.00+
					0.95

STATIC LOADS

---KV---	---KVA---	---PFL---	LEAD/LAG
L 0- 4- 1	0.21	0.96	LAG
L 0- 4- 2	0.21	0.69	LAG

SYSTEM EQUIVALENT

---FWVA---	---KV---	---X/R---
S 0- 1- 1	18.00	0.48
		5.0

ENTER COMMAND

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOF)

DATE = 05/04/84

Handwritten: CRC 5-10-84

BSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL #3(PNL 32A) LIGHTLY LOADED RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

00000

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ARS VOLTAGE ERROR= 0.000001 0.000002

-----SUMMARY OF TAPS-----

FROM-BUS TO-BUS XTAPS
2 3 -2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	0.646	0.614	0.891	0.001
2	1	-0.646	-0.614	0.891	0.001
2	3	0.646	0.614	0.891	0.001
3	2	-0.645	-0.614	0.891	0.002
3	4	0.641	0.612	0.886	0.002
4	3	-0.641	-0.612	0.886	0.002

-----BUS DATA-----

Page A88 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

BSEP UNIT #2 208/120 VOLT LOAD STUDY AS-BUILT WITH XFMR TAPPED AT -2.5% 05/04/84
 PAGE 2

NO.	NAME	VOLTAGE		GENERATION		MOTOR		STATIC		MISMATCH		
		MAG(PU)	ANG(DEG)	BASE(KV)	KU	KVAR	KU	KVAR	KU	KVAR	KU	KVAR
1	MCC2CA	1.0273	-4.05	0.480	0.65	0.61	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	1.0272	-4.05	0.480	0.00	0.00	0.00	0.00	0.00	0.00	0.0001	0.0002
3	XFMRB	1.0529	-4.05	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0045	-0.0023
4	PNL32A	1.0528	-4.04	0.208	0.00	0.00	0.00	0.64	0.61	0.0037	0.0016	

RELEASE 9, 10/1/79
 ENTER COMMAND

-INPUT CODE-	TYPE	+++CABLE OR BUS+++		+++CABLE+++		+++BUS+++		+++REACTOR OR CAPACITOR+++	
		---X---	---R---	NO.-SIZE	---FT---	---R/FT---	---FT---	---IR---	---KV---
B 1- 2- 1A	CAB	1.80E-03	2.32E-02						
B 3- 4- 1A	CAB	1.70E-03	5.20E-03						

2-WINDING TRANSFORMERS

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAR-	--X/R-
T 2- 3- 1	0.0176	0.48	0.21	30.00	30.00*	0.95

STATIC LOADS


-INPUT CODE-	--KV--	---KVA--	--PFL-	LEAD/LAG
L 0- 4- 1	0.21	0.48	0.85	LAG
L 0- 4- 2	0.21	0.35	0.50	LAG

SYSTEM EQUIVALENT

-INPUT CODE-	--FNVA--	--KV--	--X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

BSEP - Unit #2



ASDOP MODEL #4

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #4
Pnl. 2A-DG

STATIC LOADS

DATA INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-4-1	0.208	13.158	0.85	LAG	LOCA RUN
L-4-2	0.208	0.906	0.5	LAG	LOCA RUN
L-4-1	0.208	7.356	0.85	LAG	LIGHTLY LOADED RUN
L-4-2	0.208	0.367	0.5	LAG	LIGHTLY LOADED RUN

Page A91 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #4
Pnl. 2A-DG

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.0273	0.480	0.208	30	30	0.63	LOCA RUN
T2-3-1	0.0257	0.480	0.208	30	30	0.63	LIGHTLY LOADED RUN

Page A92 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP - Unit #2

CASE TITLE: Model #4
Pnl. 2A-DG

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE	RESISTANCE
		(OHMS) X	(OHMS) R
B1-2-1A	Cable	0.0037	0.0225
B3-4-1A	Cable	0.0007	0.0043

Page A93 of 113
Performed by: CRC
Checked by: SC
6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTL ? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84
CRC 5-10-84
SC 5/14/84

BSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL #4(PNL 2A-DG) LOCA RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000002 0.000002

00000

-----SUMMARY OF TAPS-----

FROM-BUS TO-BUS XTAPS
2 3 -2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	10.357	6.842	12.414	0.016
2	1	-10.340	-6.840	12.397	0.016
2	3	10.340	6.839	12.397	0.016
3	2	-10.096	-6.685	12.109	0.036
3	4	10.095	6.665	12.108	0.036
4	3	-10.079	-6.683	12.093	0.036

-----BUS DATA-----

Page A94 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

AS-BUILT WITH XFMR TAPPED AT -2.5%

RSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 2

05/19/84

NO.	NAME	-----VOLTAGE-----			-----GENERATION-----		-----MOTOR-----		-----STATIC-----		-----MISMATCH-----	
		MAG(PU)	ANG(DEG)	BASE(KV)	KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	MCCDGC	0.9313	-9.84	0.480	10.36	6.84	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFHRP	0.9301	-9.80	0.480	0.00	0.00	0.00	0.00	0.00	0.00	-0.0004	-0.0005
3	XFHRS	0.9318	-9.77	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0003	-0.0001
4	PNL2ADG	0.9306	-9.74	0.208	0.00	0.00	0.00	0.00	10.08	6.68	0.0003	0.0001

RELEASE 9, 10/1/79

ENTER COMMAND

BRANCH ELEMENTS

-INPUT CODE-	TYPE	+++CABLE OR BUS+++		++++CABLE+++++ +++++BUS+++++ ++++++				++REACTOR OR CAPACITOR++				
		---X---	---R---	NO.-SIZE	--FT--	---X/FT--	---R/FT--	--FT--	--X(PU)--	--IR--	--KV--	
B 1-	2- 1A CAB	3.70E-03	2.25E-02									
B 3-	4- 1A CAB	7.00E-04	4.30E-03									

2-WINDING TRANSFORMERS

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVA1-	--KVAR-	-X/R-
T 2- 3- 1	0.0273	0.48	0.21	30.00	30.00*	0.63

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0- 4- 1	0.21	13.16	0.85	LAG
L 0- 4- 2	0.21	0.91	0.50	LAG

SYSTEM EQUIVALENT

-INPUT CODE-	--FNVA--	--KV--	-X/R--
S 0- 1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A95 of 113
 Performed by: CRD 6-6-84
 Checked by: SC 6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84

CRC 5-10-84
SC 5/14/84

BSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL #4(PNL 2A-DG) LIGHTLY LOADED RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%

BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000001 0.000001

00000

SUMMARY OF TAPS

FROM-BUS TO-BUS XTAPS
2 3 -2.50

LINE FLOWS

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	7.182	4.667	8.565	0.010
2	1	-7.175	-4.666	8.559	0.010
2	3	7.169	4.665	8.553	0.010
3	2	-7.081	-4.610	8.449	0.022
3	4	7.084	4.610	8.452	0.022
4	3	-7.078	-4.609	8.446	0.022

BUS DATA

Page A96 of 113
Performed by: *CRC 6-6-84*
Checked by: *SC 6-6-84*

AS-BUILT WITH XFMR TAPPED AT -2.5%

BSEP UNIT #2 203/120 VOLT LOAD STUDY

PAGE 2

05/10/84

NO.	NAME	-----VOLTAGE-----		-----GENERATION-----		-----MOTOR-----		-----STATIC-----		-----MISMATCH-----		
		MAG(PU)	ANG(DEG)	BASE(KV)	KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	MCCDGC	1.0363	-3.94	0.480	7.18	4.67	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	1.0355	-3.92	0.480	0.00	0.00	0.00	0.00	0.00	0.00	-0.0065	-0.0009
3	XFMR5	1.0492	-3.91	0.208	0.00	0.00	0.00	0.00	0.00	0.00	0.0033	0.0000
4	PNL2ADG	1.0484	-3.89	0.208	0.00	0.00	0.00	0.00	7.07	4.61	-0.0031	0.0001

RELEASE 9, 10/1/79

ENTER COMMAND

BRANCH ELEMENTS

-INPUT CODE-	TYPE	++++CABLE OR BUS++++		++++CABLE+++++		++++BUS+++++		++REACTOR OR CAPACITOR++			
		---X---	---R---	NO.-SIZE	--FT--	---X/FT--	---R/FT--	--FT--	--X(PU)--	--IR--	--KV--
B 1-	2- 1A	CAB	3.70E-03	2.25E-02							
B 3-	4- 1A	CAB	7.00E-04	4.30E-03							

2-WINDING TRANSFORMERS

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVAT-	--KVAB-	-X/R-	
T 2-	3- 1	0.0257	0.48	0.21	30.00	30.00*	0.63

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG	
L 0-	4- 1	0.21	7.36	0.85	LAG
L 0-	4- 2	0.21	0.37	0.50	LAG


SYSTEM EQUIVALENT

-INPUT CODE-	--FMVA--	--KV--	-X/R--	
S 0-	1- 1	18.00	0.48	5.0

ENTER COMMAND

Page A97 of 113
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

BSEP - Unit #2



ASDOP MODEL #5

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #5
Pnl. 32B

STATIC LOADS

INPUT CODE	DATA				Comments
	Rated Voltage	Rated kVA at Rated Voltage	Load Power Factor	Lead or Lag PF	
	KV	KVA	PFL	LEAD/LAG	
L-4-1	0.208	0.819	0.85	LAG	LOCA RUN
L-4-2	0.208	3.420	0.5	LAG	LOCA RUN
L-4-1	0.208	0.786	0.85	LAG	LIGHTLY LOADED RUN
L-4-2	0.208	0.225	0.5	LAG	LIGHTLY LOADED RUN

Note: Revision 1 of this calculation reduced the LOCA run value (L-4-2) given above. With this reduced load value, the actual panel voltage would be slightly greater than the value derived in this calculation. Since this was a more conservative treatment of the model, new ASDOP runs were not performed.

Page A99 of 113
Performed by: CRP 7-27-81
Checked by: SC 7-27-81

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #5
Pnl. 32B

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.02043	0.480	0.208	30	30	0.95	LOCA RUN
T2-3-1	0.01758	0.480	0.208	30	30	0.95	LIGHTLY LOADED RUN

Page A100 of 113
Performed by: CRG 6-6-84
Checked by: SC 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP - Unit #2

CASE TITLE: Model #5
Pn1. 32B

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE	RESISTANCE
		(OHMS) X	(OHMS) R
B1-2-1A	Cable	0.0057	0.0750
B3-4-1A	Cable	0.0008	0.0026

Page A101 of 113
Performed by: *CRG*
Checked by: *SC*
6-6-84
G-C-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

DATE = 05/10/84

CRC 5-10-84

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

BSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL #5(PNL 32B) LOCA RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

00000

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000004 0.000003

-----SUMMARY OF TAPS-----

FROM-BUS TO-BUS XTAPS
2 3 -2.50

-----LINE FLOWS-----

		-----LINE POWER FLOW-----			LINE CURRENT
FROM-BUS	TO-BUS	KW	KVAR	KVA	MAG(KA)
1	2	2.094	2.941	3.611	0.005
2	1	-2.089	-2.941	3.607	0.005
2	3	2.089	2.941	3.607	0.005
3	2	-2.079	-2.930	3.593	0.011
3	4	2.081	2.930	3.594	0.011
4	3	-2.080	-2.930	3.593	0.011

-----BUS DATA-----

*****LOAD*****

Page A102 of 113
Performed by: CRC 6-6-85
Checked by: SC 6-6-84

AS-BUILT WITH XFMR TAPPED AT -2.5%

BSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 2

05/10/84

NO.	NAME	VOLTAGE		GENERATION		MOTOR		STATIC		MISMATCH	
		MAG(PU)	ANG(DEG)	BASE(KV)	KU	KVAR	KU	KVAR	KU	KVAR	KU
1	MCC2CB	0.9107	-10.34	0.480	2.09	2.94	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	0.9099	-10.28	0.480	0.00	0.00	0.00	0.00	0.00	-0.0001	-0.0009
3	XFMRB	0.9295	-10.23	0.208	0.00	0.00	0.00	0.00	0.00	0.0026	-0.0004
4	PNL32B	0.9293	-10.22	0.208	0.00	0.00	0.00	2.98	2.93	-0.0025	0.0004

RELEASE 9, 10/1/79
 ENTER COMMAND

BRANCH ELEMENTS

INPUT CODE	TYPE	NO.	SIZE	NO.	SIZE	NO.	SIZE
B 1-	2-1A CAB	5.70E-03	7.50E-02	+	+	+	+
B 3-	4-1A CAB	8.00E-04	2.60E-03	+	+	+	+

2-WINDING TRANSFORMERS

INPUT CODE	NO.	SIZE	NO.	SIZE	NO.	SIZE
T 2-	3-1	0.0204	--KV1-	0.48	--KV2-	0.21

STATIC LOADS

INPUT CODE	NO.	SIZE	NO.	SIZE	NO.	SIZE
L 0-	4-1	0.21	--KVA--	0.82	--FLL-	0.85
L 0-	4-2	0.21	--KVA--	3.42	--FLL-	0.50

SYSTEM EQUIVALENT

INPUT CODE	NO.	SIZE	NO.	SIZE
S 0-	1-1	18.00	--KV--	0.48

ENTER COMMAND

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84

CRC 5-10-84
5/11/84

BSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL #5(PNL 32B) LIGHTLY LOADED RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%

BUS VOLTAGES,CURRENTS,AND POWER FLOWS

00000

CASE TITLE:LOAD FLOW AND LIST ALL

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000001 0.000003

-----SUMMARY OF TAPS-----

FROM-BUS	TO-BUS	ZTAPS
2	3	-2.50


-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	0.866	0.674	1.097	0.001
2	1	-0.865	-0.674	1.097	0.001
2	3	0.863	0.674	1.095	0.001
3	2	-0.863	-0.673	1.094	0.003
3	4	0.861	0.670	1.092	0.003
4	3	-0.861	-0.670	1.091	0.003

-----BUS DATA-----

Page A104 of 113
Performed by: *CRC*
Checked by: *SC G-C-84*

BSEP - Unit #2



ASDOP MODEL #6

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #6
Pnl. 2B-0G

STATIC LOADS

DATA					
INPUT CODE	Rated Voltage	Rated KVA at Rated Voltage	Load Power Factor	Lead or Lag PF	Comments
	KV	KVA	PFL	LEAD/LAG	
L-4-1	0.208	12.919	0.85	LAG	LOCA RUN
L-4-2	0.208	0.897	0.5	LAG	LOCA RUN
L-4-1	0.208	7.357	0.85	LAG	LIGHTLY LOADED RUN
L-4-2	0.208	0.362	0.5	LAG	LIGHTLY LOADED RUN

Page A107 of 113
 Performed by: *DRC* 6-6-84
 Checked by: SC 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP-2

CASE TITLE: Model #6
Pnl. 2B-DG

2 - WINDING TRANSFORMERS

INPUT CODE	DATA						Comments
	Reactance In P.U. On KVA Rating	Voltage Rating Of Bus 1 Winding	Voltage Rating Of Bus 2 Winding	Top FOA KVA Rating	XFMR Base KVA	X to R Ratio	
	XT	KV ₁	KV ₂	KVAT	KVATB (KVAT)	X/R (KVAT)	
T2-3-1	0.0273	0.480	0.208	30	30	0.63	LOCA RUN
T2-3-1	0.0257	0.480	0.208	30	30	0.63	LIGHTLY LOADED RUN

Page A108 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

DUKE POWER COMPANY
ASDOP

STATION AND UNIT: BSEP - Unit #2

CASE TITLE: Model #6
Pnl. 2B-DG

BRANCH ELEMENTS			
INPUT CODE	BRANCH TYPE	REACTANCE	RESISTANCE
		(OHMS) X	(OHMS) R
B1-2-1A	Cable	0.0043	0.0573
B3-4-1A	Cable	0.0007	0.0043

Page A109 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84

CRC 5-10-84

BSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL #6(PNL 2B-DG) LOCA RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

00000

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000003 0.000003

-----SUMMARY OF TAPS-----

FROM-BUS TO-BUS XTAPS
2 3 -2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	10.214	6.735	12.234	0.016
2	1	-10.171	-6.731	12.197	0.016
2	3	10.171	6.731	12.196	0.016
3	2	-9.935	-6.583	11.918	0.035
3	4	9.935	6.582	11.917	0.035
4	3	-9.918	-6.580	11.902	0.035

-----BUS DATA-----

|||||LOAD|||||

Page A110 of 113
Performed by: *CRC*
Checked by: *SC*
6-6-84

05/10/84

AS-BUILT WITH XFMR TAPPED AT -2.5%

PAGE 2

RSEP UNIT #2 208/120 VOLT LOAD STUDY

NO.	NAME	VOLTAGE		GENERATION		MOTOR		STATIC		MISMATCH		
		MAG(PU)	ANG(DEG)	BASE(KV)	KU	KVAR	KU	KVAR	KU	KVAR	KU	KVAR
1	MCC000	0.9335	-10.09	0.480	10.21	6.73	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFMRP	0.9306	-9.99	0.480	0.00	0.00	0.00	0.00	0.00	0.00	-0.0000	-0.0001
3	XFHRS	0.9327	-9.96	0.208	0.00	0.00	0.00	0.00	0.00	0.00	-0.0003	-0.0004
4	PHL2BDG	0.9315	-9.93	0.208	0.00	0.00	0.00	9.92	6.58	0.0003	0.0004	0.0004

RELEASE 9, 10/1/79
 ENTER COMMAND

BRANCH ELEMENTS

---X---	+++CABLE OR BUS+++	---R---	NO.-SIZE	---X/FT---	+++BUS+++++	---R/FT---	---FT---	+++REACTOR OR CAPACITOR+++
B 1- 2- 1A	CAB 4.30E-03	5.73E-02						---X(PU)---
B 3- 4- 1A	CAB 7.00E-04	4.30E-03						---IR---

2-WINDING TRANSFORMERS

---XT---	---KV1---	0.48	---KV2---	0.21	---KVAT---	30.00	---KVAB---	30.00*	---X/R---	0.63
T 2- 3- 1	0.0273									

STATIC LOADS

---KV---	---KVA---	12.92	0.90	---PFL---	LEAD/LAG
L 0- 4- 1	0.21			0.85	LAG
L 0- 4- 2	0.21			0.50	LAG

SYSTEM EQUIVALENT

---FMVA---	18.00	---KV---	0.48	---X/R---	5.0
S 0- 1- 1					

ENTER COMMAND

ENTER COMMAND

NOW IN RUN MODE

DO YOU WANT TO MODIFY THE LOAD-FLOW DATA? (1=YES,0=NO)

GIVE TITLE OF RUN. IT HAS TO BE <80 CHARACTERS

LOAD FLOW AND LIST ALL

00000

DO YOU WANT TO CHANGE THE ABOVE DATA? (0=NO,C=CHANGE)

DO YOU WANT ALL BUSES OUTPUTED? (0=NO,1=YES,2=DEFAULT)

DUKE POWER COMPANY

AUXILIARY SYSTEM DESIGN
OPTIMIZATION PROGRAM
(ASDOP)

DATE = 05/10/84

RC 5-10-84

BSEP UNIT #2 208/120 VOLT LOAD STUDY
MODEL #6(PNL 2B-DG) LIGHTLY LOADED RUN

AS-BUILT WITH XFMR TAPPED AT -2.5%
BUS VOLTAGES,CURRENTS,AND POWER FLOWS

CASE TITLE:LOAD FLOW AND LIST ALL

00000

NO. OF BUSES= 4 NO. OF LINES= 3

SWING BUS NO.= 1

NO. OF ITERATIONS= 4

ABS VOLTAGE ERROR= 0.000001 0.000000

-----SUMMARY OF TAPS-----

FROM-BUS TO-BUS XTAPS
2 3 -2.50

-----LINE FLOWS-----

FROM-BUS	TO-BUS	-----LINE POWER FLOW-----			LINE CURRENT
		KW	KVAR	KVA	MAG(KA)
1	2	7.216	4.683	8.602	0.010
2	1	-7.199	-4.681	8.587	0.010
2	3	7.199	4.682	8.587	0.010
3	2	-7.110	-4.626	8.482	0.022
3	4	7.111	4.625	8.483	0.022
4	3	-7.104	-4.624	8.477	0.022

-----BUS DATA-----

Page A112 of 113
Performed by: *CRG*
Checked by: *SC 6-6-84*

AS-BUILT WITH XFMR TAPPED AT -2.5%

RSEP UNIT #2 208/120 VOLT LOAD STUDY

PAGE 2

05/10/84

NO.	NAME	-----VOLTAGE-----		-----GENERATION-----		-----MOTOR-----		-----STATIC-----		-----MISMATCH-----		
		MAG(PU)	ANG(DEG)	BASE(KV)	KW	KVAR	KW	KVAR	KW	KVAR	KW	KVAR
1	MCCDGD	1.0396	-4.15	0.480	7.22	4.6	0.00	0.00	0.00	0.00	0.0000	0.0000
2	XFHRS	1.0378	-4.09	0.480	0.00	0.00	0.00	0.00	0.00	0.0002	0.0000	
3	XFHRS	1.0514	-4.08	0.208	0.00	0.00	0.00	0.00	0.00	0.0007	-0.0003	
4	PNL2BDG	1.0507	-4.07	0.208	0.00	0.00	0.00	0.00	7.10	4.62	-0.0011	0.0001

RELEASE 9, 10/1/79
ENTER COMMAND

BRANCH ELEMENTS

		+++CABLE OR BUS+++		++++CABLE+++++		+++++BUS+++++		++REACTOR OR CAPACITOR++			
-INPUT CODE-	TYPE	----X----	----R----	NO.-SIZE	--FT--	---X/FT--	---R/FT--	--FT--	--X(PU)--	--IR--	--KV--
B 1-	2- 1A CAB	4.30E-03	5.73E-02								
B 1-	4- 1A CAB	7.00E-04	4.30E-03								

2-WINDING TRANSFORMERS

-INPUT CODE-	--XT--	--KV1-	--KV2-	--KVA1-	--KVAB-	-X/R-	
T 2-	3- 1	0.0257	0.48	0.21	30.00	30.00*	0.63

STATIC LOADS

-INPUT CODE-	--KV--	---KVA--	-PFL-	LEAD/LAG
L 0-	4- 1	0.21	7.36	0.85 LAG
L 0-	4- 2	0.21	0.36	0.50 LAG

SYSTEM EQUIVALENT

-INPUT CODE-	--FNVA--	--KV--	-X/R--
**** tso will be coming out in 5 min. please log off. *** CN(02)			
S 0-	1- 1	18.00	0.48 5.0
ENTER COMMAND****			

Page A113 of 113
Performed by: CRC 6-6-84
Checked by: SC 6-6-84

APPENDIX B

Hand Calculations

TABLE OF CONTENTS

Appendix B-1.0	<u>Sample Hand Calculation</u>
Appendix B-2.0	<u>ASDOP Model Transformer Impedances</u>
Appendix B-3.0	<u>Cable Impedance Calculations</u>
Appendix B-4.0	<u>Overtoltage Under Light Load Conditions</u>
Appendix B-5.0	<u>Correction to U.E. & C. Calculation #7453-227-3-ED00-01</u>

BSEP
Appendix B-1.0
Sample Hand Calculation

The following is an example of a hand calculation of terminal voltage for a 120 VAC single phase load. The circuit investigated is Circuit #9 of Panel 1A-TB. This Unit 1 panel is powered from Unit Substation 1E5. This example demonstrates the procedure followed in obtaining the results summarized in the tables that follow.

From ASDOP,
(Appendix A
Page A8)

$$V_p = 0.9295 \text{ p.u. @ 120V base.}$$

$$V_p = 0.9295 \times \frac{120}{115} = 0.9699 \text{ p.u. @ 115V base.}$$

Longest Cable


Circuit #9

$$R_{1x} = 0.5683 \text{ ohm}$$

$$X_{1x} = 0.0125 \text{ ohm}$$

$$\text{Load} = 21.0 \text{ VA @ } V = 115\text{V and pf} = 0.50 \text{ or } 60^\circ \text{ lagging}$$

The circuit representing Panel 1A-TB and Circuit #9 is shown below.



The load impedance (\bar{Z}_L) and load terminal voltage (\bar{V}_L) are determined as follows:

$$\bar{Z}_L = \frac{(\bar{V}_{\text{rated}})^2}{S} = R_L + jX_L \quad \text{where } \bar{V}_{\text{rated}} \text{ is the device nominal voltage and } S \text{ is the device Volt-Amp rating}$$

$$\bar{Z}_c = R_{1x} + jX_{1x} \quad \text{where } \bar{Z}_c \text{ is the cable impedance}$$

$$\bar{V}_L = \bar{V}_p \times \frac{\bar{Z}_L}{2(\bar{Z}_c) + \bar{Z}_L} \quad \text{where } \bar{V}_p \text{ is the panel voltage}$$

$$V_L = V_p \left[\frac{Z_L}{[2(R_{1x}) + R_L]^2 + [2(X_{1x}) + X_L]^2} \right]^{\frac{1}{2}}$$

BSEP
Appendix B-1.0 (Cont'd)
Sample Hand Calculation

Therefore:

$$Z_L = \frac{(115)^2}{21/-60} = 629.7619/60 = 314.8810 + j 545.3898$$

$$V_L = 0.9699 \frac{629.7619}{\left[[2(0.5683) + 314.8810]^2 + [2(0.0125) + 545.3898]^2 \right]^{\frac{1}{2}}}$$

$$V_L = 0.9690 \text{ p.u. @ 115V base.}$$

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 1 Model #1, PNL 1A-TB, 31AB, 1C, 1A, 1AB-RX, 1AB, 1A-RX (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $(115)^2$ S (Ohms)	CABLE IMPEDANCE Zc (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
1A-TB/#9	(1)	275	21 /-60	314.8810+j545.3898	0.5683 + j0.0125	0.9699	0.9690	No problem
1A-TB/#8	(2)	239	545 /-60	12.1330+j21.0150	0.4939 + j0.0109	0.9699	0.9493	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0928	Vp<1.10	No problem
31AB/#13	(1)	97	500 /-60	13.2250+22.9064	0.2004+j0.0044	0.9718	0.9641	No problem
None	(2)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0938	Vp<1.10	No problem
1C/#10	(1)	2174	84 /-60	78.7202+j136.3475	4.4929+j0.0991	0.9718	0.9428	No problem
See Ckt #10	(2)	See Ckt #10	See Ckt #10	See Ckt #10	N/A	See Ckt #10	Compare with Ckt #10	No problem
1C/#6	(3)	2129	42 /-60	N/A	N/A	0.9718	Compare with Ckt #10	No problem
1C/#24	(3)	1509	40 /-60	N/A	N/A	0.9718	Compare with Ckt #10	No problem
N/A	(4)	N/A	N/A	N/A	N/A	1.0938	Vp<1.10	No problem
1A/#22	(1)	2287	16 /-60	413.2813+j715.8241	4.7264+j0.1043	0.9716	0.9658	No problem
1A/#27	(2)	1564	84 /-60	78.7202+j136.3475	3.2322+j0.0713	0.9716	0.9508	No problem
None	(3)	N/A	N/A	N/A	N/A	0.9716	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0938	Vp<1.10	No problem
1A/#29	N/A	2180	32 /-60	206.6406+j357.9121	4.5053+j0.0994	0.9716	0.9606	No problem

*(1) Longest Cable (LOCA)
(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)

Page B4 of 24
Performed by: CRC
Checked by: SC
6-6-84

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 1 Model #1, PNL 1A-TB, 31AB, 1C, 1A, 1AB-RX, 1AB, 1A-RX (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p. u.)	LOAD TERMINAL VOLTAGE @ 115V (p. u.)	Comments
1AB-RX/#31	(1)	661	21 /-60	314.8810+j545.3898	1.3660+j0.0301	0.9706	0.9685	No problem
1AB-RX/#5	(2)	116	59 7-60	112.0763+j194.1218	^ .2397+j0.0053	0.9706	0.9696	No problem
None	(3)	N/A	N/A	N/A	N/A	0.9706	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0937	Vp<1.10	No problem
1AB/#19	(1)	169	600 /-60	11.0208+j19.0886	0.3492+j0.0077	0.9716	0.9555	No problem
1AB/#14	(2)	84	960 7-60	6.8880+j11.9304	0.1092+j0.0038	0.9716	0.9634	No problem
None	(3)	N/A	N/A	N/A	N/A	0.9716	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0938	Vp<1.10	No problem
1A-RX/#6	(1)	1072	17 /-60	388.9706+j673.7168	2.2154+j0.0488	0.9700	0.9671	No problem
1A-RX/#24	(2)	221	21 7-60	314.8810+j545.3898	0.4567+j0.0101	0.9700	0.9693	No problem
None	(3)	N/A	N/A	N/A	N/A	0.9700	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0928	Vp<1.10	No problem

*(1) Longest Cable (LOCA)
(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)

Page B5 of 24
 Performed by: CRC 6-7-
 Checked by: SC 6-7-

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 1 Model #2, PNL IAB-TB, 1B-TB, 1B-RX, 1D, 1B (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL Ckt	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
IAB-TB/#2	(1)	1090	23 /-60	287.5000+j497.9646	2.2526+j0.0497	0.9658	0.9619	No problem
IAB-TB/#18	(2)	908	882 /-60	7.4972+j12.9855	1.8765+j0.0414	0.9658	0.8398	Below 0.9
IAB-TB/#18	with 2 #12 Cables	908	882 /-60	7.4972+j12.9855	0.9383+j0.0207	0.9658	0.9023	Solution to Ckt #18
IAB-TB/#3	(22)	427	528 /-60	12.5237+j21.6916	0.3824+j0.0195	0.9658	0.9302	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0922	Vp<1.10	No problem
1B-TD/#9	(1)	251	21 /-60	314.8810+j545.3898	0.5187+j0.0114	0.9712	0.9703	No problem
None	(2)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0950	Vp<1.10	No problem
1B-RX/#32	(1)	399	21 /-60	314.8810+j545.3898	0.8246+j0.0182	0.9707	0.9654	No problem
None	(2)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0948	Vp<1.10	No problem

- *(1) Longest Cable (LOCA)
- (2) Largest Load (LOCA)
- (22) Next Largest Load (LOCA)

- (3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
- (4) Shortest Cable (Light Load)

Page B6 of 24
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 1 Model #2, PNL 1A-B-TB, 1B-TB, 1B-RX, 1D, 1B (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
1D/#12	(1)	1580	240 /-60	27.5521+j47.7216	3.2653+j0.0720	0.9718	0.9113	No problem
None	(2)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0953	Vp<1.10	No problem
1B/#27	(1)	2280	32 /-60	206.6406+j357.9121	4.7119+j0.1040	0.9715	0.9600	No problem
1B/#18	(2)	169	500 /-60	13.2250+j22.9064	0.3492+j0.0077	0.9715	0.9581	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0951	Vp<1.10	No problem

*(1) Longest Cable (LOCA)

(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)

(4) Shortest Cable (Light Load)

Page B7 of 24
Performed by: CRC 6-6-
Checked by: SC 6-6-

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

UNIT 1 Model #3, PNL 31A (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
31A/#11	(1)	194	32 /-60	206.6406+j357.9121	0.4009+j0.0088	0.9549	0.9539	No problem
31A/#1	(2)	70	52.8 /-60	125.2367+j216.9164	0.1446+j0.0032	0.9549	0.9543	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0802	Vp<1.10	No problem

*(1) Longest Cable (LOCA)
(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)

Page 88 of 24
 Performed by: CRC 6-7-84
 Checked by: SC 6-7-84

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

UNIT 1 Model #4, PNL 1A-DG (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKt	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
1A-DG/#1	(1)	229	21 /-60	314.8810+j545.3898	0.4733+j0.0104	0.9554	0.9547	No problem
1A-DG/#24	(2)	96	147.6 /-60	44.8001+j77.5961	0.1983+j0.0044	0.9554	0.9532	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0793	Vp<1.10	No problem

*(1) Longest Cable (LOCA)
(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)

PAGE B9 of 24
 Performed by: CRC
 Checked by: SC
 C-6-6-8

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 1 Model #5, PNL 31B (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKE	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p. u.)	LOAD TERMINAL VOLTAGE @ 115V (p. u.)	Comments
31B/#8	(1)	79C	353 /-60	18.7323+j32.4453	1.6450+j0.0363	0.9548	0.9108	No problem
31B/#1	(11)	156	52.8 /-60	125.2367+j216.9164	0.3224+j0.0071	0.9548	0.9535	No problem
31B/#23	(2)	85	886 /-60	7.4633+j2.9268	0.1756+j0.0038	0.9548	0.9431	No problem
None	(3)	N/A	N/A	N/A	N/A	0.9548	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0863	Vp<1.10	No problem

*(1) Longest Cable (LOCA)

(2) Largest Load (LOCA)

(11) Next Longest Cable (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)

(4) Shortest Cable (Light Load)

Note: Total load on this panel was decreased in Revision 1 of this calculation and, therefore, the actual panel voltage would be greater than the originally calculated value. Since the previously derived value provides a more conservative panel voltage, it was used in the above hand calculations.

Page B10 of 24
 Performed by: CRP
 Checked by: SC
 7-27-84
 7-27-84

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 1 Model #6, PNL 1B-DG (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p. u.)	LOAD TERMINAL VOLTAGE @ 115V (p. u.)	Comments
1B-DG/#15	(1)	858	9.4 /-60	703.4575+j1218.424	1.7732+j0.0391	0.9472	0.9460	No problem
1B-DG/#14	(2)	122	148 7-60	44.6791+j77.3864	0.2521+j0.0055	0.9472	0.9444	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0823	Vp<1.10	No problem

*(1) Longest Cable (LOCA)
(?) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)

Page B11 of 24
 Performed by: CRC 6-6-6-
 Checked by: SC 6-6-6-

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 2 Model #1, PNL 2A-TB, 32AB, 2C, 2A, 2AB-RX, 2AB, 2A-RX (MODIFIED WITH XFMR TAPS SWITCHED TO NOMINAL)

PANEL Ckt	PARAMETERS *	CABLE LENGTH (FT)	ξ (VA)	LOAD IMPEDANCE $\frac{(115)^2}{\xi}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
2A-TB/#7	(1)	1661	31.2 /-60	211.9391+j367.0893	3.4327+j0.0757	0.9607	0.9526	No problem
2A-TB/#6	(2)	127	545 /-60	12.1330+j21.0150	0.2624+j0.0058	0.9607	0.9499	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0753	Vp<1.10	No problem
32AB/#7	(1)	209	21 /-60	314.8810+j545.3898	0.4318+j0.0095	0.9639	0.9632	No problem
32AB/#22	(2)	111	500 /-60	13.2250+j22.9064	0.2294+j0.0051	0.9639	0.9552	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0771	Vp<1.10	No problem
2C/#10	(1)	2293	42 /-60	157.4405+j272.6949	4.7388+j0.1045	0.9640	0.9489	No problem
2C/#19	(2)	940	80.5 /-60	82.1429+j142.2756	1.9426+j0.0428	0.9640	0.9521	No problem
2C/#6	(3)	1549	42 /-60	Less than Ckt #10	3.2012+j0.0706	0.9640	See Ckt #10	No problem
N/A	(4)	N/A	N/A	N/A	N/A	1.0771	Vp<1.10	No problem
2A/#29	(1)	2150	32 /-60	206.6406+j357.9121	4.4433+j0.0980	0.9639	0.9531	No problem
2A/#27	(2)	1574	84 /-60	78.7202+j136.3475	3.2529+j0.0717	0.9639	0.9431	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0771	Vp<1.10	No problem

*(1) Longest Cable (LOCA)
(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)

Page B12 of 24
Performed by: CRC 6-7-84
Checked by: SC 6-7-84

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 2 Model #1, PNL 2A-TB, 32AB, 2C, 2A, 2AB-RX, 2AB, 2A-RX (MODIFIED WITH XFMR TAPS SWITCHED TO NOMINAL)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
2AB-RX/#5	(1)	115	59 /-60	112.0763+j194.1218	0.2376+j0.0052	0.9633	0.9622	No problem
None	(2)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0769	Vp<1.10	No problem
2AB/#19	(1)	136	600 /-60	11.0208+j19.0886	0.2810+j0.0062	0.9637	0.9509	No problem
2AB/#14	(2)	84	960 /-60	6.8880+j11.9304	0.1735+j0.0038	0.9637	0.9510	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0770	Vp<1.10	No problem
2A-RX/#6	(1)	1083	17 /-60	388.9706+j673.7168	2.2382+j0.0494	0.9632	0.9603	No problem
2A-RX/#27	(2)	302	31 /-60	213.3065+j369.4576	0.6241+j0.0138	0.9632	0.9617	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0768	Vp<1.10	No problem

*(1) Longest Cable (LOCA)
(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)

Page B13 of 24
 Performed by: CRC 6-6-81
 Checked by: SC 6-6-81

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 2 Model #2, PNL 2AB-TB, 2B-TB, 2B-RX, 2D, 2B (MODIFIED WITH XFMR TAPS SWITCHED TO NOMINAL)

PANEL Ckt	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p. u.)	LOAD TERMINAL VOLTAGE @ 115V (p. u.)	Comments
2AB-TB/#16	(1)	648	882 /-60	7.4972+j12.9854	1.3388+j0.0295	0.9634	0.8732	Below 0.9 Solution to Ckt #16
2AB-TB/#16	With 2 #12 Cables	648	882 /-60	7.4972+j12.9854	0.6694+j0.0148	0.9634	0.9183	
2AB-TB/#2	(11)	573	23 /-60	287.5000+j497.9646	1.184+j0.0261	0.9634	0.9613	No problem
2AB-TB/#3	(2)	425	528 /-60	12.5237+j21.6916	0.8780+j0.0194	0.9634	0.9280	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0783	Vp<1.10	No problem
2B-TB/#9	(1)	277	21 /-60	314.8810+j545.3898	0.5723+j0.0126	0.9658	0.9649	No problem
None	(2)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0794	VP<1.10	No problem
2B-RX/#30	(1)	557	21 /-60	314.8810+j545.3898	1.1511+j0.0254	0.9654	0.9636	No problem
None	(2)	N/A	N/A	N/A	N/A	0.9654	N/A	N/A
None	(3)	N/A	N/A	N/A	N/A	0.9654	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0792	VP<1.10	No problem

- *(1) Longest Cable (LOCA)
- (2) Largest Load (LOCA)
- (11) Next longest cable (LOCA)

- (3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
- (4) Shortest Cable (Light Load)

Page B14 of 24
 Performed by: CRC 6-6-84
 Checked by: SC 6-6-84

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 2 Model #2, PNL 2AB-TB, 2B-TB, 2B-RX, 2D, 2B (MODIFIED WITH XFMR TAPS SWITCHED TO NOMINAL)

PANEL Ckt	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
2D/#12	(1)	1961	240 /-60	27.5521+j47.7216	4.0527+j0.0894	0.9676	0.8929	Below 0.9 Solution to Ckt #12
2D/#12	With 2 #12 Cables	1961	240 <u>7-60</u>	27.5521+j47.7216	2.0264+j0.0447	0.9676	0.9303	
2D/#21	(11)	1812	68 /-60	97.2427+j168.4292	3.7447+j0.0826	0.9676	0.9481	No problem
2D/#22	(2)	574	96 <u>7-60</u>	68.8802+j119.3040	1.1862+j0.0262	0.9676	0.9589	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0803	Vp<1.10	No problem
2B/#27	(1)	2260	32 /-60	206.6406+j357.9121	4.6706+j0.1030	0.9674	0.9560	No problem
2B/#10	(2)	162	500 <u>7-60</u>	13.225+j22.9064	0.3348+j0.0074	0.9674	0.9546	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0802	Vp<1.10	No problem

- *(1) Longest Cable (LOCA)
- (2) Largest Load (LOCA)
- (3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)

- (4) Shortest Cable (Light Load)
- (11) Next Longest Cable (LOCA)

PAGE B15 of 24
 Performed by: CRG 6-6-8
 Checked by: SC 6-6-8

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 2 Model #3, PNL 32A (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
32A/#6	(1)	1239	17 /-60	388.9706+j673.7168	** 2.5606+j0.0564	0.9789	0.9756	No problem
32A/#1	(2)	76	52.8 /-60	125.2367+j216.9164	0.0987+j0.0034	0.9789	0.9785	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0986	Vp<1.10	No problem

*(1) Longest Cable (LOCA)
(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)
** See page B24

Page B16 of 24
 Performed by: CRC
 Checked by: SC
 6-6-84
 6-6-84

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 2 Model #4, PNL 2A-DG (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
2A-DG/#4	(1)	429	42 /-60	157.4405-j272.6949	0.8866+j0.0195	0.9711	0.9682	No problem
2A-DG/#24	(2)	123	147.6 /-60	44.8001+j77.5961	0.2541+j0.0056	0.9711	0.9682	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0940	Vp<1.10	No problem

*(1) Longest Cable (LOCA)
(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)

PAGE B17 of 24
 Performed by: CRC 6-6-8
 Checked by: SC 6-6-84

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 2 Model #5, PNL 32B (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
32B/#22	(1)	2877	32 /-60	206.6406+j357.9121	5.9457+j0.1312	0.9697	0.9551	No problem
32B/#14	(2)	875	353 /-60	18.7323+j32.4453	1.8076+j0.0399	0.9697	0.9206	No problem
32B/#11	(22)	116	886 /-60	7.4633+j12.9268	0.2397+j0.0053	0.9697	0.9536	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0971	Vp<1.10	No problem

*(1) Longest Cable (LOCA)
(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)
(4) Shortest Cable (Light Load)

Note: Total load on this panel was decreased in Revision 1 of this calculation and, therefore, the actual panel voltage would be greater than the originally calculated value. Since the previously derived value provides a more conservative panel voltage, it was used in the above hand calculations.

Page B18 of 24
 Performed by: *CPC*
 Checked by: *SC 7-27-84*

APPENDIX B-1.0
LOAD TERMINAL VOLTAGE HAND CALCULATIONS

Unit 2 Model #6, PNL 2B-DG (AS-BUILT WITH XFMR TAPPED AT - 2.5%)

PANEL CKT	PARAMETERS *	CABLE LENGTH (FT)	S (VA)	LOAD IMPEDANCE $\frac{(115)^2}{S}$ (Ohms)	CABLE IMPEDANCE Z_c (Ohms)	PANEL VOLTAGE @ 115V (p.u.)	LOAD TERMINAL VOLTAGE @ 115V (p.u.)	Comments
2B-DG/#2,9, 11,16,17,19 20	(1)	1016	33.6 /-60	196.8006+j340.8686	2.0990+j0.0463	0.9720	0.9666	No problem
2B-DG/#24	(2)	144	148 /-60	44.6791+j77.3864	0.2976+j0.0066	0.9720	0.9686	No problem
None	(3)	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	(4)	N/A	N/A	N/A	N/A	1.0964	Vp<1.10	No problem

*(1) Longest Cable (LOCA)

(2) Largest Load (LOCA)

(3) More than 50% of the Longest Cable and more than 50% of the Largest Load (LOCA)

(4) Shortest Cable (Light Load)

Page B19 of 24
 Performed by: CRG
 Checked by: SC
 6-6-88

BSEP
Appendix B-2.0
ASDOP Model Transformer Impedances

In these studies transformer worst case impedances were used in all cases (i.e., for LOCA Run models, transformer impedance was assumed to be at its maximum possible value and for LIGHTLY LOADED (Shutdown) models, the impedance was assumed to be at a minimum). These assumptions provided lowest (worst case) panel voltages for LOCA Run models and highest (worst case) panel voltages for LIGHTLY LOADED (Shutdown) models. The calculation of these values is shown below.

- 150 KVA 208/120 Transformers GF4 & GF6

$$X''_{\text{nominal}} = 3.1\% \text{ with a } \pm 7.5\% \text{ tolerance}$$

Therefore, for LOCA Run cases, X'' was assumed to be:

$$X''_{\text{LOCA}} = 0.031 + (0.031 \times 0.075) = 0.0333 \text{ p.u.}$$

For Lightly Loaded (Shutdown) cases, X'' was assumed to be:

$$X''_{\text{LITE}} = 0.031 - (0.031 \times 0.075) = 0.0287 \text{ p.u.}$$

- 30 KVA 208/120 Transformers GF2, HE1, FN3, GF3, (Unit 1) and GE7, GE8, (Unit 2)

$$X''_{\text{nominal}} = 2.62\% \text{ with a tolerance of } +4\%, -2\%$$

This yielded:

$$X''_{\text{LOCA}} = 0.0273 \text{ p.u.}$$

$$X''_{\text{LITE}} = 0.0257 \text{ p.u.}$$

- 3-10 KVA 208/120 Transformer banks FJ6 & FJ7 (Unit 2)

$$X''_{\text{nominal}} = 1.9\% \text{ with a tolerance of } \pm 7.5\%$$

This yielded:

$$X''_{\text{LOCA}} = 0.0204 \text{ p.u.}$$

$$X''_{\text{LITE}} = 0.0176 \text{ p.u.}$$

BSEP Units 1 and 2Appendix B-3.0Cable Impedance Calculations by Duke Power Company

- For Circuit #18 of Panel 1AB-TB, U.E. & C. provided the cable impedance of one #12 cable as $R = 1.8765$ ohms, $X = 0.0414$ ohms. The equivalent impedance of two parallel #12's was found from the following relationship:

$$R_{\text{equivalent}} = \frac{1}{\frac{1}{R_{\#12}} + \frac{1}{R_{\#12}}} = \frac{R_{\#12}}{2}$$

$$X_{\text{equivalent}} = \frac{1}{\frac{1}{X_{\#12}} + \frac{1}{X_{\#12}}} = \frac{X_{\#12}}{2}$$

Therefore,

$$R_{2\#12's} = 0.9383 \text{ ohms}$$

$$X_{2\#12's} = 0.0207 \text{ ohms}$$

- A similar procedure was followed in calculating the impedance of four parallel #12 cables for Circuit #8 of Panel 31B:

$$R_{\text{equivalent}} = \frac{1}{\frac{1}{R_{\#12}} + \frac{1}{R_{\#12}} + \frac{1}{R_{\#12}} + \frac{1}{R_{\#12}}} = \frac{R_{\#12}}{4}$$

$$X_{\text{equivalent}} = \frac{1}{\frac{1}{X_{\#12}} + \frac{1}{X_{\#12}} + \frac{1}{X_{\#12}} + \frac{1}{X_{\#12}}} = \frac{X_{\#12}}{4}$$

Therefore:

$$R_{4\#12's} = 0.4113 \text{ ohms}$$

$$X_{4\#12's} = 0.0091 \text{ ohms}$$

In calculating the impedance of the single #6 cable, Table 1.20 was used along with the cable length provided by U.E. & C. This yielded:

$$R_{\#6} = (796 \text{ feet}) \left(\frac{0.0493 \text{ ohms}}{100 \text{ feet cable}} \right) (1.048) = 0.4113 \text{ ohms}$$

where 1.048 was the temperature correction factor used to derate the cable for operation at a 90°C ambient temperature. Similarly:

$$X_{\#6} = (796 \text{ feet}) \left(\frac{0.00391 \text{ ohms}}{100 \text{ feet cable}} \right) = 0.0311 \text{ ohms}$$

- For Circuit #16 of Panel 2AB-TB, U.E. & C. provided the impedance of one #12 cable as $R = 1.3388$ ohms and $X = 0.0295$ ohms. As previously derived, the equivalent impedance of two parallel #12 cables is:

$$R_{2\#12's} = \frac{1.3388}{2} = 0.6694 \text{ ohms}$$

$$X_{2\#12's} = \frac{0.0295}{2} = 0.0148 \text{ ohms}$$

- Circuit #12 of Panel 2D also required a paralleling of another #12 cable with the original yielding the following resultant cable resistance and reactance:

$$R_{2\#12's} = \frac{4.0527}{2} = 2.0264 \text{ ohms}$$

$$X_{2\#12's} = \frac{0.0894}{2} = 0.0447 \text{ ohms}$$

- For Circuit #14 of Panel 32B, the recommendation was to replace the original #12 cable with a single #6 cable. The impedance of this replacement cable was calculated as shown below:

From U.E. & C. data: cable length = 875 ft.

From Table 1.20: $R_{\#6} = 0.0493$ ohms/100 ft.

$X_{\#6} = 0.00391$ ohms/100 ft.

Note: These values are at 70°C. A multiplier of 1.048 must be used to calculate cable resistance at a 90°C ambient temperature.

Therefore, for this circuit:

$$R_{\#6} = (875 \text{ feet}) \left(\frac{0.0493 \text{ ohms}}{100 \text{ feet}} \right) (1.048) = 0.4521 \text{ ohms}$$

$$X_{\#6} = (875 \text{ feet}) \left(\frac{0.00391 \text{ ohms}}{100 \text{ feet}} \right) = 0.0342 \text{ ohms}$$

BSEP

Appendix B-4.0

Overvoltage Under Light Load Conditions

For Models 1 & 2 of Unit 2 (panels powered from Unit Substations 2E7 & 2E8), the worst case overvoltage before implementing the tap change to the transformers feeding these panels was:

- Panels 2A & 2C (fed from Unit Substation 2E7)

The voltage at the panel during Light Load operation was 1.0586 p.u. on a 120VAC base or 1.1046 p.u. on a 115VAC base. This yielded:

$$(1.1046 - 1.10) \times 100 = 0.46\% \text{ overvoltage.}$$

- Panel 2D (fed from Unit Substation 2E8)

The voltage at the panel during Light Load operation was 1.0618 p.u. on a 120VAC base or 1.1080 p.u. on a 115VAC base. This yielded:

$$(1.1080 - 1.10) \times 100 = 0.80\% \text{ overvoltage.}$$

BSEP
Appendix B-5.0
Correction to U.E. & C. Calculation #7453-227-3-ED00-01

- Panel 32A, Circuit #6

The LOCA resistance is recorded on page 38 of 48 as $R_{1X} = 2.506$ ohms

From Table 1.20, the resistance of a #12 cable is:

$$R_{\#12} = 0.1972 \text{ ohms/100 ft.}$$

Therefore, for this 1239 ft. long cable, the resistance at 70°C is:

$$R = \left(\frac{0.1972 \text{ ohms}}{100 \text{ ft.}} \right) (1239 \text{ feet}) = 2.4433 \text{ ohms}$$

For use in this calculation, the cable must be derated to operate at a 90°C ambient temperature. Per U.E. & C. data on page 48 of 48, this correction factor is 1.048.

Therefore, the resistance of this cable should be:

$$R_{1X} = (1.048) (2.4433) = 2.5606 \text{ ohms}$$

ATTACHMENT #1

Transformer Data

Cable Data

Load Data

Attachment #1
 BSEP - Units 1 & 2
Miscellaneous Information Used in 208/120 Volt Load Studies

The following information was obtained from CP&L letter # ED-202 dated May 27, 1984. Transformer tap settings were obtained from memorandum from H. Nguyen to A. Benge dated 04/19/84.

- Units 1 & 2: 150 KVA 480/208/120 VAC Transformers GF4 and GF6

Taps presently set on - 2.5%.
 X = 3.1%
 R = 1.1%
 Z = 3.3%
 Tolerance = ±7.5%.

- Unit 2: Cable Impedances @ 90°C

<u>From</u>	<u>To</u>	<u>Z (Ω)</u>
Transformer GF4	Panel 2E7	0.001071+j0.0010325
Transformer GF6	Panel 2E8	0.0007038+j0.0006785

- Unit 1: 30 KVA 480/208/120 VAC Transformers GF2, HE1, FN3 & GF3
 Unit 2: 30 KVA 480/208/120 VAC Transformers GE7 & GE8

Taps presently set on - 2.5%
 X = 2.62%
 R = 4.18%
 Z = 5%
 Tolerance = +4, -2%

- Unit 2: 3-10KVA 480/208/120VAC Transformer banks F56 & F57

Taps presently set on -2.5%
 X = 1.9%
 R = 2%
 Z = 2.76%
 Tolerance = ±7.5%

- Unit 2: Cable Impedances @ 90°C

<u>From</u>	<u>To</u>	<u>Z (Ω)</u>
Unit Substation 2E7	Transformer GF4	0.01962+j0.01822
Unit Substation 2E8	Transformer GF6	0.03235+j0.02941

Attachment #1
 BSEP - Units 1 & 2
Miscellaneous Information Used in 208/120 Volt Load Studies

- Unit 1: Cable Impedances @ 90°C

<u>From</u>	<u>To</u>	<u>Z (Ω)</u>
Unit Substation 1E6	Transformer GF6	0.01773+j0.01587
Transformer GF6	Distribtuion Panel 1E6	0.000735+j0.000708
Unit Substation 1E5	Transformer GF4	0.02594+j0.02382
Transformer GF4	Distribution Panel 1E5	0.00107+j0.00103

- Units 1 & 2: Bus Voltages from ASDOP model runs for both LOCA Run and Shutdown conditions for busses powering 480/208/120 VAC transformers.

Load Data


U.E. & C. calculations 7453-127-3-ED00-01 and 7453-227-3-ED00-01 are included as part of this attachment. Load data used in this study was taken from these calculations which consist of:

- Calculation 7453-127-3-ED00-01
 - Cover Sheet ----- 1 page
 - Calculation Notes ----- 6 pages
 - Load Tabulations for Unit 1 -----47 pages
- Calculation 7453-227-3-ED00-01
 - Cover Sheet ----- 1 page
 - Calculation Notes ----- 6 pages
 - Load Tabulations for Unit 2 -----42 pages

Revision 1

Revision 1 to Duke Power Calculation MTS-2076-1808.04-00-0001 was based on a revision of the 1X-LOCA load value for circuits 31B-8 and 32B-14 (from 1621 VA to 353 VA). These values are documented on Revision 1 to pages 45 of 53 and 40 of 48 of U.E&C. Calculations 7453-127-3-ED00-01 and 7453-227-3-ED00-01, respectively.

Form 5604



CALCULATION CONTROL SHEET

PROJECT TITLE CP&L-BSEP NO. 1 DISCIPLINE ELECTRICAL

CALC. SET NO.

PRELIM.	
FINAL	✓
VOID	

SYSTEM 208/120 VOLT DISTRIBUTION SYSTEM

SUBJECT 1X LOCA - 208/120VOLT SYSTEM DATA

DESIGN CLASSIFICATION CLASS 1E (SAFETY RELATED)

STARTED BY R. ABDUL DATE 04/16/84

AUTHORIZED BY K.L. BAR DATE 04/16/84

PROBLEM STATEMENT

PREPARE LOAD DATA FOR BSEP UNIT #1
208/120 VOLT DISTRIBUTION SYSTEM BASED ON
a) NORMAL PLANT OPERATION, AND
b) A LOSS OF COOLANT ACCIDENT (LOCA)
FOR ONE UNIT AND AN ORDERLY
SHUTDOWN OF THE OTHER UNIT.

DESIGN BASIS


- UPDATED FSAR DATED 7/19/82
- REFER TO SECTION 3 FOR ADDITIONAL CRITERIA

TOTAL NUMBER OF SET COMPUTATION SHEETS 53 (EXCLUDING CALC. CONTROL SHEET)

FINISHED BY Rashid Abdul 4/24/84 CHECKED BY M. S. Mulla 4/28/84

	CHECKER	DESIGN SUPER	CONSULTANT ENG'R	DESIGN REVIEW
BY	<u>M. S. Mulla</u>	<u>Rashid Abdul</u>	<u>Rashid Abdul</u>	
DATE	<u>4/29/84</u>		<u>4/26/84</u>	


REVISION 1 STARTED DATE _____ BY _____

 United engineers & constructors inc CALCULATION SUMMARY & REFERENCE SHEET		CALC. SET NO.	
		PRELIM.	
PROJECT TITLE <u>CP&L - BSEP NO.1</u> DISCIPLINE <u>ELECTRICAL</u>		FINAL	✓
		VOID	
SYSTEM <u>208/120 VOLT DISTRIBUTION SYSTEM</u>		SHEET <u>1</u> OF <u>53</u>	
		J.O. <u>7453-127</u>	
SUBJECT <u>1X LOCA - 208/120 VOLT SYSTEM DATA</u>		Rev	
		COMP BY	CHK'D BY
DESIGN CLASSIFICATION <u>CLASS 1E (SAFETY RELATED)</u>		0	RA
		DATE	DATE
		4/21/84	2/25/84
		DATE	DATE
SUMMARY/CONCLUSIONS			
<p>REFER TO SECTION 4.0 OF THE CALCULATION - "SYSTEM LOAD DATA"</p>			
REFERENCES: (SPECIFICATIONS, DRAWINGS, CODES, CALCULATION SETS, TEXTS, REPORTS, COMPUTER DATA PSAR ETC.)			
<ol style="list-style-type: none"> 1. CALC. NO. 9527-001-3-ED00-53-F, TITLED "VOLTAGE DROP STUDY, 208/120 VOLT SAFETY RELATED LOADS" - REV. 1, DATED 5/25/81 2. NOTES OF TELEPHONE CONVERSATIONS T-1000 DATED 3/13, 16/84 AND T-961 DATED 2/28/84. 3. DRAWING SCHEDULES DATED 12/30/83 4. INDUSTRIAL POWER SYSTEM HANDBOOK BY D. BEEMAN, EDITOR, FIRST EDITION, MCGRAW HILL BOOK COMPANY, INC., 1955 5. DRAWINGS AS LISTED IN THE CIRCUIT EVALUATION TABLES FOR VARIOUS LOADS 6. CP&L WORK AUTHORIZATION NO. X532340023 TO CONTRACT NO. XM 32340000, 3/9/84 (FILE H&R/C6) 			

GENERAL COMPUTATION SHEET

7453-127-3-ED00-01

DISCIPLINE:
ELECTRICAL



NAME OF COMPANY: CP & L, BSEP UNIT: 1

SUBJECT: 1X LOCA - 208/120 VOLT SYSTEM DATA

CALC SET NO		REV	DATE BY	CHKD BY
FRELIM				
FINAL	✓	C	RA DATE 4/21/84	JT DATE 4/25/84
VOID				
SHEET 2 OF 53				
JOB 7453-127			DATE	DATE

INDEX

1. PURPOSE
2. SCOPE
3. REVIEW METHODOLOGY/CRITERIA
4. SYSTEM LOAD DATA TABLES
5. FEEDER CABLE IMPEDANCE DATA
6. ATTACHMENT TO CALCULATION
 - 6.1 CIRCUIT EVALUATION TABLES (CONTROLLED AS PART OF THIS CALCULATION)
 - 6.2 NOTES OF TELEPHONE CONVERSATIONS & CORRESPONDENCE ETC.


(ATTACHED FOR INFORMATION ONLY & CONTROLLED UNDER SEPARATE SERIAL NUMBERS; i.e., THIS IS NOT PART OF THIS CALCULATION PROCEDURALLY).

GENERAL COMPUTATION SHEET

7453-127-3-ED00-01

(DISCIPLINE)

ELECTRICAL



NAME OF

COMPANY CE&L, BSEP UNIT/1SUBJECT IX LOCA - 208/120VOLT SYSTEM DATA

CALC SET NO		REV	COMP BY	CHKD
PRELIM		0	RA	MS
FINAL	✓		DATE 4/26/84	DATE 9/26/83
VOID				
SHEET 3 OF 53			DATE	DATE
JO 7453-127				

1. PURPOSE:


Provide 208/120 VOLT AC Load data for a loss of coolant accident (LOCA) in one unit with an orderly shutdown of the other unit.

2. SCOPE:

1. To provide the maximum load data on each 208/120 VOLT distribution Panel and bus, based on a loss of Coolant accident (LOCA) on one unit and an orderly shutdown of the other unit
2. Load data will be updated with the "As Built" plant modifications through November 1983.
3. Cable data, including number of conductors, cable size, length, and impedance for feeder cables to 120/208 VOLT panels/buses and for the cables to the load terminals.
4. Transformer impedances and X/R ratio for all 480 - 208/120 VOLT transformers.

(NOTE: Refer to CE&L Work Authorization No. XS32340023 TO CONTRACT NO. XM32340000 as modified by

DISCIPLINE:
ELECTRICAL




NAME OF COMPANY: CP&L, BSEP UNITS: 1

SUBJECT: 1X LOCA - 208/120 VOLT SYSTEM DATA

CALC SET NO		REV	COMP BY	CHK'D BY
PRELIM		0	RA	M
FINAL	✓		DATE 4/26/84	DATE 4/28/83
VOID				
SHEET 4 OF 53				
JC 7453-127			DATE	DATE


NOTES OF TELEPHONE CONVERSATION NO. T-961 dated 2/28/84.

3. REVIEW METHODOLOGY / CRITERIA



GENERAL COMPUTATION SHEET

7453-127-3-ED00-01

(DISCIPLINE)
ELECTRICALNAME OF COMPANY C P & L BSEP UNIT# 1SUBJECT 1X LOCA - 208/120 VOLT SYSTEM DATA


CALC SET NO		REV	COMP BY	CHK D
PRELIM		0	RA	MS
FINAL	✓		DATE 4/21/84	DATE 4/28/84
VOID				
SHEET 5 OF 53			DATE	DATE
JO 7453-127				

A GENERAL FLOW DIAGRAM IS SHOWN ON PREVIOUS PAGE TO INDICATE THE VARIOUS ELEMENTS OF TASK. SOME LOAD DATA ARE TAKEN FROM THE EXISTING CALC. NO. 9527-001-3-ED00-53-F REV. 1, DATED 2/25/81. VARIOUS MANUFACTURERS WERE CALLED TO OBTAIN LOAD DATA WHEN F.P OR INST. MANUALS DID NOT PROVIDE THE REQUIRED INFORMATION.

THE FOLLOWING APPROACH WAS ADOPTED AS NOTED IN THE TELEPHONE CONVERSATION NOT T-1000 DATED 3/16/84:

1. CONCURRENT SHUTDOWN: MEANS ORDERLY SHUTDOWN WITH "LOCA" IN ONE UNIT NO OPERATOR ACTION WILL BE TAKEN AT LEAST WITHIN A MINUTE FOLLOWING THE EVENT TO SHUT THE OTHER UNIT.
2. TRANSFERABLE LOADS: TRANSFERABLE LOADS SHOULD BE ANALYZED TO DETERMINE THE WORST CASE LOADING CONDITION FOR THE VOLTAGE DROP STUDY.
3. BUS LOADS: SAFETY RELATED BUS LOADS WITH CABLE AND TRANSFORMER DATA ARE TO BE PROVIDED FOR LIGHT LOAD (LAT)/SHUT DOWN (SAT) CONDITIONS. IDENTIFICATIONS OF INDIVIDUAL LOADS BY TAG NOS. OR FUNCTIONAL IDENTIFICATION NO. IS NOT INTENDED. TOTAL CONNECTED LOAD

GENERAL COMPUTATION SHEET

(DISCIPLINE)
ELECTRICALNAME OF COMPANY CP&L BSEP UNIT# 1SUBJECT X LOCA - 208/120 VOLT SYSTEM DATA

CALC SET NO		REV	COMP BY	CHKD BY
PRELIM		0	RA	MJ
FINAL	✓		DATE 4/21/84	DATE 4/28/84
VOID				
SHEET 6 OF 53			DATE	DATE
JO 7453-127				

TO THE BUS UNDER VARIOUS CONDITIONS OF OPERATION IS TO BE COLLECTED.

4. CONNECTED LOAD: CONNECTED LOADS MEAN LOADS THAT ARE REQUIRED TO BE ENERGIZED DURING THE PLANT CONDITION, FOR WHICH THE VOLTAGE DROP IS INTENDED. ALL CIRCUITS ARE ANALYZED TO DETERMINE THE TOTAL CONNECTED LOADS FOR VARIOUS MODES OF PLANT OPERATION, UNLESS NOTED OTHERWISE IN THE "SYSTEM LOAD DATA" TABULATIONS
5. ALL RESISTANCE (AC) VALUES ARE CALCULATED BASED ON TABLE 1.20, PAGE 53 & CORRECTED TO 90°C CONDUCTOR TEMPERATURE.
(REFERENCE: PAGE 98 OF INDUSTRIAL POWER SYSTEM HANDBOOK BY D. BEEMAN, FIRST EDITION, 1955, EDITOR, MCGRAW HILL BOOK COMPANY, INC.)
6. FOR ADDITIONAL REVIEW CRITERIA REFER TO "REVIEW NOTES" ON SECTION 4, PAGE NO. 53 OF 53

7453-127-3-ED00-01, SEC-A

FILE NO.	REV.	DATE
7453-127-3-ED00-01	0	4/23/60
DESIGNED BY	CHKD BY	DATE
W. J. B. (initials)	W. J. B. (initials)	4/23/60

GENERAL COMPUTATION SHEET

United Engineers

NAME OF COMPANY: CP & L BSEB

SUBJECT: IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 1A
 SYSTEM LOAD DATA
 DWG NO. 0527-LL-93041 SH. 4 REV. 11 DATED 5/16/60

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHM"						REMARKS	
		NORMAL LOAD IN VA	IX-LOCA LOAD IN VA	R N	X N	Z N	R IX	X IX	Z IX		
1	1012 PROCESS RAD MON.	10	SEE NOTE #1	—	—	—	—	—	—	—	
2	1- R1P- PV-343B	15.6(5)	1016	2.0977	.0443	2.1002	—	—	—	—	
3	CAC-MONITORING SYS	55	SEE NOTE #1	—	—	—	—	—	—	—	
4	EXR 1H12-P613, 1E11-K600A, 2E04	48	SEE NOTE #1	—	—	—	—	—	—	—	
5	S600A, K605A	0	—	—	—	—	—	—	—	—	
6	EX RECIRC. (532) 1H12-P603 & P612 W/A TRANSFORMER STA	42	SEE NOTE #1	—	—	—	—	—	—	—	
7	CAC INSTRUMENT PANEL XU-60 (RECTIFIER SUPPLY)	100	SEE NOTE #1	—	—	—	—	—	—	—	
8	SPARE										
9	CAC INSTRUMENT PANEL XU-60 (120V SUPPLY)	106	SEE NOTE #1	—	—	—	—	—	—	—	
10	SPARE										
11	HPC I(E4) 1H12-P601	32	SEE NOTE #1	—	—	—	—	—	—	—	
12	TURB. TEST & VIBRATION CKTS	2000	SEE NOTE #1	—	—	—	—	—	—	—	
13	24/48 VDC BATTERY CHARGER										
14	CTL BLDG VENT. SYS										
15	FILTER "A"										
16	BRIDGE IND UNIT										
17	1-VA-TI-1299	100	SEE NOTE #1	—	—	—	—	—	—	—	

NO CHANGE AS PER C.A.S.P.

7453-127-3-ED00-01, SEC-4

REV. NO.	DATE	BY
1	4/23/60	RA
2	5/11/60	RA
3	5/11/60	RA
4	5/11/60	RA
5	5/11/60	RA
6	5/11/60	RA
7	5/11/60	RA
8	5/11/60	RA
9	5/11/60	RA
10	5/11/60	RA

GENERAL COMPUTATION SHEET

United Engineers

NAME OF COMPANY: CP&L BSEP UNIT: 1

SUBJECT: IX LOCA-208/120V SYSTEM DATA


UNIT SUB STN. 1E6 DISTRIBUTION PANEL NO 1B DWG NO. 9527-LL-930415H. 5 REV. 16 DATED 8/24/63

SYSTEM LOAD DATA

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHMS"						REMARKS					
		NORMAL		IX - LOCA		NORMAL		IX LOCA							
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}		X _{IX}	Z _{IX}			
14	R-1C (E51)1H12-P601 (ESI-K602)	48	SEE NOTE #1	48	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
15	RX BLDG VENT. FLOW MEASURING EQUP. XU-62	206	SEE NOTE #1	206	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
16	PUMP 1B COOLING WTR SOL. VLV. I-RCC-V13	21	1217	21	1217	2.5151	.0555	2.5157	.0555	2.5151	.0555	2.5157	.0555	2.5157	
17	VACUUM BERS I-CAC-X15F TO I-CAC-X18J TEST CKT.	25	SEE NOTE #1	25	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
18	DIV. II ISOLATOR CAB. XU-76	500	169	500	169	.3492	.0077	.3493	.3492	.0077	.3492	.0077	.3493	.3493	
19	SW RHR BOOSTER PUMPS 1B&1D AUX. CTL	16(56)	1454	16(56)	1454	3.0049	.0663	3.0056	3.0049	.0663	3.0056	.0663	3.0056	3.0056	
20	SPACE HEATER FOR LTG. 6 COMM. INVERTER	600	SEE NOTE #1	600	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
21	SW SEAL COOLING EXCH. DISCH. VLV. V-126 & V-125	312	SEE NOTE #1	0	-	-	-	-	-	-	-	-	-	-	-
22	REHEATER 5B V972 CONDENSER V98 SOLENOID VLV.	31	10	10	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
23	RHR PUMPS WELL WTR. SUPPLY VLV. V-143	127(5)	259	127(5)	259	.5352	.0118	.5354	.5352	.0118	.5354	.0118	.5354	.5354	
24	RX BLDG. CLOSED COOLING WTR. SYS. SV-1-RCC-V51	16(21)	448	16(21)	448	.9258	.0204	.9261	.9258	.0204	.9261	.0204	.9261	.9261	
25	SPARE														
26	I-CAC-PV-3441 GASEOUS ANALYZER	132	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
27	TEMP. SW TEST & CONTROL CAB	32(160)	2280	32(160)	2280	4.7119	.1040	4.7131	4.7119	.1040	4.7131	.1040	4.7131	4.7131	

GENERAL COMPUTATION SHEET

DISCIPLINE:
ELECTRICAL



NAME OF COMPANY: CP&L BSEP UNIT 1

SUBJECT: IX LOCA-208/120V SYSTEM DATA

7453-127-3-ED00-01, Sec-4

CALC. NO.	NO.	COMP. BY	CHKD. BY
PRELIM		RA	AY
ISS.	✓	4/23/84	7/1/88
APP.			
SHEET 13 OF 53		DATE	DATE
NO 7453-127			

SYSTEM LOAD DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO 1AB DWG NO. 9527-LL-93041 SH. 6 REV. 9 DATED 9/30/76

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	SPARE											
2	1-H12-P616 CRD RELAY LOGIC (C11)	1080	SEE NOTE #1	722	SEE NOTE #1	-	-	-	-	-	-	
3	SPARE											
4	SPARE											
5	NET PUMP SYS H12-P619 B21-K601 TO B21-K607	253	SEE NOTE #1	253	SEE NOTE #1	-	-	-	-	-	-	
6	(S32) CR RECIRC. SYS 1-H12-P603 H12-P612 SPEED CTL R620, K615	7.4	SEE NOTE #1	7.4	SEE NOTE #1	-	-	-	-	-	-	
7	CTL ROD HYD SYS 1-H12-P613 1-C11-K600 THRU K604 & N600	44	SEE NOTE #1	44	SEE NOTE #1	-	-	-	-	-	-	
8	SPARE											
9	REACTOR CONTROL PANEL (C11-R600) H12-P603	679	SEE NOTE #1	679	SEE NOTE #1	-	-	-	-	-	-	
10	H12-62A CRD HYD SYS VALVES C11-F002A & C11-F002B	20	SEE NOTE #1	20	SEE NOTE #1	-	-	-	-	-	-	
11	STNBY LIQ CTL SYS (C41) 1-H12-P613, 1-C41-N600, K600	19	SEE NOTE #1	19	SEE NOTE #1	-	-	-	-	-	-	
12	STNBY LIQ CTL SYS (C41) 1-H12-P624	30	SEE NOTE #1	30	SEE NOTE #1	-	-	-	-	-	-	
13	SPARE											
14	TRAVELING INCORE PROBE SYS (E51) H12-P607	960	84	960	84	.1092	.0038	.1093	.1092	.0038	.1093	

Page 1.17 of 106

GENERAL COMPUTATION SHEET

DISCIPLINE
ELECTRICAL

united engineers

NAME OF COMPANY CP&L BSEP UNIT 7 1

SUBJECT IX LOCA-208/120V SYSTEM DATA

7453-127-3-ED00-01, SEC-4

PROJ. NO.	7453-127	DATE	4/23/84
REV.	✓	DATE	4/23/84
SHEET	15 of 52	DATE	4/23/84
ID	7453-127	DATE	

SYSTEM LOAD DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 46 DWG NO. 7453-127-3-ED00-01 SH. 6 REV. 9 DATED 9/30/76

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX - LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
29	SPARE											
30	SPARE											
31	SPARE											
32	SPARE											
33	SPARE											
34	NUC. BOILER PROC. INST. SYS (B21) I-B32-K600, K604A, K604B, K609A, K609B, I-H12-P612	85	SEE NOTE #1	85	SEE NOTE #1	-	-	-	-	-	-	
35	SPARE											
36	NUC. BOILER PROC. INST. SYS (B21) VMTB CHASIS 21A & 21B I-H12-P614	33	SEE NOTE #1	33	SEE NOTE #1	-	-	-	-	-	-	
37	SPARE											
38	SPARE											
39	SPARE											
40	SPARE											
41	SPARE											
42	NUC. SIM. SUP. SHUTOFF (A71) RESET CKT. I-H12-P601	15	SEE NOTE #1	15	SEE NOTE #1	-	-	-	-	-	-	

Page 1 of 106

7453-127-3-ED00-01, SEC-4

DATE	17	1983
BY	17	1983
NO.	17	1983
REV.	17	1983
APP.	17	1983
CHK.	17	1983

GENERAL COMPUTATION SHEET

ELECTRICAL CP&L BSEP

UNIT 1
SUBJECT IX LOCA-208/120V SYSTEM DATA

SYSTEM LOAD DATA
UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 1A-EX DWG NO. 95-TL-93041 SH. 7 REV. 17 DATED 6/7/83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHM"						REMARKS	
		IX-LOCA		NORMAL		IX LOCA		Z IX			
		NORMAL LOAD IN VA	DIST. FROM PNL. IN FT.	R N	X N	R IX	X IX				
15	SPARE										
16	SPARE										
17	SPARE										
18	SPARE										
19	REACT. PROT. SYS (CT1) I-H21-PROBACOM MONITORS FUEL PLATFORM	84	SEE NOTE #1	96	SEE NOTE #1						
20	OPERATING FLOOR PANEL	13	SEE NOTE #1	13	SEE NOTE #1						
21	CTL PNL G31-2002-26	100	SEE NOTE #1	100	SEE NOTE #1						
22	EX BLDG VA CORE SPRAY PUMP LOCA BRIDGE IND UNIT I-VA-TT-1803	100	SEE NOTE #1	100	SEE NOTE #1						
23	RHD CHECK VLV I-E11-F050A	10	SEE NOTE #1	10	SEE NOTE #1						
24	EX BLDG AIRLOCK DOORS 301 & 302	21	221	21	221	.4567	.0101	.4568	.0101	.4568	
25	SPARE										
26	SPARE										
27	SPARE										
28	SPARE										

ASSUMED LOAD BASED ON UC31983

7453-127-3-E000-01, Sec-4

PROJ. NO.	7453-127-3-E000-01
DATE	11/15/73
BY	RA
CHECKED BY	RA
DATE	11/15/73

GENERAL COMPUTATION SHEET

UNITED ENGINEERS

CP&L BSEP

UNIT 1

IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 1A-EX DWG NO. 9577-U-93041 SH. 7 REV. 17 DATED 6/7/83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHM"						REMARKS			
		IX-LOCA		NORMAL			IX LOCA						
		LOAD IN VA	DIST FROM PNL. IN FT.	RN	XN	ZN	RIX	XIX	ZIX				
29	DRYWELL EQ. DRAIN HV-IN VLV 1-RCC-V54	0	-	-	-	-	-	-	-	-	-	-	-
30	STANDBY COMP IA REFRIG. AFTER COOLER MOTOR	587	SEE NOTE #1	587	SEE NOTE #1	-	-	-	-	-	-	-	-
31	DEYER UNIT F0E CAC-AT-1263	1737	SEE NOTE #1	1737	SEE NOTE #1	-	-	-	-	-	-	-	-
32	RADIATION DETECTOR 1-SW-RT-58-3	50	SEE NOTE #1	50	SEE NOTE #1	-	-	-	-	-	-	-	-
33	EX BLDG CONTAINMENT ATMOS MONITOR AT-1263	78	SEE NOTE #1	78	SEE NOTE #1	-	-	-	-	-	-	-	-
34	DRYWELL COOLER IA&ID INSTRUMENT POWER	38	SEE NOTE #1	38	SEE NOTE #1	-	-	-	-	-	-	-	-
35	SPARE												
36	AREA RAD. MON (D22) ALARM 1P EL. 20'-0" EX BLDG AIR LOCK												

ASSUMED LOAD

NO CABLE IN CASP

7453-127-3-ED00-01, SEE-4

PREP. BY	DATE	CHKD BY	DATE
W. J. ...	7/1/83
REV. 20 OF 53	DATE		
7453-127	DATE		

GENERAL COMPUTATION SHEET
 UNITED ENGINEERS
 NAME OF COMPANY CP&L BSEP UNIT 1
 SUBJECT IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN. 1E6 DISTRIBUTION PANEL NO 15-RX DHG NO.9527-IL-93041 SH. 6 REV.17 DATED 6/7/83
 SYSTEM LOAD DATA

CCT. NO	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL	IX - LOCA	NORMAL			IX LOCA			
		LOAD IN VA	LOAD IN VA	R N	X N	Z N	R IX	X IX	Z IX	
15	SPACE									
16	SPACE									
17	SPACE									
18	SPACE									
19	STANDBY COMP 15 REERIG AFTER COOLER MOTOR	587	587	—	—	—	—	—	—	
20	DRYWELL COOLERS 15 & 1C INSTRUMENT POWER	58	58	—	—	—	—	—	—	
21	REACT. PROT. 5% (C11) 1-21-PO12 ACCUM MONITOR S	700	800	—	—	—	—	—	—	
22	RADIATION DETECTOR 1-SW-RT-58-5	50	50	—	—	—	—	—	—	ASSUMED LOAD
23	REMOTE SHUTDOWN PANEL 1-SW-V141	0	0	—	—	—	—	—	—	
24	FLOW SWITCH B32-N002B (I61)	0	2	—	—	—	—	—	—	
25	SPACE									
26	FLOW SWITCH B32-N004B (I63)	0	2	—	—	—	—	—	—	
27	REACTOR BLDG FIRE DETECTOR PNL SUPPLY	600	600	—	—	—	—	—	—	
28	FLOW SWITCH B32-N007B (I65)	0	2	—	—	—	—	—	—	

7453-127-3-ED00-01, SET-4

REV. NO.	DATE	BY
0	11/13/80	WJL/SL
1	11/13/80	WJL/SL
2	11/13/80	WJL/SL
3	11/13/80	WJL/SL
4	11/13/80	WJL/SL
5	11/13/80	WJL/SL
6	11/13/80	WJL/SL
7	11/13/80	WJL/SL
8	11/13/80	WJL/SL
9	11/13/80	WJL/SL
10	11/13/80	WJL/SL
11	11/13/80	WJL/SL
12	11/13/80	WJL/SL
13	11/13/80	WJL/SL
14	11/13/80	WJL/SL


GENERAL COMPUTATION SHEET
 ELECTRICAL
 CP&L BSEP
 UNIT 7 I
 SUBJECT IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN. IES DISTRIBUTION PANEL NO. 145 IX DWG NO. 9527-LL-93041 SH. 9 REV. 12 DATED 11/11/80

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS		
		NORMAL		IX-LOCA		NORMAL		IX-LOCA		IX-LOCA				
		LOAD IN VA	DIKT FROM PNL-IN FT.	LOAD IN VA	DIKT FROM PNL-IN FT.	RN	XN	ZN	RIX	XIX	ZIX			
1	SPARE													
2	SPARE													
3	SPARE													
4	(D22) AREA RAD MONITOR ALARM	0	SEE NOTE #1	240										
5	(S3) RMCU R21-P002, G31-N002A R58-RATH1-H21-P002 TEMP SW.	59	116	59	116	.2397	.0053	.2398	.2397	.0053	.2398			ASSUMED LOAD BASED ON PNL. SCN. 93041 SH. 9
6	(S1) STARTUP RANGE DETECTOR DIRECTL SYS 1-H21-P008	100	SEE NOTE #1	100	SEE NOTE #1									NO CABLE IN CASP.
7	FUEL POOL 1-641-POOL													
8	SPARE													
9	FUEL SERVICE EQUIPT. VAC. PMP 1-F11-E006													NO CABLE IN CASP.
10	FUEL SERVICE EQUIPT. SAMPLER 1-F14-E014													NO CABLE IN CASP.
11	1-H21-POOL RELEP. FOR B21-ROOT	30	SEE NOTE #1	30	SEE NOTE #1									
12	AREA RAD MON (D22) RAD ALARM 1-21 NORTH OF FUEL STOR.	0		240	SEE NOTE #1									ASSUMED LOAD BASED ON PNL. SCN. 93041 SH. 9
13	AREA RAD MON (D22) RAD ALLEM 1-21 IN TIP. ROOM	0		240	SEE NOTE #1									ASSUMED LOAD BASED ON PNL. SCN. 93041 SH. 9
14	AREA RAD MON (D22) RAD ALLEM 1-29 WASH DN AREA	0		240	SEE NOTE #1									ASSUMED LOAD BASED ON PNL. SCN. 93041 SH. 9

GENERAL COMPUTATION SHEET

ELECTRICAL



NAME OF COMPANY: CP&L BSEP UNIT: 1

SUBJECT: IX LOCA-208/120V SYSTEM DATA

7453-127-3-ED00-01 > SEC-A

CALC SET NO.	REV.	CHKD BY	CHKD BY
PNL. NO.		RA	MJ
DATE		01/24/80	01/21/80
SHEET 23 OF 53		DATE	DATE
ID 7453-127			

SYSTEM LOAD DATA

UNIT SUB STN. 1ES DISTRIBUTION PANEL NO 1A5-RX DWG NO. 9527-LL 93041 SH. 9 REV. 12 DATED 11/11/80

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
15	SUPPRESSION POOL VACUUM BREAK SOV'S (12)											NO CABLE IN CASP.
16	SUPPRESSION POOL TAP SOV'S (4)											NO CABLE IN CASP.
17	SUPP. POOL & PREL CONTMNT O ₂ ANALYZER SOV'S (8)											NO CABLE IN CASP.
18	DRYWELL COOLING CRD AREA CONTROL DAMP'S IE & IF											NO CABLE IN CASP.
19	SPARE											
20	DRYWELL COOLING VOLUME CONTROL DAMPERS 1G & 1A											NO CABLE IN CASP.
21	H-HI2-P007 RECEPTACLE FOR C11-R018, B21-R006	50	SEE NOTE #1	50	SEE NOTE #1	-	-	-	-	-	-	
22	FLOW YMTR I-CAC-FT-2567	25	SEE NOTE #1	25	SEE NOTE #1	-	-	-	-	-	-	
23	SPARE											
24	AREA RAD MON (D22) RAD ALARM I-24 EL 117' BETWEEN RX & FUEL POOL	0	-	240	SEE NOTE #1	-	-	-	-	-	-	ASSUMED LOAD BASED ON FNL. SCH. 13041 SH. 9
25	NEUTRON MONITORING (CS1) INSTR. BACK H-HI2-P007 4TART-UP RANGE DRIVE CIL	0	-	0	-	-	-	-	-	-	-	
26	SPARE											
27	SPARE											
28	SPARE											

Page 1.27 of 106

NAME OF COMPANY: CP&L BSEP UNIT: 1

SUBJECT: IX LOCA-208/120V SYSTEM DATA

CALC SET NO.	REV.	CONTR BY	CHKD BY
		RB	JS
DATE		DATE	
11/11/80			
SHEET 29 OF 53			
ID 7453-127			

SYSTEM LOAD DATA

UNIT SUB STN. IES DISTRIBUTION PANEL NO 1A5-EX DWG NO 9527-LL-93041 SH. 9 REV. 12 DATED 11/11/80

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST FROM PNL. IN FT.	LOAD IN VA	DIST FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
29	SPARE											
30	SPARE											
31	RX BLDG AIRLOCK 209 & 210	21	661	21	661	1.3660	.0301	1.3664	1.3660	.0301	1.3664	
32	FLOW SW (H B32-N0010)		-	2	SEE NOTE #1	-	-	-	-	-	-	
33	SPARE											
34	FLOW SWITCH B32-N004A (I62)	0	-	2	SEE NOTE #1	-	-	-	-	-	-	
35	HPCI ROOM DOOR ALARM	19	SEE NOTE #1	19		-	-	-	-	-	-	CONTINUED LOAD NO CABLE ANALYSIS REQUIRED.
36	FLOW SWITCH B32-N007A (I64)	0	-	2		-	-	-	-	-	-	
37	SPARE											
38	SPARE											
39	SPARE											
40	SPARE											
41	SPARE											
42	RWCU (G31) INSTE BACK 1421-P023	588	SEE NOTE #1	588	SEE NOTE #1	-	-	-	-	-	-	

Page 128 of 106

7453-127-3-ED00-01, SEE-4

DATE	BY	CHK'D BY
4/23/89	W.C.	W.C.
DATE	BY	CHK'D BY

GENERAL COMPUTATION SHEET
 UNITED ENGINEERS
 CP&L BSEP UNIT 9 I
 SUBJECT IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 1A, TB DUG NO. 9527, LL 95041 SH. 10 REV. 9 DATED 12/15/83


SYSTEM LOAD DATA

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHMS"						REMARKS													
		NORMAL		IX - LOCA		NORMAL		IX LOCA															
		LOAD IN VA	DIST FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R N	X N	Z N	R IX		X IX	Z IX											
1	SPARE																						
2	SCOOP TUBE POSITIONER (B32) S1, 11A	1250	SEE NOTE #1	1250	SEE NOTE #1																		
3	FLUID DRIVE CASE BEATHER FAN UNIT 'A'	828	SEE NOTE #1	828	SEE NOTE #1																		
4	POCCAR PROSA WINDS OVERTEMP GEN'S MTR (K18A6K20A) B18M1E TSA	266	SEE NOTE #1	266	SEE NOTE #1																		
5	SPARE																						
6	TURBINE BLDG ROLL TYPE FILTER (A-SAF-TB)	545	94	545	94			.1942	.0043	.1943			.1942	.0043	.1943						.1943		
7	SPARE																						
8	TURBINE BLDG ROLL TYPE FILTER (A-SAF-TB)	545	239	545	239			.4939	.0109	.4940			.4939	.0109	.4940							.4940	
9	TURBINE BLDG AIRLOCK DOORS (A-SA-355)	21	275	21	275			.5683	.0125	.5684			.5683	.0125	.5684							.5684	
10	SPARE																						
11	SPARE																						
12	TURBINE BLDG CHILLER MACHINE (A) OIL HEATER	1500	SEE NOTE #1	1500	SEE NOTE #1																		
13	TURBINE BLDG AIRLOCK DOORS (358, 360, 361, 362)	21	250	21	250			.5166	.0114	.5168			.5166	.0114	.5168							.5168	
14	TURBINE BLDG CHILLER MACHINE (A) CONTROL CONSOLE	398	SEE NOTE #1	398	SEE NOTE #1																		

7453-127-3-ED00-01, Sec-4

FILE NO.	DATE	BY	CHK BY
7453-127-3-ED00-01	12/13/83	RP	RP
ADD	DATE		
SHEET 26 OF	DATE		
TO 7453-127			

GENERAL COMPUTATION SHEET



UNIT 1

CP&L BSEP


SUBJECT: IX LOCA-208/20V SYSTEM DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 1A.18 DHG NO. 9527-LL-93041 SH. 10 REV. 9 DATED 12/13/83
 SYSTEM LOAD DATA

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHM"						REMARKS	
		NORMAL LOAD IN VA	IX-LOCA LOAD IN VA	RN	XN	ZN	R IX	X IX	Z IX		
15	TURBINE BLDG VENT. AIR FLOW - RECIRC. SYSTEM	8.2	8.2	—	—	—	—	—	—	—	
16	SAMPLE DETECTOR SKID INCREASED RAD	2800	2800	—	—	—	—	—	—	—	
17	LIFT PUMP MOTORS SYSTEM	0	0	—	—	—	—	—	—	—	
18	SAMPLING SKIDS HEAT TRACING CABLES	340	340	—	—	—	—	—	—	—	
19	SPARE										
20	SPARE										
21	SPARE										
22	SPARE										
23	SPARE										
24	SPARE										
25	SPARE										
26	SPARE										
27	SPARE										
28	SPARE										

DISCIPLINE
ELECTRICAL

GENERAL COMPUTATION SHEET



NAME OF COMPANY CP&L ESEP UNIT 1

SUBJECT IX LOCA-208/120V SYSTEM DATA

7453-127-3-ED00-01 SER-4

DATE	4/25/83	DATE	4/25/83
SHEET	28 of 53	DATE	
NO	7453-127	DATE	

SYSTEM LOAD DATA

UNIT SUB STN. IE6 DISTRIBUTION PANEL NO. 15-TR DWG NO. 9527-LL-9301 SH. II REV. 5 DATED 5/4/83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	SPARE											
2	SCOOP TUBE POSITIONER (B32) 50015	1250	SEE NOTE #1	1250	SEE NOTE #1	-	-	-	-	-	-	
3	FLUID DRIVE CASE BREATHER FAN (B32)	828	SEE NOTE #1	828	SEE NOTE #1	-	-	-	-	-	-	
4	POD2B & POD-B WINDG C/VECTEMP. GEN. MTR (K1A6&K20E) VFMH TSB	266	SEE NOTE #1	266	SEE NOTE #1	-	-	-	-	-	-	
5	CEPT IA TURNING GEAR MTR CONTROL	0	-	0	-	-	-	-	-	-	-	
6	SPARE											
7	CONDENSATE LEVEL CONT 1-CO-LT-2,3,4,5	11	SEE NOTE #1	11	SEE NOTE #1	-	-	-	-	-	-	
8	BRIDGE IND UNIT 1-VA-TT-129B	100	SEE NOTE #1	100	SEE NOTE #1	-	-	-	-	-	-	
9	TURBINE BLDG AIRLOCK DOORS 356 & 357	21	251	21	251	.5187	.0114	.5188	.5187	.0114	.5188	
10	SPARE											
11	SPARE											
12	SPARE											
13	SPARE											
14	SPARE											

Page 1.32 of 106

7453-127-3-ED00-01, SEC-4

NAME OF COMPANY CP&L BSEP UNIT 1
 SUBJECT IX LOCA-208/120V SYSTEM DATA

CALC SET NO.	REV.	DATE	CHKD BY
	0	5/2	YJ
		4/23/69	
SHEET 31 OF 51			
ID 7453-127			

SYSTEM LOAD DATA
 UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO 1A6-TB DWG NO. 9527-U-93041 SH.12 REV.9 DATED 7/25/83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	KFPT. 1B-TURNING GEAR MTR CONTROL	0	-	0	-	-	-	-	-	-	-	
2	AIR COMPRESSOR SV-5B1 & USV	132	371	23	1090	.7667	.0169	.7669	2.2526	.0497	2.2532	
3	TURBINE BLDG EXHAUST ROLL TYPE FILTER 1A-EAF-TB	528	427	528	427	.8824	.0195	.8827	.8824	.0195	.8827	
4	SPARE											
5	SPARE											
6	SPARE											
7	D22) AREA RADIATION MON. ALARM 14" WEST EL. 45'	0	-	240	SEE NOTE #1	-	-	-	-	-	-	
8	D22) AREA RADIATION MON ALARM 13" EAST EL. 45'	0	-	240	SEE NOTE #1	-	-	-	-	-	-	
9	D22) AREA RADIATION MON ALARM 11.9" ACCESS DOOR CDR EL. 20'	0	-	240	SEE NOTE #1	-	-	-	-	-	-	
10	D22) AREA RADIATION MON ALARM 11.8" SAMPLE 6 STA EL. 20'	0	-	240	SEE NOTE #1	-	-	-	-	-	-	
11	REACT. FEED PUMP TURB 1A VIBRATION MONITORING	30	225	30	225	.4649	.0102	.4651	.4649	.0102	.4651	
12	REACT. FEED PUMP TURB 1B VIBRATING MONITORING	30	189	30	189	.3906	.0086	.3907	.3906	.0086	.3907	
13	SPARE											
14	11-06-SV-T050 SIAE SAMPLE SOL. VLV	132	167	132	167	.3451	.0076	.3452	.3451	.0076	.3452	MAY BE MODIFIED OR DELETED BY PU 80-228, 229

Page 1.35 of 106

7453-127-3-ED00 01-SEE-9

GENERAL COMPUTATION SHEET

UNITED ENGINEERS

CP&L BSEP

IX LOCA-208/120V SYSTEM DATA

DATE	32	09	83
BY	32	09	83
CHECKED BY			
DATE			

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO 4527-U-93041 SH. 12 REV. 9 DATED 7/25/83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"							REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA				
		LOAD IN VA	DIST FROM PNL IN FT.	LOAD IN VA	DIST FROM PNL IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}		
15	23' HEAT TRACE CABLE LINE # 1-RXS-24	1450	SEE NOTE #1	1450	SEE NOTE #1	-	-	-	-	-	-	-	ASSUMED LOAD BASED ON PNL. SCN. 93041-SH.12
16	113' HEAT TRACE CABLE LINE # 1-RXS-23	1200	SEE NOTE #1	1200	SEE NOTE #1	-	-	-	-	-	-	-	ASSUMED LOAD BASED ON PNL. SCN. 93041-SH.12
17	147' HEAT TRACE CABLE LINE # 1-RXS-2B	1600	SEE NOTE #1	1600	SEE NOTE #1	-	-	-	-	-	-	-	ASSUMED LOAD BASED ON PNL. SCN. 93041-SH.12
18	4 CONTRACTORS & CONTROLLERS 22' HEAT TRACE CABLE FOR LINE # 1-RXS-23	882	908	882	908	1.6765	.0414	1.8770	1.8765	.0414	1.8770	1.8770	ASSUMED LOAD BASED ON PNL. SCN. 93041-SH.12
19	26' HEAT TRACE CABLE LINE # 1-RXS-2B	1600	SEE NOTE #1	1600	SEE NOTE #1	-	-	-	-	-	-	-	ASSUMED LOAD BASED ON PNL. SCN. 93041-SH.12
20	131' HEAT TRACE CABLE LINE # 1-RXS-24	1450	SEE NOTE #1	1450	SEE NOTE #1	-	-	-	-	-	-	-	ASSUMED LOAD BASED ON PNL. SCN. 93041-SH.12
21	117' HEAT TRACE CABLE LINE # 1-RXS-24	1400	SEE NOTE #1	1400	SEE NOTE #1	-	-	-	-	-	-	-	ASSUMED LOAD BASED ON PNL. SCN. 93041-SH.12
22	SPARE												
23	SPARE												
24	SPARE												
25	REPT LO CARTRIDGE FILTER												
27	RECIRC. PUMP 1A	864	SEE NOTE #1	864	SEE NOTE #1	-	-	-	-	-	-	-	3Ø LOAD
28	REPT LO CARTRIDGE FILTER												
29	RECIRC. PUMP 1B	864	SEE NOTE #1	864	SEE NOTE #1	-	-	-	-	-	-	-	3Ø LOAD

NAME OF COMPANY: CP&L BSEP UNIT: 1
 SUBJECT: IX LOCA-208/120V SYSTEM DATA

7453-127-3-ED00-01, SEC-A

FILE NO.	REV.	DATE	BY
	0	4/12/80	RA
SHEET 33 OF 53			
NO 7453-127			

SYSTEM LOAD DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 13-DG DWG NO. 9527-LL-93041 SH. 15 REV. 7 DATED 5/16/80

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	NORTH DOOR AIRLOCK DG BLDG	21	229	21	229	.4733	.0104	.4734	.4733	.0104	.4734	
2	SPARE											
3	REMOTE SHUTDOWN PANEL	0	-	0	-	-	-	-	-	-	-	
4	SPARE											
5	SPARE											
6	SPARE											
7	DIESEL GEN #1-ENGINE CTL PNL SPACE HEATERS	500	SEE NOTE #1	500	SEE NOTE #1	-	-	-	-	-	-	
8	DIESEL GEN #1-EXCITER CTL PNL LIGHTS & RECEPTACLES	0	-	0	-	-	-	-	-	-	-	
9	BUS DUCT HTR FOR BUSES E1-E3	0	-	0	-	-	-	-	-	-	-	SEE 7-1052
10	DIESEL GEN #1-EXCITER CTL PNL SPACE HEATERS	1000	SEE NOTE #1	1000	SEE NOTE #1	-	-	-	-	-	-	
11	SPARE											
12	DIESEL GEN #1-GENERATOR CTL PNL INSTRUMENTATION	48	SEE NOTE #1	48	SEE NOTE #1	-	-	-	-	-	-	
13	480V UNIT SUBSTATION "E7" HEATER & FAN CKTS	0	-	0	-	-	-	-	-	-	-	
13A	SPARE											

Page 1.37 of 106

7453-127-3-ED00-01, SER-4

FILE NO.	DATE	BY	DATE
V	4/23/80	RA	4/23/80
UNIT	3.4 of 5.3	DATE	
NO	7453-127	DATE	


GENERAL COMPUTATION SHEET
 ELECTRICAL
 COMPANY CP & L BSEP
 UNIT 1
 SUBJECT IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 1A.DG DWG NO. 9527.U.9304I SH. 15 REV. 7 DATED 5/16/80

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS			CABLE IMPEDANCES IN "OHM"						REMARKS	
		NORMAL LOAD IN VA	IX-LOCA LOAD IN VA	DIST. FROM PNL. IN FT.	RN	XN	ZN	R IX	X IX	Z IX		
14	DIESEL GEN #1 GENERATOR CTL PNL LIGHTS & SPARE HTRS	500	500	SEE NOTE #1	-	-	-	-	-	-	-	
15	RHR SW PP 1C CONTROL PNL H80 BUS E-1	7.8	7.8	40	.0826	.0018	.0827	.0826	.0018	.0827		
16	SPARE											
17	SPARE											
18	RHR SW PP 1A CONTROL PNL H82 BUS E-3	7.8	7.8	120	.2480	.1055	.2481	.2480	.0055	.2481		
19	SPARE											
20	SPARE											
21	SPARE											
22	SPARE											
23	160V SWITCHGEAR E1 HTR & CONTROL BUS	14810	10315	SEE NOTE #1	-	-	-	-	-	-		
24	DIESEL GEN #1 ENGINE CTL PNL INSTRUMENTATION	0	147.6(24S)	96	-	-	-	.1983	.0044	.1984		

FORM NO. 104-178 GENERAL COMPUTATION SHEET

DISCIPLINE
ELECTRICAL



NAME OF COMPANY CP&L BSEP UNIT 1

SUBJECT IX LOCA- 208/120V SYSTEM DATA

7453-127-3-ED00-01, SK2-A

PROJ. NO.	REV.	COMP. BY	CHKD. BY
		RF	AK
DATE		DATE	
4/23/80		4/23/81	
SHEET 36 OF 53		DATE	
NO. 7453-127		DATE	

SYSTEM LOAD DATA

UNIT SUB STN. 1E6 DISTRIBUTION PANEL NO 15-DG DWG NO 9527-LL-930415H.16 REV.10 DATED 4/17/81

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
14	DIESEL GEN#2 GENERATOR CTL PNL LIGHTS & SPACE HTES	500	SEE NOTE #1	500	SEE NOTE #1	—	—	—	—	—	—	
15	RHR SW PF ID CTL PNL H61 BUS E-2	94(7.8)	858	94(7.8)	858	1.7732	.0391	1.7736	1.7732	.0391	1.7736	
16	SPARE											
17	SPARE											
18	RHR SW PF 1B CTL PNL H61 BUS E-4	7.8	120	7.8	120	.2480	.0055	.2481	.2480	.0055	.2481	
19	SPARE											
20	SPARE											
21	SPARE											
22	SPARE											
23	4160V SWITCHGEAR E2 HTR & CTL BUS	11310	SEE NOTE #1	10410	SEE NOTE #1	—	—	—	—	—	—	
24	DIESEL GEN#2 ENGINE CTL PNL INSTRUMENTATION	0	—	148(24.5)	122	—	—	—	.2521	.0055	.2522	

Page 140 of 106

GENERAL COMPUTATION SHEET
 DISCIPLINE: ELECTRICAL
 united engineers

NAME OF COMPANY: CP&L BSEP UNIT: 1
 SUBJECT: IX LOCA-208/120V SYSTEM DATA

7453-127-3-ED00-01>5ET-4

REL. NO.	REV. NO.	DATE
	EA	1/1/83
NO. 2	DATE	1/2/83
SHEET 41 OF 53	DATE	
NO. 7453-127	DATE	

SYSTEM LOAD DATA

UNIT SUB STN. 1E6 DISTRIBUTION PANEL NO. 1D DWG NO. 9527-LL-93041 SH. 1B REV. 9 DATED 8/8/83


CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
15	1-RIP-CS-1230(FUTURE)	-	-	-	-	-	-	-	-	-	-	
16	1-RIP-CS-1231	50	SEE NOTE #1	50	SEE NOTE #1	-	-	-	-	-	-	
17	1-RIP-CS-1232	50	SEE NOTE #1	50	SEE NOTE #1	-	-	-	-	-	-	
18	FAN COOLING CS PMP RM '1B' DISCH. VLV. 1-SW-V123	16	SEE NOTE #1	0	-	-	-	-	-	-	-	
19	VENT. RX BLDG. EXH. FAN 1B BID CTL CKT	100	SEE NOTE #1	20	SEE NOTE #1	-	-	-	-	-	-	
20	RHR PMP RM COOLER '1B' DISCH. VLV. 1-SW-V124	16	SEE NOTE #1	16	SEE NOTE #1	-	-	-	-	-	-	
21	VENT. RX BLDG. EXH. FAN DMPR'S 1B BID CTL CKT	104	SEE NOTE #1	68(182)	964	-	-	-	1.9922	.0439	1.9927	
22	VA SYSTEM BATTERY ROOM '1B'	32(80)	676	32(80)	676	1.3970	.0308	1.3973	1.3970	.0308	1.3973	
23	VENT. RX BLDG. SUPPLY FAN 1B BID 8586T 4YS 'B' CTL CKT.	164	SEE NOTE #1	20	SEE NOTE #1	-	-	-	-	-	-	
24	SPARE											
25	1-06-CS-375	-	-	-	-	-	-	-	-	-	-	NO INFO. AVAIL. ASSUME NO LOAD
26	SPARE											
27	FCV 2720 1-CAC-CS-2720-1 & 2-CAC-CS-2720-2	10	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
28	CAC MONITOR AT-1261 & 1262 SOL. VLV'S	75.2	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	

Page 145 of 106

7453-127-3-ED00-01 2 SE2-9

DATE	BY	DATE	BY
4/23/84	JH		
DATE	BY	DATE	BY

GENERAL COMPUTATION SHEET

ELECTRICAL  United Engineers

NAME OF COMPANY CP&L BSEP UNIT 7 1
 SUBJECT IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN .1E5 DISTRIBUTION PANEL NO 3/A DWG NO 9527-LL-63045H.25 REV. 10 DATED 9/26/83
 SYSTEM LOAD DATA

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS			CABLE IMPEDANCES IN "OHM"						REMARKS	
		NORMAL		IX - LOCA LOAD IN VA	NORMAL			IX LOCA				
		LOAD IN VA	DIST. FROM PNL. IN FT.		RN	XN	ZN	RIX	XIX	ZIX		
1	STEAM LEAK DETECTION SYS (S)412-P64 HPCI LOGIC TIMER RACK XU-62	528(58)	70	52.5(58)	70	.1446	.0032	.1447	.1446	.0032	.1447	
2	PWR SUPPLY MISC. INSTR. RACK XU-62	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
3	TERM. CAB XU-53 FOR 1-CAC-CS-2986	16(21)	641	0	-	1.3247	.0292	1.3250	-	-	-	
4	SPARE											
5	DC SHBD 1A STRIP HTR'S	560	SEE NOTE #1	560	SEE NOTE #1	-	-	-	-	-	-	
6	SPARE											
7	SPARE											
8	RTG BOARD-PM2 PLUG MOLD FOR RECORDERS	170	SEE NOTE #1	170	SEE NOTE #1	-	-	-	-	-	-	
9	RTG BOARD-PM1 PLUG MOLD FOR RECORDERS	96	SEE NOTE #1	96	SEE NOTE #1	-	-	-	-	-	-	
10	SPARE											
11	OFF GAS SYSTEM RADIATION MONITOR TRIP	0	-	32	194	.41009	.0088	.41010	.4009	.0088	.4010	
12	RTG BOARD-PM3 PLUG MOLD FOR RECORDERS	92	SEE NOTE #1	92	SEE NOTE #1	-	-	-	-	-	-	
13	RTG BOARD XU-51 1-CAC-LSHL-4177	6	SEE NOTE #1	6	SEE NOTE #1	-	-	-	-	-	-	
14	RTG BOARD-PM7 PLUG MOLD FOR RECORDERS	100	SEE NOTE #1	100	SEE NOTE #1	-	-	-	-	-	-	

GENERAL COMPUTATION SHEET
 ELECTRICAL  **United engineers**

7453-127-3-ED00-01, See-a

NAME OF COMPANY CP&L BSEP UNIT 1

SUBJECT IX LOCA-208/120V SYSTEM DATA

CALL NO.	REV.	DATE
	0	5/21/84
BY		
DATE		
NO	7453-127	

SYSTEM LOAD DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO 31A DWG NO. 957LL-23041 SH. 23 REV. 10 DATED 9/26/83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST FROM PNL. IN FT.	LOAD IN VA	DIST FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
15	SPARE											
16	RTG BOARD-PN11 PLUG MOLD FOR RECORDERS	65	SEE NOTE #1	65	SEE NOTE #1	-	-	-	-	-	-	
17	SPARE											
18	RTG BOARD-PM5 PLUG MOLD FOR RECORDERS	35	SEE NOTE #1	35	SEE NOTE #1	-	-	-	-	-	-	
19	SPARE											
20	I-A06 CONTROL VALVE I-HCV-102											NO CABLE IN CASE
21	SPARE											
22	TREND RECORDER C91-JR-876	0	-	0	-	-	-	-	-	-	-	
23	SPARE											
24	SPARE											

Page 148 of 106

7453-127-3-ED00-01 SER-4

GENERAL COMPUTATION SHEET

ELECTRICAL **United Engineers**

NAME OF COMPANY CP & L BSEP UNIT 1

SUBJECT IX LOCA-208/209 SYSTEM DATA

NO. 1453-127-3-ED00-01

DATE 9/24/84

BY [Signature]

DATE 9/24/84

BY [Signature]

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 316 DHG NO 95711-93041 SH. 24 REV. 9 DATED 7/1/83

SYSTEM LOAD DATA

CKT. NO	CIRCUIT DESCRIPTION	CIRCUIT LOADS		IX-LOCA DIST. FROM PNL. IN FT.	CABLE IMPEDANCES IN "OHMS"						REMARKS	
		NORMAL			NORMAL			IX LOCA				
		LOAD IN VA	DIST FROM PNL. IN FT.		R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}		
1	STEAM LEAK DETECTION SYS (B21)	52.0(45)	156	52.0(45)	156	.3224	.0071	.3225	.3224	.0071	.3225	
2	HP-664 HPCE TIMER LOGIC	0	-	0	-	-	-	-	-	-	-	
3	TRM CAB. XU-56	117	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
4	INB CRT FOR FLOOD STATUS SERV MTR INTAKE STRUCTURE	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
5	VAC BRC CONT. ISOL. VLV. V17	5-60	SEE NOTE #1	5-60	SEE NOTE #1	-	-	-	-	-	-	
6	SPARE											
7	TRM CAB. XU-56	69	SEE NOTE #1	0	-	-	-	-	-	-	-	
8	FOR 1-CAC-CS-3452	182	682	Δ 953	796	1.4094	.0311	1.4098	1.6450	.0363	1.6454	
9	TORUS DRAIN & KEEPERLL SYS. 1-TD-SV-3873 & SV-3894	0	-	0	-	-	-	-	-	-	-	
10	PUR SUPPLY FOR GASCOUS	0	-	0	-	-	-	-	-	-	-	
11	MSIV PIT TEMPERATURE SWITCHES TESTING CRT	0	-	0	-	-	-	-	-	-	-	
12	REHEATER SA V91 & CONDENSER V92 SOLENOID VALVE	31	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
13	VOLTAGE INPUT FOR 1-SCM-LRA-285-1	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
14	REHEATER SA V93 & CONDENSER V94 SOLENOID VALVE	31	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
15	REHEATER SB V95 & CONDENSER V96 SOLENOID VALVE	31	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	

7453-127-3-ED00-01, SET-4

NAME OF COMPANY CP&L BSEP UNIT 1

SUBJECT IX LOCA-20B/120V SYSTEM DATA

DATE	7/1/83	DATE	
BY	WJG	DATE	7/1/83
NO.	47 of 55	DATE	
NO.	7453-127	DATE	

SYSTEM LOAD DATA

UNIT SUB STN. 1E5 DISTRIBUTION PANEL NO. 46 DWG NO 9507-LL-93041 SH. 25 REV. 7 DATED 7/1/83


CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX - LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	RX BLDG TERM CAB XU-53 1-H12-P600, F622	72	SEE NOTE #1	0	—	—	—	—	—	—	—	
2	RX BLDG TERM CAB XU-53 1-CAC-CS-4175	133	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
3	RX BLDG TERM CAB XU-53 1-CAC-CS-1699	42	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
4	RX BLDG TERM CAB XU-53 1-CAC-CS-1527	21	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
5	RX BLDG TERM CAB XU-53 1-CAC-CS-1531	21	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
6	RX BLDG TERM CAB XU-53 1-CAC-CS-1530	5	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
7	RX BLDG TERM CAB XU-53 1-CAC-CS-2711	21	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
8	RX BLDG TERM CAB XU-53 1-CAC-CS-2710	21	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
9	RX BLDG TERM CAB XU-53 1-CAC-CS-2572	5	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
10	RX BLDG TERM CAB XU-53 1-CAC-CS-2571	5	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
11	RX BLDG TERM CAB XU-53 1-CAC-CS-2573	5	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
12	CONT. BLDG XU-75 CONT. RAD MON.	150	SEE NOTE #1	150	SEE NOTE #1	—	—	—	—	—	—	ASSUMED LOAD
13	DIV. I ISOLATOR CAB XU-77	500	97	500	97	.2004	.0044	.2005	.2004	.0044	.2005	ASSUMED LOAD BASED ON PNL SCH. 93041 SH. 25
14	SPARE											

Page 151 of 106

CP-1007 REV 7/79

GENERAL COMPUTATION SHEET

(DISCIPLINE)
ELECTRICAL



NAME OF COMPANY CP&L, BSEP UNIT/S 1

SUBJECT 1X LOCA - 208/120 VOLT SYSTEM DATA

CALC SET NO		REV	COMP BY	CH
PRELIM		0	RA	M
FINAL	X		DATE 4/21/84	DATE 4/21/84
VOID				
SHEET	49 OF 53			
JO	7453.127		DATE	DATE

Review Notes

1. The following criteria were used in preparation of the load tabulations and in determining the circuit impedances:
 - a. load distance was not determined for circuits having no operating relays and solenoids (120 volts AC).
 - b. Within individual circuits, the relays and/or solenoids which are expected to experience the maximum Voltage Drop have been tabulated outside the parenthesis in the load column. The remaining loads are summed up and tabulated within the parenthesis. Therefore, total load for the circuit is a summation of loads outside and within the parenthesis.
 - c. Circuits loads such as indicating lights, recorders, resistance heaters, cabinet fans, low voltage power transformer, instrument power, supplies, etc. have not been analyzed for load distance from panel board.
 - d. No load distance analysis was made on circuits in which the relays and/or solenoids ^{are} deenergized under 1X LOCA Condition.
 - e. Manually initiated test circuits were not analyzed for load and load distances.
2. Power factor is assumed to be .85 lagging for all AC inductive loads.
3. Cable impedances were calculated based on cable length and size available in the CASP "A" Report with resistance and reactances data from the Industrial Power Systems Handbook by Donald Beenan. (See Reference list and Sheet 53 of 53.)
4. Transformer impedance is based on information derived from manufacturer. Refer to Tele-notes T-1015, T-1066, where manufacturer's test data and foreign print records are not available.
5. Loads for which precise information was not available at all, were assumed and are so noted in the System Load Data and/or circuit evaluation Tables. in any drawing.
6. The following assumptions were used to assess individual circuit component loading:
 - a. For low voltage control transformers without size or load data, 80% of the fuse size was assumed to be the load on the transformer (conservative estimate).
 - b. Solenoids or Relays for which exact manufacturers information was not available, load was assumed to be similar to devices for which load characteristic is available.
 - c. Panel schedule load listing (Dwg. 9527-LL-93041) is assumed for circuits on which no component information or detail drawing is available.
 - d. For power supplies, convertors, the loading is assumed to be the maximum rated Power Consumptions (conservative approach).
 - e. No fire concurrent with a LOCA is assumed
 - f. Radiation alarms and proper isolation of appropriate systems due to high radiation following a LOCA are assumed for areas.
7. All assumed loads should be verified at a later date when information is available. These assumed loads are conservative enough to provide reasonable voltage profiles at their terminals.

GENERAL COMPUTATION SHEET

(DISCIPLINE)

ELECTRICAL  **United engineers & constructors, inc.**

NAME OF COMPANY CP&L, BSEP UNIT/S 1

SUBJECT 208/120V SYSTEM DATA
FEEDER CABLE IMPEDANCE DATA

REF. DWG. 9527-F-93031, REV. 4, DATED 8/19/81

CALC SET NO		REV	COMP BY	CHKD BY
PRELIM		0	RA	N/S
FINAL	✓		DATE 4/21/84	DATE 4/28/82
VOID				
SHEET	50 OF 53		DATE	DATE
JO	7453-127			

CABLE	CABLE SIZE	LENGTH(FT)	R	X	Z
HGØ-LG3	3/C # 1/0	40	.0052	.0014	.0054
H14-HG3	1-3/C-250MCM	319	.0183	.0103	.0210
H14-HG3/1	1-1/C-250MCM	319	-	-	-
HØ7-HG3	1-3/C-500MCM	65	.0020	.0019	.0027
HØ7-HG3/1	1-1/C-250MCM	65	-	-	-
HG3-HY1	1-3/C-250MCM	55	.0032	.0018	.0036
HG3-HY1/1	1-1/C-250MCM	55	-	-	-
H1Ø-HG3	1-3/C-250MCM	155	.0089	.0050	.0102
H1Ø-HG3/1	1-1/C-250MCM	155	-	-	-
H13-HG3	1-3/C-250MCM	184	.0105	.0059	.0121
H13-HG3/1	1-1/C-250MCM	184	-	-	-
BV4-GE1	1-4/C # 6	50	.0258	.0020	.0259
GE1-HQ4	1-4/C # 2	24	.0050	.0008	.0050
D45-GF2	1-4/C # 6	119	.0615	.0047	.0617
GF2-H32	1-4/C # 2	32	.0066	.0011	.0067
C74-HE1	1-4/C # 6	75	.0387	.0029	.0389
HE1-HE2	1-4/C # 2/0	30	.0031	.0010	.0033
C82-FN3	1-4/C # 6	160	.0827	.0063	.0829
FN3-HC8	1-4/C # 2	25	.0051	.0009	.0052
D89-GF3	1-4/C # 6	111	.0573	.0043	.0575
GF3-H33	1-4/C # 2	21	.0043	.0007	.0044
B79-GE2	1-4/C # 6	60	.0310	.0023	.0311
GE2-HØ5	1-4/C # 2	24	.0050	.0008	.0050

(DISCIPLINE)

ELECTRICAL



NAME OF COMPANY CP&L BSEP UNIT# 1

208/120V SYSTEM DATA

SUBJECT FEEDER CABLE IMPEDANCE DATA


REF. DWG. 9527-F-93031, REV. 4, DATED 8/19/81

CALC SET NO		REV	COMP BY	CHK'D
PRELIM		0	RA	MP
FINAL	✓		DATE 4/2/84	DATE 4/2/84
VOID				
SHEET 51 OF 53				
JO 7453-127				

CABLE	CABLE SIZE	LENGTH (FT)	R	X	Z
H12-HGφ	1-3/C-250MCM	159	.0091	.0051	.0105
H12-HGφ/1	1-1/C-250MCM	159	-	-	-
H09-SB6	1-3/C-250MCM	235	.0135	.0076	.015
H09-HGφ/1	1-1/C-250MCM	373	-	-	-
HGφ-SB6	1-3/C-250MCM	168	.0096	.0054	.011
HGφ-HYφ	1-3/C-250MCM	80	.0046	.0026	.005
HGφ-HYφ/1	1-1/C-250MCM	80	-	-	-
H06-HGφ	1-3/C-500MCM	70	.0021	.0021	.003
H06-HGφ/1	1-1/C-250MCM	70	-	-	-
H08-HGφ	1-3/C-250MCM	55	.0032	.0018	.003
H08-HGφ/1	1-1/C-250MCM	55	-	-	-
H11-HGφ/1	1-1/C-250MCM	373	-	-	-
H11-SB7	1-3/C-250MCM	70	.0040	.0023	.004
HGφ-SB7	1-3/C-250MCM	333	.0191	.0107	.021
H07-HGφ	1-3/C-250MCM	125	.0072	.0040	.0082
H07-HGφ/1	1-1/C-250MCM	125	-	-	-

GENERAL COMPUTATION SHEET

FORM 1507 REV. 7/75
(DISC. PLINE)



ELECTRICAL

NAME OF COMPANY CP&L BSEP UNIT# 1

208/120 V SYSTEM DATA

SUBJECT FEEDER CABLE IMPEDANCE DATA

CALC SET NO		REV	COMP BY	CHK
PRELIM		0	RA	1/1
FINAL	✓		DATE 4/21/84	DATE 4/21/84
VOID				
SHEET 53 OF 53				
JO 7453-127			DATE	DATE

TABLE 1.20 Approximate Resistance, Reactance, and Impedance of 600-volt Cables in Magnetic Ducts per 100 Ft


Cable size	Three single-conductor cables per duct, ohms per 100 ft			Three-conductor cable including interlocked armor cable, ohms per 100 ft		
	R*	X	Z	R*	X	Z
No. 14 Awg...	0.3135	0.00765	0.3135	0.3135	0.00468	0.31352
No. 12 Awg...	0.1972	0.00710	0.1972	0.1972	0.00456	0.19720
No. 10 Awg...	0.1240	0.00687	0.1240	0.1240	0.00448	0.12410
No. 8 Awg...	0.0779	0.00638	0.0782	0.0779	0.00427	0.07460
No. 6 Awg...	0.0498	0.00598	0.0500	0.0493	0.00391	0.04899
No. 4 Awg...	0.0318	0.00551	0.0322	0.0312	0.00362	0.03140
No. 2 Awg...	0.0203	0.00513	0.0209	0.0197	0.00344	0.02000
No. 1 Awg...	0.0163	0.00500	0.0171	0.0157	0.00342	0.01606
No. 1/0 Awg...	0.0131	0.00492	0.0140	0.0125	0.00340	0.01296
No. 2/0 Awg...	0.0106	0.00490	0.0117	0.0100	0.00336	0.01054
No. 3/0 Awg...	0.00860	0.00486	0.00986	0.00800	0.00333	0.00866
No. 4/0 Awg...	0.00700	0.00482	0.00850	0.00640	0.00327	0.00721
250 MCM....	0.00608	0.00480	0.00778	0.00547	0.00322	0.00632
300 MCM....	0.00520	0.00474	0.00704	0.00460	0.00316	0.00557
350 MCM....	0.00461	0.00469	0.00658	0.00400	0.00310	0.00510
400 MCM....	0.00419	0.00462	0.00625	0.00354	0.00304	0.00469
500 MCM....	0.00359	0.00450	0.00578	0.00292	0.00295	0.00412
750 MCM....	0.00280	0.00438	0.00520	0.00208	0.00284	0.00346


* Based on 75°C.

$$\text{RESISTANCE AT } 90^\circ\text{C} = \frac{\text{RESISTANCE AT } 75^\circ\text{C} \times 234.5 + 90}{234.5 + 75}$$

R_x 1.048

Form 5614

 united engineers & constructors inc CALCULATION CONTROL SHEET		CALC. SET NO.	
		PRELIM.	
		FINAL	✓
PROJECT TITLE <u>CP&L - BSEP No. 2</u> DISCIPLINE <u>ELECTRICAL</u>		VOID	
SYSTEM <u>208/120 VOLT DISTRIBUTION SYSTEM</u>			
SUBJECT <u>1X LOCA - 208/120VOLT SYSTEM DATA</u>			
DESIGN CLASSIFICATION <u>CLASSIE (SAFETY RELATED)</u>			
STARTED BY <u>R. ABDUL</u>		DATE <u>03/10/84</u>	
AUTHORIZED BY <u>K. L. BAR</u>		DATE <u>03/19/84</u>	
PROBLEM STATEMENT PREPARE LOAD DATA FOR ESEP UNIT #2 208/120 VOLT DISTRIBUTION SYSTEM BASED ON (a) NORMAL PLANT OPERATION (b) A LOSS OF COOLANT ACCIDENT (LOCA) FOR ONE UNIT AND AN ORDERLY SHUTDOWN OF THE OTHER UNIT.			
DESIGN BASIS <ul style="list-style-type: none"> • UPDATED FSAR DATED 7-19-82 • REFER TO SECTION 3 FOR ADDITIONAL CRITERIA. 			
TOTAL NUMBER OF SET COMPUTATION SHEETS <u>48 (EXCLUDING CALC. CONTROL SHEET)</u>			
FINISHED BY <u>R.A. 4/17/84</u>		CHECKED BY <u>M. M. M. 4/26/84</u>	
	CHECKER	DESIGN SUPER	COGNIZANT ENG'R
BY	<u>[Signature]</u>	<u>[Signature]</u>	<u>R. Abdul</u>
DATE	<u>4/17/84</u>	<u>4/17/84</u>	<u>4/17/84</u>
REVISION 1 STARTED DATE _____		BY _____	

 United engineers & constructors inc		CALC. SET NO.	
CALCULATION SUMMARY & REFERENCE SHEET		PRELIM.	
PROJECT TITLE <u>CP&L, BSEP NO. 2</u> DISCIPLINE <u>ELECTRICAL</u>		FINAL	✓
		VOID	
		SHEET 1 OF 48	
		J.O. 7453-227	
SYSTEM <u>208/120 VOLT DISTRIBUTION SYSTEM</u>	REVISION	COMP. BY	CHK'D BY
SUBJECT <u>1X LOCA - 208/120 VOLT SYSTEM DATA</u>	0	RA	NIS
DESIGN CLASSIFICATION <u>CLASS IE (SAFETY RELATED)</u>		DATE <u>4/17/84</u>	DATE <u>4/26/84</u>
		DATE	DATE
SUMMARY/CONCLUSIONS <p style="text-align: center;"> REFER TO SECTION 4.0 OF THE CALCULATION — <u>"SYSTEM LOAD DATA"</u> </p>			
REFERENCES: (SPECIFICATIONS, DRAWINGS, CODES, CALCULATION SETS, TEXTS, REPORTS, COMPUTER DATA PSAR ETC.) <ol style="list-style-type: none"> 1. CALC. NO. 9527-001-3-ED00-53-F, TITLED "VOLTAGE DROP STUDY, 208/120 VOLT SAFETY RELATED LOADS" — REV. 1, DATED 5/25/81 2. NOTES OF TELEPHONE CONVERSATIONS T-1000 DATED 3/13, 16/84 & T-961 DATED 2/28/84. 3. DRAWING SCHEDULES DATED 12/30/83. 4. INDUSTRIAL POWER SYSTEM HANDBOOK BY D. BEEMAN, EDITOR, FIRST EDITION MCGRAW HILL BOOK COMPANY, INC., 1955 5. DRAWINGS AS LISTED IN THE CIRCUIT EVAL. TABLES FOR VARIOUS LOADS. 6. CP&L WORK AUTHORIZATION NO. XS32340023 TO CONTRACT (FILE HBR/06) NO. XM32340000, 3/9/84. 			

(DISCIPLINE) ELECTRICAL

NAME OF COMPANY CP&L - BSEP UNIT# 2SUBJECT IX LOCA - 208/120VOLT SYSTEM DATA

CALC SET NO		REV	COMP BY	CHK'D BY
PRELIM		0	RA	JL
FINAL	✓		DATE 4/17/82	DATE 2-25-82
VOID				
SHEET 2 OF 48				
JO 7453-227			DATE	DATE

INDEX

1. PURPOSE
2. SCOPE
3. REVIEW METHODOLOGY/CRITERIA
4. SYSTEM LOAD DATA TABLES
5. FEEDER CABLES IMPEDANCE DATA
6. ATTACHMENT TO CALCULATION
 - 6.1 CIRCUIT EVALUATION TABLES (CONTROLLED AS PART OF THIS CALCULATION)
 - 6.2 NOTES OF TELEPHONE CONVERSATIONS & CORRESPONDENCE ETC.
(ATTACHED FOR INFORMATION ONLY. CONTROLLED SEPARATELY UNDER SEPARATE NUMBERS; I.E., THIS IS NOT PART OF THIS CALCULATION PROCEDURALLY)

7453-227-3-ED00-01

(DISCIPLINE) ELECTRICAL  united engineers
CONSTRUCTORS INC.NAME OF COMPANY CECEL, BSEP UNIT 2SUBJECT IX LOCA-208/120VOLT SYSTEM DATA

CALC SET NO.		REV	COMP BY	CHKD BY
PRELIM		0	RA	MS
FINAL	✓		DATE 4/18/84	DATE 4/16/83
VOID				
SHEET	3 of 48		DATE	DATE
JO	7453-227			

1. PURPOSE:

Provide 208/120 VOLT AC Load data for a loss of coolant accident (LOCA) in one unit with an orderly shutdown of the other unit.


2. SCOPE:

1. To provide the maximum load data on each 208/120 VOLT distribution Panel and bus, based on a loss of Coolant accident (LOCA) on one unit and an orderly shutdown of the other unit
2. Load data will be updated with the "As Built" plant modifications through November 1983.
3. Cable data, including number of conductors, cable size, length, and impedance for feeder cables to 120/208 VOLT panels/buses and for the cables to the load terminals.
4. Transformer impedances and X/R ratio for all 480 - 208/120 VOLT transformers.

(NOTE: Refer to CECEL WORK AUTHORIZATION No. X532340023 TO CONTRACT NO. XM32340000 AS MODIFIED BY

GENERAL COMPUTATION SHEET

(DISCIPLINE) ELECTRICAL




NAME OF COMPANY CP&L, BSEP UNIT# 2

SUBJECT 1X LOCA - 208/120 VOLT SYSTEM DATA


CALC SET NO		REV	COMP BY	CHK'D BY
PRELIM		0	RA	JIS
FINAL	✓		DATE 4/18/84	DATE 4/26/84
VOID				
SHEET 4 OF 48			DATE	DATE
JO 7453-227				

NOTES OF TELEPHONE CONVERSATION NO. T-961 dated 2/28/84).

3. REVIEW METHODOLOGY / CRITERIA



(DISCIPLINE) ELECTRICAL

NAME OF COMPANY CP&L, BSEP UNIT# 2SUBJECT 1X LOCA - 208/120 VOLT SYSTEM DATA

CALC SET NO.		REV	COMP BY	CHK'D BY
PRELIM		0	RA	NB
FINAL	✓		DATE 4/17/84	DATE 3/22/84
VOID				
SHEET 5 OF 48				
JO. 7453-227				

A GENERAL FLOW DIAGRAM IS SHOWN ON PREVIOUS PAGE TO INDICATE THE VARIOUS ELEMENTS OF TASK. SOME LOAD DATA ARE TAKEN FROM THE EXISTING CALC. NO. 9527-001-3-ED00-53-F REV. 1, DATED 2/25/81. VARIOUS MANUFACTURERS WERE CALLED TO OBTAIN LOAD DATA WHEN F.P OR INST. MANUALS DID NOT PROVIDE THE REQUIRED INFORMATION.

THE FOLLOWING APPROACH WAS ADOPTED AS NOTED IN THE TELEPHONE CONVERSATION NOT T-1000 DATED 3/16/84:

1. CONCURRENT SHUTDOWN: MEANS ORDERLY SHUTDOWN WITH "LOCA" IN ONE UNIT NO OPERATOR ACTION WILL BE TAKEN AT LEAST WITHIN A MINUTE FOLLOWING THE EVENT TO SHUT THE OTHER UNIT.
2. TRANSFERABLE LOADS: TRANSFERABLE LOADS SHOULD BE ANALYZED TO DETERMINE THE WORST CASE LOADING CONDITION FOR THE VOLTAGE DROP STUDY.
3. BUS LOADS: SAFETY RELATED BUS LOADS WITH CABLE AND TRANSFORMER DATA ARE TO BE PROVIDED FOR LIGHT LOAD (LAT)/SHUT DOWN (SAT) CONDITIONS. IDENTIFICATIONS OF INDIVIDUAL LOADS BY TAG NOS. OR FUNCTIONAL IDENTIFICATION NO. IS NOT INTENDED. TOTAL CONNECTED LOAD

GENERAL COMPUTATION SHEET

(DISCIPLINE) ELECTRICAL  **United engineers**
& CONSTRUCTORS INC.NAME OF COMPANY CP&L, BSEP UNIT# 2SUBJECT 1X LOCA - 208/120 VOLT SYSTEM DATA

CALC SET NO		REV	COMP BY	CHK'D BY
PRELIM		0	RA	MS
FINAL	✓		DATE 4/17/84	DATE 3/11/81
VOID				
SHEET 6 OF 48			DATE	DATE
JO 7453-227				

TO THE BUS UNDER VARIOUS CONDITIONS OF OPERATION IS TO BE COLLECTED.

4. CONNECTED LOAD: CONNECTED LOADS MEAN LOADS THAT ARE REQUIRED TO BE ENERGIZED DURING THE PLANT CONDITION, FOR WHICH THE VOLTAGE DROP IS INTENDED. ALL CIRCUITS ARE ANALYZED TO DETERMINE THE TOTAL CONNECTED LOADS FOR VARIOUS MODES OF PLANT OPERATION, UNLESS NOTED OTHERWISE IN THE "SYSTEM LOAD DATA" TABULATIONS
5. ALL RESISTANCE (AC) VALUES ARE CALCULATED BASED ON TABLE 1.20, PAGE 48 & CORRECTED TO 22°C CONDUCTOR TEMPERATURE.
(REFERENCE: PAGE 98 OF INDUSTRIAL POWER SYSTEM HANDBOOK BY D. BEEMAN, FIRST EDITION, 1955, EDITOR, MCGRAW HILL BOOK COMPANY, INC.)
6. FOR ADDITIONAL REVIEW CRITERIA REFER TO "REVIEW NOTES" ON SECTION 4, PAGE NO. 44 OF 48.

GENERAL COMPUTATION SHEET
 ELECTRICAL  United Engineers

NAME OF COMPANY: CP&L BSEP
 NO. 2
 SUBJECT: IX LOCA-208/120V SYSTEM DATA

7453-227-3-ED00-01, SEC-4

CALC. BY:	DATE:	CHKD BY:	DATE:
RA	4/1/84	JRS	4/6/84
NO.:	7	NO.:	4A
DATE:	7453-227	DATE:	

UNIT SUB STN ZE7 DISTRIBUTION PANEL NO 2A SYSTEM LOAD DATA DWG NO. LL-9341 SH 4 REV. 13 DATED 5-12-80

CCT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	LOCA SIGNAL FOR CAC	69	—	0	—	—	—	—	—	—	—	
2	2-RIP-PV-3438 CAC MONITORING SYS	15.6 (5)	441'	5	SEE NOTE #1	.9114	.0201	.9116	—	—	—	
3	RHR (E11) 2-HIZ-P601	66	SEE NOTE #1	66	SEE NOTE #1	—	—	—	—	—	—	
4	RHR 2-HIZ-P613 2-E11-K600A, K600A, 3600A, K605A	48	SEE NOTE #1	48	SEE NOTE #1	—	—	—	—	—	—	
5	RHR 2-HIZ-P617 2-E11-F051A & E11-F055A	0	—	0	—	—	—	—	—	—	—	
6	RX RECIRC. (B52) 2-HIZ-P605 & P612, M/A TRANSFORMER STA.	42	SEE NOTE #1	42	SEE NOTE #1	—	—	—	—	—	—	
7	CAC INSTRUMENT PANEL XU-60 (RECTIFIER SUPPLY)	100	SEE NOTE #1	100	SEE NOTE #1	—	—	—	—	—	—	
8	RX RECIRC (B52) SUBFEED PNL 2A-TB MG SET 2A	—	—	—	—	—	—	—	—	—	—	
9	CAC INSTRUMENT PANEL XU-60 (120V SUPPLY)	106	SEE NOTE #1	106	SEE NOTE #1	—	—	—	—	—	—	NO CABLE AS PER CASE
10	SPARE											
11	HPCI (E41) 2-HIZ-P601 TURBINE TEST & VIBRATION CKTS.	92	SEE NOTE #1	92	SEE NOTE #1	—	—	—	—	—	—	
12	24/48 V. DC BATTERY CHARGER *23A-2*	2000	SEE NOTE #1	2000	SEE NOTE #1	—	—	—	—	—	—	
13	CTL BLDG VENT SYS. FILTER "A"	—	—	—	—	—	—	—	—	—	—	
14	BRIDGE IND UNITS 2-VA-TI-1299 2-VA-TI-1447-2, 2-VA-TI-1310-2	100	SEE NOTE #1	100	SEE NOTE #1	—	—	—	—	—	—	NO CABLE AS PER CASE
15	24/48 V. DC BATTERY CHARGER *23A-1	2000	SEE NOTE #1	2000	SEE NOTE #1	—	—	—	—	—	—	

Page 1.65 of 106

NAME OF COMPANY: CP&L BSEP UNIT: 2
 SUBJECT: IX LOCA- 208/120V SYSTEM DATA

DATE	DATE	DATE
✓	✓	✓
DATE	DATE	DATE
DATE	DATE	DATE


UNIT SUB STN 2E7 DISTRIBUTION PANEL NO 2A SYSTEM LOAD DATA DWG NO LL-9341 SH 4 REV. 13 DATED 5-12-80

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
16	PUMP 2A COOLING WATER SOL. VALVE 2-RCC-V74	21	1428'	21	1428'	2.9511	.0651	2.9519	2.9511	.0651	2.9519	
17	GENERATOR & MAIN XFMR RELAY PANEL	—	—	—	—	—	—	—	—	—	—	
18	SEAL COOLING EXCH'R DISCH VLV'S V130 & V131	31.2	SEE NOTE #1	0	—	—	—	—	—	—	—	NO CABLE AS PER CASP
19	VACUUM BREAKERS 2-CAC-X18A TO 2-CAC-X18E TEST CIRCUIT	25	SEE NOTE #1	25	SEE NOTE #1	—	—	—	—	—	—	
20	SPARE											
21	BATTERY GROUND DET.	38.4	SEE NOTE #1	38.4	SEE NOTE #1	—	—	—	—	—	—	
22	SW. RHR PUMPS 2A & 2C AUXILIARY CONTROL	16(56)	1920	16(56)	1920	3.9679	0.0876	3.9689	3.9679	0.0876	3.9689	
23	RHR PUMPS WELL WTR. SUPPLY VALVE V143	0	—	0	—	—	—	—	—	—	—	
24	RK BLDG CLOSED COOLING WATER SYS. -RCC-PS 672	0	—	84	582'	—	—	—	1.2028	.0265	1.2030	
25	VITAL HEAD WELL WTR. SUPPLY VALVE V41	52.6	SEE NOTE #1	5	SEE NOTE #1	—	—	—	—	—	—	
26	RK BLDG CLOSED COOLING WATER SYS. SOL VALVE 2-RCC-V185	16(21)	388'	16(21)	388'	.8018	.0177	.8020	.8018	.0177	.8020	
27	TURB TRIP AIR RELAY DUMP VLV CTL HDR PRESS LO REL CKT	64(32)	565'	84(84)	1574'	1.1676	.0258	1.1675	3.2525	.0717	3.2537	
28	2-RIP-PV-3442 & 3440 CAC MONITORING SYS.	21(10)	936'	10	SEE NOTE #1	1.934	.0427	1.9348	—	—	—	LAMP LOAD UNDER IX CONDITION
29	TEMP. SW. TEST & CONTROL CAB	32(160)	2150'	32(160)	2150'	4.4433	.0980	4.4444	4.4433	.0980	4.4444	
31	PWR SUPPLY FOR GASEOUS ANALYZER PNL XU-55	0	—	0	—	—	—	—	—	—	—	

Page 1 of 105

GENERAL COMPUTATION SHEET

ELECTRICAL



NAME OF COMPANY: CP&L BSEP

SUBJECT: IX LOCA-208/120V SYSTEM DATA

7453-227-3-ED00-01, SEC-4

DATE	4/14/84	BY	RA
NO.	9 of 48	DATE	8/26/84
NO.	7453-227	DATE	

SYSTEM LOAD DATA
UNIT SUB STN 2EB DISTRIBUTION PANEL NO 2B DWG NO LL-9341 SH 5 REV. 17 DATED 5-13-85


CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	(D12) PROCESS RAD MON 2-D12-V27B	23	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
2	ESS LOGIC CAB H61 LIGHT CKT	0	-	0	-	-	-	-	-	-	-	
3	RHR (E11) 2-H12-P601	140	SEE NOTE #1	140	SEE NOTE #1	-	-	-	-	-	-	
4	RHR 2-H12-P612, 2-E11-K605B K600B, K603B, K604, S600B	35	SEE NOTE #1	35	SEE NOTE #1	-	-	-	-	-	-	
5	RHR 2-H12-P61B 2-E11-F074, F051B, F053B	21	856'	21	856'	1.7690	.0390	1.7694	1.7690	.0390	1.7694	
6	RX RECIRC. (BB2) 2-H12-P6031 P612 M V/I XFMR STA	42	SEE NOTE #1	42	SEE NOTE #1	-	-	-	-	-	-	
7	POST ACCIDENT SAMPLE VALVES SV-4187, 4189, 4184, 4181, 4182	25	SEE NOTE #1	25	SEE NOTE #1	-	-	-	-	-	-	
7A	POST ACCIDENT SAMPLE VALVES SV-4192, 4193, 4194	15	SEE NOTE #1	15	SEE NOTE #1	-	-	-	-	-	-	
8	RESERVED FOR PM80-033											
8A	RESERVED FOR PM80-033											
9	INSTRUMENT AIR DRYER	480	SEE NOTE #1	480	SEE NOTE #1	-	-	-	-	-	-	
10	DIV. II ISOLATOR CAB. XU-76	500	(NO DETAIL INFO ON LOAD AVAIL.)	500	(NO DETAIL INFO ON LOAD AVAIL.)	.3348	.0074	.3349	.3348	.0074	.3349	ASSUMED LOAD BASED ON PNL. SEN. 9341 SH-5
10A	RESERVED FOR PM80-033											
11	BENCH BOARD AUX. RELAY CAB. (C12-V139 & V140) H12-P624	20	SEE NOTE #1	20	SEE NOTE #1	-	-	-	-	-	-	
12	24/48V. DC BATTERY CHARGER "24B-2"	2000	SEE NOTE #1	2000	SEE NOTE #1	-	-	-	-	-	-	

Page 1 of 10

FORM NO. 81-174

GENERAL COMPUTATION SHEET

ELECTRICAL



DATE OF SHEET

CP&L BSEP

NO. 2

SHEET NO. 10 OF 48

7453-227-3-ED00-01, SEC-4


DATE	NO.	BY
10/15/84	10	RA
11/12/84	48	RA

UNIT SUB STN 2E8 DISTRIBUTION PANEL NO 2B SYSTEM LOAD DATA DWG NO LL-9341 S-1 5 REV 17 DATED 5-13-83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS			
		NORMAL		IX - LOCA		NORMAL			IX LOCA						
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R-N	X-N	Z-N	R-IX	X-IX	Z-IX				
13	24/48V DC BATTERY CHARGER "24B-1"	2000	SEE NOTE #1	2000	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
14	RCIC (E51) 2-HIS-P601 (E51-K602)	48	SEE NOTE #1	48	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
15	EX BLDG VENT FLOW MEASURING EQUIP #U-62	206	SEE NOTE #1	206	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
16	PUMP 2B COOLING WATER SOL. VALVE 2-RCC-V73	21	1902'	21	1902'	3.930	.0867	3.9317	3.930	.0867	3.9317	3.930	.0867	3.9317	-
17	VACUUM BREAKERS 2-CAC-XIBF TO 2-CAC-XIBJ TEST CIRCUIT	25	SEE NOTE #1	25	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
18	BATTERY GROUND DET.	38.4	SEE NOTE #1	38.4	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
19	SW RHR BOOSTER PMP'S "2B" 1" 30" AUXILIARY CONTROL	16(56)	1900	16(56)	1900	3.9266	0.0866	3.9376	3.9266	0.0866	3.9376	3.9266	0.0866	3.9376	-
20	SPACE HEATER FOR LTC 1 COMM INVERTER	600	SEE NOTE #1	600	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
21	SW SEAL COOLING EXCH'R DISCH. VLV'S. V126 & V125	31.2	SEE NOTE #1	0	-	-	-	-	-	-	-	-	-	-	-
22	1/4" SCAVENGERS 3TA REHEATER & CONDENSER VALVES	124	SEE NOTE #1	40	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
23	RHR PUMPS WELL WTR SUPPLY VALVE V145	127(5)	223	127(5)	223	.4608	.0101	.4610	.4608	.0101	.4610	.4608	.0101	.4610	-
24	EX BLDG CLOSED COOLING WATER SYS SV-2-RCC-V51	16(21)	564'	16(21)	564'	1.1652	.0257	1.1655	1.1652	.0257	1.1655	1.1652	.0257	1.1655	-
25	STACK MONITORING & PULGING EQUIPMENT	41	SEE NOTE #1	41	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
26	2-REP-PV-3341 CAC MONITORING SYS.	132	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	-	-	-	-
27	TRAMP SW TEST & CONTROL CABINET	32(160)	2260	32(160)	2260	4.6706	.1030	4.6718	4.6706	.1030	4.6718	4.6706	.1030	4.6718	-

FORM NO. 101-174 GENERAL COMPUTATION SHEET

INTEGRATED ELECTRICAL



NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT IX LOCA- 208/120V SYSTEM DATA

7453-227-3-ED00-01, SEC-A

DATE	DATE	DATE	DATE
RF	RF	RF	RF
4/16/84	4/16/84	4/16/84	4/16/84
11 10 88			
7453-227			

SYSTEM LOAD DATA

UNIT SUB STN 2EB DISTRIBUTION PANEL NO 2B DWG NO. LL-9341 SH 5 REV.17 DATED 5-13-83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
28	2-RIP-PV-3437 & 3439 CAC MONITORING SYS.	132	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
29	BRIDGE IND. UNIT 2-VA-TL-164B	100	SEE NOTE #1	100	SEE NOTE #1	-	-	-	-	-	-	


Page 1.69 of 106

7453-227-3-ED00-01, SEC 4

DATE	BY
12-20-48	WJ
7453-227	

GENERAL COMPUTATION SHEET

ELECTRICAL



NAME OF COMPANY: C.F. & L. BSEP

SUBJECT: IX LOCA-208/20V SYSTEM DATA

UNIT SUB STN. 2E7 DISTRIBUTION PANEL NO 2AB DWG NO 9527-L-9341 SH 6 REV. 11 DATED 9-8-83

SYSTEM LOAD DATA

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES N.O.M.						REMARKS		
		NORMAL LOAD IN VA	IX-LOCA LOAD IN VA	R-N	X-N	Z-N	R-IX	X-IX	Z-IX			
1	SPARE											
2	2-HI2-P616 CRD RELAY LOGIC (C12)	984	762	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1
3	SPARE											
4	SPARE											
5	JET PUMP SYSTEM HI2-P619	255	253	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1
6	RECORD RECIRC SYS 2-HI2-P603 2-HI2-P612 SPEED CTL R.620, K.615	7.4	7.4	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1
7	CTL ROD HD SYS 2-HI2-P613, 2-CI2-K600 THRU K601 AND N.600	44	44	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1
8	SPARE											
9	REACTOR CONTROL PANEL HI2-P603	98	98	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1
10	2-HI2-624 CRD HYD. SYS.	20	20	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1
11	STBY LIQ CTL SYS (C41) 2-HI2-P613, 2-CAL-N600, K.600	19	19	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1
12	STBY LIQ CTL SYS (C41) 2-HI2-P624	30	30	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1
13	NUCLEAR BOILER PROCESSING INST 821, R.622 RECORDER	32.5	32.5	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1	SEE NOTE #1
14	TRAVERSING IN-CORE CAL. SYS. (C51) 2-HI2-P607	960	960	84	84	1735	0038	1736	1735	0038	1736	1736

DATE	BY	CHKD BY
	CP	MS
	SI-180	alchha
SHEET 13 OF 48		
NO. 7453-227		

UNIT SUB STN DISTRIBUTION PANEL NO 2AB SYSTEM LOAD DATA DWG NO 9527-LL-9341 SH 6 REV. II DATED 9-8-83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "O-M"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
15	DEMIN SUPPLY LINE SOL VLV. 2-SW-SV-3745	0	-	0	-	-	-	-	-	-	-	
16	SPARE											
17	SPARE											
18	SPARE											
19	AREA RADIATION MON. (D22) 2-D22-P600, K603A	600	136	600	136	.2810	.0062	.2811	.2810	.0062	.2811	
20	PROCESS RAD MON 2-XU-3 2-D12-R601, R602, R603, R604 & R001A	71	SEE NOTE #1	71	SEE NOTE #1	-	-	-	-	-	-	LOAD ASSUMED BASED ON PNL SCHEDULE 9527-LL-1541546, REV 11/9/83
21	SPARE											
22	PROCESS RAD MON (D12) XU-3	18	SEE NOTE #1	18	SEE NOTE #1	-	-	-	-	-	-	
23	SPARE											
24	PROCESS RAD MON XU-3 2-D12-FOH (PNL J006)	0	-	0	-	-	-	-	-	-	-	
25	SPARE											
26	SPARE											
27	SPARE											
28	SPARE											

Page 1 of 106

7453-227-3-ED00-01, SEC-4
 GENERAL COMPUTATION SHEET
 ELECTRICAL
 CP & L BSEP
 UNIT 2
 IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN .2E7 DISTRIBUTION PANEL NO 2A-RX DWG NO LL-9341 SH 7 REV. 19 DATED 9/3/82
 SYSTEM LOAD DATA

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN OHMS			REMARKS
		NORMAL LOAD IN VA	IX - LOCA LOAD IN VA	R N	X N	Z N	
1	SPARE						
2	SPARE						
3	RHR SVS (E11) 2H21-PO1B	28	28	SEE NOTE #1	SEE NOTE #1		
4	SPARE						
5	SPARE						
6	RX BLDG VA CTL PNL 2-VA-M3-RB POWER SUPPLY	17(117)	1083	1083	2.2382	.0494	2.2387 2.2382 .0494 2.2387 ASSUMED LOAD
7	SPARE						
8	RX BLDG VA RHR PUMP RM-A BRIDGE IND UNIT 2-VA-TT-M02A	100	100	SEE NOTE #1	SEE NOTE #1		
9	HPCI ROOM 2-VA-CV-1590 CTL CKT	0.0	0.0				
10	2-G31-2002-26 CONT PNL FILTER "A" CONTROL CKT	100	100	SEE NOTE #1	SEE NOTE #1		
11	2-XU-83 CONTROL PNL FILTER "A" CONTROL CKT	100	100	SEE NOTE #1	SEE NOTE #1		ASSUMED LOAD BASED ON ICS/883
12	SPARE						
13	SPARE						
14	SPARE						
15	SPARE						
16	SPARE						

Page 1.73 of 106

7453-227-3-ED00-01, SEC 4

DATE	BY	REVISION
10/16/80	RF	1
10/16/80	RF	2
10/16/80	RF	3

GENERAL COMPUTATION SHEET
 CP&L BSEP
 IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN. 2E7 DISTRIBUTION PANEL NO 2A-RX DWG NO LL-9341 5H 7 REV. 19 DATED 9/3/82

CCT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHM"						REMARKS	
		LOAD IN VA	DIST FROM PNL. IN FT.	R N	X N	Z N	R IX	X IX	Z IX		
17	SPARE										
18	SPARE										
19	REACT. PROT. SVS. (C72)	84	SEE NOTE #1								
20	FUEL PLATFORM OPE RATING PANEL	13	SEE NOTE #1								
21	2431-E002 CONTROL PNL FILTER "A" IND LIGHT CKT	100	SEE NOTE #1								ASSUMED LOAD PAID ON 10/3/1983
22	RX BLDG VA-CORE SPRAY PUMP EM-A-BRIDGR IND. UNIT 2-VA-17-1603	100	SEE NOTE #1								
23	TESTABLE CHECK VLV 2-EII-F050A	10	SEE NOTE #1								
24	FLOW SWITCH B32-N002A (I60)	0									
25	SPARE										
26	FLOW SWITCH B32-N004A (I62)	0									
27	AIRLOCK INTERCONN	31	302	.6241	.0138	.6243	.6241	.0138	.6243		
28	FLOW SWITCH B32-N007A (I64)										
29	DRYWELL EQUIP DR. HX IN. VLV 2-RCC-V5A	0									
30	COMP. 2A REFRIGERATED AFTER COOLER MOTOR	587	SEE NOTE #1								
31	RHR PUMPS A4C RAD DETECTOR 2-SW-RT-58-4	50	SEE NOTE #1								ASSUMED LOAD
32	RADIATION DETECTOR 2-SW-RT-58-5	50	SEE NOTE #1								ASSUMED LOAD

FORM NO. 804 1/78
 GENERAL COMPUTATION SHEET
 ELECTRICAL ENGINEERS
 unitor engineers

7453-227-3-ED00-01, SEC-4

NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT IX LOCA-208/120V SYSTEM DATA

NO.	DATE	BY	CHK'D BY
1	11/16/82	RA	JT
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			
40			
41			
42			
43			
44			
45			
46			
47			
48			
49			
50			
51			
52			
53			
54			
55			
56			
57			
58			
59			
60			
61			
62			
63			
64			
65			
66			
67			
68			
69			
70			
71			
72			
73			
74			
75			
76			
77			
78			
79			
80			
81			
82			
83			
84			
85			
86			
87			
88			
89			
90			
91			
92			
93			
94			
95			
96			
97			
98			
99			
100			

SYSTEM LOAD DATA
 UNIT SUB STN. 2E7 DISTRIBUTION PANEL NO 2A-RX DWG NO LL-9341 SH 7 REV. 19 DATED 9/3/82

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN OHMS						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL IN FT.	LOAD IN VA	DIST. FROM PNL IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
33	SPARE											
34	DRYWELL COOLER 2A&2D INSTRUMENT POWER	78	SEE NOTE #1	78	SEE NOTE #1	-	-	-	-	-	-	
35	AREA RAD MON (D22) ALARM 2-19 EL 20'-0" RX BLDG AIR LOCK	38	SEE NOTE #1	38	SEE NOTE #1	-	-	-	-	-	-	
36	DRYER UNIT FOR CAC-AT-1263	1737	SEE NOTE #1	1737	SEE NOTE #1	-	-	-	-	-	-	

Page 1.75 of 106

7453-227-3-EDCO-01, SEC-4

GENERAL COMPUTATION SHEET
 ELECTRICAL
 NAME OF COMPANY: CP&L ESEP
 SHEET NO: 10 OF 48
 PROJECT: IX LOCA-208/209 SYSTEM DATA

UNIT SUB STN. 2E8 DISTRIBUTION PANEL NO. B-RX DHG NO. 9527-LL-9341 SH 8 REV. 19 DATED 9-3-82

Page 1.76 of 106

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES N.O.M.				REMARKS
		NORMAL	IX-LOCA	R _N	X _N	R _{IX}	X _{IX}	
1	SPARE							
2	2-G31-2002-26 CONT. PNL FILTER 'B' IND LIGHT CKT	100	100					ASSUMED LOAD BASED ON UC 3/1983
3	RESIDUAL HEAT REM (E11) 2-H21-P021	14	14					
4	RX BLDG VA RHR PUMP R4B BRIDGE IND UNIT	100	100					
5	LHR TESTABLE CHECK VLV 2-E11-F050B	10	10					
6	RX BLDG VA CORE SPRAY PUMP RM 'B' BRIDGE IND UNIT 2-VA-TT-E04	100	100					
7	SPARE							
8	RX BLDG FIRE PROT. ANNUN. 2-UA-39	34	34					
9	SPARE							
10	G31-2002-26 CONT. PNL FILTER 2-VA-TT-1607A	100	100					ASSUMED LOAD BASED ON UC 3/1983
11	2-XU-83 CONT. PNL RWCU FILTER 'B' CONTROL CKT.	100	100					ASSUMED LOAD
12	SPARE							
13	SPARE							

GENERAL COMPUTATION SHEET

ELECTRICAL

united engineers

NAME OF COMPANY CP&L BSEP JUNE 2

SUBJECT IX LOCA- 208/20V SYSTEM DATA

7453-227-3-ED00-01, SEC-4

REV. NO.	DATE	BY	APP'D.
1	4/17/84	RA	NO
2	4/16/84	RA	RA
SHEET 19 OF 48		DATE	DATE
NO. 7453-227			

SYSTEM LOAD DATA


UNIT SUB STN. 2E8 DISTRIBUTION PANEL NO 2B-RX DWG NO 9527-LL-9341 SH. 8 REV. 19 DATED 9-3-82

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX - LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
14	SPARE											
15	SPARE											
16	SPARE											
17	SPARE											
18	SPARE											
19	RX BLDG SPR. SYSTEM 2-FP-DV20	11	SEE NOTE #1	11	SEE NOTE #1	-	-	-	-	-	-	
20	DRYWELL COOLER 2B & 2C INSTRUMENT POWER	58	SEE NOTE #1	58	SEE NOTE #1	-	-	-	-	-	-	
21	REACT. PROT. SYS (C72) 2-H2I-PO12 ACCUM. MONITORS	700	SEE NOTE #1	800	SEE NOTE #1	-	-	-	-	-	-	
22	RHR PUMPS B & D RAD. DETECTOR 2-SW-RT-5B-5	50	SEE NOTE #1	50	SEE NOTE #1	-	-	-	-	-	-	ASSUMED LOAD
23	REMOTE SHUTDOWN PNL. RSA	0	-	0	-	-	-	-	-	-	-	
24	FLOW SWITCH B32-N002B (I61)	0	-	2	SEE NOTE #1	-	-	-	-	-	-	
25	SPARE											
26	FLOW SWITCH B32-N004B (I63)	0	-	2	SEE NOTE #1	-	-	-	-	-	-	

Page 1.77 of 106

FORM 889 REV 10/68
ELECTRICAL

GENERAL COMPUTATION SHEET



NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT IX LOCA-208/120V SYSTEM DATA

7453-227-3-ED00-01, SEC-4

CALC. BY	DATE	CHKD BY	DATE
PNL. NO.	✓	RP	4/10/84
SHEET	20 of 48		
ID	7453-227		

SYSTEM LOAD DATA

UNIT SUB STN. 2EB DISTRIBUTION PANEL NO 2B-RX DWG NO 9527-LL9341 5H 8 REV. 19 DATED 9-3-82

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
27	COMPR 2B REFRIGERATED AFTERCOOLER MOTOR	587	SEE NOTE #1	587	SEE NOTE #1	-	-	-	-	-	-	
28	FLOW SWITCH B32-N007B (I65)	0	-	2	SEE NOTE #1	-	-	-	-	-	-	
29	SPARE											
30	AIRLOCK INTERCONN	21	557	21	557	1.1511	.0254	1.1514	1.1511	.0254	1.1514	
31	TERM. CAB XU-2B DELUGE VLV 2-FP-DV-319	11	SEE NOTE #1	11	SEE NOTE #1	-	-	-	-	-	-	
32	AIRLOCK INTERCONN	21	523	21	523	1.0809	.0238	1.0811	1.0809	.0238	1.0811	
33	SPARE											
34	SWGR 2B BRKR 4A & 4B SPACE HEATER	250	SEE NOTE #1	250	SEE NOTE #1	-	-	-	-	-	-	
35	IPCLRT TEST STATION	0	-	0	-	-	-	-	-	-	-	
36	DRYER UNIT FOR CAC-AT-1259	1737	SEE NOTE #1	1737	SEE NOTE #1	-	-	-	-	-	-	

Page 1.28 of 106

7453-227-3-ED00-01, SEC-4

GENERAL COMPUTATION SHEET
 ELECTRICAL
 CP&L BSEP
 IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN. 2E7 DISTRIBUTION PANEL NO LAB-RX DWG NO 9517-LL-9341 SH 9 REV. 9 DATED 3-5-81

Page 7.79 of 106

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		IX-LOCA DIST. FROM PNL. IN FT.	CABLE IMPEDANCES N. "OHM"						REMARKS		
		NORMAL LOAD IN VA	IX-LOCA LOAD IN VA		RN	XN	ZN	R1X	X1X	Z1X			
1	SPARE												
2	SPARE												
3	(5-21) 2-H12-P007 R006	50	50	SEE NOTE #1									
4	(D22) AREA RAD MON. ALARM N# 2-26 INSIDE NEV VAULT	240	240	SEE NOTE #1									
5	(G31) RANCU H21-P002 G31-1002A & B	59	59	115	.2376	.0052	.2377	.2376	.0052	.2376			
6	(S11) START-UP RANGE DETECTOR DRIVE CTL SYS H21-P008	100	100	SEE NOTE #1									NO CABLE IN CASP
7	FUEL POOL 2-641-P001												
8	(A11) 2-H21-P002 TEMP SWITCH	19	19	SEE NOTE #1									
9	FUEL SERVICE EQUIP. VAC. PMP. 2-F11-E006												
10	FUEL SERVICE EQUIP. SAMPLER 2-FM-E014												
11	2-H12-P007 RECEPT. FOR B21-ROOT	30	30	SEE NOTE #1									
12	AREA RAD MON (D22) RAD ALARM 2-27 NORTH OF FUEL STOR.	0	240										
13	AREA RAD MON (D22) RAD ALARM 2-21 IN T.I.P. ROOM	0	240										
14	AREA RAD MON (D22) RAD ALARM 2-29 CASK WASHDN AREA	0	240										

LOADS ASSIGNED BASED ON
 PNL. SCHEDULE 9517-LL-
 9341, SH 9, REV. 3-5-81

NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT IX LOCA-208/120V SYSTEM DATA

PROJECT	NO.	DATE
✓	RA	1/1
DATE	4/7/84	APL/SA
SHEET 22 OF 40	DATE	DATE
NO. 7453-227		

SYSTEM LOAD DATA
 UNIT SUB STN. 2E7 DISTRIBUTION PANEL NO. LAB-RX DWG NO 9527-LL-9341 SH 9 REV. 9 DATED 3-5-81

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
15	SUPPRESSION POOL VACUUM BKR'S SOL. VLV'S (12)	—	—	—	—	—	—	—	—	—	—	NO CABLE IN CASP
16	SUPPRESSION POOL TAP SOV'S (4)	—	—	—	—	—	—	—	—	—	—	NO CABLE IN CASP
17	SUPP. POOL & PRI. CONTMNT O ₂ ANALYZER SOV'S (8)	—	—	—	—	—	—	—	—	—	—	NO CABLE IN CASP.
18	SPARE											
19	SPARE											
20	SPARE											
21	2-H21-POOB RECEPTACLE FOR C12-ROIB	50	SEE NOTE #1	50	SEE NOTE #1	—	—	—	—	—	—	
22	FLOW TRANSMITTER 2-CAC-FT-2567	25	↓	25	↓	—	—	—	—	—	—	ASSUMED LOAD DUE TO LACK OF INFO.
23	SPARE											
24	AREA RAD. MON (D22) RAD. ALARM EL. 117'-4" BETWEEN RX & FUEL POOL	0	—	240	SEE NOTE #1	—	—	—	—	—	—	LOAD ASSUMED BASED ON PNL SCHEDULE 9527-LL-9341, SH 9 REV. 9, 3-5-81
25	NEUTRON MONITORING (CS) INST. RACK 2-H21-POOB START-UP RANGE DRIVE CONTROL	0	—	0	—	—	—	—	—	—	—	START-UP LOADS OF 1000 VA AS PER PNL SCHEDULE 9527-LL-9341, SH 9, REV. 9, 3-5-81
26	SPARE											
27	SPARE											
28	SPARE											

Page 1.80 of 106

7453-227-3-ED00-01, SEE-4

GENERAL COMPUTATION SHEET
 ELECTRICAL
 NAME OF COMPANY: CP&L BSEP
 UNIT: 2
 SUBJECT: IX LOCA-208/120V SYSTEM DATA

DATE	BY	DATE	BY
10/23/88	WJ	10/23/88	WJ
10/23/88	WJ	10/23/88	WJ
10/23/88	WJ	10/23/88	WJ

UNIT SUB STN. 2E7 DISTRIBUTION PANEL NO 2AB-RX DUG NO 9577-U-9341 SH. 9 REV. 9 DATED 3-5-81

SYSTEM LOAD DATA

CCT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL	IX-LOCA	NORMAL			IX-LOCA			
	LOAD IN VA	DIST FROM PNL-IN FT.	-CAD IN VA	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
29	SPARE									
30	SPARE									
31	AIRLOCK INTERCONN.	105	105	SEE NOTE #1						24VAC Ckt NO CABLE ANALYSIS REQ'D
32	SPARE									
33	SPARE									
34	SWGR 2B BRER 3A & 3B SPACE HEATER	150	250	SEE NOTE #1						
35	HPCI ROOM DOOR ALARM	19	19	SEE NOTE #1						CONTINUED LOAD NO CABLE ANALYSIS REQ'D
36	SPARE									
37	OFF-GAS DRAIN TANK LOOP SEAL-KEEP FULL	0	0							
38	SPARE									
39	SPARE									
40	SPARE									
41	SPARE									
42	RMCU G31 INST. RACK 2-H2I-P023	588	588	SEE NOTE #1						

NAME OF COMPANY: CP&L BSEP UNIT: 2

SUBJECT: IX LOCA-208/120V SYSTEM DATA

DATE: 4/16/84	BY: RP	CHKD: JLD
REV: 25 OF 48		
NO: 7453-227		

SYSTEM LOAD DATA
 UNIT SUB STN 2E7 DISTRIBUTION PANEL NO 2A-TB DWG NO LL-9341 54.10 REV.13 DATED 11/18/83


CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "O-M"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
17	LIFT PUMPS SYSTEM	0.0	—	0.0	—	—	—	—	—	—	—	
18	SPARE											
19	SPARE											
20	SPARE											
21	SPARE											
22	HEAT TRACING- INCREASED RANGE RAD.	300	SEE NOTE #1	300	SEE NOTE #1	—	—	—	—	—	—	DUE TO LACK OF INFO, THE LOAD SHOWN ON LL-9341 54.10 REV.13 DATE SUBJECT IS ASSUMED AS LOAD
23	SPARE											
24	SAMPLE DETECTOR SKID INCREASED RANGE RAD.	2800	SEE NOTE #1	2800	SEE NOTE #1	—	—	—	—	—	—	DUE TO LACK OF INFO, THE LOAD SHOWN ON LL-9341 54.10 REV.13 DATE SUBJECT IS ASSUMED AS LOAD
25	SPARE											
26	TURBINE BLDG CHILLER MACHINE 2A-RM-TB OIL HTR	1500	SEE NOTE #1	1500	SEE NOTE #1	—	—	—	—	—	—	
27	SPARE											
28	TURBINE BLDG CHILLER MACHINE 2B-RM-TB OIL HTR	1500	SEE NOTE #1	1500	SEE NOTE #1	—	—	—	—	—	—	
29	SPARE											
30	POST ACCIDENT SAMPLE CONTROL CABINET	100	SEE NOTE #1	100	SEE NOTE #1	—	—	—	—	—	—	ASSUMED LOAD

Page 1 of 3 of 105

GENERAL COMPUTATION SHEET

7453-227-3-EDCO-01 sec-a

DISCIPLINE
ELECTRICAL



NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT 1X LOCA-208/120V SYSTEM DATA

FILE NO.	REV.	DATE
	✓	4/11/80
SHEET 26 OF 48		DATE
NO 7453-227		DATE

SYSTEM LOAD DATA

UNIT SUB STN 2EB DISTRIBUTION PANEL NO 2B-TB DWG NO. LL-9341 54 11 REV. 7 DATED

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS	
		NORMAL		1X-LOCA		NORMAL			1X-LOCA				
		LOAD IN VA	DIST FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{1X}	X _{1X}	Z _{1X}		
1	SPARE												
2	SCOOP TUBE POSITIONER (B32) 500IB	1250	SEE NOTE #1	1250	SEE NOTE #1	-	-	-	-	-	-		
3	FLUID DRIVE CASE BREATHER FAN (B32)	828	SEE NOTE #1	828	SEE NOTE #1	-	-	-	-	-	-		
4	POO2B & POO3B WINDG OVERTEMP GEN. & MTR (E19B & 120B) & XFMR TSD	266	SEE NOTE #1	266	SEE NOTE #1	-	-	-	-	-	-		
5	2 RFA TURNING GEAR SOLENOID S1	00	-	00	-	-	-	-	-	-	-		
6	COND. IND. SW. C152847 COND. IND SW. C152597	-	-	-	-	-	-	-	-	-	-	NO CABLE IN CASP.	
7	CONDENSATE LEV. XMTRS 2-CO-LT-2.3,4,5	11	SEE NOTE #1	11	SEE NOTE #1	-	-	-	-	-	-		
8	2-VA-7T-129B 120V TO POWER SUPPLY	100	SEE NOTE #1	100	SEE NOTE #1	-	-	-	-	-	-		
9	AIRLOCK INTERCONN	21	277	21	277	0.5723	0.0126	0.5724	0.5723	0.0126	0.5724		
10	SPARE												
11	SPARE												
12	SPARE												
13	SPARE												
14	SPARE												
15	SPARE												

Page 184 of 106

7453-227-3-ED00-01, SEC-0

GENERAL COMPUTATION SHEET

ELECTRICAL CP & L BSEP

UNIT 2

DATE	BY	CHKD BY
10/26/83	RP	MS
10/26/83	RP	MS
10/26/83	RP	MS

UNIT SUB STN 2E8 DISTRIBUTION PANEL NO. 2AB-TB DWG NO. LL-9341 5H.12 REV. 7 DATED 10/26/83


SYSTEM LOAD DATA

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS				
		NORMAL		IX-LOCA		NORMAL			IX-LOCA							
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}					
1	2 RFB TURNING GEAR SOLENOID S1	0.0	—	0.0	—	—	—	—	—	—	—	—	—	—	—	
2	AIR COMPRESSOR SV-581 & USV	132	475	23	573	0.9817	0.02166	0.9819	1.184	0.0261	1.1843	—	—	—	—	
3	EXHAUST AIR ROLL TYPE 2A-EAF-TB	528	425	528	425	0.8780	0.0194	0.8782	0.8780	0.0194	0.8782	—	—	—	—	
4	SPARE															
5	SPARE															
6	SPARE															
7	(D22) AREA RADIATION MON. ALARM "2-12" WEST EL. 45'	0	—	240	SEE NOTE #1	—	—	—	—	—	—	—	—	—	—	ASSUMED LOAD BASED ON PNL. SCH. 9341 5H.12
8	(D22) AREA RADIATION MON. ALARM "2-13" EAST EL. 45'	0	—	240	SEE NOTE #1	—	—	—	—	—	—	—	—	—	—	ASSUMED LOAD BASED ON PNL. SCH. 9341 5H.12
9	(D22) AREA RADIATION MON. ALARM "2-4" ACCESS DOOR COE. EL. 20'	0	—	240	SEE NOTE #1	—	—	—	—	—	—	—	—	—	—	ASSUMED LOAD BASED ON PNL. SCH. 9341 5H.12
10	(D22) AREA RADIATION MON. "2-11" SAMPL'G STA. EL. 20'	0	—	240	SEE NOTE #1	—	—	—	—	—	—	—	—	—	—	ASSUMED LOAD BASED ON PNL. SCH. 9341 5H.12
11	2-RFA-VT-755	30	191	30	191	0.3947	0.0087	0.3948	0.3947	0.0087	0.3948	0.4565	0.0101	0.4566	0.3451	
12	2-RFB-VT-756	30	221	30	221	0.4565	0.0101	0.4566	0.4565	0.0101	0.4566	—	—	—	—	
13	SPARE															
14	2-06-SV-7050	132	167	132	167	0.3450	0.0076	0.3451	0.3450	0.0076	0.3451	—	—	—	—	
15	INST LINE #2-RX5-23 90' HEAT TRACE	1030	SEE NOTE #1	1030	SEE NOTE #1	—	—	—	—	—	—	—	—	—	—	

GENERAL COMPUTATION SHEET

7453-227-3-ED00-01, SEC. A

ELECTRICAL



NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT IX LOCA-208/120V SYSTEM DATA

CALC. SET BY	REV.	CONF. BY	CHK. BY
PNL. NO.		RA	111
DATE	✓	4/18/84	4/16/84
NO.			
SHEET 30 OF 48			
ID 7453-227			

SYSTEM LOAD DATA

UNIT SUB STN 2E7 DISTRIBUTION PANEL NO 2A-DG DWG NO LL-9341 SH 15 REV. 9 DATED 4-17-81


CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	REMOTE SHUTDOWN PANEL	0	-	0	-	-	-	-	-	-	-	
2	DIESEL GENERATOR #3 INSTR. FEEDER	0	-	0	-	-	-	-	-	-	-	NO CABLE IN CASP
3	SPARE											
4	4 DAY FUEL TANK NR 1 SOL. VALVE 2-F0-SV-2012	42(17)	429	42(17)	429	.8866	.0195	.8868	.8866	.0195	.8868	
5	SPARE											
6	4 DAY FUEL TANK NR 3 SOL. VALVE 2-F0-SV-2036	42(17)	352	42(17)	352	.7274	.0160	.7276	.7274	.0160	.7276	
7	DIESEL #3 ENGINE CTL PNL SPACE HEATERS	500	SEE NOTE #1	500	SEE NOTE #1	-	-	-	-	-	-	
8	DIESEL GEN #3-EXCITER CTL PNL LIGHTS & RECEPTACLES	0	-	0	-	-	-	-	-	-	-	
9	SPARE											
10	DIESEL GEN #3-EXCITER CTL PNL. SPACE HEATERS	1000	SEE NOTE #1	1000	SEE NOTE #1	-	-	-	-	-	-	
11	SPARE											
12	DIESEL GEN #3-GENERATOR CTL PNL INSTRUMENTATION	48	SEE NOTE #1	48	SEE NOTE #1	-	-	-	-	-	-	
13	480V UNIT SUBSTA. E5 HEATER & FAN CKTS	0	-	0	-	-	-	-	-	-	-	
13A	SPARE											
14	DIESEL GEN #3-GENERATOR CTL PNL. LIGHTS & SPACE HTR'S.	500	SEE NOTE #1	500	SEE NOTE #1	-	-	-	-	-	-	

Page 158 of 166

GENERAL COMPUTATION SHEET

7453-227-3-ED00-01, SIC-4

DESIGN OF ELECTRICAL



NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT IX LOCA-208/120V SYSTEM DATA

CALC SET NO.		REV.	DATE
NO.	DATE	BY	CHKD BY
1	✓	RA	JPS
NO.	DATE	BY	CHKD BY
1	5/16/84	RA	JPS
SHEET	31 OF 48	DATE	7-81
ID	7453-227		

SYSTEM LOAD DATA

UNIT SUB STN 2E7 DISTRIBUTION PANEL NO. 2A-DG DWG NO. LL-9341 SH. 15 REV. 9 DATED 4-17-81

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
15	RHR SW PUMP 2C CONTROL PNL HB0 BUS E-1	7.8	120'	7.8	120'	.2479	.0055	.2480	.2479	.0055	.2480	
16	AREA RAD. MON. SENSOR 1-4 STACK FILTER HOUSE	0	-	240	SEE NOTE #1	-	-	-	-	-	-	ASSUMED LOAD
17	D.G. BLDG. FIRE DETECT. CONTROL PNL	600	-	600	-	-	-	-	-	-	-	NO FIRE ASSUMED
18	RHR SW PUMP 2A CONTROL PNL HB2 BUS E-5	7.8	SEE NOTE #1	7.8	SEE NOTE #1	-	-	-	-	-	-	
19	D.G. BLDG. FIRE DETECT. CONTROL PNL	600	SEE NOTE #1	600	SEE NOTE #1	-	-	-	-	-	-	NO FIRE ASSUMED
20	DIESEL GEN BLDG LOCAL CTL PNL	250	SEE NOTE #1	250	SEE NOTE #1	-	-	-	-	-	-	
21	BUS DUCT MTR FOR E3-E4	0	-	0	-	-	-	-	-	-	-	T-
22	DIESEL GEN. BLDG - VENT CELL -1 DAMPER CTL	8.2	371'	8.2	371'	.7665	.0169	.7667	.7665	.0169	.7667	
23	4160 V. SWITCHGEAR E3 HEATER AND CONTROL BUS	11897.5	SEE NOTE #1	10812.5	SEE NOTE #1	-	-	-	-	-	-	
24	DIESEL GEN #3 - ENGINE CTL PNL INSTRUMENTATION	0	-	147.6 (MS)	123'	-	-	-	.2541	.0056	.2542	

Page 189 of 194

7453-227-3-ED00-01, SEC-4

GENERAL COMPUTATION SHEET
 UNITED ENGINEERS
 ELECTRICAL

NAME OF COMPANY: CP&L BSEP
 PROJECT NO: 2
 SUBJECT: IX LOCA-208/120V SYSTEM DATA

DATE: 3/11/81	BY: [Signature]
SCALE: 3/3	NO: 48
PROJECT: 7453-227	REV: 1

UNIT SUB STN ZEB DISTRIBUTION PANEL NO. 2B-DG DWG NO. LL-9341 SH. 16 REV. 1; DATED 4-17-81

SYSTEM LOAD DATA

CCT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS			CABLE IMPEDANCES IN "OHM"						REMARKS	
		NORMAL		IX - LOCA DIST. FROM PNL. IN FT.	NORMAL			IX LOCA				
		LOAD IN VA	DIST. FROM PNL. IN FT.		R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}		
15	5R. SW. PUMP ZB CONTROL PNL. M83 BUS E-4	7.8	50	7.8	50	.1033	.0023	.1034	.1033	.0023	.1034	
16	D.G. BLDG. FIRE PROTECTION RELAY BOX E-PP-DV17	53.6(45.2)	1016'	53.6(45.2)	1016'	—	—	—	—	—	—	
17	D.G. BLDG. FIRE PROTECTION RELAY BOX E-PP-DV18	53.6(45.2)	1016'	53.6(45.2)	1016'	2.0990	.0463	2.1000	2.0990	.0463	2.1000	
18	5R. SW. PUMP ZB CONTROL PNL. M81 BUS E-2	7.8(9.4)	130	7.8(9.4)	130	.7686	.0059	.2687	.2686	.0059	.2687	
19	D.G. BLDG. FIRE PROTECTION RELAY BOX E-PP-DV19	53.6(45.2)	1016'	53.6(45.2)	1016'	2.0990	.0463	2.1000	2.0990	.0463	2.1000	
20	D.G. BLDG. FIRE PROTECTION RELAY BOX E-PP-DV16	53.6(45.2)	1016'	53.6(45.2)	1016'	2.0990	.0463	2.1000	2.0990	.0463	2.1000	
21	BUS DUCT HEATER FOR BUSES E2 & E4	0	—	0	—	—	—	—	—	—	—	
22	D.G. BLDG. VENT CELL #2 DAMPER CONTROL	8.2	318	8.2	318	.6571	.0145	.6573	.6571	.0145	.6573	
23	4160 V SWITCHGEAR E4 HEATER AND CONTROL BUS	1242.5	SEE NOTE #1	10617.5	SEE NOTE #1	—	—	—	—	—	—	
24	DIESEL GEN. #4-ENGINE CTL PNL INSTRUMENTATION	0	—	148(25)	144	—	—	—	.2976	.0066	.2977	

7453-227-3-ED00-01, SET 4

GENERAL COMPUTATION SHEET
 ELECTRICAL
 CP&L BSEP
 IX LOCA-208/120V SYSTEM DATA

DATE	10/15/80
BY	PA
CHECKED BY	PA
DATE	10/15/80
NO. OF SHEETS	35 OF 48
NO. OF THIS SHEET	10 7453-227

UNIT SUB STN 2E7 DISTRIBUTION PANEL NO. 2C SYSTEM LOAD DATA DWG NO. LL-9341 SH. 17 REV. 10 DATED 5/23/77

Page 193 of 106

CCT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHM"						REMARKS		
		NORMAL		NORMAL			IX LOCA					
		LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}			
15	2-RIP-CS1214	40	SEE NOTE #1	—	—	—	—	—	—	—	—	—
16	2-RIP-CS1215	60	SEE NOTE #1	—	—	—	—	—	—	—	—	—
17	TURB. BLDG VENT SYSTEM MISC. CKTS	0.0	—	—	—	—	—	—	—	—	—	—
18	FAN COOLING C.S. PMP ROOM 2A DISCH. VLV. V-128	16	SEE NOTE #1	—	—	—	—	—	—	—	—	—
19	VENTILATION-EMERG. RECIRC. FAN A	95	SEE NOTE #1	—	—	—	—	—	—	—	—	—
20	RHR PUMP ROOM COOLER 2A DISCH. VLV. V-129	16	SEE NOTE #1	—	—	—	—	—	—	—	—	—
21	VA SYSTEM BATTERY RM DISCH. CANNAL TEMP. MONITORING	232.4	SEE NOTE #1	—	—	—	—	—	—	—	—	—
22	VENTILATION, REACTOR BLDG EXHAUST FANS 2A/2C CTL CKT	18	SEE NOTE #1	18	444	—	—	—	—	—	—	—
23	VENTILATION, REACTOR BLDG ISOL DAMPERS 2A/2C CTL CKT	104.4	SEE NOTE #1	—	—	—	—	—	—	—	—	—
24	VENTILATION, REACTOR BLDG FMS 2A/2C (SPT) SYS A CTL CKT	32(195.4)	1052	—	—	—	—	—	—	—	—	—
25	VENTILATION, CTL BLDG	168.4	SEE NOTE #1	—	—	—	—	—	—	—	—	—
26	CTL ROOM AC	8.2(140.8)	1066	—	—	—	—	—	—	—	—	—
26A	CAC-MONITOR PV 12&0 SOLENOID VALVE CKT	40	SEE NOTE #1	—	—	—	—	—	—	—	—	—
27	BOP TERM. CAB. XU-5 TURBINE ALARM CKT	0.0	—	—	—	—	—	—	—	—	—	—
28	480V UNIT SUBSTA COMB. HEATERS & FAN CKT	0.0	—	—	—	—	—	—	—	—	—	—
29	BOP TERM. CAB. XU12 FANS CKT	224	SEE NOTE #1	22.4	SEE NOTE #1	—	—	—	—	—	—	—

LOAD ASSUMED
 BASE ON PNL
 SEC. 917-11-9341
 SH. 17, R. 10, 5/23/77

7453-227-3-ED00-01, SEC-4

DATE	3/19/84
BY	JR
REV	1
NO.	48
DATE	10/14/53-227


GENERAL COMPUTATION SHEET
 UNITED ENGINEERS
 CP&L BSEP
 UNIT 2
 SUBJECT IX LOCA-208/120V SYSTEM DATA

UNIT SUB STN. 2E8 DISTRIBUTION PANEL NO. 2D DATA
 DWG NO. LL-9341 5H 1B REV. 12 DATED 12/6/83

CCT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS		CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL	IX-LOCA	NORMAL			IX LOCA			
		LOAD IN VA	LOAD IN VA	RN	XN	ZN	R IX	X IX	Z IX	
16	2-RIP-CS 1231	50	50	—	—	—	—	—	—	
17	2-RIP-CS 1232	50	50	—	—	—	—	—	—	
18	FAN COOLING CS PUMP RM 2B DISCH. VLV V-123	16	0.0	—	—	—	—	—	—	
19	VENT REACTOR BLDG-EXH FANS 2B 2D CTL CKT	100	2.0	—	—	—	—	—	—	
20	RHR PUMP RM COOLER 2B DISCH. VLV V-124	16	16	—	—	—	—	—	—	
21	VENT REACTOR BLDG-ISOLA- TION DAMPERS 2B 2D CTL CKTS	104	68(182)	—	—	—	3.7447	.0826	3.7456	
22	VA SYSTEM BATT RM 2B-CB EXH FAN	96(36.4)	46(36.4)	1.1862	.0262	1.1865	1.1862	.0262	1.1865	
23	VENT REACTOR BLDG-SUPPLY FANS RM 2B 2D 2D CTL CKTS 2-DG-CB 2D	164	2.0	—	—	—	—	—	—	
24	VENTILATION-CTL BLDG CTL ROOM A/C	82(104)	82(104)	3.6662	0.0809	3.6671	3.6662	0.0809	3.6671	
25	SPARE									
26	VENTILATION EMERG. RECIRC. FAN "B"	17(15)	17(15)	.3720	.4082	.3721	.3720	.0082	.3721	
27	LOCA SIG. FOR CAC MONITORING	9.6	0.0	—	—	—	—	—	—	
28	CAC MONITOR PV 1261 & 1262 SOLENOID VALVES	75.2	10	—	—	—	—	—	—	
29	PWR SUPPLY FOR GASEOUS ANALYZER PNL-XU-61	0	0	—	—	—	—	—	—	
30	480V UNIT SUBSTA "2L" HEATER & FAN CKTS	0.0	0.0	—	—	—	—	—	—	ALTERNATE SOURCE

DISCIPLINE
ELECTRICAL

GENERAL COMPUTATION SHEET



NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT IX LOCA-208/120V SYSTEM DATA

7453-227-3-ED00-01, Sec-a

NO.	DATE	BY	CHKD.
1	4/16/84	RS	4/16/84
SHEET <u>38</u> OF <u>48</u>		DATE	DATE
7453-227			

SYSTEM LOAD DATA

UNIT SUB STN 2E7 DISTRIBUTION PANEL NO 32A DHG NO LL-9341 SH 23 REV.9 DATED 11-18-83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	STEAM LEAK DETECTION GVS (B21) HIZ - P614 HPCI LOGIC TIMER	52.8(58)	76	52.8(58)	-	.0987	.0034	.0988	.0987	.0034	.0988	
2	POWER SUPPLY MISC. INST RACK XU-62	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
3	SPARE											
4	SPARE											
5	DC SWBD. 2A STRIP HTRS	560	-	560	-	-	-	-	-	-	-	
6	DIESEL GEN 143 EXH. FAN & DAMPER CONT	17(5)	1239	17(5)	1239	2.5606	.0564	2.5612	2.506	.0564	2.5612	IMPEDANCE DATA BASED ON #10 CABLE.
7	SPARE											
8	RTG BOARD - PM2 PLUG-MOLD FOR RECORDERS	160	SEE NOTE #1	160	SEE NOTE #1	-	-	-	-	-	-	
9	RTG BOARD - PM1 PLUG-MOLD FOR RECORDERS	96	SEE NOTE #1	96	SEE NOTE #1	-	-	-	-	-	-	
10	POWER SUPPLY 2-CAG-ES-3689	48	SEE NOTE #1	48	SEE NOTE #1	-	-	-	-	-	-	
11	SPARE											
12	RTG BOARD - PM3 - PLUG-MOLD FOR RECORDERS	92	SEE NOTE #1	92	SEE NOTE #1	-	-	-	-	-	-	
13	RTG BOARD XU-51 2-CAG-LSHL-4177	6	SEE NOTE #1	6	SEE NOTE #1	-	-	-	-	-	-	
14	RTG BOARD - PM7 - PLUG-MOLD FOR RECORDERS	392	SEE NOTE #1	392	SEE NOTE #1	-	-	-	-	-	-	
15	SPARE											
16	RTG BOARD - PM11 - PLUG-MOLD FOR RECORDERS	125	SEE NOTE #1	125	SEE NOTE #1	-	-	-	-	-	-	
17	SPARE											

Page 196 of 106

GENERAL COMPUTATION SHEET

ELECTRICAL

united engineers

NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT IX LOCA-208/120V SYSTEM DATA

7453-227-3-ED00-01, SEL-4

CALC. SHEET		REV.	DATE
NO.			
1	✓	RP	1/15
2		2/16/81	1/15/81
SHEET 41 OF 48		DATE	DATE
NO. 7453-227			


SYSTEM LOAD DATA
UNIT SUB STN 2EB DISTRIBUTION PANEL NO 32B DWG NO LL-9341 SH. 24 REV. 13 DATED 4-26-83

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
17	RX BLDG TERM CAB XU-56 2-CAC-CS-1539	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
18	RX BLDG TERM CAB. XU-56 2-CAC-CS-1533	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
19	RX BLDG TERM CAB. XU-56 2-CAC-CS-1534	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
20	RX BLDG TERM CAB. XU-56 2-CAC-CS-1541	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
21	RX BLDG TERM CAB. XU-56 2-CAC-CS-1542	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
22	INST. AIR CV2889 & 2890 1-CAC-CS-2889-1 & 2-CAC-CS-2889-2	32(5)	2877	32(5)	2877	5.9457	.1312	5.9472	5.9457	.1312	5.9472	
23	CV2716 1-CAC-CS-2716-1 & 2-CAC-CS-2716-2	10	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
24	SPARE											

PAGE 199 OF 106

GENERAL COMPUTATION SHEET

ELECTRICAL



NAME OF COMPANY: CP&L BSEP UNIT: 2

SUBJECT: IX LOCA-208/120V SYSTEM DATA

7453-227-3-ED00-01, SEC-A

DATE	4/16/84	BY	MS
NO.	42 OF 48	DATE	
NO.	7453-227	DATE	

SYSTEM LOAD DATA


UNIT SUB STN 2E7 DISTRIBUTION PANEL NO 32AB DWG NO LL-9341 SH.25 REV.8 DATED 8-19-82

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX LOCA			
		LOAD IN VA	DIST. FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
1	RX BLDG TERM. CAB. XU-53 2M12-P606, P622	106.8	SEE NOTE #1	0.0	-	-	-	-	-	-	-	
2	RX BLDG TERM. CAB. XU-53 2-CAC-CS-4178	133	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
3	RX BLDG TERM. CAB. XU-53 2-CAC-1699	42	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
4	RX BLDG TERM. CAB. XU-53 2-CAC-CS-1537	21	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
5	RX BLDG TERM. CAB. XU-53 2-CAC-CS-1531	21	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
6	RX BLDG TERM. CAB. XU-53 2-CAC-CS-1530	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
7	RX BLDG TERM. CAB. XU-53 2-CAC-CS-2711	21(5)	209	21(5)	209	0.4318	0.0095	0.4319	0.4318	0.0095	0.4319	
8	RX BLDG TERM. CAB. XU-53 2-CAC-CS-2710	21(5)	209	21(5)	209	0.4318	0.0095	0.4319	0.4318	0.0095	0.4319	
9	RX BLDG TERM. CAB. XU-53 2-CAC-CS-2572	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
10	RX BLDG TERM. CAB. XU-53 2-CAC-CS-2571	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
11	RX BLDG TERM. CAB. XU-53 2-CAC-CS-2573	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
12	RX BLDG TERM. CAB. XU-53 2-CAC-CS-2683	10	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
13	2-H5-V5031-CAC-CS-2696 {2-CAC-CS-2696-2}	10	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
14	INERT. STM TEMP. TCV-2695 1-CAC-CS-2695-1 {2-CAC-CS-2695-2}	10	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
15	CAD N ₂ FCV 2717 1-CAC-CS-2717-1 {2-CAC-CS-2717-2}	10	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
16	CV 2713 1-CAC-CS-2713-1 {2-CAC-CS-2713-2}	10	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	

Page 1.100 of 108

GENERAL COMPUTATION SHEET

ELECTRICAL



NAME OF COMPANY CP&L BSEP UNIT 2

SUBJECT IX LOCA-208/120V SYSTEM DATA

7453-227-3-ED00-01, SEC. A

DATE	BY	CHKD BY
SHEET 43 OF 48		
NO 7453-227		

SYSTEM LOAD DATA


UNIT SUB STN 2E7 DISTRIBUTION PANEL NO. 32AB DWG NO. LL-9341 SH. 25 REV. B DATED 8-19-82

CKT. NO.	CIRCUIT DESCRIPTION	CIRCUIT LOADS				CABLE IMPEDANCES IN "OHM"						REMARKS
		NORMAL		IX-LOCA		NORMAL			IX-LOCA			
		LOAD IN VA	DIST FROM PNL. IN FT.	LOAD IN VA	DIST. FROM PNL. IN FT.	R _N	X _N	Z _N	R _{IX}	X _{IX}	Z _{IX}	
17	CV-2715 1-CAC-CS-2715-1 & 2-CAC-CS-2715-2	10	SEE NOTE #1	10	SEE NOTE #1	-	-	-	-	-	-	
18	CTL BLDG. SEISMIC MON. CAB. ENV-XR-823-RECEPTACLE	69	SEE NOTE #1	69	SEE NOTE #1	-	-	-	-	-	-	ASSUMED LOAD
19	POST ACC. MISC INSTR. CAB. 2-XU-75	150	SEE NOTE #1	150	SEE NOTE #1	-	-	-	-	-	-	ASSUMED LOAD.
20	SPARE											
21	SPARE											
22	DIV I ISOLATOR CAB. XU-77	500	(NO DETAIL INFO ON LOAD AVAILABLE)	500	(NO DETAIL INFO ON LOAD AVAILABLE)	.2294	.0051	.2295	.2294	.0051	.2295	ASSUMED LOAD BASED ON PNL. SK. 9341 SH. 25
23	VAC. BKR CONT. ISO VLV V16 2-CAC-CS-4222	5	SEE NOTE #1	5	SEE NOTE #1	-	-	-	-	-	-	
24	SPARE											

Page 1.101 of 106

GENERAL COMPUTATION SHEET

DISCIPLINE: ELECTRICAL



NAME OF COMPANY: CP&L, BSEP UNIT/S: 2

SUBJECT: 1X LOCA - 208/120 VOLT SYSTEM DATA

CALC SET NO		REV	COMP BY	CHKD BY
PRELIM		0	RA	N/S
FINAL	X		DATE 4/18/84	DATE 4/26/84
VOID				
SHEET	44 OF 48		DATE	DATE
JO	7453.227			

Review Notes

1. The following criteria were used in preparation of the load tabulations and in determining the circuit impedances:
 - a. load distance was not determined for circuits having no operating relays and solenoids (120 volts AC).
 - b. Within individual circuits, the relays and/or solenoids which are expected to experience the maximum Voltage Drop have been tabulated outside the parenthesis in the load column. The remaining loads are summed up and tabulated within the parenthesis. Therefore, total load for the circuit is a summation of loads outside and within the parenthesis.
 - c. Circuits loads such as indicating lights, recorders, resistance heaters, cabinet fans, low voltage power transformer, instrument power, supplies, etc. have not been analyzed for load distance from panel board.
 - d. No load distance analysis was made on circuits in which the relays and/or solenoids ^{are} deenergized under 1X LOCA Condition.
 - e. Manually initiated test circuits were not analyzed for load and load distances.
2. Power factor is assumed to be .85 lagging ~~for all ac inductive loads.~~
3. Cable impedances were calculated based on cable length and size available in the CASP "A" Report with resistance and reactances data from the Industrial Power Systems Handbook by Donald Beenan. (See Reference list and Sheet 48 of 48).
4. Transformer impedance is based on information derived from manufacturer. Refer to Tele-notes T-1015, T-1066, ~~where~~ ^{at all} manufacturer's test data and foreign print records are not available.
5. Loads for which precise information was not ~~available~~ ^{in any drawing}, were assumed and are so noted in the System Load Data and/or circuit evaluation Tables.
6. The following assumptions were used to assess individual circuit component loading:
 - a. For low voltage control transformers without size or load data, 80% of the fuse size was assumed to be the load on the transformer (conservative estimate).
 - b. Solenoids or Relays for which exact manufacturers information was not available, load was assumed to be similar to devices for which load characteristic is available.
 - c. Panel schedule load listing (Dwg. 9527-LL-9341) is assumed for circuits on which no component information or detail drawing is available.
 - d. For power supplies, convertors, the loading is assumed to be the maximum rated Power Consumptions (conservative approach).
 - e. No fire is assumed concurrent with a LOCA.
 - f. radiation alarms and proper isolation of appropriate systems due to high radiation following a LOCA are assumed for all areas.
7. All assumed loads should be verified at a later date when information is available. These assumed loads are conservative enough to provide reasonable voltage profiles at their terminals.

(DISCIPLINE)

ELECTRICAL



NAME OF COMPANY: CPAL BSEP
 SUBJECT: 208/120 V SYSTEM DATA
 FEEDER CABLE IMPEDANCE DATA
 REF. DWG 9527-F-934, REV. 7, DATED 9/19/82

UNIT/S 2


CALC SET NO	REV	COMP BY	CHK'D
PRELIM			
FINAL	✓	RA	✓
VOID		DATE 11/16/84	DATE 4/22
SHEET 45 OF 48			
JO 7453-227			

			R	X	Z
GE7-HG6	1-4/c #2	21'	.0043	.0007	.0044
D49-GE7	1-4/c #2	109'	.0225	.0037	.0232
H14-HGφ	1-3/c 250MCM	462'	.1265	.0149	.0300
H14-HGφ/1	1-1/c 250MCM	462'			
H14-HG3	1-3/c 250MCM	425'	.0244	.0137	.0277
H14-HG3/1	1-1/c 250MCM	425'	-	-	-
HφB-HGφ	1-3/c 250MCM	45'	.0026	.0014	.0033
HφB-HGφ/1	1-1/c 250MCM	45'	-	-	-
HφB-HG3	1-3/c-250MCM	40'	.0023	.0013	.0026
HφB-HG3/1	1-1/c-250MCM	40'	-	-	-
H11-HGφ	1-3/c-250MCM	181'	.0104	.0058	.0119
H11-HGφ/1	1-1/c-250MCM	181'	-	-	-
H11-HG3	1-3/c-250MCM	213'	.0122	.0069	.0140
H11-HG3/1	1-1/c-250	213'	-	-	-
GE8-HQ7	1-4/c #2	21'	.0043	.0007	.0044
D49-GE8	1-4/c #6	111'	.0573	.0043	.0575
GE2-HQ5	1-4/c #2	30'	.0062	.0010	.0063
E47-GE2	1-4/c #6	45'	.0232	.0018	.0233

GENERAL COMPUTATION SHEET

7453-227-3-ED00-01 SEC-5

DISCIPLINE: ELECTRICAL



NAME OF COMPANY: CP&L BSEP UNITS: 2
 SUBJECT: 208/120 V SYSTEM DATA
FEEDER CABLE IMPEDANCE DATA

CALC SET NO		REV	COMP BY	CHKD BY
PRELIM		0	RA	NBS
FINAL	✓		DATE	DATE
VOID			11/16/84	4/26/83
SHEET 46 OF 48		DATE	DATE	
JO 7453-227				

REF. DWG. 9527-F-9331
 REV. 7 DATED 9/13/82

CABLE	CABLE SIZE	(FT) LENGTH	R	X	Z
H12-HGφ	1-3/c-250MCM	185'	.0106	.0060	.0122
H12-HGφ/1	1-1/c-250MCM	185'	-	-	-
Hφ9-HGφ	1-3/c-250MCM	153'	.0088	.0049	.0101
Hφ9-HGφ/1	1-1/c-250MCM	153'	-	-	-
Hφ6-HGφ	1-3/c-500MCM	30'	.0009	.0009	.0013
Hφ6-HGφ/1	1-1/c-250MCM	30'	-	-	-
HGφ-LG3	1-3/c #1/0	50'	.0066	.0017	.0068
HG3-LG3	1-3/c #1/0	80'	.0105	.0027	.0108
Hφ7-HG3	1-3/c-500MCM	35'	.0011	.0010	.0015
Hφ7-HG3/1	1-1/c-250MCM	35'	-	-	-
H1φ-HG3	1-3/c-250MCM	372'	.0213	.0120	.0245
H1φ-HG3/1	1-1/c-250MCM	372'	-	-	-
FJ7-HW9	1-4/c #2/0	25'	.0026	.0008	.0028
C7B-FJ7	1-4/c #6	145'	.0750	.0057	.0751
H13-HG3	1-3/c #250MCM	495'	.0284	.0159	.0325
H13-HG3/1	1-1/c 250MCM	495'	-	-	-
GE1-HQ4	1-4/c #2	30'	.0062	.0010	.0063
E14-GE1	1-4/c #6	70'	.0362	.0027	.0363

GENERAL COMPUTATION SHEET

7453-227-3-EDCO-01, SEC. 5

(DISCIPLINE)

ELIZABETHAL  **United engineers**
& CONSTRUCTORS INC.

NAME OF COMPANY CP&L BSEP UNIT/S 2

208/120 V SYSTEM DATA

SUBJECT FEEDER CABLE IMPEDANCE DATA.

REF. DWG 9527-F-9331, REV-7, DATED 9/13/82

CALC SET NO	REV	COMP BY	CHKD
PRELIM			
FINAL	✓	RA	MS
VOID		DATE 4/16/84	DATE 4/24/84
SHEET 47 OF 48		DATE	DATE
JO 7453-227			

			R	X	Z
FJ6-HW8	1-4/c #2/0	50'	.0052	.0017	.0053
C77-FJ6	1-4/c #6	45'	.0232	.0018	.0233
HGφ-HYφ	1-3/c-250MCM	23'	.0013	.0007	.0014
HGφ-HYφ/1	1-1/c-250MCM	23'	—	—	—
HGφ-HXφ	1-3/c-250MCM	125'	.0072	.0040	.0073
HGφ-HXφ/1	1-1/c-250MCM	125'	—	—	—
HG3-HXφ	1-3/c-250MCM	90'	.0052	.0029	.0053
HG3-HXφ/1	1-1/c-250MCM	90'	—	—	—
HG3-HY1	1-3/c-250MCM	30'	.0017	.0010	.0018
HG3-HY1/1	1-1/c-250MCM	30'	—	—	—
GF4-HG0	1-3/c-500MCM	35'	.0011	.0010	.0012
GF6-HG3	1-3/c-500MCM	23'	.0070	.0007	.0071

GENERAL COMPUTATION SHEET

7453-227-3-ED00-01, SEC-5

(DISCIPLINE)

ELECTRICAL



NAME OF COMPANY CP&L BSEP UNIT/S 2
 SUBJECT 208/120 V SYSTEM DATA
FEEDER CABLE IMPEDANCE DATA

CALC SET NO		REV	COMP BY	CHKD BY
PRELIM		0	RA	M
FINAL	✓		DATE 4/16/84	DATE 3/20/83
VOID				
SHEET 48 OF 48			DATE	DATE
JOB 7453-227				

TABLE 1.20 Approximate Resistance, Reactance, and Impedance of 600-volt Cables in Magnetic Ducts per 100 Ft

Cable size	Three single-conductor cables per duct, ohms per 100 ft			Three-conductor cable including interlocked armor cable, ohms per 100 ft		
	R*	X	Z	R*	X	Z
No. 14 Awg..	0.3135	0.00765	0.3135	0.3135	0.00468	0.31352
No. 12 Awg..	0.1972	0.00710	0.1972	0.1972	0.00456	0.19720
No. 10 Awg..	0.1240	0.00617	0.1240	0.1240	0.00448	0.12410
No. 8 Awg...	0.0779	0.00638	0.0782	0.0779	0.00427	0.07460
No. 6 Awg...	0.0498	0.00598	0.0500	0.0493	0.00391	0.04899
No. 4 Awg...	0.0318	0.00551	0.0322	0.0312	0.00362	0.03140
No. 2 Awg...	0.0203	0.00513	0.0209	0.0197	0.00344	0.02000
No. 1 Awg...	0.0163	0.00500	0.0171	0.0157	0.00342	0.01606
No. 1/0 Awg..	0.0131	0.00495	0.0140	0.0125	0.00340	0.01296
No. 2/0 Awg..	0.0106	0.00490	0.0117	0.0100	0.00336	0.01054
No. 3/0 Awg..	0.00860	0.00486	0.00986	0.00800	0.00333	0.00866
No. 4/0 Awg..	0.00700	0.00482	0.00850	0.00640	0.00327	0.00721
250 MCM....	0.00608	0.00480	0.00778	0.00547	0.00322	0.00632
300 MCM....	0.00520	0.00474	0.00704	0.00460	0.00316	0.00557
350 MCM....	0.00461	0.00469	0.00658	0.00400	0.00310	0.00510
400 MCM....	0.00419	0.00462	0.00623	0.00354	0.00304	0.00469
500 MCM....	0.00359	0.00450	0.00573	0.00292	0.00295	0.00412
750 MCM....	0.00280	0.00438	0.00520	0.00208	0.00284	0.00346

* Based on 75 C.

$$RESISTANCE AT 90^{\circ}C = RESISTANCE AT 75^{\circ}C \times \frac{234.5 + 90}{234.5 + 75} =$$

R_x 1.048