



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
PO. BOX 7
PERRY, OHIO 44081

Michael D. Lyster
VICE PRESIDENT - NUCLEAR

May 15, 1992
PY-CEI/NRR-1493 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Perry Nuclear Power Plant
Docket No. 50-440
Monthly Operating Report

Gentlemen:

Attached is the April 1992 Monthly Operating Report for Perry Unit 1. This report is submitted in accordance with Technical Specification 6.9.1.8.

If there are any questions, please feel free to call.

Sincerely,


Michael D. Lyster

MDL:DWC:ss

Attachment

cc: NRR Project Manager
USNRC Senior Resident Inspector - Perry
USNRC, Region III
Director, Office of Resource Management
Ohio EPA

9205190008 720430
PDR ADECK 05000440
R PDR

190040

Operating Companies
General Electric Illuminating
Co. 330 Edison

LEDA
11

CLEVELAND ELECTRIC ILLUMINATING COMPANY

PERRY NUCLEAR POWER PLANT

April 1, 1992 - April 30, 1992

MONTHLY OPERATING REPORT TO NRC

DOCKET NUMBER : 50-440

LICENSE NUMBER: NPF-58

Table of Contents

Average Daily Unit Power Level	1
Operating Data Report	2
Unit Shutdowns and Power Reductions	3

Average Daily Unit Power Level

DOCKET NO. 50-440
UNIT Perry-1
DATE 05/15/92
Contact H. L. Hegrat
Telephone (216)259-3737

MONTH April 1992

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	N/A
16	0		

Operating Data Report

UNIT: PERRY-1
DATE: 05/15/92

OPERATING STATUS

1. Docket: 50-440
2. Reporting Period: April 1992
3. Utility Contact: H. L. Hegrat (216) 259-3737
4. Licensed Thermal Power (MWt): 3579
5. Nameplate Rating (Gross MWe): 1250
6. Design Electrical Rating (Net MWe): 1191
7. Maximum Dependable Capacity (Gross MWe): 1225
8. Maximum Dependable Capacity (Net MWe): 1166
9. If changes occur in capacity ratings (Item Numbers 4 through 8) since last report, give reasons:
None
10. Power Level To Which Restricted, If Any (Net MWe): 100%
11. Reasons for Restrictions, If Any: Operating License Limit

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
--	-------------------	-------------------	-------------------

CODED/5699/SS

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH April 1992

DOCKET NO. 50-440
 UNIT NAME Perry - 1
 DATE 05/15/92
 CONTACT H. L. Hegrat
 TELEPHONE (216)259-3737

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
92-01	03/20/92	S	719.0	C	4	N/A	N/A	N/A	Refueling Outage, continued from previous month.

SUMMARY: During April 1992, Perry-1 remained shutdown for the third refueling outage. Scheduled restart date is May 23, 1992.

- ¹ F: Forced
 S: Scheduled
- ² Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

- ³ Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continued
 5-Reduced Load
 9-Other

- ⁴ Exhibit G-Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG1022)

- ⁵ Exhibit I-Same Source