

CATAWBA NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT
March 1992

1. Personnel Exposure -

For the month of March, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-413
 UNIT NAME CATAWBA 1
 DATE 04/15/92
 COMPLETED BY W.C. SIMMONS
 TELEPHONE (704)-373-8559

Revision 1

REPORT MONTH March 1992

NO.	DATE	(1) TYPE	DURATION HOURS	(2) REASON	(3) METHOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYS- TEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
1-P	92- 3- 4	F	--	A	--		HB	INSTRU	MAIN TURBINE ELECTRO-HYDRAULIC CONTROL PROBLEMS

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source