

Georgia Power Company
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 877-7122

DS09

C. K. McCoy
Vice President, Nuclear
Veolia Project

Ngoc B. Le
57FR11732

4/7/92
USNRC



'92 MAY 13 P4:18
Georgia Power
for customer service system

9

May 7, 1992

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

Docket Nos. 50-321 50-424
50-366 50-425

Not rec'd
5/7/92

HL-2199
ELV-03703

Mr. Samuel J. Chilk
Secretary of the Commission
U.S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Docketing and Service Branch

OFFICE OF ADMINISTRATION
USNRC
92 MAY 14 P 10:05

Comments on
"Proposed Generic Communication NRC Bulletin No. 90-01, Supplement 1: Loss of Fill Oil in Transmitters Manufactured by Rosemount" (57 Federal Register 11732 of April 7, 1992)

Dear Mr. Chilk:

Georgia Power Company has reviewed the proposed bulletin supplement, "Proposed Generic Communication NRC Bulletin No. 90-01, Supplement 1: Loss of Fill Oil in Transmitters Manufactured by Rosemount" published in the Federal Register on April 7, 1992. In accordance with the request for comments, Georgia Power Company is in total agreement with the NUMARC comments which are to be provided to the NRC. In addition, Georgia Power Company provides the following comment:


Reporting requirement 3 requires the licensee to provide a statement (within 60 days after receipt of the bulletin supplement) confirming that Item 3 of Requested Actions has been completed. Item 3 of Requested Actions requires two things: 1) quarterly evaluation of measurement data for comparison with manufacturer's drift data; and 2) 18 month evaluation of all remaining transmitters subject to the enhanced surveillance monitoring program. If the licensee has not been evaluating measurement data quarterly and evaluating remaining transmitters every 18 months then the licensee cannot provide a statement confirming that this item has been completed.

9205190180 920507
PDR PR
MISC 57FR11732 PDR

Mr. Samuel J. Chilk
U.S. Nuclear Regulatory Commission
Page 2

Should you have any questions, please advise.

Respectfully submitted,


C. K. McCoy

CKM/JDK

cc: Georgia Power Company

Mr. J. T. Beckham, Jr., Vice President, Plant Hatch
Mr. W. B. Shipman, General Manager - Plant Vogtle
Mr. H. L. Sumner, Jr., General Manager - Plant Hatch
NORMS

U. S. Nuclear Regulatory Commission, Washington, DC
Mr. K. N. Jabbour, Licensing Project Manager - Hatch
Mr. D. S. Hood, Licensing Project Manager - Vogtle

U. S. Nuclear Regulatory Commission, Region II
Mr. S. D. Ebnetter, Regional Administrator
Mr. L. D. Wert, Senior Resident Inspector - Hatch
Mr. B. R. Bonser, Senior Resident Inspector - Vogtle