



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

DOCKET NO. 50-369

McGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 131  
License No. NPF-9

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-9 filed by the Duke Power Company (licensee) dated May 9, 1988, as supplemented August 1, 1988, and January 5, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 101, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director  
Project Directorate II-3  
Division of Reactor Projects-I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Technical Specification  
Changes

Date of Issuance: May 7, 1992



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20565

DUKE POWER COMPANY

DOCKET NO. 50-370

McGUIRE NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 113  
License No. NPF-17

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-17 filed by the Duke Power Company (licensee) dated May 9, 1988, as supplemented August 1, 1988, and January 5, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 113, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director  
Project Directorate II-3  
Division of Reactor Projects-I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Technical Specification Changes

Date of Issuance: May 7, 1992



ATTACHMENT TO LICENSE AMENDMENT NO.131

FACILITY OPERATING LICENSE NO. NPF-9

DOCKET NO. 50-369

AND

TO LICENSE AMENDMENT NO. 113

FACILITY OPERATING LICENSE NO. NPF-17

DOCKET NO. 50-370

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove Pages

2-8  
2-10  
3/4 3-7  
3/4 3-11  
3/4 3-14a

Insert Pages

2-8  
2-10  
3/4 3-7  
3/4 3-11  
3/4 3-14a

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTSNOTATIONNOTE 1: OVERTEMPERATURE  $\Delta T$ 

$$(\Delta T / \Delta T_0) \left( \frac{1 + \tau_1 S}{1 + \tau_2 S} \right) \left( \frac{1}{1 + \tau_3 S} \right) \leq K_1 - K_2 \left( \frac{1 + \tau_4 S}{1 + \tau_5 S} \right) \left[ T \left( \frac{1}{1 + \tau_6 S} \right) - T' \right] + K_3 (P - P') - f_1(\Delta T)$$

- where:  $\Delta T$  = Measured  $\Delta T$  by Loop Narrow Range RTD
- $\Delta T_0$  = Indicated  $\Delta T$  at RATED THERMAL POWER,
- $\frac{1 + \tau_1 S}{1 + \tau_2 S}$  = Lead-lag compensator on measured  $\Delta T$ ,
- $\tau_1, \tau_2$  = Time constants utilized in the lead-lag controller for  $\Delta T$ ,  $\tau_1 \geq 8$  sec.,  $\tau_2 \leq 3$  sec.,
- $\frac{1}{1 + \tau_3 S}$  = Lag compensator on measured  $\Delta T$ ,
- $\tau_3$  = Time constants utilized in the lag compensator for  $\Delta T$ ,  $\tau_3 \leq 2$  sec.\*
- $K_1$   $\leq$  1.1958,
- $K_2$  = 0.03143
- $\frac{1 + \tau_4 S}{1 + \tau_5 S}$  = The function generated by the lead-lag controller for  $T_{avg}$  dynamic compensation,
- $\tau_4, \tau_5$  = Time constants utilized in the lead-lag controller for  $T_{avg}$ ,  $\tau_4 \geq 28$  sec,  $\tau_5 \leq 4$  sec.,
- $T$  = Average temperature, °F,
- $\frac{1}{1 + \tau_6 S}$  = Lag compensator on measured  $T_{avg}$ ,

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINT

NOTATION (Continued)

NOTE 2: OVERPOWER  $\Delta T$

$$(\Delta T / \Delta T_0) \left( \frac{1 + \tau_1 S}{1 + \tau_2 S} \right) \left( \frac{1}{1 + \tau_3 S} \right) \leq K_4 - K_5 \left( \frac{\tau_7 S}{1 + \tau_7 S} \right) \left( \frac{1}{1 + \tau_6 S} \right) T_6^{-K} \left[ T \left( \frac{1}{1 + \tau_6 S} \right) - T'' \right] - f_2(\Delta I)$$

- Where:
- $\Delta T$  = As defined in Note 1,
  - $\Delta T_0$  = As defined in Note 1,
  - $\frac{1 + \tau_1 S}{1 + \tau_2 S}$  = As defined in Note 1
  - $\tau_1, \tau_2$  = As defined in Note 1
  - $\frac{1}{1 + \tau_3 S}$  = As defined in Note 1,
  - $K_4$   $\leq$  1.0809,
  - $K_5$  = 0.02/ $^{\circ}$ F for increasing average temperature and 0 for decreasing average temperature,
  - $\frac{\tau_7 S}{1 + \tau_7 S}$  = The function generated by the rate-lag controller for  $T_{avg}$  dynamic compensation,
  - $\tau_7$  = Time constant utilized in the rate-lag controller for  $T_{avg}$ ,  $\tau_7 \geq 5$  sec,
  - $\frac{1}{1 + \tau_6 S}$  = As defined in Note 1,
  - $\tau_6$  = As defined in Note 1,
  - $K_6$  = 0.001239/ $^{\circ}$ F for  $T > T''$  and  $K_6 = 0$  for  $T \leq T''$ ,

McGuire - UNITS 1 and 2

2-10

Amendment No. 131 (Unit 1)  
Amendment No. 113 (Unit 2)

TABLE 3.3-1 (Continued)

ACTION STATEMENTS (Continued)

- ACTION 3 - With the number of channels OPERABLE one less than the Minimum Channels OPERABLE requirement and with the THERMAL POWER level:
- a. Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint, and
  - b. Above the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint but below 10% of RATED THERMAL POWER, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above 10% of RATED THERMAL POWER.
- ACTION 4 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement suspend all operations involving positive reactivity changes.
- ACTION 5 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, verify compliance with the SHUTDOWN MARGIN requirements of Specification 3.1.1.1 or 3.1.1.2, as applicable, within 1 hour and at least once per 12 hours thereafter.
- ACTION 6 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 6 hours, and
  - b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.1.1 and Specification 4.3.2.1.
- ACTION 7- Deleted
- ACTION 8 - With less than the Minimum Number of Channels OPERABLE, within 1 hour determine by observation of the associated permissive annunciator window(s) that the interlock is in its required state for the existing plant condition, or apply Specification 3.0.3.



TABLE 4.3-1

## REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

	FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
McGuire - UNITS 1 and 2	1. Manual Reactor Trip	N.A.	N.A.	N.A.	R (11)	N.A.	1, 2, 3*, 4*, 5*
	2. Power Range, Neutron Flux High Setpoint	S	D(2, 4), M(3, 4), Q(4, 6), R(4, 5)	M	N.A.	N.A.	1, 2
3/4 3-11	Low Setpoint	S	R(4)	M	N.A.	N.A.	1 <sup>###</sup> , 2
	3. Power Range, Neutron Flux, High Positive Rate	N.A.	R(4)	M	N.A.	N.A.	1, 2
	4. Intermediate Range, Neutron Flux	S	R(4, 5)	S/U(1),M	N.A.	N.A.	1 <sup>###</sup> , 2
	5. Source Range, Neutron Flux	S	R(4, 5)	S/U(1),M(9)	N.A.	N.A.	2 <sup>##</sup> , 3, 4, 5
	6. Overtemperature ΔT	S	R(15)	M	N.A.	N.A.	1, 2
Amendment No. 131 (Unit 1) Amendment No. 113 (Unit 2)	7. Overpower ΔT	S	R(15)	M	N.A.	N.A.	1, 2
	8. Pressurizer Pressure--Low	S	R	M	N.A.	N.A.	1
	9. Pressurizer Pressure--High	S	R	M	N.A.	N.A.	1, 2
	10. Pressurizer Water Level--High	S	R	M	N.A.	N.A.	1
	11. Low Reactor Coolant Flow	S	R	M	N.A.	N.A.	1

TABLE 4.3-1 (Continued)

TABLE NOTATION

- (11) - The TRIP ACTUATING DEVICE OPERATIONAL TEST shall independently verify the OPERABILITY of the undervoltage and shunt trip circuits for the Manual Reactor Trip Function.
- (12) - The TRIP ACTUATING DEVICE OPERATIONAL TEST shall independently verify the OPERABILITY of the undervoltage and shunt trip attachments of the Reactor Trip Breakers.
- (13) - Prior to placing breaker in service, a local manual shunt trip shall be performed.
- (14) - The automative undervoltage trip capability shall be verified operable.
- (15) - Overtemperature setpoint, overpower setpoint, and  $T_{avg}$  channels require an 18 month channel calibration. Calibration of the  $\Delta T$  channels is required at the beginning of each cycle upon completion of the precision heat balance of Surveillance 4.2.3.5. RCS loop  $\Delta T$  values shall be determined by precision heat balance measurements at the beginning of each cycle in connection with Surveillance 4.2.3.5.