

Thomas J. Martin
Vice President
Engineering and Construction

Public Service Electric and Gas Company 80 Park Plaza Newark, N.J. 07101 201/430-8316

August 20, 1984

Dr. Thomas E. Murley, Administrator
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406


Dear Dr. Murley:

POTENTIAL CONSTRUCTION DEFICIENCY
SILICON CONTROLLED RECTIFIERS - EDG
HOPE CREEK GENERATING STATION

On May 3, 1984, a verbal report was made to Region I, Office of Inspection and Enforcement representative, Mr. E. C. McCabe, advising of a potentially significant construction deficiency regarding Silicon Controlled Rectifiers (SCR's) installed in our emergency diesel generator exciters. An interim report was sent to your office on June 1, 1984. The following information is provided in accordance with 10CFR50.55(e).

On June 26, 1984, Basler Electric representatives inspected the installed condition of the SCR's mounted in our diesel generator exciter panels and determined that they had been properly installed. We therefore withdraw this item as not reportable in accordance with 10CFR50.55(e).

Very truly yours,



SP-354
SQ-355

8409070149 840820
PDR ADOCK 05000354
S PDR

1/0 IE 27

C Office of Inspection and Enforcement
Division of Reactor Construction Inspection
Washington, D. C. 20555

NRC Resident Inspector - Hope Creek
P. O. Box 241
Hancocks Bridge, NJ 08038

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339