

MAY 12 1992

Docket No. STN 50-482  
License No. NPF-42

Wolf Creek Nuclear Operating Corporation  
ATTN: Bart D. Withers  
President and Chief Executive Officer  
P.O. Box 411  
Burlington, Kansas 66839

Gentlemen:

SUBJECT: CORRECTIVE ACTIONS

This is in response to your letter of April 8, 1992, that indicated your revised schedule for completing the corrective actions identified in Licensee Event Report 91-017-01. We have reviewed your revised schedule and find it to be acceptable. We will review the implementation of your corrective actions during a future inspection.

Sincerely,  
*Original Signed By:*  
A. B. BEACH

A. Bill Beach, Director  
Division of Reactor Projects

cc:  
Wolf Creek Nuclear Operating Corp.  
ATTN: Otto Maynard, Director  
Plant Operations  
P.O. Box 411  
Burlington, Kansas 66839

Shaw, Pittman, Potts & Trowbridge  
ATTN: Jay Silberg, Esq.  
1800 M Street, NW  
Washington, D.C. 20036

RIV:DRP/ [Signature]  
KKennedy, [Signature]  
5/12/92

C:DRP/ [Signature]  
ATHowe, [Signature]  
5/12/92

D:DRP [Signature]  
ABBeach  
5/12/92

1-EO/ [Signature]  
11/18

9205200017 920512  
PDR ADOCK 05000482  
G PDR

Wolf Creek Nuclear Operating  
Corporation

-2-

Public Service Commission  
ATTN: Chris R. Rogers, P.E.  
Manager, Electric Department  
P.O. Box 360  
Jefferson City, Missouri 65102

U.S. Nuclear Regulatory Commission  
ATTN: Regional Administrator, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Wolf Creek Nuclear Operating Corp.  
ATTN: Steven G. Wideman  
Supervisor Licensing  
P.O. Box 411  
Burlington, Kansas 66839

Kansas Corporation Commission  
ATTN: Robert Elliot, Chief Engineer  
Utilities Division  
1500 SW Arrowhead Rd.  
Topeka, Kansas 66604-402

Office of the Governor  
State of Kansas  
Topeka, Kansas 66612

Attorney General  
1st Floor - The Statehouse  
Topeka, Kansas 66612

Chairman, Coffey County Commission  
Coffey County Courthouse  
Burlington, Kansas 66839-1798

Kansas Department of Health  
and Environment  
Bureau of Air Quality & Radiation  
Control  
ATTN: Gerald Allen, Public  
Health Physicist  
Division of Environment  
Forbes Field Building 321  
Topeka, Kansas 66610

Kansas Department of Health and Environment  
ATTN: Robert Eye, General Counsel  
LSOB, 9th Floor  
900 SW Jackson  
Topeka, Kansas 66612

~~cc to DMS (1828)~~

Lcc distrib. by RIV:

R. D. Martin

Section Chief (DRP/D)

DRSS-RPEPS

RIV File

MIS System

Project Engineer (DRP/D)

DRS

Resident Inspector

DRP

Section Chief (RIII, DRP/3C)

CR1, Callaway, RIII

RSTS Operator

Lisa Shea, RM/ALF

# WOLF CREEK

NUCLEAR OPERATING CORPORATION

Bart D. Withers  
President and  
Chief Executive Officer

April 8, 1992

WM 92-0050

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D. C. 20555

Reference: 1) Letter WM 92-0002 dated January 6, 1992 from  
B. D. Withers, WCNOG, to R. D. Martin, NRC  
2) Letter NO 92-0010 dated January 13, 1992 from  
J. A. Bailey, WCNOG to the NRC  
Subject: Docket No. 50-482: Revised Schedule for Completion  
of Commitments

Gentlemen:

The purpose of this letter is to provide a revised schedule for the completion of actions committed to in the references. The revised schedule is primarily due to an unscheduled outage that began on February 19, 1992 and continued through March 27, 1992. The resources necessary to meet these commitments were required in support of the unscheduled outage. The extension of these commitments was discussed between Mr. S. G. Wideman, Supervisor Licensing and Mr. G. A. Pick, Senior Resident Inspector, NRC on March 30, 1992.

Reference 1 committed to review and implement enhancements to the operability determination process by March 31, 1992. Various Wolf Creek Nuclear Operating Corporation (WCNOG) disciplines have reviewed the available guidance on nonconforming conditions and operability and determined the need to enhance the entire process. Due to this expanded scope and the unscheduled outage, the effort will be completed by May 29, 1992.


Reference 2 transmitted a License Event Report 91-017-01 concerning a Fuel Building/Auxiliary Building pressure boundary door found open without a continuous watch having been established. As part of the corrective actions associated with this event, WCNOG committed to evaluate and implement any additional long-term programmatic enhancements by March 31, 1992. An administrative procedure has been drafted which provides the necessary controls for doors utilized to prevent a breach in a fire barrier, fire zone barrier, pressure boundary or security barrier. The reviews of the procedure are in process and will be completed by April 30, 1992.

WM 92-0050

Page 2

If you have any questions concerning this matter, please contact me or Mr. S. G. Wideman of my staff.

Very truly yours,



Bart D. Withers  
President and  
Chief Executive Officer

BDW/aem

cc: A. T. Howell (NRC)  
R. D. Martin (NRC)  
G. A. Pick (NRC)  
W. D. Reckley (NRC)