

UNITED STATES NUCLEAR REGULATORY COMMISSION

BALTIMORE GAS AND ELECTRIC COMPANY

DOCKET NOS. 50-317 AND 50-318

NOTICE OF WITHDRAWAL OF APPLICATION FOR

AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Baltimore Gas and Electric Company (BGE or the licensee) to withdraw its July 13, 1995, application for proposed amendments to Facility Operating License Nos. DPR-53 and DPR-69 for the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2, located in Lusby, Maryland.

The proposed amendment would have revised the Technical Specification 5.2.1, Fuel Assemblies, to allow the use of cladding materials other than Zircaloy or ZIRLO.

The Commission had previously issued a Notice of Consideration of Issuance of Amendments published in the FEDERAL REGISTER on August 30, 1995 (60 FR 45174). However, by letter dated December 21, 1995, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated July 13, 1995, and the licensee's letter dated December 21, 1995, which withdrew the application for the license amendments. The above documents are available for public inspection at the Commission's Public


9601230061 960117  
PDR ADOCK 05000317  
P PDR

9601230061

Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Calvert County Library, Prince Frederick, Maryland 20678.

Dated at Rockville, Maryland, this 17th day of January 1996.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel G. McDonald, Senior Project Manager  
Project Directorate  
Division of Reactor Projects -  
Office of Nuclear Reactor Regulation