

RCIC PUMP ROOM TEMPERATURE TRANSIENT
FOLLOWING STATION BLACKOUT

Commonwealth Edison Company
LaSalle Station Units 1&2
Project File No.: 35.2
System Code : SBO

NSLD
Calc. No. 3C7-0290-002
Date May 21, 1990
Safety Related YES
Project No(s). 8726-17
Page No. 1

CALCULATION
REVISION SUMMARY SHEET

ATD (Formerly NSLD)
Calc. No. 3C7-0290-002
Revision: 1
Page: 1
Date: May 12, 1992
Safety Related: Yes

Prepared by John J. Ely Date 5/11/92

Reviewed by Tarik Zabi Date 5.11.92

Approved by Ronald J. Peterson Date 5-12-92

RCIC PUMP ROOM TEMPERATURE TRANSIENT
FOLLOWING STATION BLACKOUT

Commonwealth Edison Company
LaSalle Station - Units 1 & 2
Project No. 8726-17
Project File No. 35.2
System Code: SBO
WIN 1218

Calc. No. 3C7-0290-002
Revision: 1
Page: 2
Project No. 8726-17

Table of Contents

| <u>Section</u> | <u>PAGE</u> |
|---|-------------|
| 1.0 Exception to Verified Data | 5 |
| 2.0 Purpose and Scope | 6 |
| 3.0 Computer Programs | 7 |
| 4.0 Method of Analysis | 8 |
| 5.0 Information and Assumptions | 9 |
| 6.0 Results and Discussion | 11 |
| 7.0 References | 12 |
| Tables | 14 |
| Figures | 17 |
| Review Method | 20 |
| Appendix A - Computer Input and Output Listings | A1-A21 |

Calc. No. 3C7-0290-002
Revision: 1
Page: 3
Project No. 8726-17

LIST OF TABLES

| <u>Table</u> | <u>Title</u> | <u>Page</u> |
|--------------|----------------------------|-------------|
| 1 | Node Parameters | 14 |
| 2 | Heat Structure Parameters | 15 |
| 3 | Heat Load in the RCIC Room | 16 |

Calc. No. 3C7-0290-002
Revision: 1
Page: 4
Project No. 8726-17

LIST OF FIGURES

| <u>Figure</u> | <u>Title</u> | <u>Page</u> |
|---------------|---|-------------|
| 1 | Reactor Building Basement Floor Elevation 673'-4" | 17 |
| 2 | Node - Heat Structure Model of the System Analyzed | 18 |
| 3 | RCIC Room (SBO) Temperature Transient | 19 |

Calc. No. 3C7-0290-002
Revision: 1
Page: 5
Project No. 8726-17

1.0 Exceptions to Verified Data

Information used in this calculation was obtained from HVACD and approved Calculations and is, therefore, considered to be verified data except as follows:

None

2.0 Purpose and Scope

In order to demonstrate compliance with 10 CFR 50 Section 50.63 requirements relative to Station Blackout (SBO), specific plant parameters have been examined for a 4-hour station blackout scenario. These parameters are directly related to plant capability of maintaining core cooling and appropriate containment integrity. This report examines the LaSalle Station Units 1&2 RCIC room temperature response to station blackout (SBO).

The purpose of this revision is to:

1. Adjust heat loads in the RCIC room.
2. Modify initial temperatures of all nodes.
3. Modify final temperatures of all nodes.

Calc. No. 3C7-0290-002
Revision: 1
Page: 7
Project No. 8726-17

3.0 Computer Programs

The heat transfer calculations reported herein were performed by using S&L Computer Program RATT (09.8.077-2.0I) and the resulting temperature plotted using another S&L Computer Program, PPP (09.8.099-1.3I). These programs are described in References 1 and 2, respectively. The documentation for these programs is maintained in the S&L Computer Software Library.

4.0 Information and Assumptions

The analytical model for this calculation consists of one dependent temperature node (1), four independent temperature nodes (2 through 5), and five heat structures. These elements are thermally connected as shown in Figure 2. A brief description of each node (summarized in Table 1) follows: 1) Node 1: the RCIC cubicle at elevation 673'-4" of the reactor building, shown in Figure 1; 2) Node 2: soil next to the east side wall of the RCIC room; 3) Node 3: the RHR heat exchanger room located at the north side of Node 1, shown in Figure 1; 4) Node 4" the equipment cubicles and containment annulus located at the west and southwest side of node 1 and off-gas filter building, shown in Figure 1; elevation 694'-6" of the reactor building.

The initial temperature of the subject room (node) was 124.0°F. The temperatures of nodes 2 through 5 were assumed to be constant throughout the transient event at the final temperature and are listed in Table 1. Table 2 identifies each of the five heat structures modeled, presents their physical dimensions, and the initial temperature and heat transfer coefficient for each Left Hand Face (LHF) and Right Hand Face (RHF). The heat load during the static blackout test to the RCIC turbine heat and other equipment is tabulated in Table 3.

5.0 Information and Assumptions

The S&L computer code RATT was used to model the physical system of interest. General assumptions relevant to RATT are discussed in detail in the users' manual for this code (Reference 1). Modeling assumptions used in this calculation are discussed below.

1. The entirety of the model used in this calculation was taken from Reference 4 with the exception of air node temperatures and the heat loads. In addition, the RCIC east wall is represented by two separate heat structures instead of one.
2. The temperatures of node 2 (soil temperature) and the wall surface facing it were assumed to be 52°F (Reference 5) and 67.2°F respectively (see below). The projected SBO temperatures of node 3 and node 5 were 129.2°F and 229.6°F, respectively (Reference 3), and the projected temperature of node 4 was taken to be 252.0°F (Reference 3).

The outer surface temperature for Wall #5 is calculated as follows:

$$Q'' = U \times (T_i - T_{soil}) = h \times (T_o - T_{soil})$$

where

$U = 0.2 \text{ Btu/Hr} \cdot \text{sq. ft-}^{\circ}\text{F}$ (overall heat transfer coefficient across the wall per Page B6 of Ref. 4)

$h = 0.95 \text{ Btu/hr-sq. ft-}^{\circ}\text{F}$ (Heat transfer coefficient for the wall outer surface per Page B7 of Ref. 4)

$T_i = 124.0^{\circ}\text{F}$ (Initial air temperature for the RCIC Pump room, Ref. 3)

$T_{soil} = 52^{\circ}\text{F}$ (Soil temperature, Ref. 5)

T_o = Outer surface temperature to be calculated.

q'' = Constant heat flux per unit area.

3. The boundary node 2 (soil node) was thermally insulated from the connected heat structure (no. 2) during the transient.
4. No HVAC systems are operating during the SBO transient. In addition, air flow was assumed to be negligible between the RCIC room and neighboring rooms.
5. The thermal properties of air within the subject room were assumed to be constant throughout the transient event.
6. Heat loss through the floor was neglected for conservatism.
7. The RCIC turbine was actuated immediately upon receiving the station blackout signal and kept at full load throughout the transient event.
8. The SBO heat loads for the RCIC room were obtained from Reference 7 and are given in Table 3. Since SBO heat loads are greater in the Unit 1 RCIC room and the Unit 2 RCIC room north wall is exposed to earth at 52°F rather than 123°F , as is the case in the Unit 1 RCIC room, the Unit 1 results present an upperbound temperature which is applicable to both units.

9. Per Reference 4, the height of the RCIC room is 18.83 feet, and per Reference 6, the length of the east wall is 46.3 feet. The 21.3 foot portion of this wall is exposed to the air in the off-gas filter building. Since this area is contained within node 4, the highest initial and final temperatures of all the rooms comprising node 4 were used for conservatism. Therefore, the initial air temperature of this adjacent area was assumed to be at 118.0°F per Reference 3. The 25 foot portion of the east wall is exposed to earth.
10. To be conservative, the nodes are stepped up to the final temperature at time zero.

6.0 Results and Discussion

Figure 3 shows the RCIC cubicle temperature profile following SBO. The room temperature was at 124.0°F prior to the station blackout and reached 153.7°F in 30 min. Subsequently, the room temperature rose at a slower rate and reached 164.7°F at 4 hours after the transient started. S&L computer program PPP (Reference 2) was used to plot the results.

Two items to note are:

- a) The RCIC turbine pump was assumed to be manually initiated immediately after the station blackout to obtain a conservative room temperature transient profile. However, it should be noted that there is a certain time delay between the station blackout and the initiation of the RCIC system.
- b) Single active failures were not postulated in this analysis.

7.0 References

1. User's Manual for RATT (S&L Program No. 09.8.077-2.01), "Room Air Temperature Transient." This computer code is stored in the S&L Computer Software Library.
2. S&L Program PPP, No. 09.8.099-1.3I, "Post Processing Program". This computer code is stored in the S&L Computer Software Library.
3. "Temperature in the area adjacent to the Control Room and AEER for SBO," DIT LS-HVAC-0033-04, May 11, 1992.
4. "Station Blackout: RCIC Room Temperature Transient Study," LaSalle Station NSLD Calc. No. 3C7-1082-003, Rev. 0, approved February 7, 1983.
5. "Research Report on Methods for Disposing of Excess Shelter Heat," John D. Hummell, et al, Battelle Memorial Institute, August 1964, Contract No. OCD-OS-62-191, Subtask 1422A.
6. S&L Drawing A-217, Rev. R
7. "Heat Generated from Electrical Equipment & Cables in RCIC Room (Units 1 & 2) During a SBO," DIT LS-EPED-0091, March 6, 1990.

Calc. No. 3C7-0290-002
Revision: 1
Page: 14
Project No. 8726-17

TABLE 1. NODE PARAMETERS

| Node Number | Description | Volume ft ³ | Temperature (°F) | |
|-------------|--|------------------------|------------------|------------|
| | | | Initial | Final |
| 1 | RCIC Cubicle | 19,000 | 124.0 | Calculated |
| 2 | Soil next to the RCIC eastside wall | -- | 52.0 | 52.0 |
| 3 | Northside neighboring room of node 1 (unit 2 RHR Hx Room) | -- | 123.0 | 129.2 |
| 4 | Westside neighboring rooms of node 1 (containment annulus & equipment cubicle) & off-gas filter building | -- | 118.0 | 252.0 |
| 5 | Equipment room above the RCIC cubicle | -- | 114.0 | 229.6 |

Calc. No. 3C7-0290-002
Revision: 1
Page: 15
Project No. 8726-17

TABLE 2, HEAT STRUCTURE PARAMETERS

| Heat Structure No. | Description | Area (sq. ft.) | Thickness (ft) | Nodes Connected | | LHF Heat Transfer Coefficient (BTU/sq. ft./F/hr) | RHF Heat Transfer Coefficient (BTU/sq. ft.F/hr) |
|--------------------|--|----------------|----------------|-----------------|-----|--|---|
| | | | | LHF | RHF | | |
| 1 | RCIC Cubicle Ceiling | 1190. | 2.33 | 1 | 5 | 1.63 | Natural Convection |
| 2 | RCIC eastside wall (portion exposed to soil) | 470. | 3.00 | 1 | 2 | Natural Convection | Insulated Boundary Condition |
| 3 | RCIC Cubicle northside wall | 725. | 3.00 | 1 | 3 | Natural Convection | Natural Convection |
| 4 | RCIC Cubicle westside wall | 1110. | 2.00 | 1 | 4 | Natural Convection | Natural Convection |
| 5 | RCIC eastside wall (portion exposed to the off-gas filter building) | 401. | 3.00 | 1 | 5 | Natural Convection | Natural Convection |

Note: LHF = Left Hand Face, RHF = Right Hand Face

Calc. No. 3C7-0290-002
Revision: 1
Page: 16
Project No. 8726-17

TABLE 3

T LOAD IN THE RCIC ROOM

| <u>Source</u> | <u>Condition</u> | <u>Heat Load (Btu/h)</u> | <u>Reference</u> |
|---------------|--------------------|--------------------------|------------------|
| Mechanical | 0-4 Hours | 70,000 | 3 |
| Electrical | 0-1 Minute | 106,247 | 7 |
| | 1 Minute - 4 Hours | 29,284 | 7 |

HEAT LOAD (Btu/hr)

| | |
|--|---------|
| Total load for the first minute | 176,247 |
| Total load after the first minute up to 4.0 hours | 99,284 |

Calc. No. 3C7-0290-002
Revision: 1
Page: 18
Project No. 8726-17




FIGURE 2: Node-Heat Structures Model
of the System Analyzed




FIGURE 3 : RCIC ROOM (SBO) TRANSIENT LIMITATION

Calc. No. 3C7-C290-002
Revision: 1
Page: 19
Project No. 8726-17

REVIEW METHOD SHEET

Calc. No. 3C7-0290-002
 Revision: 1
 Page: 20/20
 Project No. 8726-17

This calculation has been reviewed by me according to the method(s) checked below.

1. Computer Aided Calculations

| | |
|-----|---|
| a | Review to determine that the computer program(s) has been validated and documented, is suitable to the problem being analyzed and that the calculation contains all necessary information for reconstruction at a later date. |
| b | Review to determine that the input data as specified for program execution is consistent with the design input, correctly defines the problem for the computer algorithm and is sufficiently accurate to produce results within any numerical limitations of the program. |
| c ✓ | Review to verify that the results obtained from the program are correct and within stated assumptions and limitations of the program and are consistent with the input. |
| d | Review validation documentation for temporary changes to listed, or developmental, or unique single application programs, to assure that methods used adequately validate the program for the intended application. |
| e ✓ | Review of code input only, since the computer program has sufficient history of use at Sargent & Lundy in similar calculations. |
| f ✓ | Review arithmetic necessary to prepare code input data. |
| g | Other: _____ |

2. Hand Prepared Design Calculations

| | |
|---|---|
| a | Detailed review of the original calculations. |
| b | Review by an alternate, simplified, or approximate method of calculation. |
| c | Review of a representative sample of repetitive calculations. |
| d | Review of the calculation against a similar calculation previously performed. |

3. Revisions

| | |
|-----|---|
| a ✓ | Editorial changes only. |
| b | Elimination of unapproved input data without altering calculated results. |
| c | Other: _____ |

4. Other

| | |
|--|--|
| | |
|--|--|

Reviewer: *Tank Loh*

Date 5-11-92

Calc. No. 3C7-0290-002
Revision: 1
Page: A1
Project No. 8726-17

APPENDIX A1
COMPUTER INPUT AND OUTPUT LISTINGS

SARGENT & LUNDY / Engineers

Nuclear Safeguards & Licensing Division

Computer Output for

Safeguards Systems Section

PART 1

| | | | | |
|--------|---------------------------------|--------------|--------------|-------|
| **** | Program | RATO98077201 | | |
| * +0 * | | | | |
| * 0+ * | | | | |
| **** | | | | |
| | CECo LASALLE STATION UNITS 1&2 | | Calc No | Rev |
| | RCIC ROOM TEMP. TRANSIENT STUDY | | | |
| | DURING SBO, 0 TO 6 HOURS | | 3C7-0290-002 | + |
| | | | | |
| | [XX] SAFETY-RELATED | | Date | Time |
| | [XX] | | 12 MAY 92 | 11:31 |
| | | | | |

| | | | | |
|-----------|-----------------------------|-------------|---------------------------|------|
| Client | COMMONWEALTH EDISON COMPANY | Prepared by | <i>Laura J. Blakely</i> | Date |
| Project | LASALLE 1&2 | Reviewed by | <i>Tank Zai</i> | Date |
| Proj. No. | 8726-17 | Approved by | <i>Robert J. Peterson</i> | Date |

5-12-92

Calc. No. 3C7-0290-002
 Revision: 1
 Page: A2
 Project No. 8726-17

Sym File TXY-LAS-SBO-SYM(15)

RUN ID T.S. 01JB

TOC Entry In Temp File TOC

Calc. No. 3C7-0290-002
Revision: 1
Page: A3
Project No. 8726-17

S&L

3C7-0290-002

PART 1

PROJECT 8726-17

REV 1

TAB

DATE 051292

SPRT. 5 RUN TXY-LAS-SBO+RCIC-RUP'RAT1
FURPUR 29R2E-O1 (880511 1229:45) 1992 May 12 Tue 1131:27

SARGE LUNDY

Calc. No. 3C7-0290-002
Revision: 1
Page: A5
Project No. 8726-17

DATE 05/24/92

PART 1

PROJECT 8726-17

S&L NSL0 CALC 3C7-C290-002 REV 1

*DELETE,C,TXY-LAS-SBO+RCIC-PLOT1.

*ASG,UP TXY-LAS-SBO+RCIC-PLOT1.
1:002333 ASG complete.

*REF 12.
W 120433 filename not known to this run.

*USE 12.,TXY-LAS-SBO+RCIC-PLOT1.
1:002333 USE complete.

*XOT OPS\$,098ABSOLUTES.RAT098077201

S&L NSLD CALC 3C7-0290-002 REV 1 PROJECT 8726-17 FART 1 TJB DATE 051292 PARA 1

LA5901226•TPF\$1G1 RUN(24)

1 *OPSS\$•098ABSOLUTES.PPP098099131/LOGO SYM,TOC
 2 RAT09807720I
 3 CECO LASALLE STATION UNITS 1&2
 4 RCIC ROOM TEMP. TRANSIENT STUDY
 5 DURING SBO, 0 TO 6 HOURS
 6
 7 3C7-0290-002 1
 8 PART 1
 9 COMMONWEALTH EDISON COMPANY
 10 LASALLE 1&2
 11 8726-17
 12 *PRT,S, RUN TXY-LAS-SBO+RCIC,RUNRAT1
 13 *DELETE,C TXY-LAS-SBO+RCIC-PLOT1
 14 *ASG UP TXY-LAS-SBO+RCIC-PLOT1
 15 *FREE 12.
 16 *USE 12.,TXY-LAS-SBO+RCIC-PLOT1
 17 *XQT OPSS\$•098ABSOLUTES.RAT09807720I
 18 STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT
 19 \$DATA
 20 NW=5,
 21 AW=1190.,470.,725.,1110.,401.,
 22 XW=2.33,3.,3.,2.,3.,
 23 KW=5•0.92,
 24 CW=5•0.156,
 25 DW=5 145.,
 26 NX=5 6,6,4,6,
 27 HE(1,:)=-1.63,-1,-1,-1,-1,
 28 IAW(1,1)=1,1,1,1,1,
 29 HE(1,2)=-1.0.,-1,-1,-1,
 30 IAW(1,2)=5,2,3,4,4,
 31 NA=5
 32 ITA(1)=-1,0,1,2,3,
 33 TAI(1)=124.,67.2,123.0,118.,124.,
 34 DA(1)=0.068,
 35 VA(1)=19000.,
 36 CV(1)=0.171,
 37 CP(1)=0.24,
 38 Q(1)=1.,
 39 ITQ(1)=1,
 40 NIT=4,
 41 NTT=7,
 42 TIN=0.,
 43 TMAX=6.,
 44 DT=0.005,
 45 DTF=0.05,
 46 DTO=0.05,
 47 CRITER=T,
 48 STEADY=T,
 49 RFILE=12,
 50 TIME=0.0, 0.0001, 0.0167, 0.0168, 1.7, 1.7001, 6.0,
 51 CT=176247., 176247., 176247., 99284., 99284., 99284., 99284.,
 52 TEMP=123., 129.2, 129.2, 129.2, 129.2, 129.2, 129.2, 129.2,
 53 118., 252., 252., 252., 252., 252., 252., 252.,
 54 124., 229.6, 229.6, 229.6, 229.6, 229.6, 229.6, 229.6, 229.6
 55 \$END
 56 *EOF

Calc. No. 3C7-0290-002
 Revision: 1
 Page: A4
 Project No. 8726-17

S&L No.: JALC 3C7-0290 002 REV 1 PROJECT 8726-17
STATION BLACKOUT RCTC ROOM TEMPERATURE TRANSIENT

PART 1 JOB DATE 05/17/87

FINITE INCREMENT LIMITS FOR STABILITY (* VIOLATED BY SPEC):

| IW | IA | SPEC DX | MAX DT | SPEC DT | MIN DX | M | N |
|----|----|---------|--------|----------|----------|-------|------|
| 1 | 1 | 4660 | 2.670 | 5000-002 | 2017-001 | 1068 | 8256 |
| | 1 | | 1.462 | | 2053-001 | | 5065 |
| | 5 | | 1.772 | | 2039-001 | | |
| 2 | 1 | 5000 | 2.073 | 5000-002 | 2017-001 | 1229. | 5435 |
| | 1 | | 1.991 | | 2039-001 | | 0000 |
| | 2 | | 3.073 | | 2017-001 | | |
| 3 | 1 | 5000 | 3.073 | 5000-002 | 2017-001 | 1229. | 5435 |
| | 1 | | 1.991 | | 2039-001 | | |
| | 3 | | 1.991 | | 2039-001 | | |
| 4 | 1 | 5000 | 3.073 | 5000-002 | 2C17-001 | 1229. | 5435 |
| | 1 | | 1.991 | | 2039-001 | | |
| | 4 | | 1.991 | | 2039-001 | | |
| 5 | 1 | 5000 | 3.073 | 5000-002 | 2017-001 | 1229. | 5435 |
| | 1 | | 1.991 | | 2039-001 | | |
| | 4 | | 1.991 | | 2039-001 | | |

TEMPERATURE TRANSIENT:

| t | (IA1) | TA | TW | (IW) | TW | TA | (IA2) | QW(IW,1) | QW(IW,2) | QW(IW,3) | QW(IW,4) |
|-----|-------|--------|--------|-------|--------|--------|-------|-----------|------------|-----------|----------|
| 000 | { 1 } | 124.00 | 124.00 | { 1 } | 124.00 | 124.00 | { 5 } | .000 | .000 | 1.762+005 | 000 |
| 000 | { 1 } | 124.00 | 99.05 | { 2 } | 67.20 | 67.20 | { 2 } | 4.591+003 | .000 | 1.762+005 | 000 |
| 000 | { 1 } | 124.00 | 123.57 | { 3 } | 123.45 | 123.00 | { 3 } | 2.973+001 | 2.973+001 | 1.762+005 | 000 |
| 000 | { 1 } | 124.00 | 121.50 | { 4 } | 120.49 | 118.00 | { 4 } | 5.160+002 | 5.160+002 | 1.762+005 | 000 |
| 000 | { 1 } | 124.00 | 121.65 | { 5 } | 120.33 | 118.00 | { 4 } | 1.620+002 | 1.620+002 | 1.762+005 | 000 |
| 050 | { 1 } | 141.79 | 124.24 | { 1 } | 124.68 | 229.60 | { 5 } | 3.405+004 | -3.935+004 | 9.928+004 | 000 |
| 050 | { 1 } | 141.79 | 99.17 | { 2 } | 67.31 | 67.20 | { 2 } | 1.135+004 | .000 | 9.928+004 | 000 |
| 050 | { 1 } | 141.79 | 123.62 | { 3 } | 123.45 | 129.20 | { 3 } | 5.540+003 | -1.224+003 | 9.928+004 | 000 |
| 050 | { 1 } | 141.79 | 121.56 | { 4 } | 121.41 | 252.00 | { 4 } | 9.809+003 | -1.085+005 | 9.928+004 | 000 |
| 050 | { 1 } | 141.79 | 121.71 | { 5 } | 121.26 | 252.00 | { 4 } | 3.507+003 | -3.975+004 | 9.928+004 | 000 |
| 100 | { 1 } | 147.26 | 124.65 | { 1 } | 125.59 | 229.60 | { 5 } | 4.386+004 | -8.829+004 | 9.928+004 | 000 |
| 100 | { 1 } | 147.26 | 99.36 | { 2 } | 67.42 | 67.20 | { 2 } | 1.326+004 | .000 | 9.928+004 | 000 |
| 100 | { 1 } | 147.26 | 123.73 | { 3 } | 123.47 | 129.20 | { 3 } | 7.059+003 | -1.218+003 | 9.928+004 | 000 |
| 100 | { 1 } | 147.26 | 121.68 | { 4 } | 122.54 | 252.00 | { 4 } | 1.146+004 | -1.085+005 | 9.928+004 | 000 |
| 100 | { 1 } | 147.26 | 121.83 | { 5 } | 122.39 | 252.00 | { 4 } | 1.825+003 | -3.928+004 | 9.928+004 | 000 |
| 150 | { 1 } | 149.80 | 125.11 | { 1 } | 126.47 | 229.60 | { 5 } | 4.769+004 | -8.728+004 | 9.928+004 | 000 |
| 150 | { 1 } | 149.80 | 99.58 | { 2 } | 67.53 | 67.20 | { 2 } | 1.411+004 | .000 | 9.928+004 | 000 |
| 150 | { 1 } | 149.80 | 123.86 | { 3 } | 123.49 | 129.20 | { 3 } | 8.958+003 | -1.213+003 | 9.928+004 | 000 |
| 150 | { 1 } | 149.80 | 121.82 | { 4 } | 123.63 | 252.00 | { 4 } | 1.518+004 | -1.073+005 | 9.928+004 | 000 |
| 150 | { 1 } | 149.80 | 121.97 | { 5 } | 123.48 | 252.00 | { 4 } | 5.445+003 | -3.683+004 | 9.928+004 | 000 |

Calc. No. 3C7-0290-002
Revision: 1
Page: A6
Project No. 8726-17

SARGENT LUNDY

S&L NSLD CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART I TJB DATE 0512'62 FILE

STATION BLACKOUT RCIC ROOM TEMPERATURE TRANSIENT

| T | (TA1) | TA | TW | (TW) | TW | TA | (TA2) | OW(TW,1) | OW(TW,2) | QAT(A1) | QAT(A2) |
|-----|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|---------|
| 200 | (1) | 151.08 | 125.59 | (1) | 127.31 | 229.60 | (5) | 4.942+004 | -8.631+004 | 9.928+004 | 000 |
| 200 | (1) | 151.08 | 99.81 | (2) | 67.64 | 67.20 | (2) | 1.450+004 | .000 | 9.928+004 | 000 |
| 200 | (1) | 151.08 | 124.00 | (3) | 123.51 | 129.20 | (3) | 9.485+003 | -1.208+003 | 9.928+004 | 000 |
| 200 | (1) | 151.08 | 121.97 | (4) | 121.68 | 252.00 | (4) | 1.600+004 | -1.061+005 | 9.928+004 | 000 |
| 200 | (1) | 151.08 | 122.12 | (5) | 124.53 | 252.00 | (4) | 5.741+003 | -3.839+004 | 9.928+004 | 000 |
| 250 | (1) | 151.81 | 126.07 | (1) | 128.12 | 229.60 | (5) | 4.993+004 | -8.538+004 | 9.928+004 | 000 |
| 250 | (1) | 151.81 | 100.04 | (2) | 67.74 | 67.20 | (2) | 1.468+004 | .000 | 9.928+004 | 000 |
| 250 | (1) | 151.81 | 124.15 | (3) | 123.53 | 129.20 | (3) | 9.760+003 | -1.203+003 | 9.928+004 | 000 |
| 250 | (1) | 151.81 | 122.12 | (4) | 125.69 | 252.00 | (4) | 1.643+004 | -1.049+005 | 9.928+004 | 000 |
| 250 | (1) | 151.81 | 122.28 | (5) | 125.55 | 252.00 | (4) | 5.894+003 | -3.797+004 | 9.928+004 | 000 |
| 300 | (1) | 152.31 | 126.54 | (1) | 128.90 | 229.60 | (5) | 4.999+004 | -8.449+004 | 9.928+004 | 000 |
| 300 | (1) | 152.31 | 100.27 | (2) | 67.84 | 67.20 | (2) | 1.478+004 | .000 | 9.928+004 | 000 |
| 300 | (1) | 152.31 | 124.29 | (3) | 123.54 | 129.20 | (3) | 9.826+003 | -1.198+003 | 9.928+004 | 000 |
| 300 | (1) | 152.31 | 122.28 | (4) | 126.67 | 252.00 | (4) | 1.668+004 | -1.038+005 | 9.928+004 | 000 |
| 300 | (1) | 152.31 | 122.43 | (5) | 126.52 | 252.00 | (4) | 5.984+003 | -3.757+004 | 9.928+004 | 000 |
| 350 | (1) | 152.71 | 127.00 | (1) | 129.65 | 229.60 | (5) | 4.988+004 | -8.364+004 | 9.928+004 | 000 |
| 350 | (1) | 152.71 | 100.49 | (2) | 67.94 | 67.20 | (2) | 1.484+004 | .000 | 9.928+004 | 000 |
| 350 | (1) | 152.71 | 124.43 | (3) | 123.56 | 129.20 | (3) | 1.004+004 | -1.193+003 | 9.928+004 | 000 |
| 350 | (1) | 152.71 | 122.43 | (4) | 127.62 | 252.00 | (4) | 1.585+004 | -1.028+005 | 9.928+004 | 000 |
| 350 | (1) | 152.71 | 122.58 | (5) | 127.47 | 252.00 | (4) | 6.048+003 | -3.719+004 | 9.928+004 | 000 |
| 400 | (1) | 153.06 | 127.44 | (1) | 130.37 | 229.60 | (5) | 4.969+004 | -8.282+004 | 9.928+004 | 000 |
| 400 | (1) | 153.06 | 100.71 | (2) | 68.04 | 67.20 | (2) | 1.488+004 | .000 | 9.928+004 | 000 |
| 400 | (1) | 153.06 | 124.57 | (3) | 123.56 | 129.20 | (3) | 1.014+004 | -1.188+003 | 9.928+004 | 000 |
| 400 | (1) | 153.06 | 122.58 | (4) | 128.53 | 252.00 | (4) | 1.700+004 | -1.017+005 | 9.928+004 | 000 |
| 400 | (1) | 153.06 | 122.73 | (5) | 128.38 | 252.00 | (4) | 6.100+003 | -3.681+004 | 9.928+004 | 000 |
| 450 | (1) | 153.38 | 127.87 | (1) | 131.07 | 229.60 | (5) | 4.949+004 | -8.203+004 | 9.928+004 | 000 |
| 450 | (1) | 153.38 | 100.93 | (2) | 68.13 | 67.20 | (2) | 1.492+004 | .000 | 9.928+004 | 000 |
| 450 | (1) | 153.38 | 124.71 | (3) | 123.59 | 129.20 | (3) | 1.022+004 | -1.184+003 | 9.928+004 | 000 |
| 450 | (1) | 153.38 | 122.73 | (4) | 129.41 | 252.00 | (4) | 1.712+004 | -1.008+005 | 9.928+004 | 000 |
| 450 | (1) | 153.38 | 122.88 | (5) | 129.27 | 252.00 | (4) | 6.145+003 | -3.646+004 | 9.928+004 | 000 |
| 500 | (1) | 153.69 | 128.28 | (1) | 131.74 | 229.60 | (5) | 4.928+004 | -8.127+004 | 9.928+004 | 000 |
| 500 | (1) | 153.69 | 101.14 | (2) | 68.23 | 67.20 | (2) | 1.495+004 | .000 | 9.928+004 | 000 |
| 500 | (1) | 153.69 | 124.85 | (3) | 123.61 | 129.20 | (3) | 1.030+004 | -1.179+003 | 9.928+004 | 000 |
| 500 | (1) | 153.69 | 122.88 | (4) | 130.26 | 252.00 | (4) | 1.724+004 | -9.980+004 | 9.928+004 | 000 |
| 500 | (1) | 153.69 | 123.02 | (5) | 130.12 | 252.00 | (4) | 6.166+003 | -3.611+004 | 9.928+004 | 000 |
| 550 | (1) | 153.98 | 128.68 | (1) | 132.38 | 229.60 | (5) | 4.907+004 | -8.054+004 | 9.928+004 | 000 |
| 550 | (1) | 153.98 | 101.35 | (2) | 68.32 | 67.20 | (2) | 1.498+004 | .000 | 9.928+004 | 000 |
| 550 | (1) | 153.98 | 124.99 | (3) | 123.63 | 129.20 | (3) | 1.037+004 | -1.175+003 | 9.928+004 | 000 |
| 550 | (1) | 153.98 | 123.02 | (4) | 121.08 | 252.00 | (4) | 1.735+004 | -9.887+004 | 9.928+004 | 000 |
| 550 | (1) | 153.98 | 123.17 | (5) | 130.94 | 252.00 | (4) | 6.226+003 | -3.578+004 | 9.928+004 | 000 |

Calc. No. 3C7-0290-002
Revision: 1
Page: A7
Project No. 8726-17

S&L No.:J CALC 3C7-0290-C02 REV 1 PROJECT 8726-17

STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT

DATE 05-12-92

| R | (1A1) | TA | TW | (1W) | TA | TW | (1A2) | QW(1W,1) | QW(1W,2) | QW(1A1) | QW(1A2) |
|-----|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|---------|
| 600 | (1) | 154.27 | 129.08 | (1) | 133.00 | 229.60 | (5) | 4.887+004 | -7.984+004 | 9.528+004 | .000 |
| 600 | (1) | 154.27 | 101.56 | (2) | 68.40 | 67.20 | (2) | 1.501+004 | .000 | 9.928+004 | .000 |
| 600 | (1) | *54.27 | 125.12 | (3) | 123.64 | 129.20 | (3) | 1.044+004 | -1.171+003 | 9.928+004 | .000 |
| 600 | (1) | 154.27 | 123.16 | (4) | 131.88 | 252.00 | (4) | 1.745+004 | -9.799+004 | 9.928+004 | .000 |
| 600 | (1) | 154.27 | 123.31 | (5) | 131.74 | 252.00 | (4) | 6.263+003 | -3.546+004 | 9.928+004 | .000 |
| 650 | (1) | 154.55 | 129.45 | (1) | 123.60 | 229.60 | (5) | 4.867+004 | -7.917+004 | 9.928+004 | .000 |
| 650 | (1) | 154.55 | 101.76 | (2) | 63.49 | 67.20 | (2) | 1.503+004 | .000 | 9.928+004 | .000 |
| 650 | (1) | 154.55 | 125.25 | (3) | 123.65 | 129.20 | (3) | 1.051+004 | -1.166+003 | 9.928+004 | .000 |
| 650 | (1) | 154.55 | 123.30 | (4) | 132.65 | 252.00 | (4) | 1.755+004 | -9.713+004 | 9.928+004 | .000 |
| 650 | (1) | 154.55 | 123.45 | (5) | 132.51 | 252.00 | (4) | 6.299+003 | -3.515+004 | 9.928+004 | .000 |
| 700 | (1) | 154.82 | 129.82 | (1) | 134.18 | 229.60 | (5) | 4.849+004 | -7.852+004 | 9.928+004 | .000 |
| 700 | (1) | 154.82 | 101.95 | (2) | 68.57 | 67.20 | (2) | 1.506+004 | .000 | 9.928+004 | .000 |
| 700 | (1) | 154.82 | 125.38 | (3) | 123.67 | 129.20 | (3) | 1.058+004 | -1.163+003 | 9.928+004 | .000 |
| 700 | (1) | 154.82 | 123.44 | (4) | 133.40 | 252.00 | (4) | 1.764+004 | -9.620+004 | 9.928+004 | .000 |
| 700 | (1) | 154.82 | 123.59 | (5) | 133.25 | 252.00 | (4) | 6.334+003 | -3.485+004 | 9.928+004 | .000 |
| 750 | (1) | 155.08 | 130.18 | (1) | 134.74 | 229.60 | (5) | 4.831+004 | -7.790+004 | 9.928+004 | .000 |
| 750 | (1) | 155.08 | 102.15 | (2) | 68.66 | 67.20 | (2) | 1.508+004 | .000 | 9.928+004 | .000 |
| 750 | (1) | 155.08 | 125.51 | (3) | 123.68 | 129.20 | (3) | 1.064+004 | -1.159+003 | 9.928+004 | .000 |
| 750 | (1) | 155.08 | 123.58 | (4) | 134.12 | 252.00 | (4) | 1.774+004 | -9.550+004 | 9.928+004 | .000 |
| 750 | (1) | 155.08 | 123.72 | (5) | 133.98 | 252.00 | (4) | 6.367+003 | -3.456+004 | 9.928+004 | .000 |
| 800 | (1) | 155.34 | 130.53 | (1) | 135.28 | 229.60 | (5) | 4.813+004 | -7.729+004 | 9.928+004 | .000 |
| 800 | (1) | 155.34 | 102.34 | (2) | 68.74 | 67.20 | (2) | 1.510+004 | .000 | 9.928+004 | .000 |
| 800 | (1) | 155.34 | 125.64 | (3) | 123.70 | 129.20 | (3) | 1.070+004 | -1.155+003 | 9.928+004 | .000 |
| 800 | (1) | 155.34 | 123.71 | (4) | 134.81 | 252.00 | (4) | 1.783+004 | -9.473+004 | 9.928+004 | .000 |
| 800 | (1) | 155.34 | 123.86 | (5) | 134.67 | 252.00 | (4) | 6.399+003 | -3.428+004 | 9.928+004 | .000 |
| 850 | (1) | 155.59 | 130.87 | (1) | 135.80 | 229.60 | (5) | 4.797+004 | -7.671+004 | 9.928+004 | .000 |
| 850 | (1) | 155.59 | 102.53 | (2) | 68.82 | 67.20 | (2) | 1.512+004 | .000 | 9.928+004 | .000 |
| 850 | (1) | 155.59 | 125.77 | (3) | 123.71 | 129.20 | (3) | 1.076+004 | -1.151+003 | 9.928+004 | .000 |
| 850 | (1) | 155.59 | 123.84 | (4) | 135.49 | 252.00 | (4) | 1.794+004 | -9.399+004 | 9.928+004 | .000 |
| 850 | (1) | 155.59 | 123.99 | (5) | 135.35 | 252.00 | (4) | 6.430+003 | -3.401+004 | 9.928+004 | .000 |
| 900 | (1) | 155.84 | 131.19 | (1) | 136.31 | 229.60 | (5) | 4.780+004 | -7.616+004 | 9.928+004 | .000 |
| 900 | (1) | 155.84 | 102.71 | (2) | 68.90 | 67.20 | (2) | 1.514+004 | .000 | 9.928+004 | .000 |
| 900 | (1) | 155.84 | 125.89 | (3) | 123.72 | 129.20 | (3) | 1.081+004 | -1.148+003 | 9.928+004 | .000 |
| 900 | (1) | 155.84 | 123.97 | (4) | 136.14 | 252.00 | (4) | 1.799+004 | -9.327+004 | 9.928+004 | .000 |
| 900 | (1) | 155.84 | 124.12 | (5) | 136.01 | 252.00 | (4) | 6.460+003 | -3.375+004 | 9.928+004 | .000 |
| 950 | (1) | 156.08 | 131.51 | (1) | 136.79 | 229.60 | (5) | 4.765+004 | -7.562+004 | 9.928+004 | .000 |
| 950 | (1) | 156.08 | 102.89 | (2) | 68.97 | 67.20 | (2) | 1.516+004 | .000 | 9.928+004 | .000 |
| 950 | (1) | 156.08 | 126.01 | (3) | 123.73 | 129.20 | (3) | 1.087+004 | -1.144+003 | 9.928+004 | .000 |
| 950 | (1) | 156.08 | 124.10 | (4) | 136.78 | 252.00 | (4) | 1.807+004 | -9.257+004 | 9.928+004 | .000 |
| 950 | (1) | 156.08 | 124.25 | (5) | 136.64 | 252.00 | (4) | 6.489+003 | -3.350+004 | 9.928+004 | .000 |

Calc. No. 3C7-0290-002
 Revision: 1
 Page: A8
 Project No. 8726-17

S&L NSLD CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART 1 TJB DATE 051292 PAGE

STATION BLACKOUT RCIC ROOM TEMPERATURE TRANSIENT

| t | (IA1) | TA | TW | (IW) | TW | TA | (IA2) | QWE(IW,1) | QWE(IW,2) | QAE(IA1) | QAE(IA2) |
|-------|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|----------|
| 1.000 | (1) | 156.31 | 131.82 | (1) | 137.26 | 229.60 | (5) | 4.771+004 | -7.510+004 | 9.928+004 | 000 |
| 1.000 | (1) | 156.31 | 103.07 | (2) | 69.05 | 67.20 | (2) | 1.304 | .000 | 9.928+004 | 000 |
| 1.000 | (1) | 156.31 | 126.15 | (3) | 123.75 | 129.20 | (3) | 1.412+004 | -1.141+003 | 9.928+004 | 000 |
| 1.000 | (1) | 156.31 | 124.23 | (4) | 137.39 | 252.00 | (4) | 1.815+004 | -9.190+004 | 9.928+004 | 000 |
| 1.000 | (1) | 156.31 | 124.38 | (5) | 137.26 | 252.00 | (4) | 6.516+003 | -3.325+004 | 9.928+004 | 000 |
| 1.050 | (1) | 156.54 | 132.12 | (1) | 137.72 | 229.60 | (5) | 4.736+004 | -7.459+004 | 9.928+004 | 000 |
| 1.050 | (1) | 156.54 | 103.24 | (2) | 69.12 | 67.20 | (2) | 1.520+004 | .000 | 9.928+004 | 000 |
| 1.050 | (1) | 156.54 | 126.25 | (3) | 123.76 | 129.20 | (3) | 1.097+004 | -1.137+003 | 9.928+004 | 000 |
| 1.050 | (1) | 156.54 | 124.35 | (4) | 137.99 | 252.00 | (4) | 1.822+004 | -9.125+004 | 9.928+004 | 000 |
| 1.050 | (1) | 156.54 | 124.50 | (5) | 137.85 | 252.00 | (4) | 6.543+003 | -3.302+004 | 9.928+004 | 000 |
| 1.100 | (1) | 156.76 | 132.42 | (1) | 138.16 | 229.60 | (5) | 4.722+004 | -7.411+004 | 9.928+004 | 000 |
| 1.100 | (1) | 156.76 | 103.41 | (2) | 69.19 | 67.20 | (2) | 1.521+004 | .000 | 9.928+004 | 000 |
| 1.100 | (1) | 156.76 | 126.37 | (3) | 123.77 | 129.20 | (3) | 1.102+004 | -1.134+003 | 9.928+004 | 000 |
| 1.100 | (1) | 156.76 | 124.48 | (4) | 138.57 | 252.00 | (4) | 1.829+004 | -9.061+004 | 9.928+004 | 000 |
| 1.100 | (1) | 156.76 | 124.62 | (5) | 138.43 | 252.00 | (4) | 6.569+003 | -3.279+004 | 9.928+004 | 000 |
| 1.150 | (1) | 156.98 | 132.71 | (1) | 138.59 | 229.60 | (5) | 4.708+004 | -7.364+004 | 9.928+004 | 000 |
| 1.150 | (1) | 156.98 | 103.58 | (2) | 69.26 | 67.20 | (2) | 1.523+004 | .000 | 9.928+004 | 000 |
| 1.150 | (1) | 156.98 | 126.48 | (3) | 123.78 | 129.20 | (3) | 1.107+004 | -1.131+003 | 9.928+004 | 000 |
| 1.150 | (1) | 156.98 | 124.60 | (4) | 139.13 | 252.00 | (4) | 1.836+004 | -9.000+004 | 9.928+004 | 000 |
| 1.150 | (1) | 156.98 | 124.74 | (5) | 138.99 | 252.00 | (4) | 6.594+003 | -3.257+004 | 9.928+004 | 000 |
| 1.200 | (1) | 157.19 | 132.98 | (1) | 139.00 | 229.60 | (5) | 4.695+004 | -7.318+004 | 9.928+004 | 000 |
| 1.200 | (1) | 157.19 | 103.74 | (2) | 69.33 | 67.20 | (2) | 1.524+004 | .000 | 9.928+004 | 000 |
| 1.200 | (1) | 157.19 | 126.60 | (3) | 123.79 | 129.20 | (3) | 1.111+004 | -1.128+003 | 9.928+004 | 000 |
| 1.200 | (1) | 157.19 | 124.72 | (4) | 139.67 | 252.00 | (4) | 1.843+004 | -8.941+004 | 9.928+004 | 000 |
| 1.200 | (1) | 157.19 | 124.86 | (5) | 139.54 | 252.00 | (4) | 6.618+003 | -3.235+004 | 9.928+004 | 000 |
| 1.250 | (1) | 157.40 | 133.25 | (1) | 139.40 | 229.60 | (5) | 4.683+004 | -7.274+004 | 9.928+004 | 000 |
| 1.250 | (1) | 157.40 | 103.91 | (2) | 69.40 | 67.20 | (2) | 1.526+004 | .000 | 9.928+004 | 000 |
| 1.250 | (1) | 157.40 | 126.71 | (3) | 123.80 | 129.20 | (3) | 1.116+004 | -1.125+003 | 9.928+004 | 000 |
| 1.250 | (1) | 157.40 | 124.84 | (4) | 140.20 | 252.00 | (4) | 1.849+004 | -8.884+004 | 9.928+004 | 000 |
| 1.250 | (1) | 157.40 | 124.98 | (5) | 140.07 | 252.00 | (4) | 6.641+003 | -3.215+004 | 9.928+004 | 000 |
| 1.300 | (1) | 157.60 | 133.52 | (1) | 139.79 | 229.60 | (5) | 4.671+004 | -7.232+004 | 9.928+004 | 000 |
| 1.300 | (1) | 157.60 | 104.07 | (2) | 69.47 | 67.20 | (2) | 1.527+004 | .000 | 9.928+004 | 000 |
| 1.300 | (1) | 157.60 | 126.82 | (3) | 123.81 | 129.20 | (3) | 1.120+004 | -1.122+003 | 9.928+004 | 000 |
| 1.300 | (1) | 157.60 | 124.95 | (4) | 140.72 | 252.00 | (4) | 1.856+004 | -8.828+004 | 9.928+004 | 000 |
| 1.300 | (1) | 157.60 | 125.10 | (5) | 140.58 | 252.00 | (4) | 6.663+003 | -3.195+004 | 9.928+004 | 000 |
| 1.350 | (1) | 157.80 | 133.78 | (1) | 140.17 | 229.60 | (5) | 4.659+004 | -7.191+004 | 9.928+004 | 000 |
| 1.350 | (1) | 157.80 | 104.22 | (2) | 69.51 | 67.20 | (2) | 1.528+004 | .000 | 9.928+004 | 000 |
| 1.350 | (1) | 157.80 | 126.93 | (3) | 123.82 | 129.20 | (3) | 1.124+004 | -1.119+003 | 9.928+004 | 000 |
| 1.350 | (1) | 157.80 | 125.07 | (4) | 141.21 | 252.00 | (4) | 1.862+004 | -8.774+004 | 9.928+004 | 000 |
| 1.350 | (1) | 157.80 | 125.21 | (5) | 141.08 | 252.00 | (4) | 6.685+003 | -3.175+004 | 9.928+004 | 000 |

Calc. No. 3C7-0290-002
Revision: 1
Page: A9
Project No. 8726-17

S&L NNU CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART 1 TJB DATE 05/1/92 PAGE

STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT

| t | (iA1) | TA | TW | (iW) | TW | TA | (iA2) | QW(iW,1) | QW(iW,2) | QAI(iA1) | QAI(iA2) |
|-------|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|----------|
| 1.400 | (1) | 158.00 | 134.03 | (1) | 140.53 | 229.60 | (5) | 4.648+004 | -7.151+004 | 9.928+004 | 000 |
| 1.400 | (1) | 158.00 | 104.38 | (2) | 69.60 | 67.20 | (2) | 1.529+004 | .000 | 9.928+004 | 000 |
| 1.400 | (1) | 158.00 | 127.04 | (3) | 123.83 | 129.20 | (3) | 1.128+004 | -1.116+003 | 9.928+004 | 000 |
| 1.400 | (1) | 158.00 | 125.18 | (4) | 141.70 | 252.00 | (4) | 1.867+004 | -8.722+004 | 9.928+004 | 000 |
| 1.400 | (1) | 158.00 | 125.33 | (5) | 141.57 | 252.00 | (4) | 6.706+003 | -3.156+004 | 9.928+004 | 000 |
| 1.450 | (1) | 158.19 | 134.28 | (1) | 140.89 | 229.60 | (5) | 4.637+004 | -7.112+004 | 9.928+004 | 000 |
| 1.450 | (1) | 158.19 | 104.53 | (2) | 69.66 | 67.20 | (2) | 1.531+004 | .000 | 9.928+004 | 000 |
| 1.450 | (1) | 158.19 | 127.15 | (3) | 123.84 | 129.20 | (3) | 1.132+004 | -1.114+003 | 9.928+004 | 000 |
| 1.450 | (1) | 158.19 | 125.29 | (4) | 142.17 | 252.00 | (4) | 1.873+004 | -8.671+004 | 9.928+004 | 000 |
| 1.450 | (1) | 158.19 | 125.44 | (5) | 142.04 | 252.00 | (4) | 6.726+003 | -3.138+004 | 9.928+004 | 000 |
| 1.500 | (1) | 158.37 | 134.52 | (1) | 141.23 | 229.60 | (5) | 4.626+004 | -7.075+004 | 9.928+004 | 000 |
| 1.500 | (1) | 158.37 | 104.68 | (2) | 69.72 | 67.20 | (2) | 1.532+004 | .000 | 9.928+004 | 000 |
| 1.500 | (1) | 158.37 | 127.25 | (3) | 123.85 | 129.20 | (3) | 1.136+004 | -1.111+003 | 9.928+004 | 000 |
| 1.500 | (1) | 158.37 | 125.40 | (4) | 142.63 | 252.00 | (4) | 1.879+004 | -8.622+004 | 9.928+004 | 000 |
| 1.500 | (1) | 158.37 | 125.55 | (5) | 142.50 | 252.00 | (4) | 6.746+003 | -3.120+004 | 9.928+004 | 000 |
| 1.550 | (1) | 158.55 | 134.76 | (1) | 141.57 | 229.60 | (5) | 4.616+004 | -7.038+004 | 9.928+004 | 000 |
| 1.550 | (1) | 158.55 | 104.83 | (2) | 69.78 | 67.20 | (2) | 1.533+004 | .000 | 9.928+004 | 000 |
| 1.550 | (1) | 158.55 | 127.36 | (3) | 123.86 | 129.20 | (3) | 1.139+004 | -1.108+003 | 9.928+004 | 000 |
| 1.550 | (1) | 158.55 | 125.51 | (4) | 143.07 | 252.00 | (4) | 1.884+004 | -8.574+004 | 9.928+004 | 000 |
| 1.550 | (1) | 158.55 | 125.66 | (5) | 142.94 | 252.00 | (4) | 6.765+003 | -3.103+004 | 9.928+004 | 000 |
| 1.600 | (1) | 158.73 | 134.99 | (1) | 141.89 | 229.60 | (5) | 4.606+004 | -7.003+004 | 9.928+004 | 000 |
| 1.600 | (1) | 158.73 | 104.97 | (2) | 69.84 | 67.20 | (2) | 1.534+004 | .000 | 9.928+004 | 000 |
| 1.600 | (1) | 158.73 | 127.46 | (3) | 123.87 | 129.20 | (3) | 1.143+004 | -1.106+003 | 9.928+004 | 000 |
| 1.600 | (1) | 158.73 | 125.62 | (4) | 143.51 | 252.00 | (4) | 1.889+004 | -8.528+004 | 9.928+004 | 000 |
| 1.600 | (1) | 158.73 | 125.77 | (5) | 143.38 | 252.00 | (4) | 6.784+003 | -3.086+004 | 9.928+004 | 000 |
| 1.650 | (1) | 158.91 | 135.21 | (1) | 142.21 | 229.60 | (5) | 4.596+004 | -6.969+004 | 9.928+004 | 000 |
| 1.650 | (1) | 158.91 | 105.11 | (2) | 69.90 | 67.20 | (2) | 1.525+004 | .000 | 9.928+004 | 000 |
| 1.650 | (1) | 158.91 | 127.56 | (3) | 123.88 | 129.20 | (3) | 1.146+004 | -1.103+003 | 9.928+004 | 000 |
| 1.650 | (1) | 158.91 | 125.73 | (4) | 143.93 | 252.00 | (4) | 1.894+004 | -8.482+004 | 9.928+004 | 000 |
| 1.650 | (1) | 158.91 | 125.87 | (5) | 143.80 | 252.00 | (4) | 6.802+003 | -3.069+004 | 9.928+004 | 000 |
| 1.700 | (1) | 159.08 | 135.43 | (1) | 142.52 | 229.60 | (5) | 4.587+004 | -6.935+004 | 9.928+004 | 000 |
| 1.700 | (1) | 159.08 | 105.26 | (2) | 69.96 | 67.20 | (2) | 1.536+004 | .000 | 9.928+004 | 000 |
| 1.700 | (1) | 159.08 | 127.66 | (3) | 123.89 | 129.20 | (3) | 1.150+004 | -1.101+003 | 9.928+004 | 000 |
| 1.700 | (1) | 159.08 | 125.83 | (4) | 144.34 | 252.00 | (4) | 1.899+004 | -8.438+004 | 9.928+004 | 000 |
| 1.700 | (1) | 159.08 | 125.98 | (5) | 144.21 | 252.00 | (4) | 6.810+003 | -3.054+004 | 9.928+004 | 000 |
| 1.750 | (1) | 159.25 | 135.65 | (1) | 142.82 | 229.60 | (5) | 4.578+004 | -6.903+004 | 9.928+004 | 000 |
| 1.750 | (1) | 159.25 | 105.39 | (2) | 70.01 | 67.20 | (2) | 1.537+004 | .000 | 9.928+004 | 000 |
| 1.750 | (1) | 159.25 | 127.76 | (3) | 123.90 | 129.20 | (3) | 1.153+004 | -1.098+003 | 9.928+004 | 000 |
| 1.750 | (1) | 159.25 | 125.94 | (4) | 144.74 | 252.00 | (4) | 1.903+004 | -8.396+004 | 9.928+004 | 000 |
| 1.750 | (1) | 159.25 | 126.08 | (5) | 144.61 | 252.00 | (4) | 6.836+003 | -3.038+004 | 9.928+004 | 000 |

CALC. NO. 3C7-0290-002
REVISION: 1
Page: 210
Project No. 3726-17

| S&L | NSLD | CALC | 3C7-0290-002 | REV | PROJECT | 8726-17 | PART | TJB | DATE | 051282 | FILE |
|--|-------|--------|--------------|------|---------|---------|-------|-----------|------------|-----------|---------|
| t | (+A1) | TA | TW | (+W) | TW | TA | (+A2) | QW(+W,1) | QW(+W,2) | QA(+A1) | QA(+A2) |
| STATION BLACKOUT RCIC ROOM TEMPERATURE TRANSIENT | | | | | | | | | | | |
| 1.800 | (+1) | 159.42 | 135.86 | (-1) | 143.11 | 229.60 | (-5) | 4.569+004 | -6.871+004 | 9.928+004 | 000 |
| 1.800 | (+1) | 159.42 | 105.53 | (-2) | 70.07 | 67.20 | (-2) | 1.538+004 | .000 | 9.928+004 | 000 |
| 1.800 | (+1) | 159.42 | 127.36 | (-3) | 123.91 | 129.20 | (-3) | 1.156+004 | -1.096+003 | 9.928+004 | 000 |
| 1.800 | (+1) | 159.42 | 126.04 | (-4) | 145.13 | 252.00 | (-4) | 1.908+004 | -8.354+004 | 9.928+004 | 000 |
| 1.800 | (+1) | 159.42 | 126.18 | (-5) | 145.00 | 252.00 | (-4) | 6.852+003 | -3.023+004 | 9.928+004 | 000 |
| 1.850 | (+1) | 159.58 | 136.07 | (-1) | 145.40 | 229.60 | (-5) | 4.561+004 | -6.841+004 | 9.928+004 | 000 |
| 1.850 | (+1) | 159.58 | 105.66 | (-2) | 70.13 | 67.20 | (-2) | 1.538+004 | .000 | 9.928+004 | 000 |
| 1.850 | (+1) | 159.58 | 127.95 | (-3) | 123.92 | 129.20 | (-3) | 1.159+004 | -1.094+003 | 9.928+004 | 000 |
| 1.850 | (+1) | 159.58 | 126.14 | (-4) | 145.51 | 252.00 | (-4) | 1.912+004 | -8.314+004 | 9.928+004 | 000 |
| 1.850 | (+1) | 159.58 | 126.28 | (-5) | 145.38 | 252.00 | (-4) | 6.868+003 | -3.008+004 | 9.928+004 | 000 |
| 1.900 | (+1) | 159.74 | 136.27 | (-1) | 143.67 | 229.60 | (-5) | 4.552+004 | -6.811+004 | 9.928+004 | 000 |
| 1.900 | (+1) | 159.74 | 105.80 | (-2) | 70.18 | 67.20 | (-2) | 1.539+004 | .000 | 9.928+004 | 000 |
| 1.900 | (+1) | 159.74 | 128.05 | (-3) | 123.92 | 129.20 | (-3) | 1.162+004 | -1.091+003 | 9.928+004 | 000 |
| 1.900 | (+1) | 159.74 | 126.24 | (-4) | 145.88 | 252.00 | (-4) | 1.917+004 | -8.274+004 | 9.928+004 | 000 |
| 1.900 | (+1) | 159.74 | 126.38 | (-5) | 145.75 | 252.00 | (-4) | 6.884+003 | -2.994+004 | 9.928+004 | 000 |
| 1.950 | (+1) | 159.90 | 136.47 | (-1) | 143.94 | 229.60 | (-5) | 4.544+004 | -6.782+004 | 9.928+004 | 000 |
| 1.950 | (+1) | 159.90 | 105.93 | (-2) | 70.23 | 67.20 | (-2) | 1.540+004 | .000 | 9.928+004 | 000 |
| 1.950 | (+1) | 159.90 | 128.14 | (-3) | 123.93 | 129.20 | (-3) | 1.165+004 | -1.089+003 | 9.928+004 | 000 |
| 1.950 | (+1) | 159.90 | 126.34 | (-4) | 146.25 | 252.00 | (-4) | 1.921+004 | -8.236+004 | 9.928+004 | 000 |
| 1.950 | (+1) | 159.90 | 126.48 | (-5) | 146.12 | 252.00 | (-4) | 6.899+003 | -2.980+004 | 9.928+004 | 000 |
| 2.000 | (+1) | 160.05 | 136.66 | (-1) | 144.21 | 229.60 | (-5) | 4.537+004 | -6.754+004 | 9.928+004 | 000 |
| 2.000 | (+1) | 160.05 | 106.05 | (-2) | 70.29 | 67.20 | (-2) | 1.541+004 | .000 | 9.928+004 | 000 |
| 2.000 | (+1) | 160.05 | 128.24 | (-3) | 123.94 | 129.20 | (-3) | 1.166+004 | -1.087+003 | 9.928+004 | 000 |
| 2.000 | (+1) | 160.05 | 126.44 | (-4) | 146.60 | 252.00 | (-4) | 1.925+004 | -8.198+004 | 9.928+004 | 000 |
| 2.000 | (+1) | 160.05 | 126.58 | (-5) | 146.47 | 252.00 | (-4) | 6.913+003 | -2.967+004 | 9.928+004 | 000 |
| 2.050 | (+1) | 160.20 | 136.85 | (-1) | 144.46 | 229.60 | (-5) | 4.529+004 | -6.726+004 | 9.928+004 | 000 |
| 2.050 | (+1) | 160.20 | 106.18 | (-2) | 70.34 | 67.20 | (-2) | 1.541+004 | .000 | 9.928+004 | 000 |
| 2.050 | (+1) | 160.20 | 128.33 | (-3) | 123.95 | 129.20 | (-3) | 1.170+004 | -1.085+003 | 9.928+004 | 000 |
| 2.050 | (+1) | 160.20 | 126.53 | (-4) | 146.94 | 252.00 | (-4) | 1.929+004 | -8.162+004 | 9.928+004 | 000 |
| 2.050 | (+1) | 160.20 | 126.68 | (-5) | 146.81 | 252.00 | (-4) | 6.927+003 | -2.953+004 | 9.928+004 | 000 |
| 2.100 | (+1) | 160.35 | 137.04 | (-1) | 144.71 | 229.60 | (-5) | 4.521+004 | -6.699+004 | 9.928+004 | 000 |
| 2.100 | (+1) | 160.35 | 106.31 | (-2) | 70.39 | 67.20 | (-2) | 1.542+004 | .000 | 9.928+004 | 000 |
| 2.100 | (+1) | 160.35 | 128.42 | (-3) | 123.96 | 129.20 | (-3) | 1.173+004 | -1.083+003 | 9.928+004 | 000 |
| 2.100 | (+1) | 160.35 | 126.63 | (-4) | 147.28 | 252.00 | (-4) | 1.933+004 | -8.126+004 | 9.928+004 | 000 |
| 2.100 | (+1) | 160.35 | 126.77 | (-5) | 147.15 | 252.00 | (-4) | 6.941+003 | -2.941+004 | 9.928+004 | 000 |
| 2.150 | (+1) | 160.50 | 137.22 | (-1) | 144.96 | 229.60 | (-5) | 4.514+004 | -6.673+004 | 9.928+004 | 000 |
| 2.150 | (+1) | 160.50 | 106.43 | (-2) | 70.44 | 67.20 | (-2) | 1.543+004 | .000 | 9.928+004 | 000 |
| 2.150 | (+1) | 160.50 | 128.51 | (-3) | 123.96 | 129.20 | (-3) | 1.175+004 | -1.081+003 | 9.928+004 | 000 |
| 2.150 | (+1) | 160.50 | 126.72 | (-4) | 147.61 | 252.00 | (-4) | 1.936+004 | -8.092+004 | 9.928+004 | 000 |
| 2.150 | (+1) | 160.50 | 126.87 | (-5) | 147.48 | 252.00 | (-4) | 6.955+003 | -2.928+004 | 9.928+004 | 000 |

Calc. No. 3C7-0290-002
 Revision: 1
 Page: A11
 Project No. 8726-17

| S&L | NSLO | CALC | 3C7-0290-002 | REV | I | PROJECT | 8726-17 | PART | I | TJB | DATE | 051292 | PAGE | I |
|--|-------|--------|--------------|------|--------|---------|---------|-----------|------------|-----------|---------|--------|------|---|
| STATION BLACKOUT RCIC ROOM TEMPERATURE TRANSIENT | | | | | | | | | | | | | | |
| t | (TA1) | TA | TW | (TW) | TW | TA | (TA2) | QW(TW,1) | QW(TW,2) | QAT(A1) | QAT(A2) | | | |
| 2.200 | (1) | 160.64 | 137.40 | (1) | 145.20 | 229.60 | (5) | 4.507+004 | -6.647+004 | 9.928+004 | 000 | . | | |
| 2.200 | (1) | 160.64 | 106.55 | (2) | 70.49 | 67.20 | (2) | 1.543+004 | .000 | 9.928+004 | 000 | . | | |
| 2.200 | (1) | 160.54 | 128.60 | (3) | 122.97 | 129.20 | (3) | 1.178+004 | -1.079+003 | 9.928+004 | 000 | . | | |
| 2.200 | (1) | 160.64 | 126.81 | (4) | 126.93 | 252.00 | (4) | 1.940+004 | -8.058+004 | 9.928+004 | 000 | . | | |
| 2.200 | (1) | 160.64 | 126.96 | (5) | 147.80 | 252.00 | (4) | 6.968+003 | -2.916+004 | 9.928+004 | 000 | . | | |
| 2.250 | (1) | 160.78 | 137.58 | (1) | 145.43 | 229.60 | (5) | 4.500+004 | -6.622+004 | 9.928+004 | 000 | . | | |
| 2.250 | (1) | 160.78 | 106.67 | (2) | 70.54 | 67.20 | (2) | 1.544+004 | .000 | 9.928+004 | 000 | . | | |
| 2.250 | (1) | 160.78 | 128.69 | (3) | 123.98 | 129.20 | (3) | 1.180+004 | -1.077+003 | 9.928+004 | 000 | . | | |
| 2.250 | (1) | 160.78 | 126.91 | (4) | 148.24 | 252.00 | (4) | 1.943+004 | -8.025+004 | 9.928+004 | 000 | . | | |
| 2.250 | (1) | 160.78 | 127.05 | (5) | 148.11 | 252.00 | (4) | 6.981+003 | -2.904+004 | 9.928+004 | 000 | . | | |
| 2.300 | (1) | 160.92 | 137.75 | (1) | 145.66 | 229.60 | (5) | 4.494+004 | -6.598+004 | 9.928+004 | 000 | . | | |
| 2.300 | (1) | 160.92 | 106.79 | (2) | 70.59 | 67.20 | (2) | 1.545+004 | .000 | 9.928+004 | 000 | . | | |
| 2.300 | (1) | 160.92 | 128.78 | (3) | 123.98 | 129.20 | (3) | 1.183+004 | -1.075+003 | 9.928+004 | 000 | . | | |
| 2.300 | (1) | 160.92 | 127.00 | (4) | 148.55 | 252.00 | (4) | 1.947+004 | -7.992+004 | 9.928+004 | 000 | . | | |
| 2.300 | (1) | 160.92 | 127.14 | (5) | 148.42 | 252.00 | (4) | 6.993+003 | -2.892+004 | 9.928+004 | 000 | . | | |
| 2.350 | (1) | 161.06 | 137.92 | (1) | 145.88 | 229.60 | (5) | 4.487+004 | -6.574+004 | 9.928+004 | 000 | . | | |
| 2.350 | (1) | 161.06 | 106.91 | (2) | 70.63 | 67.20 | (2) | 1.545+004 | .000 | 9.928+004 | 000 | . | | |
| 2.350 | (1) | 161.06 | 128.86 | (3) | 123.99 | 129.20 | (3) | 1.185+004 | -1.073+003 | 9.928+004 | 000 | . | | |
| 2.350 | (1) | 161.06 | 127.09 | (4) | 148.85 | 252.00 | (4) | 1.950+004 | -7.961+004 | 9.928+004 | 000 | . | | |
| 2.350 | (1) | 161.06 | 127.23 | (5) | 148.72 | 252.00 | (4) | 7.005+003 | -2.881+004 | 9.928+004 | 000 | . | | |
| 2.400 | (1) | 161.19 | 138.09 | (1) | 146.10 | 229.60 | (5) | 4.481+004 | -6.551+004 | 9.928+004 | 000 | . | | |
| 2.400 | (1) | 161.19 | 107.02 | (2) | 70.68 | 67.20 | (2) | 1.546+004 | .000 | 9.928+004 | 000 | . | | |
| 2.400 | (1) | 161.19 | 128.95 | (3) | 124.00 | 129.20 | (3) | 1.187+004 | -1.071+003 | 9.928+004 | 000 | . | | |
| 2.400 | (1) | 161.19 | 127.18 | (4) | 149.14 | 252.00 | (4) | 1.953+004 | -7.930+004 | 9.928+004 | 000 | . | | |
| 2.400 | (1) | 161.19 | 127.32 | (5) | 149.02 | 252.00 | (4) | 7.017+003 | -2.870+004 | 9.928+004 | 000 | . | | |
| 2.450 | (1) | 161.33 | 138.26 | (1) | 146.32 | 229.60 | (5) | 4.474+004 | -6.528+004 | 9.928+004 | 000 | . | | |
| 2.450 | (1) | 161.33 | 107.13 | (2) | 70.73 | 67.20 | (2) | 1.546+004 | .000 | 9.928+004 | 000 | . | | |
| 2.450 | (1) | 161.33 | 129.03 | (3) | 124.01 | 129.20 | (3) | 1.190+004 | -1.069+003 | 9.928+004 | 000 | . | | |
| 2.450 | (1) | 161.33 | 127.26 | (4) | 149.43 | 252.00 | (4) | 1.957+004 | -7.900+004 | 9.928+004 | 000 | . | | |
| 2.450 | (1) | 161.33 | 127.41 | (5) | 149.30 | 252.00 | (4) | 7.029+003 | -2.859+004 | 9.928+004 | 000 | . | | |
| 2.500 | (1) | 161.46 | 138.42 | (1) | 146.53 | 229.60 | (5) | 4.468+004 | -6.506+004 | 9.928+004 | 000 | . | | |
| 2.500 | (1) | 161.46 | 107.25 | (2) | 70.77 | 67.20 | (2) | 1.547+004 | .000 | 9.928+004 | 000 | . | | |
| 2.500 | (1) | 161.46 | 129.12 | (3) | 124.01 | 129.20 | (3) | 1.192+004 | -1.067+003 | 9.928+004 | 000 | . | | |
| 2.500 | (1) | 161.46 | 127.35 | (4) | 149.71 | 252.00 | (4) | 1.960+004 | -7.870+004 | 9.928+004 | 000 | . | | |
| 2.500 | (1) | 161.46 | 127.49 | (5) | 149.58 | 252.00 | (4) | 7.040+003 | -2.848+004 | 9.928+004 | 000 | . | | |
| 2.550 | (1) | 161.59 | 138.58 | (1) | 146.73 | 229.60 | (5) | 4.462+004 | -6.484+004 | 9.928+004 | 000 | . | | |
| 2.550 | (1) | 161.59 | 107.36 | (2) | 70.82 | 67.20 | (2) | 1.547+004 | .000 | 9.928+004 | 000 | . | | |
| 2.550 | (1) | 161.59 | 129.20 | (3) | 124.02 | 129.20 | (3) | 1.194+004 | -1.066+003 | 9.928+004 | 000 | . | | |
| 2.550 | (1) | 161.59 | 127.44 | (4) | 149.99 | 252.00 | (4) | 1.963+004 | -7.842+004 | 9.928+004 | 000 | . | | |
| 2.550 | (1) | 161.59 | 127.58 | (5) | 149.86 | 252.00 | (4) | 7.051+003 | -2.838+004 | 9.928+004 | 000 | . | | |

Calc. No. 3C7-0290-002
 Revision: 1
 Page: A12
 Project No. 8726-17

S8L NSLD CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART 1 TJB DATE 051292 PAGE

STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT

| t | (IA1) | TA | TW | (IW) | TW | TA | (IA2) | QW(IW,1) | QW(IW,2) | QA(IA1) | QA(IA2) |
|-------|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|---------|
| 2.600 | (1) | 161.71 | 138.74 | (1) | 146.93 | 229.60 | (5) | 4.457+004 | -6.463+004 | 9.928+004 | 000 |
| 2.600 | (1) | 161.71 | 107.47 | (2) | 70.86 | 67.20 | (2) | 1.548+004 | .000 | 9.928+004 | 000 |
| 2.600 | (1) | 161.71 | 129.28 | (3) | 124.02 | 129.20 | (3) | 1.196+004 | -1.064+003 | 9.928+004 | 000 |
| 2.600 | (1) | 161.71 | 127.52 | (4) | 150.26 | 252.00 | (4) | 1.966+004 | -7.813+004 | 9.928+004 | 000 |
| 2.600 | (1) | 161.71 | 127.67 | (5) | 150.33 | 252.00 | (4) | 7.062+003 | -2.827+004 | 9.928+004 | 000 |
| 2.650 | (1) | 161.84 | 138.89 | (1) | 147.13 | 229.60 | (5) | 4.451+004 | -6.442+004 | 9.928+004 | 000 |
| 2.650 | (1) | 161.84 | 107.57 | (2) | 70.90 | 67.20 | (2) | 1.548+004 | .000 | 9.928+004 | 000 |
| 2.650 | (1) | 161.84 | 129.36 | (3) | 124.03 | 129.20 | (3) | 1.198+004 | -1.062+003 | 9.928+004 | 000 |
| 2.650 | (1) | 161.84 | 127.61 | (4) | 150.52 | 252.00 | (4) | 1.969+004 | -7.786+004 | 9.928+004 | 000 |
| 2.650 | (1) | 161.84 | 127.75 | (5) | 150.39 | 252.00 | (4) | 7.072+003 | -2.817+004 | 9.928+004 | 000 |
| 2.700 | (1) | 161.96 | 139.04 | (1) | 147.32 | 229.60 | (5) | 4.445+004 | -6.421+004 | 9.928+004 | 000 |
| 2.700 | (1) | 161.96 | 107.68 | (2) | 70.95 | 67.20 | (2) | 1.549+004 | .000 | 9.928+004 | 000 |
| 2.700 | (1) | 161.96 | 129.44 | (3) | 124.04 | 129.20 | (3) | 1.200+004 | -1.060+003 | 9.928+004 | 000 |
| 2.700 | (1) | 161.96 | 127.69 | (4) | 150.78 | 252.00 | (4) | 1.972+004 | -7.759+004 | 9.928+004 | 000 |
| 2.700 | (1) | 161.96 | 127.83 | (5) | 150.65 | 252.00 | (4) | 7.083+003 | -2.808+004 | 9.928+004 | 000 |
| 2.750 | (1) | 162.08 | 139.19 | (1) | 147.51 | 229.60 | (5) | 4.440+004 | -6.401+004 | 9.928+004 | 000 |
| 2.750 | (1) | 162.08 | 107.79 | (2) | 70.99 | 67.20 | (2) | 1.549+004 | .000 | 9.928+004 | 000 |
| 2.750 | (1) | 162.08 | 129.52 | (3) | 124.04 | 129.20 | (3) | 1.202+004 | -1.059+003 | 9.928+004 | 000 |
| 2.750 | (1) | 162.08 | 127.77 | (4) | 151.03 | 252.00 | (4) | 1.974+004 | -7.732+004 | 9.928+004 | 000 |
| 2.750 | (1) | 162.08 | 127.92 | (5) | 150.91 | 252.00 | (4) | 7.093+003 | -2.798+004 | 9.928+004 | 000 |
| 2.800 | (1) | 162.20 | 139.34 | (1) | 147.70 | 229.60 | (5) | 4.435+004 | -6.382+004 | 9.928+004 | 000 |
| 2.800 | (1) | 162.20 | 107.89 | (2) | 71.03 | 67.20 | (2) | 1.550+004 | .000 | 9.928+004 | 000 |
| 2.800 | (1) | 162.20 | 129.60 | (3) | 124.05 | 129.20 | (3) | 1.204+004 | -1.057+003 | 9.928+004 | 000 |
| 2.800 | (1) | 162.20 | 127.86 | (4) | 151.28 | 252.00 | (4) | 1.977+004 | -7.706+004 | 9.928+004 | 000 |
| 2.800 | (1) | 162.20 | 128.00 | (5) | 151.16 | 252.00 | (4) | 7.103+003 | -2.789+004 | 9.928+004 | 000 |
| 2.850 | (1) | 162.32 | 139.49 | (1) | 147.88 | 229.60 | (5) | 4.429+004 | -6.362+004 | 9.928+004 | 000 |
| 2.850 | (1) | 162.32 | 107.99 | (2) | 71.07 | 67.20 | (2) | 1.550+004 | .000 | 9.928+004 | 000 |
| 2.850 | (1) | 162.32 | 129.68 | (3) | 124.06 | 129.20 | (3) | 1.206+004 | -1.055+003 | 9.928+004 | 000 |
| 2.850 | (1) | 162.32 | 127.94 | (4) | 151.53 | 252.00 | (4) | 1.980+004 | -7.681+004 | 9.928+004 | 000 |
| 2.850 | (1) | 162.32 | 128.08 | (5) | 151.40 | 252.00 | (4) | 7.112+003 | -2.780+004 | 9.928+004 | 000 |
| 2.900 | (1) | 162.44 | 139.63 | (1) | 148.06 | 229.60 | (5) | 4.424+004 | -6.343+004 | 9.928+004 | 000 |
| 2.900 | (1) | 162.44 | 108.10 | (2) | 71.12 | 67.20 | (2) | 1.550+004 | .000 | 9.928+004 | 000 |
| 2.900 | (1) | 162.44 | 129.76 | (3) | 124.06 | 129.20 | (3) | 1.208+004 | -1.054+003 | 9.928+004 | 000 |
| 2.900 | (1) | 162.44 | 128.02 | (4) | 151.77 | 252.00 | (4) | 1.982+004 | -7.556+004 | 9.928+004 | 000 |
| 2.900 | (1) | 162.44 | 128.16 | (5) | 151.64 | 252.00 | (4) | 7.122+003 | -2.771+004 | 9.928+004 | 000 |
| 2.950 | (1) | 162.56 | 139.77 | (1) | 148.24 | 229.60 | (5) | 4.419+004 | -6.325+004 | 9.928+004 | 000 |
| 2.950 | (1) | 162.56 | 108.20 | (2) | 71.16 | 67.20 | (2) | 1.551+004 | .000 | 9.928+004 | 000 |
| 2.950 | (1) | 162.56 | 129.83 | (3) | 124.07 | 129.20 | (3) | 1.210+004 | -1.052+003 | 9.928+004 | 000 |
| 2.950 | (1) | 162.56 | 128.10 | (4) | 152.00 | 252.00 | (4) | 1.985+004 | -7.632+004 | 9.928+004 | 000 |
| 2.950 | (1) | 162.56 | 128.24 | (5) | 151.88 | 252.00 | (4) | 7.131+003 | -2.762+004 | 9.928+004 | 000 |

CALC. NO. 3C7-0290-002
Revision: 1
Page: A1
Project No. 8726-17

S&L NSLU CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART 1 TUB DATE 051292 TAB

STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT

| t | (TA1) | TA | TW | (TW) | TW | TA | (TA2) | OW(TW,1) | OW(TW,2) | QAE(TA1) | QAE(TA2) |
|-------|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|----------|
| 3.000 | (1) | 162.67 | 139.91 | (1) | 148.41 | 229.60 | (5) | 4.414+004 | -6.307+004 | 9.928+004 | 000 |
| 3.000 | (1) | 162.67 | 108.30 | (2) | 71.20 | 67.20 | (2) | 1.551+004 | .000 | 9.928+004 | 000 |
| 3.000 | (1) | 162.67 | 129.91 | (3) | 124.07 | 129.20 | (3) | 1.211+004 | -1.051+003 | 9.928+004 | 000 |
| 3.000 | (1) | 162.67 | 128.18 | (4) | 152.23 | 252.00 | (4) | 1.987+004 | -7.608+004 | 9.928+004 | 000 |
| 3.000 | (1) | 162.67 | 128.32 | (5) | 152.11 | 252.00 | (4) | 7.140+003 | -2.753+004 | 9.928+004 | 000 |
| 3.050 | (1) | 162.78 | 140.05 | (1) | 148.58 | 229.60 | (5) | 4.409+004 | -6.289+004 | 9.928+004 | 000 |
| 3.050 | (1) | 162.78 | 108.39 | (2) | 71.24 | 67.20 | (2) | 1.552+004 | .000 | 9.928+004 | 000 |
| 3.050 | (1) | 162.78 | 129.98 | (3) | 124.08 | 129.20 | (3) | 1.213+004 | -1.049+003 | 9.928+004 | 000 |
| 3.050 | (1) | 162.78 | 128.26 | (4) | 152.46 | 252.00 | (4) | 1.990+004 | -7.584+004 | 9.928+004 | 000 |
| 3.050 | (1) | 162.78 | 128.39 | (5) | 152.33 | 252.00 | (4) | 7.149+003 | -2.744+004 | 9.928+004 | 000 |
| 3.100 | (1) | 162.89 | 140.13 | (1) | 148.75 | 229.60 | (5) | 4.405+004 | -6.271+004 | 9.928+004 | 000 |
| 3.100 | (1) | 162.89 | 108.49 | (2) | 71.28 | 67.20 | (2) | 1.552+004 | .000 | 9.928+004 | 000 |
| 3.100 | (1) | 162.89 | 130.06 | (3) | 124.08 | 129.20 | (3) | 1.215+004 | -1.048+003 | 9.928+004 | 000 |
| 3.100 | (1) | 162.89 | 128.33 | (4) | 152.68 | 252.00 | (4) | 1.992+004 | -7.561+004 | 9.928+004 | 000 |
| 3.100 | (1) | 162.89 | 128.47 | (5) | 152.56 | 252.00 | (4) | 7.158+003 | -2.736+004 | 9.928+004 | 000 |
| 3.150 | (1) | 163.01 | 140.32 | (1) | 148.91 | 229.60 | (5) | 4.400+004 | -6.254+004 | 9.928+004 | 000 |
| 3.150 | (1) | 163.01 | 108.59 | (2) | 71.32 | 67.20 | (2) | 1.552+004 | .000 | 9.928+004 | 000 |
| 3.150 | (1) | 163.01 | 130.13 | (3) | 124.09 | 129.20 | (3) | 1.216+004 | -1.046+003 | 9.928+004 | 000 |
| 3.150 | (1) | 163.01 | 128.41 | (4) | 152.90 | 252.00 | (4) | 1.994+004 | -7.538+004 | 9.928+004 | 000 |
| 3.150 | (1) | 163.01 | 128.55 | (5) | 152.78 | 252.00 | (4) | 7.167+003 | -2.728+004 | 9.928+004 | 000 |
| 3.200 | (1) | 163.11 | 140.45 | (1) | 149.07 | 229.60 | (5) | 4.395+004 | -6.237+004 | 9.928+004 | 000 |
| 3.200 | (1) | 163.11 | 108.68 | (2) | 71.35 | 67.20 | (2) | 1.553+004 | .000 | 9.928+004 | 000 |
| 3.200 | (1) | 163.11 | 130.21 | (3) | 124.09 | 129.20 | (3) | 1.218+004 | -1.045+003 | 9.928+004 | 000 |
| 3.200 | (1) | 163.11 | 128.49 | (4) | 153.12 | 252.00 | (4) | 1.997+004 | -7.516+004 | 9.928+004 | 000 |
| 3.200 | (1) | 163.11 | 128.62 | (5) | 152.99 | 252.00 | (4) | 7.175+003 | -2.720+004 | 9.928+004 | 000 |
| 3.250 | (1) | 163.22 | 140.58 | (1) | 149.23 | 229.60 | (5) | 4.391+004 | -6.220+004 | 9.928+004 | 000 |
| 3.250 | (1) | 163.22 | 108.78 | (2) | 71.39 | 67.20 | (2) | 1.553+004 | .000 | 9.928+004 | 000 |
| 3.250 | (1) | 163.22 | 130.28 | (3) | 124.10 | 129.20 | (3) | 1.220+004 | -1.043+003 | 9.928+004 | 000 |
| 3.250 | (1) | 163.22 | 128.56 | (4) | 153.33 | 252.00 | (4) | 1.999+004 | -7.494+004 | 9.928+004 | 000 |
| 3.250 | (1) | 163.22 | 128.70 | (5) | 153.20 | 252.00 | (4) | 7.184+003 | -2.712+004 | 9.928+004 | 000 |
| 3.300 | (1) | 163.33 | 140.71 | (1) | 149.39 | 229.60 | (5) | 4.386+004 | -6.204+004 | 9.928+004 | 000 |
| 3.300 | (1) | 163.33 | 108.87 | (2) | 71.43 | 67.20 | (2) | 1.553+004 | .000 | 9.928+004 | 000 |
| 3.300 | (1) | 163.33 | 130.35 | (3) | 124.10 | 129.20 | (3) | 1.221+004 | -1.042+003 | 9.928+004 | 000 |
| 3.300 | (1) | 163.33 | 128.54 | (4) | 153.54 | 252.00 | (4) | 2.001+004 | -7.472+004 | 9.928+004 | 000 |
| 3.300 | (1) | 163.33 | 128.77 | (5) | 153.41 | 252.00 | (4) | 7.192+003 | -2.704+004 | 9.928+004 | 000 |
| 3.350 | (1) | 163.43 | 140.84 | (1) | 149.54 | 229.60 | (5) | 4.382+004 | -6.188+004 | 9.928+004 | 000 |
| 3.350 | (1) | 163.43 | 108.96 | (2) | 71.47 | 67.20 | (2) | 1.554+004 | .000 | 9.928+004 | 000 |
| 3.350 | (1) | 163.43 | 130.42 | (3) | 124.11 | 129.20 | (3) | 1.223+004 | -1.040+003 | 9.928+004 | 000 |
| 3.350 | (1) | 163.43 | 128.71 | (4) | 153.74 | 252.00 | (4) | 2.003+004 | -7.451+004 | 9.928+004 | 000 |
| 3.350 | (1) | 163.43 | 128.85 | (5) | 153.62 | 252.00 | (4) | 7.200+003 | -2.697+004 | 9.928+004 | 000 |

Calc. No. 3C7-0290-00C
Revision: 1
Page: A14
Project No. 8726-17

S&L NSLD CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART 1 TJB DATE 051232 PAGE 11

STATION BLACKOUT RCIC ROOM TEMPERATURE TRANSIENT

| t | (+A1) | TA | TW | (+W) | TW | TA | (+A2) | QW(+W,1) | QW(+W,2) | QA(+A1) | QA(+A2) |
|-------|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|---------|
| 3.400 | (1) | 163.54 | 140.97 | (1) | 149.70 | 229.60 | (5) | 4.378+004 | -6.172+004 | 9.928+004 | 000 |
| 3.400 | (1) | 163.54 | 109.06 | (2) | 71.50 | 67.20 | (2) | 1.554+004 | .000 | 9.928+004 | 000 |
| 3.400 | (1) | 163.54 | 130.49 | (3) | 124.11 | 129.20 | (3) | 1.224+004 | -1.039+003 | 9.928+004 | 000 |
| 3.400 | (1) | 163.54 | 128.79 | (4) | 153.94 | 252.00 | (4) | 2.005+004 | -7.431+004 | 9.928+004 | 000 |
| 3.400 | (1) | 163.54 | 128.92 | (5) | 153.82 | 252.00 | (4) | 7.208+003 | -2.689+004 | 9.928+004 | 000 |
| 3.450 | (1) | 163.64 | 141.09 | (1) | 149.85 | 229.60 | (5) | 4.374+004 | -6.156+004 | 9.928+004 | 000 |
| 3.450 | (1) | 153.64 | 109.15 | (2) | 71.54 | 67.20 | (2) | 1.554+004 | .000 | 9.928+004 | 000 |
| 3.450 | (1) | 163.64 | 130.56 | (3) | 124.12 | 129.20 | (3) | 1.226+004 | -1.038+003 | 9.928+004 | 000 |
| 3.450 | (1) | 163.64 | 128.86 | (4) | 154.14 | 252.00 | (4) | 2.008+004 | -7.410+004 | 9.928+004 | 000 |
| 3.450 | (1) | 163.64 | 128.99 | (5) | 154.02 | 252.00 | (4) | 7.216+003 | -2.682+004 | 9.928+004 | 000 |
| 3.500 | (1) | 163.74 | 141.22 | (1) | 149.99 | 229.60 | (5) | 4.369+004 | -6.141+004 | 9.928+004 | 000 |
| 3.500 | (1) | 162.74 | 109.24 | (2) | 71.58 | 67.20 | (2) | 1.555+004 | .000 | 9.928+004 | 000 |
| 3.500 | (1) | 163.74 | 130.63 | (3) | 124.12 | 129.20 | (3) | 1.227+004 | -1.036+003 | 9.928+004 | 000 |
| 3.500 | (1) | 163.74 | 128.93 | (4) | 154.34 | 252.00 | (4) | 2.010+004 | -7.390+004 | 9.928+004 | 000 |
| 3.500 | (1) | 163.74 | 129.06 | (5) | 154.21 | 252.00 | (4) | 7.224+003 | -2.674+004 | 9.928+004 | 000 |
| 3.550 | (1) | 163.84 | 141.34 | (1) | 150.14 | 229.60 | (5) | 4.365+004 | -6.125+004 | 9.928+004 | 000 |
| 3.550 | (1) | 163.84 | 109.32 | (2) | 71.61 | 67.20 | (2) | 1.555+004 | .000 | 9.928+004 | 000 |
| 3.550 | (1) | 163.84 | 130.70 | (3) | 124.13 | 129.20 | (3) | 1.229+004 | -1.035+003 | 9.928+004 | 000 |
| 3.550 | (1) | 163.84 | 129.01 | (4) | 154.53 | 252.00 | (4) | 2.012+004 | -7.370+004 | 9.928+004 | 000 |
| 3.550 | (1) | 163.84 | 129.13 | (5) | 154.41 | 252.00 | (4) | 7.231+003 | -2.667+004 | 9.928+004 | 000 |
| 3.600 | (1) | 163.94 | 141.46 | (1) | 150.28 | 229.60 | (5) | 4.361+004 | -6.110+004 | 9.928+004 | 000 |
| 3.600 | (1) | 163.94 | 109.41 | (2) | 71.65 | 67.20 | (2) | 1.555+004 | .000 | 9.928+004 | 000 |
| 3.600 | (1) | 163.94 | 130.77 | (3) | 124.13 | 129.20 | (3) | 1.230+004 | -1.034+003 | 9.928+004 | 000 |
| 3.600 | (1) | 163.94 | 129.08 | (4) | 154.72 | 252.00 | (4) | 2.013+004 | -7.351+004 | 9.928+004 | 000 |
| 3.600 | (1) | 163.94 | 129.21 | (5) | 154.60 | 252.00 | (4) | 7.239+003 | -2.660+004 | 9.928+004 | 000 |
| 3.650 | (1) | 164.04 | 141.58 | (1) | 150.42 | 229.60 | (5) | 4.357+004 | -6.096+004 | 9.928+004 | 000 |
| 3.650 | (1) | 164.04 | 109.50 | (2) | 71.68 | 67.20 | (2) | 1.556+004 | .000 | 9.928+004 | 000 |
| 3.650 | (1) | 164.04 | 130.84 | (3) | 124.14 | 129.20 | (3) | 1.232+004 | -1.032+003 | 9.928+004 | 000 |
| 3.650 | (1) | 164.04 | 129.15 | (4) | 154.91 | 252.00 | (4) | 2.015+004 | -7.331+004 | 9.928+004 | 000 |
| 3.650 | (1) | 164.04 | 129.28 | (5) | 154.78 | 252.00 | (4) | 7.246+003 | -2.653+004 | 9.928+004 | 000 |
| 3.700 | (1) | 164.14 | 141.70 | (1) | 150.56 | 229.60 | (5) | 4.353+004 | -6.081+004 | 9.928+004 | 000 |
| 3.700 | (1) | 164.14 | 109.59 | (2) | 71.72 | 67.20 | (2) | 1.556+004 | .000 | 9.928+004 | 000 |
| 3.700 | (1) | 164.14 | 130.90 | (3) | 124.14 | 129.20 | (3) | 1.233+004 | -1.031+003 | 9.928+004 | 000 |
| 3.700 | (1) | 164.14 | 129.22 | (4) | 155.09 | 252.00 | (4) | 2.017+004 | -7.312+004 | 9.928+004 | 000 |
| 3.700 | (1) | 164.14 | 129.34 | (5) | 154.97 | 252.00 | (4) | 7.253+003 | -2.646+004 | 9.928+004 | 000 |
| 3.750 | (1) | 164.24 | 141.82 | (1) | 150.70 | 229.60 | (5) | 4.350+004 | -6.067+004 | 9.928+004 | 000 |
| 3.750 | (1) | 164.24 | 109.67 | (2) | 71.75 | 67.20 | (2) | 1.556+004 | .000 | 9.928+004 | 000 |
| 3.750 | (1) | 164.24 | 130.97 | (3) | 124.15 | 129.20 | (3) | 1.235+004 | -1.030+003 | 9.928+004 | 000 |
| 3.750 | (1) | 164.24 | 129.29 | (4) | 155.27 | 252.00 | (4) | 2.019+004 | -7.294+004 | 9.928+004 | 000 |
| 3.750 | (1) | 164.24 | 129.41 | (5) | 155.15 | 252.00 | (4) | 7.261+003 | -2.640+004 | 9.928+004 | 000 |

Calc. No. 3C7-0290-002
Revision: 1
Page: A15
Project No. 8726-17

S&L NSLD CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART 1 TJR DATE 051292 PAGE 51

STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT

| t | (+A1) | TA | TW | (+R) | TW | TA | (+A2) | QWE(+W,1) | QWE(+W,2) | QA(+A1) | QA(+A2) |
|-------|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|---------|
| 3.800 | (1) | 164.34 | 141.93 | (1) | 150.84 | 229.60 | (5) | 4.346+004 | -6.053+004 | 9.928+004 | 000 |
| 3.800 | (1) | 164.34 | 109.76 | (2) | 71.79 | 67.20 | (2) | 1.556+004 | .000 | 9.928+004 | 000 |
| 3.800 | (1) | 164.34 | 131.04 | (3) | 124.15 | 129.20 | (3) | 1.236+004 | -1.029+003 | 9.928+004 | 000 |
| 3.800 | (1) | 164.34 | 129.36 | (4) | 155.45 | 252.00 | (4) | 2.021+004 | -7.275+004 | 9.928+004 | 000 |
| 3.800 | (1) | 164.34 | 129.48 | (5) | 155.33 | 252.00 | (4) | 7.268+003 | -2.633+004 | 9.928+004 | 000 |
| 3.850 | (1) | 164.43 | 142.05 | (1) | 150.97 | 229.60 | (5) | 4.342+004 | -6.039+004 | 9.928+004 | 000 |
| 3.850 | (1) | 164.43 | 109.84 | (2) | 71.82 | 67.20 | (2) | 1.557+004 | .000 | 9.928+004 | 000 |
| 3.850 | (1) | 164.43 | 131.10 | (3) | 124.16 | 129.20 | (3) | 1.237+004 | -1.027+003 | 9.928+004 | 000 |
| 3.850 | (1) | 164.43 | 129.43 | (4) | 155.63 | 252.00 | (4) | 2.023+004 | -7.257+004 | 9.928+004 | 000 |
| 3.850 | (1) | 164.43 | 129.55 | (5) | 155.50 | 252.00 | (4) | 7.275+003 | -2.626+004 | 9.928+004 | 000 |
| 3.900 | (1) | 164.53 | 142.16 | (1) | 151.10 | 229.60 | (5) | 4.338+004 | -6.025+004 | 9.928+004 | 000 |
| 3.900 | (1) | 164.53 | 109.93 | (2) | 71.85 | 67.20 | (2) | 1.557+004 | .000 | 9.928+004 | 000 |
| 3.900 | (1) | 164.53 | 131.17 | (3) | 124.16 | 129.20 | (3) | 1.239+004 | -1.026+003 | 9.928+004 | 000 |
| 3.900 | (1) | 164.53 | 129.50 | (4) | 155.80 | 252.00 | (4) | 2.025+004 | -7.240+004 | 9.928+004 | 000 |
| 3.900 | (1) | 164.53 | 129.62 | (5) | 155.68 | 252.00 | (4) | 7.282+003 | -2.620+004 | 9.928+004 | 000 |
| 3.950 | (1) | 164.62 | 142.27 | (1) | 151.23 | 229.60 | (5) | 4.335+004 | -6.011+004 | 9.928+004 | 000 |
| 3.950 | (1) | 164.62 | 110.01 | (2) | 71.89 | 67.20 | (2) | 1.557+004 | .000 | 9.928+004 | 000 |
| 3.950 | (1) | 164.62 | 131.23 | (3) | 124.17 | 129.20 | (3) | 1.240+004 | -1.025+003 | 9.928+004 | 000 |
| 3.950 | (1) | 164.62 | 129.57 | (4) | 155.98 | 252.00 | (4) | 2.026+004 | -7.222+004 | 9.928+004 | 000 |
| 3.950 | (1) | 164.62 | 129.68 | (5) | 155.85 | 252.00 | (4) | 7.288+003 | -2.614+004 | 9.928+004 | 000 |
| 4.000 | (1) | 164.71 | 142.38 | (1) | 151.36 | 229.60 | (5) | 4.331+004 | -5.998+004 | 9.928+004 | 000 |
| 4.000 | (1) | 164.71 | 110.09 | (2) | 71.92 | 67.20 | (2) | 1.558+004 | .000 | 9.928+004 | 000 |
| 4.000 | (1) | 164.71 | 131.30 | (3) | 124.17 | 129.20 | (3) | 1.241+004 | -1.024+003 | 9.928+004 | 000 |
| 4.000 | (1) | 164.71 | 129.64 | (4) | 156.15 | 252.00 | (4) | 2.028+004 | -7.205+004 | 9.928+004 | 000 |
| 4.000 | (1) | 164.71 | 129.75 | (5) | 156.02 | 252.00 | (4) | 7.295+003 | -2.607+004 | 9.928+004 | 000 |
| 4.050 | (1) | 164.80 | 142.49 | (1) | 151.49 | 229.60 | (5) | 4.328+004 | -5.985+004 | 9.928+004 | 000 |
| 4.050 | (1) | 164.80 | 110.17 | (2) | 71.95 | 67.20 | (2) | 1.558+004 | .000 | 9.928+004 | 000 |
| 4.050 | (1) | 164.80 | 131.36 | (3) | 124.18 | 129.20 | (3) | 1.243+004 | -1.023+003 | 9.928+004 | 000 |
| 4.050 | (1) | 164.80 | 129.71 | (4) | 156.31 | 252.00 | (4) | 2.030+004 | -7.188+004 | 9.928+004 | 000 |
| 4.050 | (1) | 164.80 | 129.82 | (5) | 156.19 | 252.00 | (4) | 7.302+003 | -2.601+004 | 9.928+004 | 000 |
| 4.100 | (1) | 164.90 | 142.60 | (1) | 151.62 | 229.60 | (5) | 4.324+004 | -5.972+004 | 9.928+004 | 000 |
| 4.100 | (1) | 164.90 | 110.25 | (2) | 71.99 | 67.20 | (2) | 1.558+004 | .000 | 9.928+004 | 000 |
| 4.100 | (1) | 164.90 | 131.42 | (3) | 124.18 | 129.20 | (3) | 1.244+004 | -1.021+003 | 9.928+004 | 000 |
| 4.100 | (1) | 164.90 | 129.78 | (4) | 156.48 | 252.00 | (4) | 2.031+004 | -7.171+004 | 9.928+004 | 000 |
| 4.100 | (1) | 164.90 | 129.88 | (5) | 156.35 | 252.00 | (4) | 7.308+003 | -2.595+004 | 9.928+004 | 000 |
| 4.150 | (1) | 164.99 | 142.71 | (1) | 151.74 | 229.60 | (5) | 4.321+004 | -5.959+004 | 9.928+004 | 000 |
| 4.150 | (1) | 164.99 | 110.33 | (2) | 72.02 | 67.20 | (2) | 1.558+004 | .000 | 9.928+004 | 000 |
| 4.150 | (1) | 164.99 | 131.49 | (3) | 124.18 | 129.20 | (3) | 1.245+004 | -1.020+003 | 9.928+004 | 000 |
| 4.150 | (1) | 164.99 | 129.84 | (4) | 156.64 | 252.00 | (4) | 2.033+004 | -7.154+004 | 9.928+004 | 000 |
| 4.150 | (1) | 164.99 | 129.95 | (5) | 156.51 | 252.00 | (4) | 7.315+003 | -2.589+004 | 9.928+004 | 000 |

Calc. No. 3C7-10290-1002
 Revision 1
 Page A16
 Project No. 8726-17

| S&L | NSLD | CALC | 3C7-0290-002 | REV | 1 | PROJECT | B726-17 | PART | 1 | TJB | DATE | 05/12/32 | Page | 1 | Calc. No. | 3C7-0290-002 | Revision | 1 | Page | h17 | Project No. | 8/26-17 |
|--|-------|--------|--------------|------|--------|---------|---------|-----------|------------|-----------|----------|----------|------|---|-----------|--------------|----------|---|------|-----|-------------|---------|
| STATION BLACKOUT RCIC ROOM TEMPERATURE TRANSIENT | | | | | | | | | | | | | | | | | | | | | | |
| t | (IA1) | TA | TW | (IW) | TW | TA | (IA2) | QAE(IW,1) | QAE(IW,2) | QAE(IA1) | QAE(IA2) | | | | | | | | | | | |
| 4.200 | (1) | 165.08 | 142.82 | (1) | 151.86 | 229.60 | (5) | 4.317+004 | -5.946+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.200 | (1) | 165.08 | 110.41 | (2) | 72.05 | 67.20 | (2) | 1.559+004 | -0.000 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.200 | (1) | 165.08 | 131.5 | (3) | 124.19 | 129.20 | (3) | 1.246+004 | -1.019+003 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.200 | (1) | 165.08 | 129.91 | (4) | 156.80 | 252.00 | (4) | 2.034+004 | -7.138+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.200 | (1) | 165.08 | 130.01 | (5) | 156.68 | 252.00 | (4) | 7.321+003 | -2.583+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.250 | (1) | 165.17 | 142.93 | (1) | 151.99 | 229.60 | (5) | 4.314+004 | -5.933+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.250 | (1) | 165.17 | 110.49 | (2) | 72.08 | 67.20 | (2) | 1.559+004 | -0.000 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.250 | (1) | 165.17 | 131.61 | (3) | 124.19 | 129.20 | (3) | 1.248+004 | -1.018+003 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.250 | (1) | 165.17 | 129.98 | (4) | 156.96 | 252.00 | (4) | 2.036+004 | -7.121+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.250 | (1) | 165.17 | 130.08 | (5) | 156.83 | 252.00 | (4) | 7.328+003 | -2.577+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.300 | (1) | 165.25 | 143.03 | (1) | 152.11 | 229.60 | (5) | 4.311+004 | -5.921+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.300 | (1) | 165.25 | 110.57 | (2) | 72.11 | 67.20 | (2) | 1.559+004 | -0.000 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.300 | (1) | 165.25 | 131.67 | (3) | 124.20 | 129.20 | (3) | 1.249+004 | -1.017+003 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.300 | (1) | 165.25 | 130.05 | (4) | 157.12 | 252.00 | (4) | 2.037+004 | -7.105+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.300 | (1) | 165.25 | 130.14 | (5) | 156.99 | 252.00 | (4) | 7.334+003 | -2.572+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.350 | (1) | 165.34 | 143.14 | (1) | 152.23 | 229.60 | (5) | 4.307+004 | -5.909+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.350 | (1) | 165.34 | 110.65 | (2) | 72.15 | 67.20 | (2) | 1.559+004 | -0.000 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.350 | (1) | 165.34 | 131.74 | (3) | 124.20 | 129.20 | (3) | 1.250+004 | -1.016+003 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.350 | (1) | 165.34 | 130.11 | (4) | 157.28 | 252.00 | (4) | 2.039+004 | -7.089+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.350 | (1) | 165.34 | 130.20 | (5) | 157.15 | 252.00 | (4) | 7.340+003 | -2.566+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.400 | (1) | 165.43 | 143.24 | (1) | 152.34 | 229.60 | (5) | 4.304+004 | -5.896+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.400 | (1) | 165.43 | 110.72 | (2) | 72.18 | 67.20 | (2) | 1.560+004 | -0.000 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.400 | (1) | 165.43 | 131.80 | (3) | 124.20 | 129.20 | (3) | 1.251+004 | -1.015+003 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.400 | (1) | 165.43 | 130.18 | (4) | 157.43 | 252.00 | (4) | 2.040+004 | -7.074+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.400 | (1) | 165.43 | 130.27 | (5) | 157.30 | 252.00 | (4) | 7.346+003 | -2.560+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.450 | (1) | 165.52 | 143.34 | (1) | 152.46 | 229.60 | (5) | 4.301+004 | -5.884+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.450 | (1) | 165.52 | 110.80 | (2) | 72.21 | 67.20 | (2) | 1.560+004 | -0.000 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.450 | (1) | 165.52 | 131.86 | (3) | 124.21 | 129.20 | (3) | 1.252+004 | -1.014+003 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.450 | (1) | 165.52 | 130.24 | (4) | 157.58 | 252.00 | (4) | 2.042+004 | -7.058+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.450 | (1) | 165.52 | 130.33 | (5) | 157.45 | 252.00 | (4) | 7.353+003 | -2.555+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.500 | (1) | 165.60 | 143.45 | (1) | 152.58 | 229.60 | (5) | 4.298+004 | -5.872+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.500 | (1) | 165.60 | 110.88 | (2) | 72.24 | 67.20 | (2) | 1.560+004 | -0.000 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.500 | (1) | 165.60 | 131.92 | (3) | 124.21 | 129.20 | (3) | 1.254+004 | -1.012+003 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.500 | (1) | 165.60 | 130.31 | (4) | 157.73 | 252.00 | (4) | 2.043+004 | -7.043+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.500 | (1) | 165.60 | 130.39 | (5) | 157.60 | 252.00 | (4) | 7.359+003 | -2.549+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.550 | (1) | 165.69 | 143.55 | (1) | 152.69 | 229.60 | (5) | 4.295+004 | -5.861+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.550 | (1) | 165.69 | 110.95 | (2) | 72.27 | 67.20 | (2) | 1.560+004 | -0.000 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.550 | (1) | 165.69 | 131.98 | (3) | 124.22 | 129.20 | (3) | 1.255+004 | -1.011+003 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.550 | (1) | 165.69 | 130.37 | (4) | 157.88 | 252.00 | (4) | 2.045+004 | -7.028+004 | 9.928+004 | 000 | | | | | | | | | | | |
| 4.550 | (1) | 165.69 | 130.45 | (5) | 157.75 | 252.00 | (4) | 7.365+003 | -2.544+004 | 9.928+004 | 000 | | | | | | | | | | | |

S&L NSLO CALC 3C7-0290-002 REV 1 PROJECT 8726-17

PART 1 TJB DATE 05/29/

STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT

| t | (iA1) | TA | TW | (iA2) | TW | TA | (iA2) | 0W(iA1) | 0W(iA2) | QA(iA1) | QA(iA2) |
|-------|-------|--------|--------|-------|--------|--------|-------|-----------|------------|-----------|---------|
| 4.600 | (1) | 165.77 | 143.65 | (1) | 152.80 | 229.60 | (5) | 4.291+004 | -5.849+004 | 9.928+004 | .000 |
| 4.600 | (1) | 165.77 | 111.03 | (2) | 72.30 | 67.20 | (2) | 1.561+004 | .000 | 9.928+004 | .000 |
| 4.600 | (1) | 165.77 | 132.04 | (3) | 124.22 | 129.20 | (3) | 1.256+004 | -1.010+003 | 9.928+004 | .000 |
| 4.600 | (1) | 165.77 | 130.44 | (4) | 158.03 | 252.00 | (4) | 2.046+004 | -7.013+004 | 9.928+004 | .000 |
| 4.600 | (1) | 165.77 | 130.51 | (5) | 157.90 | 252.00 | (4) | 7.371+003 | -2.538+004 | 9.928+004 | .000 |
| 4.650 | (1) | 165.86 | 143.75 | (1) | 152.91 | 229.60 | (5) | 4.288+004 | -5.837+004 | 9.928+004 | .000 |
| 4.650 | (1) | 165.86 | 111.10 | (2) | 72.33 | 67.20 | (2) | 1.561+004 | .000 | 9.928+004 | .000 |
| 4.650 | (1) | 165.86 | 132.10 | (3) | 124.22 | 129.20 | (3) | 1.257+004 | -1.009+003 | 9.928+004 | .000 |
| 4.650 | (1) | 165.86 | 130.50 | (4) | 158.17 | 252.00 | (4) | 2.047+004 | -6.998+004 | 9.928+004 | .000 |
| 4.650 | (1) | 165.86 | 130.57 | (5) | 158.04 | 252.00 | (4) | 7.376+003 | -2.533+004 | 9.928+004 | .000 |
| 4.700 | (1) | 165.94 | 143.85 | (1) | 153.03 | 229.60 | (5) | 4.285+004 | -5.826+004 | 9.928+004 | .000 |
| 4.700 | (1) | 165.94 | 111.18 | (2) | 72.36 | 67.20 | (2) | 1.561+004 | .000 | 9.928+004 | .000 |
| 4.700 | (1) | 165.94 | 132.16 | (3) | 124.23 | 129.20 | (3) | 1.258+004 | -1.008+003 | 9.928+004 | .000 |
| 4.700 | (1) | 165.94 | 130.57 | (4) | 158.32 | 252.00 | (4) | 2.049+004 | -6.984+004 | 9.928+004 | .000 |
| 4.700 | (1) | 165.94 | 130.64 | (5) | 158.19 | 252.00 | (4) | 7.382+003 | -2.528+004 | 9.928+004 | .000 |
| 4.750 | (1) | 166.02 | 143.95 | (1) | 153.14 | 229.60 | (5) | 4.282+004 | -5.815+004 | 9.928+004 | .000 |
| 4.750 | (1) | 166.02 | 111.25 | (2) | 72.39 | 67.20 | (2) | 1.561+004 | .000 | 9.928+004 | .000 |
| 4.750 | (1) | 166.02 | 132.21 | (3) | 124.23 | 129.20 | (3) | 1.259+004 | -1.007+003 | 9.928+004 | .000 |
| 4.750 | (1) | 166.02 | 130.63 | (4) | 158.46 | 252.00 | (4) | 2.050+004 | -6.969+004 | 9.928+004 | .000 |
| 4.750 | (1) | 166.02 | 130.70 | (5) | 158.33 | 252.00 | (4) | 7.388+003 | -2.523+004 | 9.928+004 | .000 |
| 4.800 | (1) | 166.11 | 144.04 | (1) | 153.24 | 229.60 | (5) | 4.279+004 | -5.804+004 | 9.928+004 | .000 |
| 4.800 | (1) | 166.11 | 111.32 | (2) | 72.42 | 67.20 | (2) | 1.562+004 | .000 | 9.928+004 | .000 |
| 4.800 | (1) | 166.11 | 132.27 | (3) | 124.24 | 129.20 | (3) | 1.260+004 | -1.006+003 | 9.928+004 | .000 |
| 4.800 | (1) | 166.11 | 130.70 | (4) | 158.60 | 252.00 | (4) | 2.051+004 | -6.955+004 | 9.928+004 | .000 |
| 4.800 | (1) | 166.11 | 130.76 | (5) | 158.47 | 252.00 | (4) | 7.394+003 | -2.517+004 | 9.928+004 | .000 |
| 4.850 | (1) | 166.19 | 144.14 | (1) | 153.35 | 229.60 | (5) | 4.276+004 | -5.792+004 | 9.928+004 | .000 |
| 4.850 | (1) | 166.19 | 111.40 | (2) | 72.45 | 67.20 | (2) | 1.562+004 | .000 | 9.928+004 | .000 |
| 4.850 | (1) | 166.19 | 132.33 | (3) | 124.24 | 129.20 | (3) | 1.262+004 | -1.005+003 | 9.928+004 | .000 |
| 4.850 | (1) | 166.19 | 130.76 | (4) | 158.74 | 252.00 | (4) | 2.052+004 | -6.941+004 | 9.928+004 | .000 |
| 4.850 | (1) | 166.19 | 130.82 | (5) | 158.61 | 252.00 | (4) | 7.400+003 | -2.512+004 | 9.928+004 | .000 |
| 4.900 | (1) | 166.27 | 144.24 | (1) | 153.46 | 229.60 | (5) | 4.274+004 | -5.781+004 | 9.928+004 | .000 |
| 4.900 | (1) | 166.27 | 111.47 | (2) | 72.48 | 67.20 | (2) | 1.562+004 | .000 | 9.928+004 | .000 |
| 4.900 | (1) | 166.27 | 132.39 | (3) | 124.24 | 129.20 | (3) | 1.263+004 | -1.004+003 | 9.928+004 | .000 |
| 4.900 | (1) | 166.27 | 130.82 | (4) | 158.88 | 252.00 | (4) | 2.054+004 | -6.927+004 | 9.928+004 | .000 |
| 4.900 | (1) | 166.27 | 130.87 | (5) | 158.74 | 252.00 | (4) | 7.405+003 | -2.507+004 | 9.928+004 | .000 |
| 4.950 | (1) | 166.35 | 144.33 | (1) | 153.56 | 229.60 | (5) | 4.271+004 | -5.771+004 | 9.928+004 | .000 |
| 4.950 | (1) | 166.35 | 111.54 | (2) | 72.50 | 67.20 | (2) | 1.562+004 | .000 | 9.928+004 | .000 |
| 4.950 | (1) | 166.35 | 132.44 | (3) | 124.25 | 129.20 | (2) | 1.264+004 | -1.003+003 | 9.928+004 | .000 |
| 4.950 | (1) | 166.35 | 130.89 | (4) | 159.02 | 252.00 | (4) | 2.055+004 | -6.913+004 | 9.928+004 | .000 |
| 4.950 | (1) | 166.35 | 130.93 | (5) | 158.88 | 252.00 | (4) | 7.414+003 | -2.502+004 | 9.928+004 | .000 |

Project No. 3C7-0290-002
Revision: J
Page: A18
CALC.

S&L NSLD CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART 1 TJB DATE 051292 FILE 19

STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT

| t | (A1) | TA | TW | (W) | TW | TA | (A2) | QW(W,1) | QW(W,2) | QA(A1) | QA(A2) |
|-------|------|--------|--------|------|--------|--------|------|-----------|------------|-----------|--------|
| 5.000 | (1) | 166.43 | 144.43 | (1) | 153.67 | 229.60 | (5) | 4.268+004 | -5.750+004 | 9.928+004 | 000 |
| 5.000 | (1) | 166.43 | 111.61 | (2) | 72.53 | 67.20 | (2) | 1.562+004 | .000 | 9.928+004 | 000 |
| 5.000 | (1) | 166.43 | 132.50 | (3) | 124.25 | 129.20 | (3) | 1.265+004 | -1.002+003 | 9.928+004 | 000 |
| 5.000 | (1) | 166.43 | 130.95 | (4) | 159.15 | 252.00 | (4) | 2.056+004 | -6.899+004 | 9.928+004 | 000 |
| 5.000 | (1) | 166.43 | 130.99 | (5) | 159.02 | 252.00 | (4) | 7.416+003 | -2.497+004 | 9.928+004 | 000 |
| 5.050 | (1) | 166.51 | 144.52 | (1) | 153.77 | 229.60 | (5) | 4.265+004 | -5.749+004 | 9.928+004 | 000 |
| 5.050 | (1) | 166.51 | 111.58 | (2) | 72.56 | 67.20 | (2) | 1.563+004 | .000 | 9.928+004 | 000 |
| 5.050 | (1) | 166.51 | 132.56 | (3) | 124.25 | 129.20 | (3) | 1.266+004 | -1.001+003 | 9.928+004 | 000 |
| 5.050 | (1) | 166.51 | 131.01 | (4) | 159.29 | 252.00 | (4) | 2.057+004 | -6.886+004 | 9.928+004 | 000 |
| 5.050 | (1) | 166.51 | 131.05 | (5) | 159.15 | 252.00 | (4) | 7.422+003 | -2.493+004 | 9.928+004 | 000 |
| 5.100 | (1) | 166.59 | 144.62 | (1) | 153.88 | 229.60 | (5) | 4.262+004 | -5.739+004 | 9.928+004 | 000 |
| 5.100 | (1) | 166.59 | 111.75 | (2) | 72.59 | 67.20 | (2) | 1.563+004 | .000 | 9.928+004 | 000 |
| 5.100 | (1) | 166.59 | 132.61 | (3) | 124.26 | 129.20 | (3) | 1.267+004 | -1.000+003 | 9.928+004 | 000 |
| 5.100 | (1) | 166.59 | 131.08 | (4) | 159.42 | 252.00 | (4) | 2.058+004 | -6.872+004 | 9.928+004 | 000 |
| 5.100 | (1) | 166.59 | 131.11 | (5) | 159.28 | 252.00 | (4) | 7.427+003 | -2.488+004 | 9.928+004 | 000 |
| 5.150 | (1) | 166.67 | 144.71 | (1) | 153.98 | 229.60 | (5) | 4.259+004 | -5.728+004 | 9.928+004 | 000 |
| 5.150 | (1) | 166.67 | 111.82 | (2) | 72.62 | 67.20 | (2) | 1.563+004 | .000 | 9.928+004 | 000 |
| 5.150 | (1) | 166.67 | 132.67 | (3) | 124.26 | 129.20 | (3) | 1.268+004 | -9.993+002 | 9.928+004 | 000 |
| 5.150 | (1) | 166.67 | 131.14 | (4) | 159.55 | 252.00 | (4) | 2.060+004 | -6.859+004 | 9.928+004 | 000 |
| 5.150 | (1) | 166.67 | 131.17 | (5) | 159.41 | 252.00 | (4) | 7.433+003 | -2.483+004 | 9.928+004 | 000 |
| 5.200 | (1) | 166.75 | 144.81 | (1) | 154.08 | 229.60 | (5) | 4.257+004 | -5.718+004 | 9.928+004 | 000 |
| 5.200 | (1) | 166.75 | 111.89 | (2) | 72.65 | 67.20 | (2) | 1.563+004 | .000 | 9.928+004 | 000 |
| 5.200 | (1) | 166.75 | 132.73 | (3) | 124.27 | 129.20 | (3) | 1.269+004 | -9.983+002 | 9.928+004 | 000 |
| 5.200 | (1) | 166.75 | 131.20 | (4) | 159.68 | 252.00 | (4) | 2.061+004 | -6.845+004 | 9.928+004 | 000 |
| 5.200 | (1) | 166.75 | 131.22 | (5) | 159.54 | 252.00 | (4) | 7.436+003 | -2.478+004 | 9.928+004 | 000 |
| 5.250 | (1) | 166.83 | 144.90 | (1) | 154.18 | 229.60 | (5) | 4.254+004 | -5.707+004 | 9.928+004 | 000 |
| 5.250 | (1) | 166.83 | 111.96 | (2) | 72.67 | 67.20 | (2) | 1.564+004 | .000 | 9.928+004 | 000 |
| 5.250 | (1) | 166.83 | 132.78 | (3) | 124.27 | 129.20 | (3) | 1.270+004 | -9.974+002 | 9.928+004 | 000 |
| 5.250 | (1) | 166.83 | 131.26 | (4) | 159.81 | 252.00 | (4) | 2.062+004 | -6.833+004 | 9.928+004 | 000 |
| 5.250 | (1) | 166.83 | 131.25 | (5) | 159.67 | 252.00 | (4) | 7.444+003 | -2.473+004 | 9.928+004 | 000 |
| 5.300 | (1) | 166.91 | 144.95 | (1) | 154.28 | 229.60 | (5) | 4.251+004 | -5.697+004 | 9.928+004 | 000 |
| 5.300 | (1) | 166.91 | 112.03 | (2) | 72.70 | 67.20 | (2) | 1.564+004 | .000 | 9.928+004 | 000 |
| 5.300 | (1) | 166.91 | 132.84 | (3) | 124.27 | 129.20 | (3) | 1.271+004 | -9.964+002 | 9.928+004 | 000 |
| 5.300 | (1) | 166.91 | 131.33 | (4) | 159.94 | 252.00 | (4) | 2.063+004 | -6.820+004 | 9.928+004 | 000 |
| 5.300 | (1) | 166.91 | 131.34 | (5) | 159.80 | 252.00 | (4) | 7.449+003 | -2.469+004 | 9.928+004 | 000 |
| 5.350 | (1) | 166.98 | 145.08 | (1) | 154.38 | 229.60 | (5) | 4.249+004 | -5.687+004 | 9.928+004 | 000 |
| 5.350 | (1) | 166.98 | 112.10 | (2) | 72.73 | 67.20 | (2) | 1.564+004 | .000 | 9.928+004 | 000 |
| 5.350 | (1) | 166.98 | 132.89 | (3) | 124.28 | 129.20 | (3) | 1.272+004 | -9.955+002 | 9.928+004 | 000 |
| 5.350 | (1) | 166.98 | 131.39 | (4) | 160.07 | 252.00 | (4) | 2.064+004 | -6.807+004 | 9.928+004 | 000 |
| 5.350 | (1) | 166.98 | 131.39 | (5) | 159.93 | 252.00 | (4) | 7.454+003 | -2.464+004 | 9.928+004 | 000 |

Calc. No. 3C7-0290-002
Revision: 1
Page: A19
Project No. 8726-17

S&L NNU CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART 1 TJB DATE 051292 PAGE 1

STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT

| t | (IA1) | TA | TW | (IW) | TW | TA | (IA2) | QW(IW,1) | QW(IW,2) | QAI(IA1) | QAI(IA2) |
|-------|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|----------|
| 5.400 | (1) | 167.06 | 145.17 | (1) | 154.48 | 229.60 | (5) | 4.246+004 | -5.677+004 | 9.928+004 | .000 |
| 5.400 | (1) | 167.06 | 112.17 | (2) | 72.76 | 67.20 | (2) | 1.564+004 | .000 | 9.928+004 | .000 |
| 5.400 | (1) | 167.06 | 132.95 | (3) | 124.28 | 129.20 | (3) | 1.273+004 | -9.945+002 | 9.928+004 | .000 |
| 5.400 | (1) | 167.06 | 131.45 | (4) | 160.19 | 252.00 | (4) | 2.065+004 | -6.794+004 | 9.928+004 | .000 |
| 5.400 | (1) | 167.06 | 131.45 | (5) | 160.05 | 252.00 | (4) | 7.460+003 | -2.460+004 | 9.928+004 | .000 |
| 5.450 | (1) | 167.14 | 145.26 | (1) | 154.57 | 229.60 | (5) | 4.243+004 | -5.667+004 | 9.928+004 | .000 |
| 5.450 | (1) | 167.14 | 112.23 | (2) | 72.78 | 67.20 | (2) | 1.565+004 | .000 | 9.928+004 | .000 |
| 5.450 | (1) | 167.14 | 133.00 | (3) | 124.28 | 129.20 | (3) | 1.274+004 | -9.936+002 | 9.928+004 | .000 |
| 5.450 | (1) | 167.14 | 131.51 | (4) | 160.32 | 252.00 | (4) | 2.066+004 | -6.782+004 | 9.928+004 | .000 |
| 5.450 | (1) | 167.14 | 131.51 | (5) | 160.18 | 252.00 | (4) | 7.465+003 | -2.455+004 | 9.928+004 | .000 |
| 5.500 | (1) | 167.21 | 145.35 | (1) | 154.67 | 229.60 | (5) | 4.241+004 | -5.657+004 | 9.928+004 | .000 |
| 5.500 | (1) | 167.21 | 112.30 | (2) | 72.81 | 67.20 | (2) | 1.565+004 | .000 | 9.928+004 | .000 |
| 5.500 | (1) | 167.21 | 133.05 | (3) | 124.29 | 129.20 | (3) | 1.275+004 | -9.927+002 | 9.928+004 | .000 |
| 5.500 | (1) | 167.21 | 131.57 | (4) | 160.44 | 252.00 | (4) | 2.067+004 | -6.769+004 | 9.928+004 | .000 |
| 5.500 | (1) | 167.21 | 131.56 | (5) | 160.30 | 252.00 | (4) | 7.470+003 | -2.451+004 | 9.928+004 | .000 |
| 5.550 | (1) | 167.29 | 145.44 | (1) | 154.77 | 229.60 | (5) | 4.238+004 | -5.648+004 | 9.928+004 | .000 |
| 5.550 | (1) | 167.29 | 112.37 | (2) | 72.84 | 67.20 | (2) | 1.365+004 | .000 | 9.928+004 | .000 |
| 5.550 | (1) | 167.29 | 133.11 | (3) | 124.29 | 129.20 | (3) | 1.276+004 | -9.918+002 | 9.928+004 | .000 |
| 5.550 | (1) | 167.29 | 131.64 | (4) | 160.57 | 252.00 | (4) | 2.068+004 | -6.757+004 | 9.928+004 | .000 |
| 5.550 | (1) | 167.29 | 131.62 | (5) | 160.42 | 252.00 | (4) | 7.475+003 | -2.446+004 | 9.928+004 | .000 |
| 5.600 | (1) | 167.37 | 145.53 | (1) | 154.86 | 229.60 | (5) | 4.236+004 | -5.638+004 | 9.928+004 | .000 |
| 5.600 | (1) | 167.37 | 112.43 | (2) | 72.86 | 67.20 | (2) | 1.565+004 | .000 | 9.928+004 | .000 |
| 5.600 | (1) | 167.37 | 133.16 | (3) | 124.29 | 129.20 | (3) | 1.277+004 | -9.909+002 | 9.928+004 | .000 |
| 5.600 | (1) | 167.37 | 131.70 | (4) | 160.69 | 252.00 | (4) | 2.069+004 | -6.745+004 | 9.928+004 | .000 |
| 5.600 | (1) | 167.37 | 131.67 | (5) | 160.54 | 252.00 | (4) | 7.481+003 | -2.442+004 | 9.928+004 | .000 |
| 5.650 | (1) | 167.44 | 145.62 | (1) | 154.96 | 229.60 | (5) | 4.233+004 | -5.628+004 | 9.928+004 | .000 |
| 5.650 | (1) | 167.44 | 112.50 | (2) | 72.89 | 67.20 | (2) | 1.566+004 | .000 | 9.928+004 | .000 |
| 5.650 | (1) | 167.44 | 133.22 | (3) | 124.30 | 129.20 | (3) | 1.278+004 | -9.900+002 | 9.928+004 | .000 |
| 5.650 | (1) | 167.44 | 131.76 | (4) | 160.81 | 252.00 | (4) | 2.070+004 | -6.733+004 | 9.928+004 | .000 |
| 5.650 | (1) | 167.44 | 131.73 | (5) | 160.66 | 252.00 | (4) | 7.486+003 | -2.438+004 | 9.928+004 | .000 |
| 5.700 | (1) | 167.52 | 145.71 | (1) | 155.05 | 229.60 | (5) | 4.231+004 | -5.619+004 | 9.928+004 | .000 |
| 5.700 | (1) | 167.52 | 112.57 | (2) | 72.92 | 67.20 | (2) | 1.566+004 | .000 | 9.928+004 | .000 |
| 5.700 | (1) | 167.52 | 133.27 | (3) | 124.30 | 129.20 | (3) | 1.279+004 | -9.891+002 | 9.928+004 | .000 |
| 5.700 | (1) | 167.52 | 131.82 | (4) | 160.93 | 252.00 | (4) | 2.071+004 | -6.720+004 | 9.928+004 | .000 |
| 5.700 | (1) | 167.52 | 131.78 | (5) | 160.78 | 252.00 | (4) | 7.491+003 | -2.433+004 | 9.928+004 | .000 |
| 5.750 | (1) | 167.59 | 145.79 | (1) | 155.14 | 229.60 | (5) | 4.228+004 | -5.609+004 | 9.928+004 | .000 |
| 5.750 | (1) | 167.59 | 112.63 | (2) | 72.94 | 67.20 | (2) | 1.566+004 | .000 | 9.928+004 | .000 |
| 5.750 | (1) | 167.59 | 133.32 | (3) | 124.30 | 129.20 | (3) | 1.280+004 | -9.882+002 | 9.928+004 | .000 |
| 5.750 | (1) | 167.59 | 131.88 | (4) | 161.05 | 252.00 | (4) | 2.071+004 | -6.709+004 | 9.928+004 | .000 |
| 5.750 | (1) | 167.59 | 131.84 | (5) | 160.90 | 252.00 | (4) | 7.496+003 | -2.429+004 | 9.928+004 | .000 |

Calc. No.: 3C7-0290-002
 Revision: 1
 Page: A20
 Project No.: 8726-17

S&L NSLD CALC 3C7-0290-002 REV 1 PROJECT 8726-17 PART I TJB DATE 051292 PAGE 1

STATION BLACKOUT: RCIC ROOM TEMPERATURE TRANSIENT

| t | (IA1) | TA | TW | (IW) | TW | TA | (IA2) | OW(IW,1) | OW(IW,2) | QA(IA1) | QA(IA2) |
|-------|-------|--------|--------|------|--------|--------|-------|-----------|------------|-----------|---------|
| 5.800 | (1) | 167.67 | 145.88 | (1) | 155.23 | 229.60 | (5) | 4.226+004 | -5.600+004 | 9.928+004 | .000 |
| 5.800 | (1) | 167.67 | 112.70 | (2) | 72.97 | 67.20 | (2) | 1.566+004 | .000 | 9.928+004 | .000 |
| 5.800 | (1) | 167.67 | 133.37 | (3) | 124.31 | 129.20 | (3) | 1.281+004 | -9.873+002 | 9.928+004 | .000 |
| 5.800 | (1) | 167.67 | 131.94 | (4) | 161.17 | 252.00 | (4) | 2.072+004 | -6.697+004 | 9.928+004 | .000 |
| 5.800 | (1) | 167.67 | 131.89 | (5) | 161.02 | 252.00 | (4) | 7.501+003 | -2.425+004 | 9.928+004 | .000 |
| 5.850 | (1) | 167.74 | 145.97 | (1) | 155.33 | 229.50 | (5) | 4.223+004 | -5.590+004 | 9.928+004 | .000 |
| 5.850 | (1) | 167.74 | 112.76 | (2) | 72.99 | 67.20 | (2) | 1.566+004 | .000 | 9.928+004 | .000 |
| 5.850 | (1) | 167.74 | 133.43 | (3) | 124.31 | 129.20 | (3) | 1.282+004 | -9.865+002 | 9.928+004 | .000 |
| 5.850 | (1) | 167.74 | 132.00 | (4) | 161.28 | 252.00 | (4) | 2.073+004 | -6.685+004 | 9.928+004 | .000 |
| 5.850 | (1) | 167.74 | 131.95 | (5) | 161.13 | 252.00 | (4) | 7.506+003 | -2.421+004 | 9.928+004 | .000 |
| 5.900 | (1) | 167.81 | 146.05 | (1) | 155.42 | 229.60 | (5) | 4.221+004 | -5.581+004 | 9.928+004 | .000 |
| 5.900 | (1) | 167.81 | 112.82 | (2) | 73.02 | 67.20 | (2) | 1.567+004 | .000 | 9.928+004 | .000 |
| 5.900 | (1) | 167.81 | 133.48 | (3) | 124.31 | 129.20 | (3) | 1.283+004 | -9.856+002 | 9.928+004 | .000 |
| 5.900 | (1) | 167.81 | 132.07 | (4) | 161.40 | 252.00 | (4) | 2.074+004 | -6.673+004 | 9.928+004 | .000 |
| 5.900 | (1) | 167.81 | 132.00 | (5) | 161.25 | 252.00 | (4) | 7.511+003 | -2.416+004 | 9.928+004 | .000 |
| 5.950 | (1) | 167.89 | 146.14 | (1) | 155.51 | 229.60 | (5) | 4.218+004 | -5.572+004 | 9.928+004 | .000 |
| 5.950 | (1) | 167.89 | 112.89 | (2) | 73.05 | 67.20 | (2) | 1.567+004 | .000 | 9.928+004 | .000 |
| 5.950 | (1) | 167.89 | 133.53 | (3) | 124.32 | 129.20 | (3) | 1.284+004 | -9.847+002 | 9.928+004 | .000 |
| 5.950 | (1) | 167.89 | 132.13 | (4) | 161.52 | 252.00 | (4) | 2.075+004 | -6.662+004 | 9.928+004 | .000 |
| 5.950 | (1) | 167.89 | 132.05 | (5) | 161.36 | 252.00 | (4) | 7.516+003 | -2.412+004 | 9.928+004 | .000 |
| 6.000 | (1) | 167.96 | 146.23 | (1) | 155.60 | 229.60 | (5) | 4.216+004 | -5.563+004 | 9.928+004 | .000 |
| 6.000 | (1) | 167.96 | 112.95 | (2) | 73.07 | 67.20 | (2) | 1.567+004 | .000 | 9.928+004 | .000 |
| 6.000 | (1) | 167.96 | 133.58 | (3) | 124.32 | 129.20 | (3) | 1.285+004 | -9.839+002 | 9.928+004 | .000 |
| 6.000 | (1) | 167.96 | 132.19 | (4) | 161.63 | 252.00 | (4) | 2.075+004 | -6.650+004 | 9.928+004 | .000 |
| 6.000 | (1) | 167.96 | 132.11 | (5) | 161.47 | 252.00 | (4) | 7.521+003 | -2.408+004 | 9.928+004 | .000 |

END RATT

PROGRAM HAD O D VRFLW, O UNDFLW, 4 DIVFLT, O O/O FLT .

@HDG, N

Calc. No. 3C7-0290-002
 Revision: 1
 Page: A21/21
 Project No. 8726-17