

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.6.1-1 to determine which SRs apply for each Primary Containment Isolation Function.
 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains primary containment isolation capability.
-

SURVEILLANCE		FREQUENCY
SR 3.3.6.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.6.1.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.6.1.3	-----NOTE----- For Function 1.d, radiation detectors are excluded. ----- Perform CHANNEL CALIBRATION.	92 days
SR 3.3.6.1.4	-----NOTE----- Prior to installation of Modification 5386, CHANNEL CALIBRATION frequency for Function 2.c is 12 months. ----- Perform CHANNEL CALIBRATION.	18 months
SR 3.3.6.1.5	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.6.1.6	Calibrate each radiation detector.	24 months
SR 3.3.6.1.7	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

9601230235 960116
PDR ADOCK 05000277
P PDR

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 1 of 3)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Main Steam Line Isolation					
a. Reactor Vessel Water Level - Low Low Low (Level 1)	1,2,3	2	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ -160.0 inches
b. Main Steam Line Pressure - Low	1	2	E	SR 3.3.6.1.3 SR 3.3.6.1.7	≥ 850.0 psig
c. Main Steam Line Flow - High	1,2,3	2 per MSL	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 123.3 psid
d. Main Steam Line - High Radiation	1,2,3	2	D	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 15 X Full Power Background
e. Main Steam Tunnel Temperature - High	1,2,3	8	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 200.0 °F
2. Primary Containment Isolation					
a. Reactor Vessel Water Level - Low (Level 3)	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 1.0 inches
b. Drywell Pressure - High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 2.0 psig
c. Main Stack Monitor Radiation - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.7	≤ 2 X 10 ⁻² μCi/cc ^(b)
d. Reactor Building Ventilation Exhaust Radiation - High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 16.0 mR/hr
e. Refueling Floor Ventilation Exhaust Radiation - High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 16.0 mR/hr

(continued)

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 3 of 3)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. Reactor Water Cleanup (RWCU) System Isolation					
a. RWCU Flow - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 125% rated flow (23.0 in-wc)
b. SLC System Initiation	1,2	1	H	SR 3.3.6.1.7	NA
c. Reactor Vessel Water Level - Low (Level 3)	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 1.0 inches
6. RHR Shutdown Cooling System Isolation					
a. Reactor Pressure - High	1,2,3	1	F	SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 70.0 psig
b. Reactor Vessel Water Level - Low (Level 3)	3,4,5	2 ^(a)	I	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 1.0 inches
7. Feedwater Recirculation Isolation					
a. Reactor Pressure - High	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 600 psig

(a) In MODES 4 and 5, provided RHR Shutdown Cooling System integrity is maintained, only one channel per trip system with an isolation signal available to one shutdown cooling pump suction isolation valve is required.

(b) Prior to the installation of Modification 5386, the Allowable Value of Function 2.c is ≤ 1X10⁶ cps.

SURVEILLANCE REQUIREMENTS

-----NOTES-----

1. Refer to Table 3.3.6.1-1 to determine which SRs apply for each Primary Containment Isolation Function.
 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains primary containment isolation capability.
-

SURVEILLANCE		FREQUENCY
SR 3.3.6.1.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.6.1.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.6.1.3	-----NOTE----- For Function 1.d, radiation detectors are excluded. ----- Perform CHANNEL CALIBRATION.	92 days
SR 3.3.6.1.4	-----NOTE----- Prior to installation of Modification 5386, CHANNEL CALIBRATION frequency for Function 2.c is 12 months. ----- Perform CHANNEL CALIBRATION.	18 months
SR 3.3.6.1.5	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.6.1.6	Calibrate each radiation detector.	24 months
SR 3.3.6.1.7	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

Primary Containment Isolation Instrumentation
3.3.6.1

Table 3.3.6.1-1 (page 1 of 3)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Main Steam Line Isolation					
a. Reactor Vessel Water Level - Low Low Low (Level 1)	1,2,3	2	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ -160.0 inches
b. Main Steam Line Pressure - Low	1	2	E	SR 3.3.6.1.3 SR 3.3.6.1.7	≥ 850.0 psig
c. Main Steam Line Flow - High	1,2,3	2 per MSL	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 123.3 psid
d. Main Steam Line - High Radiation	1,2,3	2	D	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 15 X Full Power Background
e. Main Steam Tunnel Temperature - High	1,2,3	8	D	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 200.0 °F
2. Primary Containment Isolation					
a. Reactor Vessel Water Level - Low (Level 3)	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 1.0 inches
b. Drywell Pressure - High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 2.0 psig
c. Main Stack Monitor Radiation - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.7	≤ 2 X 10 ⁻² μCi/cc ^(b)
d. Reactor Building Ventilation Exhaust Radiation - High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 16.0 mR/hr
e. Refueling Floor Ventilation Exhaust Radiation - High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 16.0 mR/hr

(continued)

Table 3.3.6.1-1 (page 3 of 3)
Primary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. Reactor Water Cleanup (RWCU) System Isolation					
a. RWCU Flow - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 125% rated flow (23.0 in-wc)
b. SLC System Initiation	1,2	1	H	SR 3.3.6.1.7	NA
c. Reactor Vessel Water Level - Low (Level 3)	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 1.0 inches
6. RHR Shutdown Cooling System Isolation					
a. Reactor Pressure - High	1,2,3	1	F	SR 3.3.6.1.3 SR 3.3.6.1.7	≤ 70.0 psig
b. Reactor Vessel Water Level - Low (Level 3)	3,4,5	2 ^(a)	I	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≥ 1.0 inches
7. Feedwater Recirculation Isolation					
a. Reactor Pressure - High	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 600 psig

(a) In MODES 4 and 5, provided RHR Shutdown Cooling System integrity is maintained, only one channel per trip system with an isolation signal available to one shutdown cooling pump suction isolation valve is required.

(b) Prior to the installation of Modification 5386, the Allowable Value of Function 2.c is ≤ 1X10⁴ cps.

ATTACHMENT 2

BASES

APPLICABLE
SAFETY ANALYSES,
LCO, and
APPLICABILITY

2.b. Drywell Pressure-High (continued)

The Allowable Value was selected to be the same as the ECCS Drywell Pressure-High Allowable Value (LCO 3.3.5.1), since this may be indicative of a LOCA inside primary containment.

This Function isolates the Group II(B) valves listed in Reference 1.

2.c. Main Stack Monitor Radiation-High

Main stack monitor radiation is an indication that the release of radioactive material may exceed established limits. Therefore, when Main Stack Monitor Radiation-High is detected when there is flow through the Standby Gas Treatment System, an isolation of primary containment purge supply and exhaust penetrations is initiated to limit the release of fission products. However, this Function is not assumed in any accident or transient analysis in the UFSAR because other leakage paths (e.g., MSIVs) are more limiting.

The drywell radiation signals are initiated from radiation detectors that isokinetically sample the main stack utilizing sample pumps. Two channels of Main Stack Radiation-High Function are available and are required to be OPERABLE to ensure that no single instrument failure can preclude the isolation function.

The Allowable Value includes both the pre and post modification (5386) Allowable Values. Modification 5386 is being installed post ITS implementation due to an installation schedule change. The Allowable Value is set below the maximum allowable release limit in accordance with the Offsite Dose Calculation Manual (ODCM).

This Function isolates the containment vent and purge valves and other Group III(E) valves listed in Reference 1.

2.d., 2.e. Reactor Building Ventilation and Refueling Floor Ventilation Exhaust Radiation-High

High secondary containment exhaust radiation is an indication of possible gross failure of the fuel cladding. The release may have originated from the primary containment due to a break in the RCPB. When Reactor Building or Refueling Floor Ventilation Exhaust Radiation-High is detected, the affected ventilation pathway and primary

(continued)

BASES

SURVEILLANCE REQUIREMENTS SR 3.3.6.1.3, SR 3.3.6.1.4, SR 3.3.6.1.5, and SR 3.3.6.1.6 (continued)

The 92 day Frequency of SR 3.3.6.1.3 is conservative with respect to the magnitude of equipment drift assumed in the setpoint analysis. The Frequency of SR 3.3.6.1.4 is based on the assumption of an 18 month calibration interval in the determination of the magnitude of equipment drift in the setpoint analysis. SR 3.3.6.1.4 includes a Note that prior to the installation of Modification 5386, the calibration frequency is 12 months for each radiation monitor. The Frequencies of SR 3.3.6.1.5 and SR 3.3.6.1.6 are based on the assumption of a 24 month calibration interval in the determination of the magnitude of equipment drift in the setpoint analysis.

SR 3.3.6.1.7

The LOGIC SYSTEM FUNCTIONAL TEST demonstrates the OPERABILITY of the required isolation logic for a specific channel. The system functional testing performed on PCIVs in LCO 3.6.1.3 overlaps this Surveillance to provide complete testing of the assumed safety function.

While this Surveillance can be performed with the reactor at power for some of the Functions, operating experience has shown these components will pass the Surveillance when performed at the 24 month Frequency. Therefore, the Frequency was found to be acceptable from a reliability standpoint.

REFERENCES

1. UFSAR, Section 7.3.
2. NRC Safety Evaluation Report for Amendment Numbers 156 and 158 to Facility Operating License Numbers DPR-44 and DPR-56, Peach Bottom Atomic Power Station, Unit Nos. 2 and 3, September 7, 1990.
3. UFSAR, Chapter 14.
4. NEDO-31466, "Technical Specification Screening Criteria Application and Risk Assessment," November 1987.
5. UFSAR, Section 4.9.3.

(continued)

BASES

APPLICABLE
SAFETY ANALYSES,
LCO, and
APPLICABILITY

2.b. Drywell Pressure-High (continued)

The Allowable Value was selected to be the same as the ECCS Drywell Pressure-High Allowable Value (LCO 3.3.5.1), since this may be indicative of a LOCA inside primary containment.

This Function isolates the Group II(B) valves listed in Reference 1.

2.c. Main Stack Monitor Radiation-High

Main stack monitor radiation is an indication that the release of radioactive material may exceed established limits. Therefore, when Main Stack Monitor Radiation-High is detected when there is flow through the Standby Gas Treatment System, an isolation of primary containment purge supply and exhaust penetrations is initiated to limit the release of fission products. However, this Function is not assumed in any accident or transient analysis in the UFSAR because other leakage paths (e.g., MSIVs) are more limiting.

The drywell radiation signals are initiated from radiation detectors that isokinetically sample the main stack utilizing sample pumps. Two channels of Main Stack Radiation-High Function are available and are required to be OPERABLE to ensure that no single instrument failure can preclude the isolation function.

The Allowable Value includes both the pre and post modification (5386) Allowable Values. Modification 5385 is being installed post ITS implementation due to an installation schedule change. The Allowable Value is set below the maximum allowable release limit in accordance with the Offsite Dose Calculation Manual (ODCM).

This Function isolates the containment vent and purge valves and other Group III(E) valves listed in Reference 1.

2.d., 2.e. Reactor Building Ventilation and Refueling Floor Ventilation Exhaust Radiation-High

High secondary containment exhaust radiation is an indication of possible gross failure of the fuel cladding. The release may have originated from the primary containment due to a break in the RCPB. When Reactor Building or Refueling Floor Ventilation Exhaust Radiation-High is detected, the affected ventilation pathway and primary

(continued)

BASES

SURVEILLANCE
REQUIREMENTS
(continued)

SR 3.3.6.1.2

A CHANNEL FUNCTIONAL TEST is performed on each required channel to ensure that the entire channel will perform the intended function. Any setpoint adjustment shall be consistent with the assumptions of the current plant specific setpoint methodology.

The 92 day Frequency of SR 3.3.6.1.2 is based on the reliability analysis described in Reference 7.

SR 3.3.6.1.3, SR 3.3.6.1.4, SR 3.3.6.1.5, and
SR 3.3.6.1.6

A CHANNEL CALIBRATION is a complete check of the instrument loop and the sensor. This test verifies the channel responds to the measured parameter within the necessary range and accuracy. CHANNEL CALIBRATION leaves the channel adjusted to account for instrument drifts between successive calibrations, consistent with the assumptions of the current setpoint methodology. SR 3.3.6.1.6, however, is only a calibration of the radiation detectors using a standard radiation source.

As noted for SR 3.3.6.1.3, the main steam line radiation detectors (Function 1.d) are excluded from CHANNEL CALIBRATION due to ALARA reasons (when the plant is operating, the radiation detectors are generally in a high radiation area; the steam tunnel). This exclusion is acceptable because the radiation detectors are passive devices, with minimal drift. The radiation detectors are calibrated in accordance with SR 3.3.6.1.6 on a 24 month Frequency.

The 92 day Frequency of SR 3.3.6.1.3 is conservative with respect to the magnitude of equipment drift assumed in the setpoint analysis. The Frequency of SR 3.3.6.1.4 is based on the assumption of an 18 month calibration interval in the determination of the magnitude of equipment drift in the setpoint analysis. SR 3.3.6.1.4 includes a Note that prior to the installation of Modification 5386, the calibration frequency is 12 months for each radiation monitor. The Frequencies of SR 3.3.6.1.5 and SR 3.3.6.1.6 are based on the assumption of a 24 month calibration interval in the determination of the magnitude of equipment drift in the setpoint analysis.

(continued)