


WEC PROPRIETARY CLASS 3



Westinghouse Energy Systems




9205200319 920508
PDR ADOCK 05000338
P PDR

North Anna Unit 1
Steam Generator Startup Approval Meeting
Presentation Materials

April 1992

Approved by:



M. J. Wootten, Manager
Steam Generator Technology & Engineering

WESTINGHOUSE ELECTRIC CORPORATION
Nuclear Services Division
P.O. Box 355
Pittsburgh, PA 15230-0355

A meeting was held on March 2, 1992 between Virginia Power Company, Westinghouse and the NRR at One White Flint Building, Rockville, MD, to discuss the status of the North Anna Unit 1 steam generators. The meeting agenda included discussions on:

1. Basis for Startup Approval (Virginia Power)
2. Summary of SG Tube Eddy Current Inspection Program and Results (Virginia Power)
3. Detailed Discussion of Inspection Results (Westinghouse)
4. Tube Integrity Evaluation (Westinghouse)
5. Operational Considerations (Virginia Power)
6. Startup Basis Summary and Schedule (Virginia Power)

This document presents a compilation of the presentation materials used by Westinghouse. Section 1 presents the materials used for the "Detailed Discussion of Inspection Results". Section 2 presents the "Tube Integrity Evaluation" presentation materials. Section 3 contains information which was not included directly in the presentations to the NRC on March 2, 1992, but which was provided to supplement the materials presented in Sections 1 and 2 of this report, as follows:

Pages 3-2 to 3-7 provide supplementary data for the evaluation of tubes with mixed mode degradation at the TSPs. Pages 3-2 and 3-3 show eddy current data from the 2-coil RPC for tube R8C33-2H (SG C), which is one of 7 tubes shown on page 1-18 with mixed mode indications at the same edge of the TSP. Pages 3-4 to 3-7 show EC data from 2-coil and 3-coil RPC probes for tube R14C10-2H (SG C), which had axial and circumferential indications at opposite edges of the TSP (see page 2-27); the figures indicate that the 3-coil RPC did not improve resolution of potential mixed mode indications at the same elevation relative to the 2-coil RPC.

Page 3-8 shows a plot of burst pressure vs. crack angle for single throughwall and segmented cracks. Page 3-9 shows burst pressure vs. crack angle for single cracks with 50% deep circumferential degradation beyond the throughwall region of the crack. These figures supplement the tube burst capability summary on page 2-13.

Pages 3-10 to 3-12 provide supplementary eddy current data on the tubes with the largest circumferential indications presented on page 2-14.

Pages 3-13 to 3-15 provide supplementary eddy current data for the assessment of WEXTEx and TSP MCIs on page 2-21.

Pages 3-16 and 3-17 show eddy current data for tube R29C16-1H of SG C, supplementing the data for potential mixed mode cracking presented on pages 2-24 to 2-26.

Page 3-18 provides eddy current data for tube R25C8 of SG B, which had the largest WEXTEx circumferential indication in Zone 1 for the tube vibration assessment (page 2-31).

Page 3-19 provides eddy current data for tube R45C50-1H of SG A, which had the largest TSP circumferential indication in Zone 1 for the tube vibration assessment (page 2-33).

Page 3-20 supplements the summary of the EOC SLB leakage evaluation presented on page 2-36.

Westinghouse

Detailed Discussion of Inspection Results

D. D. Malinowski

NORTH ANNA #1

FEBRUARY 1992

TUBE PLUGGING SUMMARY

| | A | B | C |
|-------------------|-------|-------|-------|
| THROUGH 1991 | 463 | 425 | 650 |
| WEXTEX (HL) (RPC) | 15 | 10 | 11 |
| TSP (HL) (RPC) | 143 | 148 | 178 |
| OTHER (BOBBIN) | 1 | 0 | 2 |
| PREVENTIVE | 7 | 2 | 10 |
| TOTAL 1992 | 166 | 160 | 201 |
| CUMULATIVE | 629 | 585 | 851 |
| % PLUGGED | 18.6% | 17.3% | 25.1% |

NORTH ANNA #1
FEBRUARY 1992

WEXTEx INSPECTION RESULTS


| # TUBES | STEAM GENERATOR | | |
|--------------------------|-----------------|---|---|
| | A | B | C |
| SINGLE AXIAL | 3 | 0 | 2 |
| MULTIPLE AXIAL | 0 | 0 | 0 |
| SINGLE CIRCUMFERENTIAL | 10 | 9 | 7 |
| MULTIPLE CIRCUMFERENTIAL | 2 | 1 | 2 |

- THERE WERE 0 TUBES WITH MIXED MODE DEGRADATION IDENTIFIED IN THE WEXTEx TRANSITIONS.

NORTH ANNA UNIT 1 S/G A 2/27 PLUG LIST WEXTEX INDICATIONS (RPC PROBES)

MAP STATISTICS

| | | | |
|---|---|----|---|
| ● | A | ■ | M |
| 3 | 0 | 10 | 2 |



MANWAY
NOZZLE

● SAI

▲ MAI

■ SCI

■ MCI


TOP OF TUBESHEET

NORTH ANNA UNIT 1 S/G B 2/27 PLUG LIST

WEXTEX INDICATIONS (RPC PROBES)

MAF STATISTICS

| | |
|---|---|
| ● | 0 |
| ▲ | 0 |
| ■ | 9 |
| ■ | 1 |



1 - 5



● SAI
▲ MAI
■ TOP OF TUBESHEET

■ SCI

■ MCI

NORTH ANNA UNIT 1 S/G C 2/27/92 PLUG LIST


WEXTEX INDICATIONS (RPC PROBES)



- SAI
- ▲ MAI
- TOP OF TUBESHEET
- SCl
- MCl

NORTH ANNA UNIT 1 ALL S/G'S WEXTEX CIRCUMFERENTIAL INDICATIONS

CUMULATIVE DISTRIBUTION FUNCTION



1991 HISTOGRAM
 1992 HISTOGRAM
 1991 CPDF
 1992 CPDF

NORTH ANNA #1

FEBRUARY 1992


TSP CIRCUMFERENTIAL CRACKS

| ELEVATION | STEAM GENERATOR | | |
|-----------|-----------------|--------------|--------------|
| | A SCI/MCI | B SCI/MCI | C SCI/MCI |
| 1H | 25/3 | 22/0 | 27/0 |
| 2H | 15/0 | 33/3 | 42/3 |
| 3H | 2/0 | 7/2 | 19/1 |
| 4H | 3/0 | 0/0 | 3/0 |
| 5H | 1/0 | 0/0 | 1/0 |
| 6H | 0/0 | 0/0 | 0/0 |
| 7H | 0/0 | 0/0 | 0/0 |

SCI - SINGLE CIRCUMFERENTIAL INDICATION
MCI - MULTIPLE CIRCUMFERENTIAL INDICATIONS

NORTH ANNA UNIT 1 S/G A 2/27 PLUG LIST SUPPORT PLATE CIRCUMFERENTIAL INDICATIONS (RPC)

MAP STATISTICS
 C 25 15 2 3 1
 A 3 0 0 0 0




- SC1
 - TSP 1
 - TSP 5
 - ▲ MCI
 - TSP 2
 - TSP 6
 - TSP 3
 - TSP 7
 - TSP 4
- STEAM GENERATOR INFORMATION SYSTEM (C) WESTINGHOUSE ELECTRIC CO. 1986

NORTH ANNA UNIT 1 S/G B 2/27 PLUG LIST

SUPPORT PLATE CIRCUMFERENTIAL INDICATIONS (RPC)

MAP STATISTICS

| | | | |
|---|----|----|---|
| ● | 22 | 33 | 7 |
| ▲ | 0 | 3 | 2 |



MANWAY

NOZZLE


- SCI
- ▲ MCI
- TSP 1
- TSP 2
- TSP 3
- TSP 4
- TSP 5
- TSP 6
- TSP 7

STEAM GENERATOR INFORMATION SYSTEM (C) WESTINGHOUSE ELECTRIC CORP 1990 DATE PLOTTED: 7/27/1993

NORTH ANNA UNIT 1 S/G C 2/27/92 PLUG LIST SUPPORT PLATE CIRCUMFERENTIAL INDICATIONS (RPC)

MAP STATISTICS

| | | | | | | |
|----|----|----|---|---|---|---|
| ● | ▲ | ■ | ■ | ■ | ■ | ■ |
| 27 | 42 | 19 | 3 | 1 | 0 | 0 |



MANWAY


NOZZLE

- SCI
- ▲ MCI
- TSP 1
- TSP 2
- TSP 3
- TSP 4
- TSP 5
- TSP 6
- TSP 7

STEAM GENERATOR INFORMATION SYSTEM (C) WESTINGHOUSE ELECTRIC CORP. 1990

DATE PLOTTED

NORTH ANNA UNIT 1 ALL S/G's SUPPORT PLATE CIRCUMFERENTIAL IND.



1 - 12

1991 HISTOGRAM
 1992 HISTOGRAM
 1991 CPDF
 1992 CPDF

NORTH ANNA #1
FEBRUARY 1992

TSP AXIAL CRACKS

| ELEVATION | STEAM GENERATOR | | |
|-----------|-----------------|--------------|--------------|
| | A SAI/MAI | B SAI/MAI | C SAI/MAI |
| 1H | 36/0 | 53/4 | 37/5 |
| 2H | 24/2 | 14/3 | 41/1 |
| 3H | 7/0 | 6/0 | 5/1 |
| 4H | 5/0 | 5/0 | 8/0 |
| 5H | 21/0 | 1/0 | 1/0 |
| 6H | 3/0 | 1/0 | 2/0 |
| 7H | 0/0 | 0/0 | 0/0 |


SAI - SINGLE AXIAL INDICATION
MAI - MULTIPLE AXIAL INDICATIONS

NORTH ANNA UNIT 1 S/G A 2/27 PLUG LIST

SUPPORT PLATE AXIAL INDICATIONS (RPC)

MAP STATISTICS

| | | | | | | |
|---|----|----|---|---|----|---|
| ● | 36 | 24 | 7 | 5 | 21 | 3 |
| ▲ | 0 | 2 | 0 | 0 | 0 | 0 |



1 - 14

| | | | |
|---------|---------|---------|---------|
| ● SAI | ▲ MAI | ■ TSP 3 | ■ TSP 4 |
| ■ TSP 1 | ■ TSP 2 | ■ TSP 5 | ■ TSP 6 |
| ■ TSP 5 | ■ TSP 6 | ■ TSP 7 | |


SITAM GENERATOR INFORMATION SYSTEM (C) WESTINGHOUSE ELECTRIC CORP. 1990 DATE PLATED: 5/23/93

NORTH ANNA UNIT 1 S/G C 2/27/92 PLUG LIST

SUPPORT PLATE AXIAL INDICATIONS (RPC)

MAP STATISTICS

| | | | | | | |
|---|----|----|---|---|---|---|
| ● | 37 | 41 | 3 | R | 1 | 2 |
| ▲ | 5 | 1 | 1 | 0 | 0 | 0 |



- SA
 - ▲ MAI
 - TSP 1
 - TSP 2
 - TSP 3
 - TSP 4
 - TSP 5
 - TSP 6
- STEAM GENERATOR INFORMATION SYSTEM (C) WESTINGHOUSE ELECTRIC CORP. 1990

NORTH ANNA #1
FEBRUARY 1992

WEXTEX CIRCUMFERENTIAL CRACK GROWTH

24 WEXTEX CIRCUMFERENTIAL CRACKS WERE EVALUATED FOR GROWTH FROM 1991 TO 1992 USING RPC DATA.

AVERAGE CHANGE*: $12.8^{\circ} \pm 12.2^{\circ}$

SUPPORT PLATE CIRCUMFERENTIAL CRACK GROWTH

23 TSP CIRCUMFERENTIAL CRACKS COULD BE EVALUATED FOR GROWTH FROM 1991 TO 1992 USING RPC DATA.

AVERAGE CHANGE*: $10.5^{\circ} \pm 12.2^{\circ}$

*ALL NEGATIVE CHANGES SET TO ZERO.

NORTH ANNA #1
FEBRUARY 1992

TSPs WITH BOTH CIRCUMFERENTIAL
AND AXIAL CRACKS

NO CASES OF MIXED MODE DEGRADATION WERE DETECTED IN
S/G A AND S/G B.

SEVEN (7) LOCATIONS WITH MIXED MODE DEGRADATION AT THE
SAME TSP EDGE WERE OBSERVED IN S/G C.

| <u>ELEVATION</u> | <u>TUBE EDGE*</u> | <u>CIRCUM.</u> | <u>MINIMUM SEPARATING LIGAMENT</u> |
|------------------|-------------------|----------------|--|
| TSP #1: | R29C16 + | 750 | > 250 |
| | R3C43 + | 730 | > 390 |
| | R18C46 + | 690 | > 690 |
| TSP #2: | R10C29 - | 1190 | >1130 |
| | R8C33 + | 760 | > 370 |
| | R29C64 - | 910 | > 270 |
| | + | 630 | > 170 |
| | R30C67 + | 1330 | > 200 |



DATA WAS ACQUIRED WITH 2X RPC PROBE; FOR CLOSEST
AXIAL-CIRCUMFERENTIAL PROXIMITY 3 COIL ZETEC PROBE
WAS USED; NO APPARENT IMPROVEMENT IN RESOLUTION.

ALL THESE INTERSECTIONS WERE JUDGED TO BE ACCEPTABLE
AGAINST TUBE BURST CRITERIA.

*
+ UPPER EDGE
- LOWER EDGE

NORTH ANNA UNIT 1 S/G C FEB 1992 INSPECTION POTENTIAL MIXED MODE INDICATIONS

MAP STATISTICS



● PMI
■ 1H
■ 2H

North Anna Unit 1
Steam Generator Mid-Cycle Inspection Outage
NRC Startup Approval Meeting

March 2, 1992

Westinghouse
Tube Integrity Evaluation
T. A. Pitterle

This package contains information proprietary to
Westinghouse Electric Corporation.

TUBE INTEGRITY ASSESSMENT

DISCUSSION TOPICS

GROWTH RATES: '92 RPC vs '91 8X1

"INSPECTION TRANSCIENT" CONSIDERATIONS

ACCEPTABLE INDICATIONS FOR BURST AND VIBRATION
(WCAP-13034)

TUBE INTEGRITY EVALUATION

- LARGEST SCI AND SAI ASSESSMENT

- MULTIPLE CIRCUMFERENTIAL INDICATION ASSESSMENT
 - TUBE BURST TESTS
 - ASSESSMENT

- POTENTIAL COMBINED CIRC. & AXIAL ASSESSMENT

- SUSCEPTABILITY TO TUBE VIBRATION

- EOC SLB LEAK RATES



GROWTH RATE COMPARISONS

| | <u>RPC: '92-'91*</u> | | <u>3X1: '91-'89</u> | |
|-------------------------|----------------------|-------------|---------------------|-------------|
| | <u>WEXTEX</u> | <u>TSPs</u> | <u>WEXTEX</u> | <u>TSPs</u> |
| AVERAGE | 26° | 21° | 30° | 31° |
| 90% CUM. PROBABILITY | 57° | 47° | 60° | 54° |
| 95% CUM. PROBABILITY | 66° | 63° | 73° | 67° |

* MEASURED GROWTH FOR SHORT CYCLE (254 VS 506 EFPD)
MULTIPLIED BY FACTOR OF TWO FOR FULL CYCLE
COMPARISON

- 24 WEXTEX INDICATIONS IN '92 VS 112 IND. IN '91
- 23 TSP IND. IN '92 VS 77 IND. IN '91

WEXTEX Cumulative and Interval Crack Growth Distributions



TSP Cumulative and Interval Crack Growth Distributions




Chart TSP Growth Rates 2/27/92

"INSPECTION TRANSIENT" CONSIDERATIONS

PROJECTIONS (18 MO.) OF WCAP-13034


● WEXTX PROJECTIONS

- PROJECTIONS BASED ON 8x1 INSPECTION HISTORY SIGNIFICANTLY OVERESTIMATED NUMBER AND SIZE OF INDICATIONS
- TYPICAL OF CYCLE FOLLOWING AN "INSPECTION TRANSIENT" (FIRST APPLICATION OF MORE SENSITIVE, RPC PROBE)


● TSP PROJECTIONS

- PROJECTIONS BASED ON 8x1 HISTORY UNDERESTIMATED NUMBER AND SIZE OF INDICATIONS
- TYPICAL OF CYCLE HAVING AN "INSPECTION TRANSIENT"
- FEWER INDICATIONS WOULD BE ANTICIPATED NEXT CYCLE

WEXTEX 1992 EOC Projections vs. Actual



TSP 1992 EOC Projections vs. Actual



EXAMPLE OF "INSPECTION TRANSIENTS"

| | NORTH ANNA-1 | | PLANT A |
|----------------------------|---------------|------------|---------------|
| | <u>WEXTEX</u> | <u>TSP</u> | <u>WEXTEX</u> |
| CYCLE BEFORE RPC | 28 | 110 | 0 |
| RPC "INSPECTION TRANSIENT" | 216 | 212 | 56 |
| CYCLE AFTER RPC | 31 | TBD | 2 |

REG. GUIDE 1.121
CRITERIA FOR THRU-WALL CIRCUMFERENTIAL CRACKS

TUBE BURST CAPABILITY OF THREE TIMES NORMAL OPERATING PRESSURE DIFFERENTIAL

ADEQUATE MARGIN AGAINST RAPID CRACK PROPAGATION AND TUBE RUPTURE UNDER ACCIDENT CONDITIONS

- CRACK PROPAGATION FROM TUBE VIBRATION UNDER NORMAL OPERATING CONDITIONS INCLUDED IN THE EVALUATION

LEAK RATE LIMIT THAT PROVIDES LEAK BEFORE BREAK

ALLOWANCE IN ACCEPTABLE CRACK LENGTHS FOR EC UNCERTAINTY AND GROWTH (PLANT SPECIFIC) BETWEEN INSPECTIONS

CONFIRM ACCEPTABLE LEAKAGE DURING LIMITING ACCIDENT CONDITION

- STEAM LINE BREAK IS TYPICALLY LIMITING

TUBE INTEGRITY ASSESSMENT

APPROACH

2/92 INSPECTION RESULTS TYPICAL OF EXPECTED AT END OF NEXT CYCLE


- CYCLE LENGTHS
 - 254 EFPD PRIOR CYCLE
 - 252 EFPD NEXT CYCLE

PERFORM TUBE INTEGRITY ASSESSMENT FOR 2/92 INSPECTION RESULTS


- CONSERVATIVE FOR NEXT EOC
 - 100% RPC INSPECTION OF H.L. TSP INTERSECTIONS
- TUBE BURST ASSESSMENTS
 - SINGLE CRACKS
 - MCIs
 - POTENTIAL MIXED MODE
- SUSCEPTIBILITY TO TUBE VIBRATION
- SLB LEAK RATES

Crack Growth Models for ODSCC and PWSCC

ODSCC



PWSCC



a,c

e,c

CIRCUMFERENTIAL AND AXIAL CRACK TUBE BURST CAPABILITY SUMMARY

CRACK MORPHOLOGY

$3 \Delta P_{N.O.}$

ΔP_{SLB}

CIRCUMFERENTIAL CRACK ANGLES

SEGMENTED CRACKS

SINGLE CRACK

SINGLE CRACK WITH 50%
DEEP CRACK

[]^{b,c}

AXIAL CRACK LENGTHS - INCH

SEGMENTED CRACKS

SINGLE CRACKS

[]^{b,c}

BURST CAPABILITY ASSESSMENT

WEXTEX CIRCUMFERENTIAL INDICATIONS

- 199⁰ LARGEST WEXTEX CIRCUMFERENTIAL INDICATION
 - S/G B, R25C36
- ALL INDICATIONS MEET 3 Δ P BURST CAPABILITY
 - []^{b,c} FOR EXPECTED SEGMENTED CRACK MORPHOLOGY
 - []^{b,c} FOR THROUGHWALL CRACK

TSP CIRCUMFERENTIAL INDICATIONS

- TWO INDICATIONS HAVE RPC CRACK ANGLES EXCEEDING []^{b,c} FOR 3 Δ P FOR UNIFORM, THROUGHWALL CRACK
- 240⁰ @ S/G A, R34C42, 2H
 - DEEPEST PART OF CRACK ~134⁰
- 239⁰ @ S/G A, R18C39, 1H
 - DEEPEST PART OF CRACK ~ 96⁰
- ALL INDICATIONS EXPECTED TO MEET 3 Δ P BURST CAPABILITY

BURST CAPABILITY ASSESSMENT

AXIAL INDICATIONS EXTENDING OUTSIDE TSP

- MAXIMUM LENGTH OF 0.54" LESS THAN PRIOR OUTAGES OF ~0.9"
 - RPC LENGTHS SHORTER THAN BOBBIN LENGTHS USED PREVIOUSLY DUE TO REDUCED LEAD-IN AND LEAD-OUT EFFECTS FOR RPC COMPARED TO BOBBIN
 - WESTINGHOUSE ROLL TRANSITION STUDIES INDICATE MEASURED RPC LENGTHS SHOULD BE REDUCED BY 0.1 INCH.
 - EPRI NP-6368-L ALSO SHOWS GOOD AGREEMENT OF RPC LENGTHS WITH PULLED TUBE DATA.
- CRACK LENGTH OF 0.72" MEETS $3\Delta P$ BURST CAPABILITY FOR EXPECTED SEGMENTED CRACK MORPHOLOGY
- AXIAL INDICATIONS AT TSPs MEET $3\Delta P$ BURST CAPABILITY





MCI BURST CAPABILITY ASSESSMENT

MINIMUM LIGAMENT BETWEEN CIRCUMFERENTIAL INDICATIONS

- RPC LIGAMENT CALL REQUIRES RETURN TO NULL POINT (BACKGROUND) BETWEEN CIRCUMFERENTIAL CRACKS
- TPC LIGAMENT REQUIRES 30° - 35° (0.2"-0.25") BETWEEN DEEP CIRCUMFERENTIAL CRACKS DUE TO RESOLUTION (COIL LEAD-IN AND LEAD-OUT EFFECTS) LIMITATIONS
 - CONFIRMED BY MEASUREMENTS OF EDM NOTCHES
- MINIMUM LIGAMENT IN MCIS = RPC LIGAMENT ANGLE + 30°

RPC MEASUREMENTS OF THROUGHWALL CRACKS OVERESTIMATED BY $\sim 30^{\circ}$

- 8° REDUCTION IN ANGLE CAN BE CONSERVATIVELY APPLIED AT EACH END OF CRACK



BURST TESTS FOR MULTIPLE CIRCUMFERENTIAL INDICATIONS

BURST TESTS

B.C

OBJECTIVE

- CONFIRM ACCEPTABLE LIGAMENTS FOR MCIs TO MEET STRUCTURAL INTEGRITY REQUIREMENTS

RESULTS

- MCI BURST CAPABILITY WITH MINIMUM ACCEPTABLE LIGAMENTS EXCEEDS BURST PRESSURE OF SCI HAVING SAME TOTAL CRACK ANGLE
 - MINIMUM ACCEPTABLE LIGAMENT = 30° - 35° FULL THICKNESS
 - MINIMUM ACCEPTABLE LIGAMENT = 60° - 70° WITH 50% DEEP CRACK

Tube Burst Test Results for MCIs

Single Circumferential Slot

b,c

Multiple Symmetric Circumferential Slots

b,c

Multiple Non-Symmetric Circumferential Slots

b,c

BURST PRESSURE VERSUS TOTAL CRACK ANGLE

7/8X0.050 INCH TUBING WITH TSP RESTRAINT

b,c

MCI BURST CAPABILITY ASSESSMENT

WEXTEX MCIs

- 5 MCIs IDENTIFIED
- SMALLEST RPC LIGAMENT = 12° (S/G A, R24C33)
- MINIMUM LIGAMENT $\sim 42^{\circ}$ AND SUM OF CRACK ANGLES $< 218^{\circ}$ AFTER RPC RESOLUTION ADJUSTMENT
- ALL MCI LIGAMENTS EXCEED 30-35 $^{\circ}$ LIGAMENT SIZE REQUIRED FOR MCI BURST CAPABILITY TO EXCEED THAT OF SINGLE CRACK WITH A 70° LIGAMENT
- ALL WEXTEX MCIs MEET $3\Delta P$ BURST CAPABILITY

TSP MCIs

- 15 MCIs IDENTIFIED
- MINIMUM RPC LIGAMENT FOR ALL 15 MCIs $\sim 41^{\circ}$
 - MINIMUM LIGAMENT $\sim 71^{\circ}$ AFTER RPC RESOLUTION ADJUSTMENT
 - LIGAMENTS EXCEED 60-70 $^{\circ}$ LIGAMENT SIZE REQUIRED FOR MCI $3\Delta P$ BURST CAPABILITY
- ALL TSP MCIs MEET $3\Delta P$ BURST CAPABILITY

North Anna-1
WEXTX MCIs

| <u>Tube</u> | <u>Location</u> | <u>Circ.1</u> | <u>Lig.1</u> | <u>Circ.2</u> | <u>Lig.2</u> | <u>Total Circ.</u> |
|--------------------------|-----------------|---------------|--------------|---------------|--------------|------------------------|
| <u>Steam Generator A</u> | | | | | | |
| R10C32 | TS-.12 | 102° | 24°(54°)(1) | 82° | 152° | 184° |
| R24C33 | TS-.08 | 149° | 114° | 85° | 12°(42°)(1) | 234°(218°) |
| <u>Steam Generator B</u> | | | | | | |
| R9C36 | TS+.00 | 81° | 17°(47°)(1) | 82° | 180° | 163° |
| <u>Steam Generator C</u> | | | | | | |
| R10C72 | TS-.02 | 76° | 38° | 76° | 170° | 151° |
| R25C50 | TS-.04 | 67° | 46° | 59° | 178° | 126° |

Note 1. RPC measured ligament increased by 30° for resolution limitations (coil lead-in and lead-out effects).

North Anna-1
TSP Multiple Circumferential Indications (MCIs)

| <u>Tube</u> | <u>Location</u> | <u>Circ. 1</u> | <u>Lig. 1</u> | <u>Circ. 2</u> | <u>Lig. 2</u> |
|--------------------------|-----------------|----------------|---------------|----------------|---------------|
| <u>Steam Generator A</u> | | | | | |
| R6C6 | 1H+.39 | 81° | 91° | 78° | 110° |
| R17C10 | 1H+.50 | 90° | 86° | 95° | - 89° |
| R29C30 | 1H+.26 | 131° | 75° | 87° | - 67° |
| <u>Steam Generator B</u> | | | | | |
| R11C8 | 2H-.21 | 114° | 68° | 117° | 61° |
| | 2H+.23 | 108° | 65° | 81° | 106° |
| R12C8 | 3H+.23 | 128° | 75° | 98° | 59° |
| R22C24 | 2H-.30 | 132° | 73° | 101° | 54° |
| R2C41 | 3H+.29 | 138° | 66°(96°)(1) | 115° | 41°(71°)(1) |
| | 3H-.25 | 91° | 88° | 101° | 80° |
| R36C62 | 2H-.23 | 83° | 69° | 107° | 101° |
| <u>Steam Generator C</u> | | | | | |
| R20C9 | 3H-.27 | 130° | 64° | 79° | 87° |
| R24C10 | 3H+.28 | 105° | 92° | 88° | - 75° |
| R10C29 | 2H+.35 | 80° | 83° | 107° | 90° |
| R18C44 | 2H+.35 | 99° | 90° | 109° | - 62° |
| R27C71 | 2H-.30 | 79° | 95° | 82° | 103° |

Note 1. RPC measured ligament angles based on return of signal amplitude to background or null point. For deep circumferential indications, the actual ligament exceeds the measured ligament by about 30° or more (Figure 4-2, WCAP-13034) due to RPC coil lead-in and lead-out resolution limits on crack angles.

TAP2023:022992

EVALUATION FOR POTENTIAL MIXED MODE CRACKING

14 OCCURRENCES IN S/G C OF CIRC. AND AXIAL IND. AT SAME TSP


- 7 OCCURRENCES WITH AXIAL ON OPPOSITE EDGE OR INSIDE TSP COMPARED TO CIRCUMFERENTIAL CRACK
 - NOT A CONCERN FOR MIXED MODE CONSIDERATIONS
- 7 OCCURRENCES WITH AXIAL AT SAME EDGE AS CIRCUMFERENTIAL
 - EVALUATED FOR LIGAMENT BETWEEN AXIAL AND CIRC.

MINIMUM RPC LIGAMENT IS 20° FOR R30C67, 2H

- MINIMUM LIGAMENT OF 28° AFTER ADJUSTMENT FOR RPC RESOLUTION
- MINIMUM LIGAMENT REQUIREMENT

- ALL LIG' 3 FOR POTENTIAL MIXED MODE CRACK EXCEED] AND WOULD MEET $3\Delta P$ BURST CAPABILITY





North Anna-1
Mixed Mode Evaluation

| <u>Tube</u> | <u>Location</u> | <u>Circ. Angle</u> | <u>C.L. to C.L.</u> | <u>Derived⁽¹⁾ Lig. Angle</u> | <u>Measured⁽²⁾ Lig. + 0.5 Axial θ</u> | <u>Resolution⁽³⁾</u> |
|--------------------------|-----------------|---|---------------------|---|--|---------------------------------|
| <u>Steam Generator C</u> | | | | | | |
| R20C9 | 3H-.27 | 130 ⁰ /79 ⁰ | | | | Opposite Edges, No Concern |
| R14C10 | 2H+.20 | 101 ⁰ | | | | Opposite Edges, No Concern |
| R5C11 | 1H-.27 | 96 ⁰ | | | | Axial Inside TSP, No Concern |
| R29C16 | 1H+.26 | 75 ⁰ | 62 ⁰ | 25 ⁰ | 5 ⁰ +28 ⁰ | Acceptable, large ligament |
| R10C29 | 2H-.29 | 119 ⁰ | | | 90 ⁰ +23 ⁰ | Acceptable, large ligament |
| R6C32 | 1H-.30 | 85 ⁰ | | | | Opposite Edges, No Concern |
| R8C33 | 2H+.18 | 76 ⁰ | 82 ⁰ | 44 ⁰ | 10 ⁰ +27 ⁰ | Acceptable, large ligament |
| R6C40 | 3H-.26 | 104 ⁰ | | | | Opposite Edges, No Concern |
| R3C43 | 1H+.31 | 73 ⁰ | 75 ⁰ | 39 ⁰ | 17 ⁰ +20 ⁰ | Acceptable, large ligament |
| R18C46 | 1H+.33 | 69 ⁰ | | | 36 ⁰ +33 ⁰ | Acceptable, large ligament |
| R29C64 | 2H-.33 | 91 ⁰ | 75 ⁰ | 30 ⁰ | 10 ⁰ +17 ⁰ | Acceptable, large ligament |
| | 2H+.47 | 63 ⁰ | | | | Opposite Edges, No Concern |
| R30C67 | 2H+.26 | 133 ⁰ (117 ⁰) ³ | 86 ⁰ | 20 ⁰ (28 ⁰) ³ | 5 ⁰ +19 ⁰ | Acceptable, large ligament |
| R30C70 | 2H+.31 | 96 ⁰ | | | | Opposite Edges, No Concern |

Notes:

- 1) Ligament angle obtained as circumferential crack centerline to axial crack centerline distance minus one-half the circumferential angle.
- 2) Ligament angle obtained as the measured ligament angle plus one-half the axial crack angle.
- 3) RPC measurements adjusted for resolution (coil lead-in and lead-out) in measuring deep crack angles. Resolution typically -1 coil diameter (0.105", 15⁰) at each end of crack. Conservatively applying 8⁰ at each crack end.

ZONES FOR TUBE VIBRATION ASSESSMENT

WEXTEX ZONES FOR INITIATION OF CRACK PROPAGATION


- ZONE 1: INITIATION AT TW ANGLES OF []^{b,c}
 - 620 TUBES
- ZONE 2: INITIATION AT TW ANGLES OF []^{b,c}
 - 344 TUBES
- ZONE 3: INITIATION AT TW ANGLES OF []^{b,c}
 - 940 TUBES
- ZONE 4: INITIATION REQUIRES TW ANGLES []^b
 - 1484 TUBES
 - 90% OF WEXTEX CIRCUMFERENTIAL INDICATIONS OCCUR IN ZONE 4.

ZONES ALSO ENVELOPE CRACK PROPAGATION FOR CIRCUMFERENTIAL INDICATIONS AT BOTTOM OF 1ST TSP

- TURBULENCE INITIATION AT []^{b,c} IN ZONE 1

MINIMUM ANGLES FOR CRACK PROPAGATION IN EACH ZONE APPLY TO ONLY A FEW TUBES IN THE ZONE.

INSPECTION BOUNDARIES BOUNDARY TUBE MAP



ACCEPTABLE RPC CRACK ANGLES FOR TUBE VIBRATION

| | WEXTEX PWSCC | TSP ODSCC(1) | |
|----------------------------------|--------------|--------------|------------|
| | | TW ONLY | TW+ 50%(2) |
| CONSERVATIVE TW CRACKS | | | |
| O PERIPHERAL REGION | [| | b,c |
| - TURBULENCE | | | |
| - FLUIDELASTIC | | | |
| O CENTRAL REGION | | | |
| - TURBULENCE | | | |
| - FLUIDELASTIC |] | | |
| EXPECTED CRACK MORPHOLOGY | | | |
| O PWSCC SEGMENTED CRACKS | [| | b,c |
| - TURBULENCE | | | |
| - FLUIDELASTIC |] | | |
| O ODSCC MODEL | [| | b,c |
| - PERIPHERAL: | | | |
| TURBULENCE | | | |
| FLUIDELASTIC | | | |
| - CENTRAL: | | | |
| TURBULENCE | | | |
| FLUIDELASTIC |] | | |

NOTES:

1. LIMITING CRACK ANGLES AT TSPs APPLICABLE TO BOTTOM OF 1ST TSP ONLY. HIGHER ELEVATIONS TO BOTTOM OF TOP TSP REQUIRE TW CRACK ANGLES []^{b,c} EVALUATED FOR CRACK PROPAGATION DUE TO VIBRATION.
2. THROUGHWALL CRACK []^{a,c}
3. MOST LIMITING PERIPHERAL TUBE LOCATIONS
4. ODSCC MODEL ASSUMES []^{a,c}

TUBE VIBRATION ASSESSMENT

WEXTEX CIRCUMFERENTIAL INDICATIONS

CRACK PROPAGATION DUE TO VIBRATION DOES NOT OCCUR FOR EXPECTED SEGMENTED PWSCC CRACK MORPHOLOGY EVEN FOR []^{b,c} CRACK NETWORK ANGLES

LARGEST CRACK ANGLES

- ZONE 1: S/G B, R25C8 - 157° (FIELD-142°)
 - WELL DEFINED CRACK ANGLE ~107°
 - POSSIBLE TW ANGLE []^{b,c} MINIMUM ZONE 1 OR []^{b,c} AT R25C8 NECESSARY FOR TURBULENT CRACK PROPAGATION AT THIS LOCATION
 - ONLY 1 WEXTEX CIRC. INDICATION IN ZONE 1
- ZONE 2: NO CIRCUMFERENTIAL INDICATIONS
- ZONE 3: S/G A, R21C23 - 118°
 - TWO WEXTEX CIRC. INDICATIONS IN THIS ZONE HAVE RPC CRACK ANGLES []^{b,c} MINIMUM TW ANGLE FOR CRACK PROPAGATION
- ZONE 4: S/G B, R25C36 - 199°
 - ALL WEXTEX CIRC. INDICATIONS IN THIS ZONE HAVE RPC CRACK ANGLES []^{b,c} MINIMUM TW ANGLE FOR CRACK PROPAGATION

CONCLUSION


- NO WEXTEX INDICATIONS SUBJECT TO CRACK PROPAGATION DUE TO TUBE VIBRATION.

NORTH ANNA UNIT I ALL GENERATORS WEXTEX CIRCUMFERENTIAL INDICATIONS

MAP STATISTICS

●
▲

26
5



2-32

NOZZLE

MANWAY

▲ MCI

● SCI

■ WEXTEX REGION

TUBE VIBRATION ASSESSMENT

TSP CIRCUMFERENTIAL INDICATIONS

POTENTIAL FOR CRACK PROPAGATION EXISTS ONLY FOR TSP CIRC. INDICATIONS AT BOTTOM OF 1ST TSP


- NO CIRCUMFERENTIAL INDICATIONS FOUND ABOVE 5TH TSP
- 31 CIRC. INDICATIONS OF BOTTOM OF 1ST TSP

LARGEST CRACK ANGLES AT BOTTOM OF 1ST TSP

- ZONE 1: S/G A, R45C50 - 167°
 - WELL DEFINED, DEEP CRACK ANGLES ~93°
 - POSSIBLE TW ANGLE []^{b,c} MINIMUM IN ZONE 1 OR []^{b,c} AT R45C50 NECESSARY FOR TURBULENT CRACK PROPAGATION
 - REMAINING 6 CIRC. INDICATIONS <104° RPC ANGLE
- ZONE 2: S/G B, R15C9 - 121°
 - ALL 3 INDICATIONS IN ZONE 2 ARE []^{b,c} MINIMUM TW CRACK NECESSARY FOR PROPAGATION
- ZONE 3: S/G C, R17C80 - 173°
 - ALL 6 INDICATIONS IN ZONE 3 ARE []^{b,c} MINIMUM TW CRACK NECESSARY FOR PROPAGATION
- ZONE 4: S/G A, R18C39 239°
 - ALL 15 INDICATIONS IN ZONE 4 ARE []^{b,c} MINIMUM TW CRACK ANALYZED FOR CRACK PROPAGATION

NORTH ANNA UNIT I ALL GENERATORS 2/27 DATA
 LOWER EDGE CIRCUMFERENTIAL IND.

MAP STATISTICS
 31
 0



MGZLIT

MANWAY

▲ MCI

● SCI
 ■ 1H(-)

TUBE VIBRATION ASSESSMENT
MCI AND MIXED MODE

MCIs

● WEXTEX

- ALL MCIs IN ZONE 4
- NO TUBE VIBRATION CONCERN EVEN AT SUM OF CRACK ANGLES

● TSPs

- NO OCCURRENCES OF MCIs AT BOTTOM OF 1ST TSP

MIXED MODE

● WEXTEX

- NO OCCURRENCES

● TSPs

- NO OCCURRENCES OF CIRC. + AXIAL AT BOTTOM EDGE OF 1ST TSP

EOC SLB LEAKAGE EVALUATION

METHODS OF ANALYSIS PER WCAP-13034

a,c

EOC SLB LEAKAGE

- 0.43 GPM: WEXTX CIRCUMFERENTIAL
- 20.4 GPM: TSP CIRCUMFERENTIAL
- 3.40 GPM: TSP AXIAL
- 24.2 GPM: TOTAL

NORTH ANNA-1 TUBE INTEGRITY ASSESSMENT

OVERALL CONCLUSIONS

OPERATION TO END OF NEXT PLANNED OPERATING CYCLE (252 EFPD) IS ACCEPTABLE AND MEETS R.G. 1.121 GUIDELINES

TUBE BURST REQUIREMENTS ($3\Delta P$) ARE MET AT EOC FOR SCIS, MCIS AND POTENTIAL MIXED MODE CONSIDERATIONS

THE POTENTIAL FOR PROPAGATION OF CIRCUMFERENTIAL CRACKS DUE TO TUBE VIBRATION IS NEGLIGIBLE

GROWTH RATES OF CIRCUMFERENTIAL CRACKS ARE MODEST

- AVERAGE OF 21° - 26° PER 18 MONTH CYCLE

THE ESTIMATED EOC SLB LEAK RATE IS ~24 GPM

- 100% RPC INSPECTION AT TSPs LIKELY TO REDUCE TSP INDICATIONS AND POTENTIAL LEAKAGE FOR NEXT CYCLE


North Anna Unit 1
Steam Generator Mid-Cycle Inspection Outage
NRC Startup Approval Meeting

March 2, 1992


Westinghouse

Supplemental Information Package


This package contains information proprietary to
Westinghouse Electric Corporation.




154 Pancake



NORTH ANNA _____ 01/19/92 INLET UNIT: 1_ SG: C REEL: 191 SEC



FE 10 5 1 2



| | |
|-------------------------|----------------|
| SIZE: | 50 |
| X ROTATION: | 34 |
| Y ROTATION: | 205 |
| NO. OF SCAN LINES: | 57 |
| MEASUREMENT PITCH/SCAN: | 70/70 (170/70) |


| | | | |
|------|------|------|------|
| SC | 1 | ROW | COL |
| REEL | 31 | DISK | SIDE |
| S/C | TRIT | TRIT | TRIT |

| | | |
|--------|-------|--------|
| ZH | -0.32 | IN |
| EXTENT | ZH | ZH |
| SPEED | 0.15 | in/sec |

TRIGGERS: 1
COILS: 1

TRIGGER CIRC AXIAL

CENTER AREA W/ CIRC SENSITIVE COIL
 NOTE THAT CENTER AREA REMAINS, WHILE
 AXIAL AT LOWER EDGE HAS DISAPPEARED.
 THE CONTINUED PRESENCE OF AN INDICATION
 IN THE CENTER AREA WITH ALL 3 COILS
 INDICATES A GEOMETRY CHANGE RATHER
 THAN A PRESENCE OF A FLAW.



9.5


REEL: 303

| | | | | | |
|------|-------|--------|------|--------|-------|
| SG | 31 | ROW | 4 | COL | 11 |
| REEL | 113 | DIR | 41 | SIDE | R |
| S/C | C | UNIT | 1 | INLET | |
| ZH | -8.14 | EXTENT | 2M | 2M | |
| | | SPEED | 8.15 | in/sec | TRAIN |


SIZE: 56
 R ROTATIONS: 36
 V ROTATIONS: 285
 MB. BY SCAN LENGTH: 57
 STRIPES PER/SEMI: 78/78 (78/78)


TRIGGERS
 COILS

TRIGGER
 CIRC AXIAL




CENTER AREA PIVOT COIL - ONLY A
 GEOMETRY CHANGE. ALSO NOTE THAT
 AXIAL INDICATION CURVES AS IT GOES
 THRU THE TSP AND ON DOWN THE TUBE.
 ALSO NOTE THE AXIAL @ LOWER EDGE
 APPEARS MORE PROMINENT THAN CENTER
 AREA





BURST PRESSURE VERSUS TOTAL CRACK ANGLE

7/8X0.050 INCH TUBING WITH TSP RESTRAINT



37-1


BURST PRESSURE VERSUS TOTAL CRACK ANGLE


7/8X0.050 INCH TUBING WITH TSP RESTRAINT


BURST PRESSURE, KSI


b.c

TOTAL CRACK ANGLE, DEGREES














LEAK RATE VERSUS CIRCUMFERENTIAL CRACK ANGLE
SEGMENTED CRACKS IN 7/8X0.050" TUBING

LEAK RATE, GPD

b.c

TOTAL CRACK NETWORK ANGLE, DEGREES