



Callaway Plant

May 13, 1992

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

ULNRC-2637

Gentlemen:

DOCUMENT NUMBER 50-483
CALLAWAY PLANT UNIT 1
FACILITY OPERATING LICENSE NPF-30
SPECIAL REPORT 92-02
NUMBER OF TUBES PLUGGED DURING SIXTH
STEAM GENERATOR TUBE INSERVICE INSPECTION

This special report is submitted in accordance with Technical Specification (T/S) 4.4.5.5.a, which states:

"Within 15 days following the completion of each inservice inspection of steam generator tubes, the number of tubes plugged in each steam generator shall be reported to the Commission in a Special Report pursuant to Specification 6.9.2."

The Steam Generator (S/G) Inservice Inspection was completed for S/G's 'B' and 'C' on 4/28/92 to meet the surveillance requirements of T/S 3/4.4.5, "Steam Generators". The plant was in Mode 6 - Refueling, with the core defueled for the planned Refuel V outage. Twenty-nine tubes were plugged as a result of the inspection and are identified on the following page.

92052: 102 920513
PDR ADDCK 05000483
S PDR

Mailing Address: P.O. Box 620, Fulton, MO 65251

A001
11/1

S/G 'B'

<u>COLUMN</u>	<u>ROW</u>
9	30
19	41
20	41
22	41
28	49
32	51
69	51
70	23
73	47
73	51
81	32
84	47
93	51
101	44
113	32

S/G 'C'

<u>COLUMN</u>	<u>ROW</u>
10	32
19	41
22	44
23	44
23	43
24	45
34	45
56	12
64	41
98	2
101	44
104	41
105	40
106	40

In addition, two tubes were plugged in S/G 'D' as a precautionary measure, using data from the fifth inservice inspection. These tubes were plugged since they were of a similar profile to a tube plugged in the 'C' S/G. The tubes are:

S/G 'D'

<u>COLUMN</u>	<u>ROW</u>
11	33
15	37

M.E. Taylor
for J. D. Blosser

JDB/TPS/M&D/lrj
Enclosure
cc: Distribution attached

cc distribution for ULNRC-2637

Mr. A. Bert Davis
Regional Administrator
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Manager, Electric Department
Missouri Public Service Commission
P. O. Box 360
Jefferson City, MO 65102

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, GA 30339

Mr. L. Raymond Wharton (2 copies)
U. S. Nuclear Regulatory Commission
OWFN - Mail Stop 13E21
Washington, D. C. 20555

Mr. Meriin Williams
Manager, Plant Support
Wolf Creek Nuclear Operating Corp.
P. O. Box 411
Burlington, KS 66839

Mr. R. L. Hague
Chief, Project Section 3C
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

NRC Senior Resident Inspector