

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) VERMONT YANKEE NUCLEAR POWER STATION	DOCKET NUMBER (2) 0 5 0 0 0 2 7 1 1	PAGE (3) 1 OF 0 2
---	--	----------------------

TITLE (4)  
Service Water Sampling Not Performed

EVENT DATE (5)			LER NUMBER (6)		REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES
0 7	3 0	8 4	8 4	0 1 7	0	0 0	8 2	9 8 4	DOCKET NUMBER(S) 0 5 0 0 0

OPERATING MODE (8) N	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)				
POWER LEVEL (10) 0 1 0 1 0	20.402(b)	20.406(e)	50.73(a)(2)(iv)	73.71(b)	OTHER (Specify in Abstract below and in Text, NRC Form 365A)
	20.406(a)(1)(i)	50.36(e)(1)	50.73(a)(2)(v)	73.71(e)	
	20.406(a)(1)(ii)	50.36(e)(2)	50.73(a)(2)(vi)		
	20.406(a)(1)(iii)	X 50.73(a)(2)(i)	50.73(a)(2)(vii)(A)		
	20.406(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)		
	20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)		

LICENSEE CONTACT FOR THIS LER (12)	
NAME James P. Pelletier, Plant Manager	TELEPHONE NUMBER AREA CODE: 8 1 0 2    2 5 7 1 7 1 1

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)		EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO				

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On 7/25/84, the Service Water Radiation Monitor, RAM 17-332, was taken out of service for the installation of a new discharge line for the Turbine Building Clean Equipment and Floor Drain Sump Pumps. As required by Tech. Spec. Section 3.9.C.2, daily sampling of the Service Water System commenced and samples were analyzed for gross activity.

Samples were not taken on 7/26/84 and 7/27/84. Sampling was restarted on 7/28/84 and continued daily until 7/30/84 when the Radiation Monitor was returned to service. Analysis of the samples taken did not reveal other than normal readings.

8409070429 840829  
PDR ADOCK 05000271  
S PDR

T-22  
1/11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)  VERMONT YANKEE	DOCKET NUMBER (2)  0   5   0   0   0   2   7   1	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		8   4	-   0   1   7	-   0   0	0   2	OF 0   2


TEXT (If more space is required, use additional NRC Form 365A's) (17)

On 7/25/84, the Service Water Radiation Monitor, RAM 17-332, was taken out of service for the installation of a new discharge line for the Turbine Building Clean Equipment and Floor Drain Sump Pumps. The discharge from the Radiation Monitor flows into the drain sump.

As required by Tech. Spec. Section 3.9.C.2, daily sampling of the Service Water System commenced and samples were analyzed for gross activity. However, samples were not taken on 7/26/84 and 7/27/84. Sampling was restarted on 7/28/84 and continued daily until 7/30/84 when the Radiation Monitor was returned to service. Analysis of the samples taken did not reveal other than normal readings. The plant was in a shutdown condition and no fuel movements or other major evolutions were in progress during this time.

The on-duty Chemistry and Health Physics Assistant did not inform the assistant relieving him of the requirement to sample the Service Water System. The assistant will be instructed on the need to provide a complete plant status at shift turnover.

Based on the above, there were no adverse consequences to the public health and safety. No previous similar occurrences have been reported.



VERMONT YANKEE NUCLEAR POWER CORPORATION

P. O. BOX 157  
GOVERNOR HUNT ROAD  
VERNON, VERMONT 05354

VYV 84-435

August 29, 1984

U.S. Nuclear Regulatory Commission  
Document No. 50-271  
Washington, D.C. 20555

REFERENCE: Operating License DPR-28  
Docket No. 50-271  
Reportable Occurrence No. LER 84-17

Dear Sirs:

As defined by 10CFR50.73, we are reporting the attached Reportable Occurrence as LER 84-17.

Very truly yours,

James P. Pelletier  
Plant Manager

RDP/drc

cc: Regional Administrator  
USNRC Office of Inspection and Enforcement  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

JE22  
1/1