TRC Form 366 (9/63)									LICENSEE EVENT REPORT (LER)									U.S	U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3150-0104 EXPIRES: 8/31/85						
PACILIT	Y NAME	(1)	-	-			-		-							19		10	DOCKET NUMBER (2) PAGE (3)						
SAN ONOFRE NUCLEAR GENERATING								NG	STATION LINIT 3											1010	0 0 0 1 3 1 6 1 2 1 0 5 0 1 1				
TITLE (176	NUC		us u	In IV.	VALL	NG	SIAL	LUIY,		NAL.	,		_				1-1-	1-1-	13101	- 1 - 1 -	1011		
CON	TATN	FNT	PI	IRGE	IS	OLA:	TION	SY	STEM	(C	219) AC	THATTO	N											
CONTAINMENT PURGE ISOLATION SY								SILI		TE (7)	OTHER FACILITIES INVOLVED (8)														
MONTH	DAY	Y 8	AR	YEAR SEQ.			REV.		MONTH		DAY	YEAR	PACILITY NAMES					DOCKET N)			
																					0 5 0	10 0	11		
				100					n di				1.44		1										
01 7	217	1 8	14	81	4	- 0	310	-	010	01	8	217	814							- 1	0 5 0	0 0 1	1.1		
						_						ENTS C	ENTS OF 10 CFR §: (Check one or more of the following) (11)												
MODE (9) 5					20.402(b)				20.405(c)				X 50.73(a)(2)(iv)					73.71(b)							
POWER					20.405(a)(1)(i)					50.36(c)(1)				50.73(a)(2)(v)						73.71(c)					
LEV (10		0 0	0		20.405(a)(1)(ii)					50.36(c)(2)					50.73(a)(2)(vii)			(vii)		-	OTHER (Specify in Abstract				
1.71.71.7				20.405(a)(1)(iii)			in a	5			50.73(a)(2)(i)			50.73(a)(2)(viii)						below and in Text, NRC Form 366A)					
				20.405(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(v													
					20.4	05(a)	(1)(v)			5	0.73	(a)(2)(i	(1)		-		3(a)(2)								
*****			-						LICE	-			FORT	HIS LE	-	-			-						
NAME							1111													TEL	EPHONE	NUMBE	R		
																			AREA	300					
			- (5 F	AYN	FS.	STA	TIO	N MA	NAGE	P								711	14	4 9 2	-171	71010		
												MPONEN	T FAILU	RE DES	CRIE	BED	IN THI	S REPO			71215	-1/1	11010		
AUSE SYSTEM		COMPON						EPOR	TABLE			*						MANUPAC		REP	ORTABLE				
			-01		TURER			TO NPROS			CAU		CAUSE	YSTEM	COMPONENT		TURER		TO NPRDS						
X	VA		R	IL	N	3 0	5	N						-				1	11						
			1	1												1			LI						
					SUPP	PLEM	ENTA	LRE	PORT	EXPE	CTE	ED (14)									MONTH	DAY	YEAR		
10.00	716				VOEC	TED							- 11					SU	BMISS	ON			1		
1	ES SUE	yes, co	ON	DATE	AFEC	160			Y	NO								D	ATE (1	5)	1	1	1 1		

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On July 27, 1984, at 1758, with Unit 3 in Mode 5 and a containment main purge in progress, Containment Purge Isolation System (CPIS) (EIIS System Identifer VA) Train 'A' was actuated by a spurious instrument fail signal from Containment Area Radiation Monitor 3RT-7856 (EIIS Component Identifier RIT). The actuation occurred when the cabinet housing 3RT-7856 was closed after performance of a routine surveillance. At that time, a deenergization of the instrument failure relay occurred, initiating the fail signal. All Train 'A' CPIS actuated valves functioned properly, isolating the main purge. Redundant Train 'B' remained operable to perform the required safety functions.

The relay was immediately reset, and the instrument fail setpoint was verified to be properly set. An instrument check was performed and the monitor was operating correctly. There were no apparent defects found which would cause a fail signal. CPIS Train'A' was reset and the main purge was reestablished.

The 3RT-7856 instrument failure could not be reproduced. However, an engineering evaluation is currently in progress to determine the area and process radiation monitor's susceptibility to noise, and the results will be reported in a revision to LER 84-023 (Docket No. 50-361).

8409100036 840827 PDR ADDCK 05000362 S PDR

Southern California Edison Company



SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES

August 27, 1984

TELEPHONE (714) 492-7700

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Subject: Docket No. 50-362

30-Day Report

Licensee Event Report No. 84-030

San Onofre Nuclear Generating Station, Unit 3

Pursuant to 10 CFR 50.73(a)(2)(iv), this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving the actuation of the Containment Purge Isolation System (CPIS). Neither the health and safety of plant personnel nor the public were affected by this event.

If you require any additional information, please so advise.

Sincerely, Vo. Laynes

Enclosure: LER No. 84-030

cc: A. E. Chaffee (USNRC Senior Resident Inspector, Units 1, 2 and 3)

J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

J. B. Martin (Regional Administrator, NRC Region V)

Institute of Nuclear Power Operations (INPO)

IEZZ