



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

84 AUG 15 1984 1:36

NUCLEAR LICENSING & SAFETY DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30323

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 84-031/0 -
Inoperability of Floor Drain and
Equipment Drain Demineralizers
AECM-84/0423

On June 12, 1984, the floor drain and equipment drain demineralizers were declared inoperable when it was determined that both demineralizers were passing resins. A Limiting Condition for Operation (LCO) was entered pursuant to Technical Specification 3.11.1.3. It was determined that the demineralizer septums were damaged allowing the resins to pass through.

A maintenance work authorization has been issued to inspect and replace the septums. New septums are on order. This is reported pursuant to Technical Specification 6.9.2 due to the equipment being inoperable for more than 31 days.

Yours truly,

[Handwritten signature]

L. F. Dale
Director

EBS/SHH:lm

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8409100086 840810
PDR ADOCK 05000416
PDR
S

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Member Middle South Utilities System

OFFICIAL COPY

TE22/0