



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

84 AUG 15 1984

NUCLEAR LICENSING & SAFETY DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30323

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 84-030/0 - Fire
Rated Penetration Opened to
Implement Design Change Package
AECM-84/0409

On July 5, 1984, fire rated penetration CE-259D was opened to implement a design change package. A fire watch was established in accordance with Technical Specification 3.7.7 until the penetration was restored on July 24, 1984.

This Special Report is submitted pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation (LCO) time limit was exceeded. This condition had no effect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

[Handwritten signature]

L. F. Dale
Director

EBS/HH:rg

- cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. G. B. Taylor

8409100097 840808
PDR ADOCK 05000416
S PDR

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Member Middle South Utilities System

OFFICIAL COPY

1/0 TE 22