

**CP&L**

PRP  
OFFICIAL COPY

Carolina Power & Light Company

34 AUG 21 A 9:22  
P.O. Box 101, New Hill, N.C. 27522  
August 16, 1984

Mr. James P. O'Reilly  
United States Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Northwest (Suite 2900)  
Atlanta, Georgia 30323

NRC-256

CAROLINA POWER & LIGHT COMPANY  
SHEARON HARRIS NUCLEAR POWER PLANT  
1986 - 900,000 KW - UNIT 1  
PRESSURE SENSING LINE IN THE STARTING AIR SYSTEM  
FOR EMERGENCY STANDBY DIESEL-GENERATOR SETS,  
PURCHASE ORDER NY-435079, ITEM 80

Dear Mr. O'Reilly:

Attached is the final report on the subject item which was deemed reportable per the provisions of 10CFR50.55(e), on April 19, 1982. With this report, Carolina Power & Light Company considers this matter closed.

If you have any questions regarding this matter, please do not hesitate to contact me.

Yours very truly,



R. M. Parsons  
Project General Manager  
Shearon Harris Nuclear Power Plant

RMP/jam

Attachment

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNP)  
Mr. R. C. DeYoung (NRC)

B409100101 B40816  
PDR ADOCK 05000400  
S PDR

OFFICIAL COPY

11 JE 27

CAROLINA POWER & LIGHT COMPANY  
SHEARON HARRIS NUCLEAR POWER PLANT

UNIT NO. 1

FINAL REPORT

PRESSURE SENSING LINE IN THE STARTING AIR SYSTEM FOR THE  
EMERGENCY STANDBY DIESEL ENGINE GENERATOR SETS

ITEM 80  
(DDR 870)

AUGUST 17, 1984

REPORTABLE UNDER 10CFR50.55(e)

IE 27  
111

SUBJECT: Shearon Harris Nuclear Power Plant Unit No. 1  
10CFR50.55(e) reportable deficiency concerning a  
potential problem with the pressure sensing lines in  
the starting air systems for the Emergency Standby  
Diesel Engine Generator Sets supplied by Transamerica  
DeLaval, Inc., under Purchase Order NY-435079.

ITEM: The pressure sensing line between the starting air  
storage tank manual isolation valve and pressure  
switch mounted on the starting air compressor for the  
Transamerica DeLaval, Inc. Standby Diesel Engine  
Generators: Model No. DS RV-16-4.

SUPPLIED BY: The manual isolation valves, compressors, and air  
tanks are supplied by Transamerica DeLaval, Inc.,  
Oakland, California. The sensing line is furnished  
and installed by CP&L in accordance with the design  
documents generated by Ebasco Services, Inc.

NATURE OF  
DEFICIENCY: In a letter dated March 24, 1982, Transamerica  
DeLaval notified CP&L that in the event of a pressure  
sensing line failure during a seismic event, the  
starting air pressure could bleed down to 150 psig in  
a minimum of six minutes. The engine will not  
automatically start when the starting air pressure is  
less than 150 psig.

DATE PROBLEM  
OCCURRED: Refer to section above.

DATE PROBLEM  
REPORTED: April 19, 1982 - CP&L (N. J. Chiangi) notified the  
NRC (Region II - C. Julian) that this item was  
reportable under 10CFR50.55(e). Transamerica DeLaval  
reported this to the NRC under 10CFR, Part 21 on  
March 19, 1982.

SCOPE OF  
PROBLEM: Upon objective review of the design documents, it was  
determined that this potential problem does not  
affect the SHNPP diesel generator sets.

SAFETY  
IMPLICATION: The Emergency Standby Diesel Engine-Generator Sets  
supply power to the emergency safety features buses  
in the event of a loss of normal on-site and off-site  
power sources. The pressure sensing line is Seismic  
Category I and should not fail during a seismic  
event.

REASON

DEFICIENCY IS  
REPORTABLE:

This item was not reportable since the sensing line is Seismic Category I.

CORRECTIVE  
ACTION:

Transamerica DeLaval had recommended the installation of an 1/8" restrictive orifice between the manual isolation valve and the starting air tank, which would increase the time to reach 150 psig to 53 minutes if the sensing line failed. This orifice will not be installed since the sensing line used at SHNPP is Seismic Category I and should not fail during a seismic event.