

**TABLE 3-14**  
SNUBBER VISUAL INSPECTION INTERVAL  
NUMBER OF UNACCEPTABLE SNUBBERS

<u>Population</u> (Notes 1 and 2)	<u>Column A</u> <u>Extend Interval</u> (Note 3)	<u>Column B</u> <u>Repeat Interval</u> (Note 4)	<u>Column C</u> <u>Reduce Interval</u> (Note 5)
1	0	0	1
80	0	0	2
100	0	1	4
150	0	3	8
200	2	5	13
300	5	12	25
400	8	18	36
500	12	24	48
750	20	40	78

Note 1: The next visual inspection interval for a snubber population shall be determined based upon the previous inspection interval and the number of unacceptable snubbers found during that interval. The first inspection interval determined using this criteria shall be based upon the previous inspection interval as established by the requirements in effect before amendment 145. Snubbers may be categorized, based upon their accessibility during power operation, as accessible or inaccessible. These categories may be examined separately or jointly. However, the licensee must make and document that decision before any inspection and shall use that decision as the basis upon which to determine the next inspection interval for that category.

Note 2: Interpolation between population or category sizes and the number of unacceptable snubbers is permissible. Use next lower integer for the value of the limit for Columns A, B, or C if that integer includes a fractional value of unacceptable snubbers as determined by interpolation.

Note 3: If the number of unacceptable snubbers is equal to or less than the number in Column A, the next inspection interval may be twice the previous interval up to a 48 month interval.

Note 4: If the number of unacceptable snubbers is equal to or less than the number in Column B but greater than the number in Column A, the next inspection interval shall be the same as the previous interval.