



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 14, 1992

Docket Nos. 50-317
and 50-318

LICENSEE: Baltimore Gas and Electric Company (BG&E)
FACILITY: Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 & 2
SUBJECT: MEETING MINUTES REGARDING THE MAY 5, 1992, MEETING TO DISCUSS THE SEISMIC ANALYSIS OF THE NEW EMERGENCY DIESEL GENERATOR BUILDINGS - CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 (TAC NOS. M83222 AND M83223)

BACKGROUND:

On July 21, 1988, the Code of Federal Regulations 10 CFR Part 50, was amended to include a new Section 50.63, entitled, "Loss of All Alternating Current Power," referred to as the station blackout (SBO) rule. The SBO rule requires that each light-water cooled nuclear power plant be able to withstand and recover from an SBO of specified duration. The SBO rule also requires that information defined in the rule be provided to the staff for review.

BG&E responded to the requirements of the rule and the staff approved its response by letter dated February 12, 1992. The staff's approval included the addition of two new safety-related Class 1E emergency diesel generators (EDGs). A meeting was held on November 7, 1991, to discuss the design details and modifications associated with the installation of the new EDGs.

PURPOSE:

By letter dated April 24, 1992, BG&E requested the subject meeting. The requested meeting is the first of a series of meetings with the staff to discuss various technical issues associated with the addition of the EDGs. Some of the other topics to be discussed at future meetings include: American Society of Mechanical Engineers (ASME) Code requirements, mechanical and electrical design, instrumentation and controls design, and EDG surveillance requirements.

A list of attendees is attached as Enclosure 1 and the BG&E presentation is attached as Enclosure 2.

SUMMARY:

Representatives of BG&E and its architect/engineer, Bechtel Power Corporation, presented the design and seismic details provided in Enclosure 2, a description of the buildings being designed to house the EDGs, the seismic parameters being used, and the methods and procedures used in performing the seismic analysis was discussed.

9205260083 920514
PDR ADDCK 05000317
P PDR

NRC FILE CENTER COPY


DFO1

May 14, 1992

Two separate buildings will be constructed to house the new EDGs including their associated diesel fuel tanks and cooling systems (radiators and fans). Provisions are being included in the initial design to add a third separate building at a future date. The seismic design parameters included discussions of the response spectra, time history, critical damping factors, and the supporting media (soil). The discussion of the seismic analysis methods and procedures included details of the type (dynamic) of methods, natural frequencies, response loads being considered and the procedures used for modeling.

The staff provided several comments during the presentation in areas where additional consideration should be given to assure that the BG&E submittal will include sufficient detail and address all necessary areas.

The staff indicated that the presentation was informative, facilitated communications, and should assist a timely review when the EDG modifications are provided for staff review.



Donald G. McDonald, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. BG&E Presentation Handout

cc w/enclosures:
See next page

Mr. G. C. Creel
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 and 2

cc:

Mr. Michael Moore, President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, Maryland 20678

Mr. Joseph H. Walter
Engineering Division
Public Service Commission of
Maryland
American Building
231 E. Baltimore Street
Baltimore, Maryland 21202-3486

D. A. Brune, Esquire
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Kristen A. Burger, Esquire
Maryland People's Counsel
American Building, 9th Floor
231 E. Baltimore Street
Baltimore, Maryland 21202

Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, DC 20037

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P. O. Box 33111
Baltimore, Maryland 21218

Mr. G. L. Detter, Director, NRM
Calvert Cliffs Nuclear Power Plant
MD Rts. 2 & 4, P. O. Box 1535
Lusby, Maryland 20657

Resident Inspector
c/o U.S. Nuclear Regulatory
Commission
P. O. Box 287
St. Leonard, Maryland 20685

Mr. Richard I. McLean
Administrator - Radioecology
Department of Natural Resources
580 Taylor Avenue
Tawes State Office Building
B3
Annapolis, Maryland 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. G. C. Creel
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 and 2

cc:

Mr. Michael Moore, President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, Maryland 20678

Mr. Joseph H. Walter
Engineering Division
Public Service Commission of
Maryland
American Building
231 E. Baltimore Street
Baltimore, Maryland 21202-3486

D. A. Brune, Esquire
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Kristen A. Burger, Esquire
Maryland People's Counsel
American Building, 9th Floor
231 E. Baltimore Street
Baltimore, Maryland 21202

Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, DC 20037

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P. O. Box 33111
Baltimore, Maryland 21218

Mr. G. L. Dotter, Director, NRM
Calvert Cliffs Nuclear Power Plant
MD Rts. 2 & 4, P. O. Box 1535
Lusby, Maryland 20657

Resident Inspector
c/o U.S. Nuclear Regulatory
Commission
P. O. Box 287
St. Leonard, Maryland 20685

Mr. Richard I. McLean
Administrator - Radioecology
Department of Natural Resources
580 Taylor Avenue
Tawes State Office Building
B3
Annapolis, Maryland 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

ATTENDANCE LIST

<u>NAME</u>	<u>ORGANIZATION</u>
Daniel G. McDonald	NRC/NRR/DRP
Robert A. Capra	NRC/NRR/DRP
Robert L. Rothman	NRC/NRR/ESGB
Sam Sae-Ung	Bechtel
James C. Cleinik	Bechtel
Eugene W. Thomas	Bechtel
Pat Furio	Baltimore Gas & Electric
Charles Mahon	Baltimore Gas & Electric
Pyllis Sobel	NRC/NRR/ESGB
Hans Ashar	NRC/NRR/DET/ESGB
Raman Pichumani	NRC/NRR/DET/ESGB
Yong Kim	NRC/NRR/DET/ESGB
Goutham Bagchi	NRC/NRR/DET/ESGB
Eugene Dec	Bechtel
Wayne A. Smith	Bechtel
Philip J. Hebrank	Baltimore Gas & Electric
Gary J. O'Connell	Baltimore Gas & Electric

**SEISMIC ANALYSIS
OF
NEW DIESEL
GENERATOR BUILDINGS
AT
CALVERT CLIFFS
NUCLEAR
POWER PLANT**

**PREPARED BY
BECHTEL POWER CORPORATION
FOR
BALTIMORE GAS AND ELECTRIC COMPANY**

MAY 5, 1992

OUTLINE OF PRESENTATION

- A. DESCRIPTION OF STRUCTURES**
- B. SEISMIC DESIGN PARAMETERS
(SRP SECTION 3.7.1)**
- C. SEISMIC SYSTEM ANALYSIS
(SRP SECTION 3.7.2)**
- D. SUMMARY**

A. DESCRIPTION OF STRUCTURES

(SEE FIGURES 1 - 6)

TWO SEPARATE DG BUILDINGS
INITIALLY

THIRD SEPARATE DG BUILDING
LATER

SEPARATED BY SEISMIC JOINTS




FIGURE 1: EXISTING PLANT LAYOUT




FIGURE 2: ENLARGED PLAN VIEW




FIGURE 3: PLAN VIEW - EL. 45'- 6"




FIGURE 4: PLAN VIEW - EL. 80'-6




FIGURE 5: ELEVATION VIEW
(SECTION A-A)




FIGURE 6: PLAN VIEW - EL. 35'- 6"

B. SEISMIC DESIGN PARAMETERS (SRP SECTION 3.7.1, REV. 2)

1. DESIGN GROUND MOTION

a. DESIGN RESPONSE SPECTRA

- 1.) REGULATORY GUIDE 1.60
- 2.) MAXIMUM GROUND ACCELERATIONS:

QUAKE	DIRECTION	
	HOR.	VERT.
SSE	0.15 g	0.10 g
OBE	0.08 g	0.053 g

- 3.) CONTROL MOTIONS
DEFINED AT BOTTOM OF
EFFECTIVE BASE SLAB
(EL. 35'- 6")

b. DESIGN TIME HISTORY

- 1.) THREE TIME HISTORIES
APPLIED IN
ORTHOGONAL
DIRECTIONS
(SEE FIGURES 7 - 9)

- 2.) SPECTRA ENVELOPING
(SEE FIGURES 10 - 12)

- 3.) POWER SPECTRAL
DENSITY
(SEE FIGURES 13 - 15)

- 4.) TOTAL DURATION
(SEE FIGURES 7 - 9)

- 5.) STRONG MOTION
DURATION
(SEE FIGURES 16 - 18)

- 6.) STATISTICAL
INDEPENDENCE
(SEE FIGURES 19 - 21)




FIGURE 7: HORIZONTAL
TIME HISTORY H1




FIGURE 8: HORIZONTAL
TIME HISTORY H2




FIGURE 9: VERTICAL
TIME HISTORY




FIGURE 10: SPECTRA ENVELOPING
HOR. TIME HISTORY H1




FIGURE 11: SPECTRA ENVELOPING
HOR. TIME HISTORY H2




FIGURE 12: SPECTRA ENVELOPING
VERT. TIME HISTORY




FIGURE 13: POWER SPECTRAL
DENSITY - HOR.
TIME HISTORY H1




FIGURE 14: POWER SPECTRAL DENSITY - HOR. TIME HISTORY H2




FIGURE 15: POWER SPECTRAL DENSITY - VERT. TIME HISTORY




FIGURE 16: STRONG MOTION DURATION - HOR. TIME HISTORY H1




FIGURE 17: STRONG MOTION DURATION - HOR. TIME HISTORY H2




FIGURE 18: STRONG MOTION DURATION - VERT. TIME HISTORY

CORRELATION COEFFICIENT = 0.024




FIGURE 19: STATISTICAL
INDEPENDENCE - HOR.
TIME HISTORY H1 VS.
HOR. TIME HISTORY H2

CORRELATION COEFFICIENT = 0.106




FIGURE 20: STATISTICAL
INDEPENDENCE - HOR.
TIME HISTORY H1 VS.
VERT. TIME HISTORY

CORRELATION COEFFICIENT = 0.018




FIGURE 21: STATISTICAL
INDEPENDENCE - HOR.
TIME HISTORY H2 VS.
VERT. TIME HISTORY

2. PERCENT OF CRITICAL DAMPING VALUES

- a. REGULATORY GUIDE 1.61
DAMPING

- b. RACEWAY DAMPING VALUES
BASED ON BECHTEL/ANCO
TESTS

- c. CORRELATION BETWEEN
STRESS LEVELS AND DAMPING
VALUES

- d. GROUND WATER EFFECTS ON
SOIL DAMPING

3. SUPPORTING MEDIA FOR CATEGORY I STRUCTURES

a. FOUNDATION EMBEDMENT DEPTH (SEE FIGURE 5)

MIN. = 4.5 ft.

MAX. = 14.5 ft.

b. DEPTH OF SOIL OVER BEDROCK

APPROX. 2500 ft.

c. SOIL LAYERING CHARACTERISTICS

(SEE TABLE 1)

DEPTH	SOIL DESCRIPTION	SHEAR WAVE VEL. (ft/sec)	SHEAR MOD. (ksf)	DEN. (pcf)	POISSON'S RATIO
0 - 18	MEDIUM STIFF TO STIFF SILTY CLAY	850	2500	110	0.47
18 - 33	MEDIUM DENSE TO DENSE SILTY FINE SAND, TRACE TO SOME SHELL FRAGMENTS, OCCASIONAL CEMENTATION	1250	5800	120	0.34
33 - 50	LOOSE TO MEDIUM DENSE SILTY FINE SAND	1050	4100	120	0.39
50 - 100	MEDIUM DENSE TO DENSE SILTY FINE SAND	1350	7000	125	0.35
BELOW 100	DENSE SILTY FINE SAND TO SANDY SILT	1600	9500	120	0.35
-	CRUSHED STONE	1300	6800	130	0.4

TABLE 1: SOIL LAYERING CHARACTERISTICS AND PROPERTIES

d. DESIGN GROUNDWATER
ELEVATION

25 ft. BELOW GRADE
(EL. 20'- 0")

e. DIMENSIONS OF THE
STRUCTURAL FOUNDATION

(SEE FIGURES 3 AND 6)

f. TOTAL STRUCTURAL HEIGHT

58.5 ft. ABOVE GRADE
(SEE FIGURE 5)

g. SOIL PROPERTIES AS A
FUNCTION OF DEPTH
(SEE TABLE 1)

EXISTING SOIL ABOVE
EL. 27'- 0" REPLACED WITH
CRUSHED STONE

**C. SEISMIC SYSTEM ANALYSIS
(SRP SECTION 3.7.2, REV.2)**

**1. SEISMIC ANALYSIS METHODS
(DYNAMIC ANALYSIS)**

- a. CLASSICAL
ELASTIC HALF-SPACE
GREEN'S FUNCTION

- b. SOIL-STRUCTURE INTERACTION
(SEE TABLE 1 FOR SOIL
LAYERING)

- c. 3D MODEL
TORSIONAL, ROCKING AND
TRANSLATIONAL RESPONSES
(SEE FIGURE 22)




FIGURE 22: PROPOSED 3-D
STRUCTURAL MODEL

d. NUMBER OF MASSES/DEGREES
OF FREEDOM

e. MODAL MASS

f. RELATIVE DISPLACEMENTS
BETWEEN BUILDINGS

2. NATURAL FREQUENCIES AND
RESPONSE LOADS

LATER

3. PROCEDURES USED FOR ANALYTICAL MODELING

a. DECOUPLING CRITERIA

1.) RADIATORS

2.) FUEL OIL TANK

3.) DIESEL GENERATOR

b. FLOOR FLEXIBILITY WILL BE ACCOUNTED FOR IN THE VERTICAL DIRECTION

4. SOIL-STRUCTURE INTERACTION

a. CLASSI

b. EMBEDMENT EFFECTS

c. EQUIVALENT LINEAR SOIL
PROPERTIES - SHAKE

d. THREE SETS OF SOIL
PROPERTIES

1.) AVERAGE (BEST
ESTIMATE)

2.) TWICE AVERAGE

3.) HALF AVERAGE

- e. CONTROL MOTIONS DEFINED
AT BOTTOM OF EFFECTIVE
BASE SLAB (EL. 35'- 6")

- f. GROUNDWATER EFFECTS NOT
SIGNIFICANT FOR DAMPING

- g. STRUCTURE-TO-STRUCTURE
INTERACTION NOT
SIGNIFICANT

5. DEVELOPMENT OF FLOOR
RESPONSE SPECTRA (FRS)

a. FLOOR TIME HISTORIES FROM
CLASSI

b. REGULATORY GUIDE 1.122
BROADENING

c. ENVELOPE OF 3 SETS OF SOIL
PROPERTIES

6. THREE COMPONENTS OF
EARTHQUAKE MOTION

MAXIMUM DIRECTIONAL
RESPONSES COMBINED BY SRSS
(OR THE MORE CONSERVATIVE
100-40-40 PERCENT RULE)

7. COMBINATION OF MODAL
RESPONSES

NOT APPLICABLE TO TIME
HISTORY ANALYSIS

8. INTERACTION OF NON CATEGORY I
STRUCTURES WITH CATEGORY I
STRUCTURES

NOT APPLICABLE

9. EFFECTS OF PARAMETER
VARIATIONS ON FLOOR RESPONSE
SPECTRA (FRS)

FRS BROADENED IN
ACCORDANCE WITH
REGULATORY GUIDE 1.122

10. USE OF EQUIVALENT VERTICAL
STATIC FACTORS

NOT APPLICABLE

11. METHODS USED TO ACCOUNT
FOR TORSIONAL EFFECTS

TORSIONAL DEGREES OF
FREEDOM INCORPORATED INTO
MODEL

12. COMPARISON OF RESPONSES
(RESPONSE SPECTRUM VS.
TIME HISTORY)

NOT APPLICABLE

13. ANALYSIS PROCEDURE FOR
DAMPING

NOT APPLICABLE

14. DETERMINATION OF
CATEGORY I STRUCTURES
OVERTURNING MOMENTS

BASED ON 100-40-40 PERCENT
RULE FOR THREE COMPONENTS
OF SEISMIC RESPONSE

D. SUMMARY

1. MAX. HOR. OBE & SSE
GROUND ACCELERATIONS
- 0.08 G & 0.15 G,
RESPECTIVELY

VERT. = 2/3 HOR.

2. REG. GUIDE 1.60
DESIGN SPECTRA
3. USE THREE SINGLE
TIME HISTORIES
FOR ANALYSIS
4. USE CLASSI FOR
SEISMIC ANALYSIS

MAJOR POINTS

- 3D ANALYSIS
- SOIL LAYERING

D. SUMMARY (CONTINUED)

- VARIATION OF SOIL PROPERTIES
- PARAMETRIC STUDIES TO ADDRESS FOUNDATION CONDITIONS
- DECOUPLING CRITERIA
- SPECTRA BROADENING PER REG. GUIDE 1.122

May 14, 1992

Two separate buildings will be constructed to house the new EDGs including their associated diesel fuel tanks and cooling systems (radiators and fans). Provisions are being included in the initial design to add a third separate building at a future date. The seismic design parameters included discussions of the response spectra, time history, critical damping factors, and the supporting media (soil). The discussion of the seismic analysis methods and procedures included details of the type (dynamic) of methods, natural frequencies, response loads being considered and the procedures used for modeling.

The staff provided several comments during the presentation in areas where additional consideration should be given to assure that the BG&E submittal will include sufficient detail and address all necessary areas.

The staff indicated that the presentation was informative, facilitated communications, and should assist a timely review when the EDG modifications are provided for staff review.

Original Signed By

Donald G. McDonald, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. BG&E Presentation Handout

cc w/enclosures:
See next page

OFFICE	LA:PDI-1	PM:PDI-1 <i>Quid</i>	D:FDI-1		
NAME	CSVogan <i>CV</i>	DGMcDonald:pc	RACapra <i>CA</i>		
DATE	5/14/92	05/14/92	5/14/92	/ /92	/ /92

OFFICIAL RECORD COPY
FILENAME: B:\CC83222.MTS

DISTRIBUTION: Meeting Summary

Docket File

NRC & Local PDRs

PDI-1 Reading

TEMurley

FJMiraglia

JGPartlow

SAVarga

JACalvo

RACapra

CSVogan

DGMcDonald

OGC

EJordan, MNBB 3701

RRothman

PSobel

HAshe

RPichumeni

YKim

GBagchi

ACRS (10)

RLobel, 17G21

CCowgill, RI

cc: Plant Service List
Licensee