

January 23, 1996

Mr. Donald Schnell  
Senior Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING UNION ELECTRIC  
COMPANY'S SEPTEMBER 6, 1995, REQUEST TO REVISE CALLAWAY PLANT  
TECHNICAL SPECIFICATIONS (TAC NO. M93704)

Dear Mr. Schnell:

The NRC staff has reviewed your September 6, 1995, request to increase the fuel enrichment at the Callaway Plant from 4.45 to 5.00 weight percent U-235 for fuel with integral fuel burnable absorbers (IFBAs) and from 3.85 to 4.10 weight percent U-235 for fuel without IFBAs and has identified areas where additional information is needed to complete the review. The information needed is detailed in the enclosure. Since NRC approval of the request is needed to support your October 1996 refueling outage, we request that you respond in writing to this request for additional information as soon as possible.

The requirements affect nine or fewer respondents and, therefore, are not subject to the Office of Management and Budget review under P.L. 96-511. If you have any questions, please contact me at (301) 415-1362.

Sincerely,

Original signed by:  
Kristine M. Thomas, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. <sup>5</sup>20-483

Enclosure: Request for Additional  
Information

cc w/encl: See next page

DISTRIBUTION:

|                  |                |
|------------------|----------------|
| Docket File      | PUBLIC         |
| JRoe             | EAdensam       |
| WBateman         | KThomas        |
| EPeyton          | ACRS, TWFN     |
| PDIV-2 Reading   | OGC, 015B18    |
| WJohnson, RIV    | JDyer, RIV     |
| NWagner, SPLB    | GHubbard, SPBL |
| CMcCracken, SPLB |                |

Document Name: CA993704.RAI

|      |          |            |
|------|----------|------------|
| OFC  | LA:PD4-2 | PM:PD4-2   |
| NAME | EPeyton  | KThomas:pk |
| DATE | 1/23/96  | 1/23/96    |

OFFICIAL RECORD COPY

9601250228 960123  
PDR ADOCK 05000483  
P PDR

220009

NRC FILE CENTER COPY

DFD 1/1

January 23, 1996

Mr. Donald Schnell  
Senior Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING UNION ELECTRIC COMPANY'S SEPTEMBER 6, 1995, REQUEST TO REVISE CALLAWAY PLANT TECHNICAL SPECIFICATIONS (TAC NO. M93704)

Dear Mr. Schnell:

The NRC staff has reviewed your September 6, 1995, request to increase the fuel enrichment at the Callaway Plant from 4.45 to 5.00 weight percent U-235 for fuel with integral fuel burnable absorbers (IFBAs) and from 3.85 to 4.10 weight percent U-235 for fuel without IFBAs and has identified areas where additional information is needed to complete the review. The information needed is detailed in the enclosure. Since NRC approval of the request is needed to support your October 1996 refueling outage, we request that you respond in writing to this request for additional information as soon as possible.

The requirements affect nine or fewer respondents and, therefore, are not subject to the Office of Management and Budget review under P.L. 96-511. If you have any questions, please contact me at (301) 415-1362.

Sincerely,

Original signed by:  
Kristine M. Thomas, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 40-483

Enclosure: Request for Additional  
Information

cc w/encl: See next page

DISTRIBUTION:

|                  |                |
|------------------|----------------|
| Docket File      | PUBLIC         |
| JRoe             | EAdensam       |
| WBateman         | KThomas        |
| EPeyton          | ACRS, TWFN     |
| PDIV-2 Reading   | OGC, 015B18    |
| WJohnson, RIV    | JDyer, RIV     |
| NWagner, SPLB    | GHubbard, SPBL |
| CMcCracken, SPLB |                |

Document Name: CA993704.RAI

|      |          |            |
|------|----------|------------|
| OFC  | LA:PD4-2 | PM:PD4-2   |
| NAME | EPeyton  | KThomas:pk |
| DATE | 1/23/96  | 1/23/96    |

OFFICIAL RECORD COPY

Mr. D. F. Schnell

- 2 -

cc w/encl:

Professional Nuclear  
Consulting, Inc.  
19041 Raines Drive  
Derwood, Maryland 20855

Gerald Charnoff, Esq.  
Thomas A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Mr. H. D. Bono  
Supervising Engineer,  
Site Licensing  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission  
Resident Inspector Office  
8201 NRC Road  
Steedman, Missouri 65077-1302

Mr. G. L. Randolph, Vice President  
Nuclear Operations  
Union Electric Company  
P.O. Box 620  
Fulton, Missouri 65251

Manager - Electric Department  
Missouri Public Service Commission  
301 W. High  
Post Office Box 360  
Jefferson City, Missouri 65102

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Harris Tower & Pavilion  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

Mr. Ronald A. Kucera, Deputy Director  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, Missouri 65102

Mr. Neil S. Carns  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
P.O. Box 411  
Burlington, Kansas 66839

Mr. Dan I. Bolef, President  
Kay Drey, Representative  
Board of Directors Coalition  
for the Environment  
6267 Delmar Boulevard  
University City, Missouri 65130

Mr. Lee Fritz  
Presiding Commissioner  
Callaway County Court House  
10 East Fifth Street  
Fulton, Missouri 65151

Mr. Alan C. Passwater, Manager  
Licensing and Fuels  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

Mr. J. V. Laux, Manager  
Quality Assurance  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

CALLAWAY PLANT, UNIT NO. 1DOCKET NO. 50-483REQUEST FOR ADDITIONAL INFORMATION REGARDING SEPTEMBER 6, 1995 SUBMITTAL

In support of the Union Electric Company's amendment request of September 6, 1995, information is required that demonstrates that the thermal-hydraulic characteristics of the Callaway spent fuel pool (SFP) are in conformance with previously accepted criteria or with present NRC guidelines for the fuel enrichment changes that have been requested. Therefore, the following information is requested:

1. Describe the licensing bases for the Callaway SFP and related systems, making reference to licensing documents and correspondence as applicable, and explain what impact the proposed changes in fuel enrichment will have on these licensing bases. Identify any relevant assumptions and other licensing basis considerations such as postulated accident conditions, single-failure considerations, and environmental effects on equipment in the vicinity of the SFP.
2. If not included in the response to 1 above, provide the following information:
  - a. The worst-case decay heat load that will result from spent fuel stored in the SFP as a consequence of a normal core offload and a full core offload. For each, specify the bases for the results obtained, including the number and types of spent fuel elements stored.
  - b. The worst-case bulk temperatures of the SFP coolant and the bases for these temperatures for a normal core offload and for a full core offload.
  - c. The minimum time to reach bulk boiling in the SFP coolant after reaching the worst-case temperatures in the case of a normal core offload and a full core offload.
  - d. The maximum (worst-case) fuel cladding temperature that could be reached for fuel stored in the SFP.
3. Discuss to what extent coolant boiling may result from storage of spent fuel in the SFP and to what degree voids resulting from such boiling have been included in the criticality analysis for the proposed changes in fuel enrichment.
4. Explain what is meant by "thermal hydraulic constraints" and their resolution (see pages 1 and 2 of Attachment 3 to the September 6, 1995, submittal).
5. Describe how the fuel pool cleanup system will be protected in the event of high SFP coolant temperatures.