

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

September 7, 1984

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:


In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

In accordance with the requirement of 10 CFR 50.49(h), we are providing notification of additional equipment that has been discovered to not meet requirements of NUREG-0588 for qualification. As a result of a recent nonconformance report which identified an event that would increase the temperature limits in the steam valve vault rooms, six main steam line pressure transmitters (PT-1-2B, -9A, -9B, -20A, -20B and -27B) have been determined to be unqualified. Additional background information and a justification for continued operation were discussed in my August 2, 1984 letter to you regarding main steam superheating inside and outside containment. We are therefore requesting an extension for qualification of these components for unit 1 until the end of the cycle 3 refueling outage presently scheduled to begin in June 1985. This schedule relief request is the same as that previously granted TVA on April 11, 1984. For unit 2, we plan to resolve this issue before startup from the next refueling outage presently scheduled to begin September 21, 1984.

If you have any questions concerning this matter, please get in touch with Jerry Wills at FTS 858-2683.

Very truly yours,


TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Licensing

8409110139 840907
PDR ADDCK 05000327
P PDR

Sworn to, and subscribed before me
this 7th day of Sept. 1984



Notary Public
My Commission Expires 8-24-88

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

AO48
/10