



# PECO ENERGY

**Gerald R. Rainey**  
Vice President  
Peach Bottom Atomic Power Station

PECO Energy Company  
RD 1, Box 208  
Delta, PA 17314-9739  
717 456 7014

January 11, 1996

Docket Nos. 50-277  
50-278

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

SUBJECT: 1995 Annual Report on Safety Relief Challenges for the Peach Bottom Atomic Power Station

Gentlemen:

This represents the 1995 Annual Report on Safety Relief Challenges for the Peach Bottom Atomic Power Station (PBAPS) as required by the TMI Action Plan, Item II. K.3, and by PBAPS Technical Specifications, Paragraph 6.9.1.C: During 1995 there were no automatic actuations of the Main Steam Safety or Relief Valves in response to high reactor pressure.

If you have any questions regarding this matter, please call.

Sincerely,

Gerald R. Rainey  
Vice President

*Handwritten:*  
CWR  
1/11/96  
RWC  
1/11/96

GRR/BWK:dec

- cc: B. Gorman, Public Service Electric & Gas
- R. R. Janati, Commonwealth of Pennsylvania
- R. I. McLean, State of Maryland
- T. T. Martin, Administrator, Region I, USNRC
- W. L. Schmidt, USNRC Senior Resident Inspector
- H. C. Schwemm, Atlantic Electric
- A. S. Kirby, Delmarva Power
- INPO Record Center
- Correspondance Control Desk, 61B-3

CCN 96-14006

9601260182 960111  
PDR ADOCK 05000277  
P PDR

260051

*Handwritten:*  
ADD 1/0