

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

---

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to  $L_a$ , 0.1 percent by weight of the containment air per 24 hours, at the calculated peak containment pressure  $P_a$ , greater than or equal to 44.1 psig.
- b. A combined leakage rate of less than or equal to  $0.60 L_a$  for all penetrations and valves subject to Type B and C tests, when pressurized to  $P_a$ , greater than or equal to 44.1 psig.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With either (a) the measured overall integrated containment leakage rate exceeding  $0.75 L_a$  or (b) with the measured combined leakage rate for all penetrations and valves subject to Type B and C tests exceeding  $0.60 L_a$ , restore the overall integrated leakage rate to less than  $0.75 L_a$  and the combined leakage rate for all penetrations subject to Type B and C tests to less than or equal to  $0.60 L_a$  prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

---

4.6.1.2 The containment and containment penetrations shall be tested by performing leakage rate testing as required by 10 CFR 50, Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September 1995. The provisions of Specification 4.0.2 are not applicable.

9601260214 960123  
PDR ADOCK 05000338  
P PDR

## 3/4.6 CONTAINMENT SYSTEMS

### 3/4.6.1 CONTAINMENT

#### CONTAINMENT INTEGRITY

#### LIMITING CONDITION FOR OPERATION

---

---

3.6.1.1 Primary CONTAINMENT INTEGRITY shall be maintained.

APPLICABILITY: MODES 1, 2, 3, and 4

ACTION:

Without primary CONTAINMENT INTEGRITY, restore CONTAINMENT INTEGRITY within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

---

4.6.1.1 Primary CONTAINMENT INTEGRITY shall be demonstrated:

- a. At least once per 31 days by verifying that all penetrations\* not capable of being closed by OPERABLE containment automatic isolation valves and required to be closed during accident conditions are closed by valves, blind flanges, or deactivated automatic valves, secured in their positions, except for valves that are open under administrative control as permitted by Specification 3.6.3.1.
- b. By verifying that each containment air lock is OPERABLE per Specification 3.6.1.3.
- c. After each closing of the equipment hatch, by leak rate testing the equipment hatch seals, with gas at  $P_a$ , greater than or equal to 44.1 psig. Results shall be evaluated against the criteria of Specification 3.6.1.2.b as required by 10 CFR 50, Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September 1995.
- d. Each time containment integrity is established after vacuum has been broken by pressure testing the butterfly isolation valves in the containment purge lines and the containment vacuum ejector line.

---

\* Except valves, blind flanges, and deactivated automatic valves which are located inside the containment and are locked sealed or otherwise sealed in the closed position. These penetrations shall be verified closed during each COLD SHUTDOWN except that such surveillance need not be performed more often than once per 92 days.

## CONTAINMENT SYSTEMS

### CONTAINMENT AIR LOCKS

#### LIMITING CONDITION FOR OPERATION

---

---

3.6.1.3 Each containment air lock shall be OPERABLE with:

- a. Both doors closed except when the air lock is being used for normal transit entry and exit through the containment, then at least one air lock door shall be closed, and
- b. An overall air lock leakage rate of less than or equal to  $0.05 L_a$  at  $P_a$  greater than or equal to 44.1 psig.

APPLICABILITY: MODES 1, 2, 3 and 4.

#### ACTION:

- a. With one containment air lock door inoperable:
  1. Maintain at least the OPERABLE air lock door closed and either restore the inoperable air lock door to OPERABLE status within 24 hours or lock the OPERABLE air lock door closed.+
  2. Operation may then continue until performance of the next required overall air lock leakage test provided that the OPERABLE air lock door is verified to be locked closed at least once per 31 days.
  3. Otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
  4. The provisions of Specification 3.0.4 are not applicable.
- b. With a containment air lock inoperable, except as the result of an inoperable air lock door, maintain at least one air lock door closed; restore the inoperable air lock to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

---

4.6.1.3 Each containment air lock shall be demonstrated OPERABLE:

- a. By performing leakage rate testing as required by 10 CFR 50, Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September 1995. The provisions of Specification 4.0.2 are not applicable.
- b. At least once per refueling outage by verifying that only one door in each air lock can be opened at a time.

---

+ Entry to repair the inner air lock door, if inoperable, is allowed.

## CONTAINMENT SYSTEMS

### CONTAINMENT STRUCTURAL INTEGRITY

#### LIMITING CONDITIONS FOR OPERATION

---

---

3.6.1.6 The structural integrity of the containment shall be maintained at a level consistent with the acceptance criteria in Specification 4.6.1.6.1.

APPLICABILITY: MODES 1, 2, 3 and 4.

#### ACTION:

With the structural integrity of the containment not conforming to the above requirements, restore the structural integrity to within the limits within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

---

4.6.1.6.1 Containment Surfaces The structural integrity of the exposed accessible interior and exterior surfaces of the containment, including the liner plate shall be determined by performing visual examinations as required by 10 CFR 50, Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September 1995. The provisions of Specification 4.0.2 are not applicable.

**Attachment 2**

**Technical Specifications Change**

**North Anna Power Station - Unit 2**

3/4.6 CONTAINMENT SYSTEMS

3/4.6.1 CONTAINMENT

CONTAINMENT INTEGRITY

**LIMITING CONDITION FOR OPERATION**

---

---

3.6.1.1 Primary CONTAINMENT INTEGRITY shall be maintained.

APPLICABILITY: MODES 1, 2, 3, and 4

ACTION:

Without primary CONTAINMENT INTEGRITY, restore CONTAINMENT INTEGRITY within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

**SURVEILLANCE REQUIREMENTS**

---

---

4.6.1.1 Primary CONTAINMENT INTEGRITY shall be demonstrated:

- a. At least once per 31 days by verifying that all penetrations\* not capable of being closed by OPERABLE containment automatic isolation valves and required to be closed during accident conditions are closed by valves, blind flanges, or deactivated automatic valves, secured in their positions, except for valves that are open under administrative control as permitted by Specification 3.6.3.1.
- b. By verifying that each containment air lock is OPERABLE per Specification 3.6.1.3.
- c. After each closing of the equipment hatch, by leak rate testing the equipment hatch seals, with gas at  $P_a$ , greater than or equal to 44.1 psig. Results shall be evaluated against the criteria of Specification 3.6.1.2.b as required by 10 CFR 50, Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September 1995.
- d. Each time containment integrity is established after vacuum has been broken by pressure testing the butterfly isolation valves in the containment purge lines and the containment vacuum ejector line.

---

\* Except valves, blind flanges and deactivated automatic valves which are located inside the containment and are locked sealed or otherwise sealed in the closed position. These penetrations shall be verified closed during each COLD SHUTDOWN except that such surveillance need not be performed more often than once per 92 days.

## CONTAINMENT SYSTEMS

### CONTAINMENT LEAKAGE

#### LIMITING CONDITION FOR OPERATION

---

---

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to  $L_a$ , 0.1 percent by weight of the containment air per 24 hours, at the calculated peak containment pressure  $P_a$ , greater than or equal to 44.1 psig.
- b. A combined leakage rate of less than or equal to  $0.60 L_a$  for all penetrations and valves subject to Type B and C tests, when pressurized to  $P_a$ , greater than or equal to 44.1 psig.

APPLICABILITY: MODES 1, 2, 3, and 4.

#### ACTION:

With either (a) the measured overall integrated containment leakage rate exceeding  $0.75 L_a$  or (b) with the measured combined leakage rate for all penetrations and valves subject to Type B and C tests exceeding  $0.60 L_a$ , restore the overall integrated leakage rate to less than  $0.75 L_a$  and the combined leakage rate for all penetrations subject to Type B and C tests to less than or equal to  $0.60 L_a$  prior to increasing the Reactor Coolant System temperature above 200°F.

#### SURVEILLANCE REQUIREMENTS

---

---

4.6.1.2 The containment and containment penetrations shall be tested by performing leakage rate testing as required by 10 CFR 50, Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September 1995. The provisions of Specification 4.0.2 are not applicable.



## CONTAINMENT SYSTEMS

### CONTAINMENT AIR LOCKS

#### LIMITING CONDITION FOR OPERATION

---

---

3.6.1.3 Each containment air lock shall be OPERABLE with:

- a. Both doors closed except when the air lock is being used for normal transit entry and exit through the containment, then at least one air lock door shall be closed, and
- b. An overall air lock leakage rate of less than or equal to  $0.05 L_a$  at  $P_a$  greater than or equal to 44.1 psig.

APPLICABILITY: MODES 1, 2, 3 and 4.

#### ACTION:

- a. With one containment air lock door inoperable:
  1. Maintain at least the OPERABLE air lock door closed and either restore the inoperable air lock door to OPERABLE status within 24 hours or lock the OPERABLE air lock door closed.+
  2. Operation may then continue until performance of the next required overall air lock leakage test provided that the OPERABLE air lock door is verified to be locked closed at least once per 31 days.
  3. Otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
  4. The provisions of Specification 3.0.4 are not applicable.
- b. With a containment air lock inoperable, except as the result of an inoperable air lock door, maintain at least one air lock door closed; restore the inoperable air lock to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

---

4.6.1.3 Each containment air lock shall be demonstrated OPERABLE:

- a. By performing leakage rate testing as required by 10 CFR 50, Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September 1995. The provisions of Specification 4.0.2 are not applicable.
- b. At least once per refueling outage by verifying that only one door in each air lock can be opened at a time.

---

+ Entry to repair the inner air lock door, if inoperable, is allowed.



## CONTAINMENT SYSTEMS

### CONTAINMENT STRUCTURAL INTEGRITY

#### LIMITING CONDITIONS FOR OPERATION

---

---

3.6.1.6 The structural integrity of the containment shall be maintained at a level consistent with the acceptance criteria in Specification 4.6.1.6.1.

APPLICABILITY: MODES 1, 2, 3 and 4.

#### ACTION:

With the structural integrity of the containment not conforming to the above requirements, restore the structural integrity to within the limits within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

---

4.6.1.6.1 Containment Surfaces The structural integrity of the exposed accessible interior and exterior surfaces of the containment, including the liner plate shall be determined by performing visual examinations as required by 10 CFR 50, Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September 1995. The provisions of Specification 4.0.2 are not applicable.