

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1): Washington Nuclear Plant - Unit 2
DOCKET NUMBER (2): 05000397
PAGE(S): 1 OF 2

TITLE (4): Unusual Event Dueto Offsite Fire

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
08	12	84	84	08	4	08	30	84			05000
THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)											

OPERATING MODE (9): 3	20.402(b)	20.406(a)	80.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10): 0,0,0	20.406(a)(1)(i)	80.38(a)(1)	80.73(a)(2)(v)	73.71(a)
	20.406(a)(1)(ii)	80.38(a)(2)	80.73(a)(2)(vi)	X OTHER (Specify in Abstract below and in Text, NRC Form 366A)
	20.406(a)(1)(iii)	80.73(a)(2)(i)	80.73(a)(2)(vii)(A)	50.72(a)(i)
	20.406(a)(1)(iv)	80.73(a)(2)(ii)	80.73(a)(2)(vii)(B)	
	20.406(a)(1)(v)	X 80.73(a)(2)(iii)	80.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12)

NAME: R. L. Koenigs, Compliance Engineer	TELEPHONE NUMBER: 509 377-2501
	Ext. 2279

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRRDS
X	-	-	-	N					

SUPPLEMENTAL REPORT EXPECTED (14): YES NO

EXPECTED SUBMISSION DATE (15): MONTH: | DAY: | YEAR: |

ABSTRACT (16) (Limit to 400 characters or approximately fifteen single-space typewritten lines) (16)

At 1735 hours on August 12, 1984, a grass fire which was approaching the plant boundaries, caused an Unusual Event to be declared due to the potential for loss of offsite electrical power supplies.

D.O.E. firefighting crews combated the fire and at 2000 hours the Unusual Event was terminated.

No actual loss of offsite electrical power supply was incurred.

Notification was provided to the NRC via ENS at 1745 hours on 8/12/84.

8409110235 840830
PDR ADOCK 05000397
S PDR

IE22
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Washington Nuclear Plant - Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 9 7 8 4	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		8 4	- 0 8 4	- 0 1 0	0 1 2	OF 0 1 2

TEXT (If more space is required, use additional NRC Form 388A's) (17)

Plant Conditions

- a) Power Level - 0%
- b) Plant Mode - 3

Event

At 1534 hours on 8/12/84, WNP-2 received notification from D.G.E. personnel that the State Emergency Control Center had been activated in response to a Hanford area range fire. At 1732 the Bonneville Power Authority (BPA) provided notification that a high potential existed for the loss of both offsite electrical power supplies.

Immediate Corrective Actions

At 1735 hours an Unusual Event was declared and Division 1 and 2 diesel generators were brought on line to supply safety related electrical loads.

Further Corrective Action

BPA notified WNP-2 at 2000 hours that there was little likelihood of losing the 230 KV normal offsite power supply. The Unusual Event was terminated at this time.

Safety Significance

There are no safety consequences associated with this event. No loss of offsite electrical power was incurred and those systems that were manually operated performed as required.

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

August 30, 1984

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: NUCLEAR PLANT NO. 2
LICENSEE EVENT REPORT NO. 84-084

Dear Sir:

Transmitted herewith is Licensee Event Report No. 84-084 for WNP-2 Plant. This report is submitted in response to the report requirements of 10CFR50.73 and discusses the item of reportability, corrective action taken, and action taken to preclude recurrence.

This is the follow-up report to the verbal notification given at 1745 hours on August 12, 1984.

Very truly yours,

JDM Powers for

J. D. Martin (M/D 927M)
WNP-2 Plant Manager

JDM:mm

Enclosure:

Licensee Event Report No. 84-084

cc: Mr. John B. Martin, NRC - Region V
Mr. A. D. Toth, NRC - Site (901A)
Ms. Dottie Sherman, ANI
INPO Records Center - Atlanta, GA

IE22
1/1