

WISCONSIN ELECTRIC POWER COMPANY
POINT BEACH NUCLEAR POWER PLANT UNITS 1 & 2

USNRC GENERIC LETTER 87-02
UNRESOLVED SAFETY ISSUE A-46
RESOLUTION

RELAY EVALUATION REPORT

Original Issue June 1995

Revision 1 January 1996

Prepared By:

Timothy J. Dykstra
T. J. Dykstra

12/29/95
Date

Reviewed By:

Charles W. Krause
Wisconsin Electric Power Co.

1/2/96
Date

Approved By:

A. L. Reimer
Wisconsin Electric Power Co.

1/16/96
Date



RELAY EVALUATION REPORT

TABLE OF CONTENTS

	TABLE OF CONTENTS	Rev. 1
	LIST OF ACRONYMS	Rev. 0
	1.0 INTRODUCTION	Rev. 0
	1.1 PURPOSE	
	1.2 BACKGROUND	
	1.3 USI A-46 RELAY EVALUATION	
	1.4 PBNP RELAY REVIEW METHODOLOGY	
	1.5 DEFINITIONS	
	1.6 REPORT ORGANIZATION	
	2.0 RESULTS AND PLANNED ACTIONS	Rev. 1
	2.1 SUMMARY OF RESULTS	
	2.2 RELAY OUTLIERS	
	2.3 COMPLETION ACTIVITIES	
	3.0 COMMITMENTS, CRITERIA AND GOVERNING ASSUMPTIONS	Rev. 1
	3.1 SQUG COMMITMENTS	
	3.2 CRITERIA AND GOVERNING ASSUMPTIONS	
	4.0 RELAY FUNCTIONALITY REVIEW	Rev. 1
	4.1 METHODOLOGY	
	4.2 SAFE SHUTDOWN FUNCTIONS	
	4.2.1 Reactor Reactivity Control	
	4.2.2 Reactor Coolant Pressure Control	
	4.2.3 Reactor Coolant Inventory Control	
	4.2.4 Decay Heat Removal	



RELAY EVALUATION REPORT

TABLE OF CONTENTS

4.3	RELAY REVIEW SAFE SHUTDOWN EQUIPMENT LIST	
4.4	RELAY FUNCTIONAL SCREENING	
4.5	RELAY SEISMIC CAPACITY SCREENING	
4.6	RELAY DETAILED CIRCUIT ANALYSIS	
4.7	RELAY WALKDOWN	
5.0	RESULTS OF RELAY SCREENING AND EVALUATION	Rev. 1
5.1	INTRODUCTION	
5.2	BACKGROUND	
5.3	RESULTS	
6.0	REFERENCES	Rev. 1
APPENDIX A	Relay Review Safe Shutdown Equipment List	Rev. 1
APPENDIX B	Associated Relay List	Rev. 1
APPENDIX C	Essential Relay List	Rev. 1
APPENDIX D	Relay Outlier List	Rev. 0
APPENDIX E	Essential Relay Cabinets	Rev. 0
APPENDIX F	System / Circuit Evaluation Discussions	Rev. 1
APPENDIX G	In-Structure Response Spectra	Rev. 0
APPENDIX H	Relay Seismic Capacity Data	Rev. 0
APPENDIX I	Resume of Lead Relay Reviewer	Rev. 0



2.0 RESULTS AND PLANNED ACTIONS

2.1 Summary of Results

This section provides a summary of the results of the seismic functionality review of relays affecting USI A-46 safe shutdown components for PBNP. The review was performed in accordance with the methodology and procedures established for the resolution of USI A-46; specifically, the GIP [6.3], the NRC SSER No. 2 [6.4], EPRI NP-7148-SL [6.7], and EPRI NP-7148-SL Volume 2 [6.8]. There were no significant or programmatic deviations from the GIP taken during the USI A-46 relay functionality review.

The relay functionality review process is outlined in Figure 2.1, and explained in detail in Sections 3 and 4. The PBNP Safe Shutdown Equipment List (SSEL) consists of all of the components required to bring the plant to a safe shutdown condition. Section 4 provides an overview of the safe shutdown path selection. The SSEL Report [6.10] provides a detailed description of the safe shutdown equipment selection. From the SSEL, a list of components requiring a relay review, the Relay Review SSEL (R-SSEL), was developed. The R-SSEL contains 755 components.

The Functional Screening (FS) of the control circuits for the components on the R-SSEL identified 2370 relays which were included on the PBNP Associated Relay List (ARL). The associated relay list is provided in Appendix B. Of these relays, 731 relays were screened as chatter acceptable (CA), and 1639 relays were screened as seismic screening required (SS). The relays screened as seismic screening required make up the "essential" relay list. The list of essential relays is found in Appendix C. The essential relays fall into one of the following three (3) categories: 1) a relay specific capacity vs. demand comparison is required, 2) the relay is included in the switchgear rule-of-the-box (SWGR), or 3) the relay is



RELAY EVALUATION REPORT

RESULTS AND PLANNED ACTIONS




Figure 2.1-1 - PBNP Relay Functionality Review Process Flowchart



RELAY EVALUATION REPORT

RESULTS AND PLANNED ACTIONS

mounted on vibrating equipment such as an air compressor or emergency diesel generator. Section 4.4 explains the categories in more detail. Of the 1639 relays, 1461 relays require a specific capacity vs. demand comparison, 69 relays are seismically adequate based on switchgear rule-of-the-box, and 109 relays are considered seismically adequate by virtue of them being mounted on vibrating equipment.

The seismic capacity screening was performed for the 1461 essential relays requiring the relay specific capacity vs. demand check. The relay seismic capacity data was obtained from EPRI NP-7147 [6.12], EPRI NP-7147, Volume 2, Addendum 1 [6.13], EPRI NP-7147, Volume 2, Addendum 2 [6.14], EPRI NP-5223 [6.15] and equipment specific IEEE Standard 344 [6.9] seismic qualification test data. The relay seismic capacity data is provided in Appendix H. The seismic demand levels used for the seismic capacity screening were derived from the PBNP in-structure response spectra (ISRS) and the estimated in-cabinet amplification factor (AF). The PBNP ISRS were determined to be "conservative-design" ISRS [6.5]. The NRC Staff agreed with this determination [6.6]. The AF used was taken from Appendix I of EPRI NP-7148 [6.7] based on the type of cabinet or enclosure the relay was in. One exception to this was the 4160 VAC vital switchgear, located in the control building vital switchgear room, where a cabinet specific AF was determined. Appendix G provides the PBNP ISRS used for the seismic capacity vs. demand check.

Of the 1461 relays requiring the relay specific capacity vs. demand check, 1329 relays have sufficient seismic capacity and 132 relays are identified as outliers. A relay is considered an outlier if it is a low ruggedness relay or if it has either insufficient seismic capacity or unknown seismic capacity. Eight (8) relays were identified as "bad actor" low ruggedness relays. A total of 124 relays have an unknown seismic capacity.



RELAY EVALUATION REPORT

RESULTS AND PLANNED ACTIONS

The relay walkdown verified (via spot check) that the essential relays are properly mounted, that the relay types are correct, and that the known location of the relays based on drawing information is accurate. During the walkdown, fourteen (14) incorrect relay locations were noted. The relay was actually located in the same type of cabinet directly adjacent to the one indicated, and therefore did not affect the outcome of the relay evaluation. All of the cabinets and enclosures containing essential relays were included on the Seismic Walkdown SSEL and verified to be seismically adequate [6.16]. The list of cabinets containing essential relays is found in Appendix E.

2.2 Relay Outliers

Appendix D provides a listing of the 132 USI A-46 relay outliers. The 8 relays which are identified as "low ruggedness" relays are the Westinghouse ITH relays. These relays are used in the over-current protection circuit for eight 4160 VAC vital switchgear breakers. The other 124 relays are relays with an unknown seismic capacity, i.e., relays not covered by EPRI NP-7147-SL [6.12, 6.13, 6.14].

The majority of these relays are associated with the control circuits for the G-01 and G-02 emergency diesel generators. The other relays are used in the over-current protection for the 4160 VAC vital switchgear.

2.3 Completion Activities

The preferred method for resolving all of the outliers is to determine an accurate seismic capacity of the relays with the use of IEEE Standard 344 test data. For the Westinghouse ITH relay, chatter is not acceptable, therefore, the second option for resolving the outlier is to replace the relays with seismically adequate models. For the other 124 relays with unknown capacity, the second option for resolving each outlier is to evaluate the function of the relay and attempt to screen the relay as chatter acceptable. The third option for resolving the outlier is to



RELAY EVALUATION REPORT

RESULTS AND PLANNED ACTIONS

replace the relay with seismically adequate models. The relay outlier resolution, using one of the options above, is proposed to be complete by January of 1998.



RELAY EVALUATION REPORT

3.0 COMMITMENTS, EQUIPMENT SELECTION CRITERIA AND GOVERNING ASSUMPTIONS

3.1 SQUG Commitments

By committing to the SQUG methodology presented in the GIP, WE commits to following these SQUG commitments regarding the identification and evaluation of relays. These commitments include the clarifications, interpretations and exceptions issued by the NRC in SSER #2 [6.4].

3.1.1 Identification of Relays To Be Evaluated

The licensee will identify the relays to be evaluated using a two-step process. First, the systems to be examined will be those identified pursuant to Section II.3, "Identification of Safe Shutdown Equipment," of the GIP [6.3]. Using this approach, the licensee will develop a Safe Shutdown Equipment List (SSEL) for relays which will include: (1) electrically controlled or powered safe shutdown equipment whose function could be affected by relay malfunction, and (2) inactive safe shutdown equipment for which relay malfunction could cause spurious operation. Second, plant electrical drawings of the circuits associated with the above safe shutdown equipment will be used to identify relays to be evaluated. Certain additional assumptions will be used to establish the scope of the relay review:

- Relays will not be damaged by the earthquake, with the exception of certain particularly fragile types.
- Unqualified relays are assumed to malfunction during the short period of strong motion during an earthquake.



RELAY EVALUATION REPORT

- Relay types to be reviewed include auxiliary relays, protective relays, contactors, control switches, and other similar contact devices occurring in circuits controlling the systems identified.
- Solid state relays and mechanically-actuated switches are considered to be seismically rugged and need not be evaluated for contact chatter.

3.1.2 Evaluation of Consequences of Relay Malfunction

The licensee will evaluate the relays as set forth in Section II.6.1.1, "Identification of Relays to be Evaluated," of the GIP, as described in Section 3.1.1 above, for the consequences of relay malfunction on safe shutdown functions. The relays whose malfunction will not prevent achievement of any safe shutdown function and will not otherwise cause unacceptable spurious actuation of equipment will not be further evaluated.

The seismic adequacy of the remaining essential relays will be verified to assure that safe shutdown can be achieved and maintained in the event of a Safe Shutdown Earthquake (SSE).

3.1.3 Assessment of Relay Seismic Adequacy

The licensee will verify the seismic adequacy of the essential relays identified pursuant to Sections II.6.1.1, "Identification of Relays to be Evaluated," and II.6.1.2, "Evaluation of Consequences of Relay Malfunction," of the GIP, as described in Sections 3.1.1 and 3.1.2 above, by comparing the relay seismic capacity to the seismic demand imposed upon the relay. Three types of data can be used to establish the seismic capacity of essential relays:

- Generic Equipment Ruggedness Spectra (GERS)



RELAY EVALUATION REPORT

- Earthquake Experience Data
- Plant-specific or relay-specific seismic test data

3.1.4 Relay Walkdown

The licensee will conduct one or more walkdowns, as needed, to accomplish four objectives:

- Obtain information as required to determine in-cabinet amplification, including identification of cabinets, panels and/or racks which house or support essential relays.
- Verify the seismic adequacy of the cabinets or enclosures which support essential relays.
- Spot check relay mountings.
- Spot check relay types and locations.

The relay walkdowns may be accomplished together with, or separate from, the main USI A-46 walkdown conducted pursuant to Section II.4, "Screening Verification and Walkdown," of the GIP.

3.2 Criteria and Governing Assumptions

For resolution of USI A-46 it is not necessary to verify the seismic adequacy of all plant equipment defined as Seismic Class 1 in NRC Regulatory Guide 1.29. Instead, only those systems, subsystems, and components required to bring the plant from a normal operating condition to a safe shutdown condition are included in the scope of USI A-46. As a result, the scope of



RELAY EVALUATION REPORT

the seismic verification review is limited to equipment which provides functions necessary for achieving and maintaining safe shutdown.

3.2.1 Safe Shutdown Equipment Selection Criteria

The criteria and assumptions needed to define the systems and equipment which are needed to bring the plant to a safe shutdown condition are described in detail in Section II.3, "Identification of Safe Shutdown Equipment," of the GIP and the SSEL Report [6.10] and are summarized as follows:

- 3.2.1.1 The plant should be brought to a hot shutdown condition (as defined by the Technical Specifications [6.11]) and maintained there during the 72 hours following the SSE.
- 3.2.1.2 The earthquake does not cause a loss of coolant accident (LOCA) or other such events.
- 3.2.1.3 A LOCA is not postulated to occur simultaneously with or following the SSE.
- 3.2.1.4 Offsite AC power may be lost during or after the SSE.
- 3.2.1.5 There should be sufficient redundancy such that the failure of the active function of a single item of safe shutdown equipment may occur without losing the ability to achieve and maintain safe shutdown conditions.

3.2.2 Relay Review Equipment Selection Criteria

The safe shutdown equipment required to undergo the relay functionality review is a subset of equipment on the SSEL. The Relay Review SSEL is developed based on the following criteria [6.3, Section II.6.3.2]:



RELAY EVALUATION REPORT

3.2.2.1 Active safe shutdown equipment which is electrically controlled or powered and whose function could be affected by relay malfunction is selected for relay review.

3.2.2.2 Inactive safe shutdown equipment which could inadvertently change state or become active due to relay malfunction and result in unacceptable consequences is selected for relay review.

3.2.3 Relay Functionality Review Governing Assumptions

In addition to the equipment selection criteria stated above, the following specific assumptions provide the bases for the relay evaluation:

3.2.3.1 The safe shutdown earthquake (SSE) period of strong motion is assumed to last for a period of 30 seconds. The SSE event is described in more detail in Section 3.4 of the SSEL Report [6.10].

3.2.3.2 Unqualified relays are assumed to malfunction during the short period of strong motion during an earthquake. Such a malfunction, typically chatter, may result in loss of system function or inadvertent actuation of systems during the strong shaking period. It is also possible that relay malfunction during strong shaking can result in unacceptable seal-in or lockout of specific circuits which are designed to have this feature. In such cases, operator actions to reset or restore such circuits to their original condition may be acceptable provided there is sufficient time, awareness, access and procedures for the operators to take this action.

3.2.3.3 "Chatter" is the inadvertent opening/closing of a contact with sustained output of ≥ 2 milliseconds (ms).

3.2.3.4 Earthquake experience data and test data show that, in general, relays are not structurally damaged during an earthquake. Therefore, with the exception of two specific relay models, General Electric IJD (non 1E class) and English Electric YCG [6.7, Appendix E], it is assumed that relays are not damaged as a result of the earthquake and will be functional after the period of strong shaking.



RELAY EVALUATION REPORT

3.2.3.5 Relay types to be evaluated under this program include those devices which are provided to cause contact operation in electric control circuits. In general, they fall into three categories:

- The largest category is designated auxiliary relays. This category typically includes electromechanical, pneumatic timing and solid state relays used for general purpose control, blocking, closing, lockout, seal-in and other logic or control functions.
- A second category includes protective electromechanical and solid state relays whose function is to protect equipment from system faults and other abnormal or dangerous conditions by automatically initiating appropriate control circuit action. Protective relays include over-current and under-voltage relays.
- The third general category of relays is contactors. A contactor is a heavy duty relay which may carry significant amounts of current. It is distinguished from a circuit breaker such as is used in switchgear in that its contacts are moved by a small solenoid-type mechanism rather than by compressed springs or other actuating mechanisms.



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

4.0 RELAY FUNCTIONALITY REVIEW

4.1 Methodology

The methodology for evaluating the seismic functionality of relays is based on a four-part screening and evaluation process. The first part of the screening process identifies a set of plant systems and components which are required to function to maintain the plant in a safe condition during and immediately following the safe shutdown earthquake (SSE). This screening process results in a list of plant equipment which makes up the PBNP Safe Shutdown Equipment List (SSEL). The SSEL Report [6.10] describes the PBNP safe shutdown path and equipment selection. The second part of the screening process develops the Relay Review SSEL by screening the equipment on the SSEL based on the equipment function. The third part of the screening process is a "functional screening" consisting of the identification and screening of the relays in the control circuits of the equipment of the Relay Review SSEL (R-SSEL). This screening results in a list of "associated" relays and a list of "essential" relays. The fourth part of the screening and evaluation process is to assess the seismic ruggedness of the essential relays. The steps used for each part of the relay functionality review are based on the commitments made by WE as described in Section 3 of this report and the guidance provided in Section II.6, "Relay Functionality Review," of the GIP [6.3] and EPRI NP-7148 [6.7, 6.8].

An independent review of the Relay Evaluation Process was performed by a degreed electrical engineer who has attended the SQUG Safe Shutdown Equipment Selection and Relay Screening and Evaluation Course. Input was initially provided on the specific methodology for performing the relay functionality review and then, different steps in the evaluation process were audited. Comments were provided on the process itself as well as detailed comments on



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

the R-SSEL and the functional screening results. All of the independent review comments were resolved.

4.2 Safe Shutdown Functions and Systems

Part one of the relay functionality review is to determine the list of equipment required for review. Resolution of USI A-46 requires verification of the seismic adequacy of the equipment necessary to achieve and maintain PBNP in a safe shutdown condition during and for a period of 72 hours following the PBNP SSE. Four system operating functions are considered for achieving and maintaining a safe shutdown condition. These functions are as follows:

- Reactor reactivity control
- Reactor coolant pressure control
- Reactor coolant inventory control
- Decay heat removal

The systems best suited to perform these safe shutdown functions at PBNP are identified following the GIP equipment selection criteria and governing assumptions stated in Section 3 of this report. The following sections provide a summary of the safe shutdown system selection for each of the safe shutdown functions. The SSEL Report provides the detailed equipment selection evaluation.

4.2.1 Reactor Reactivity Control

Systems - The reactivity control function is accomplished by the insertion of negative reactivity into the reactor core shortly after obtaining the signal to



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

shutdown. Additional negative reactivity may also be needed to compensate for the combined effects of Xenon-135 decay and reactor coolant temperature decreases. The preferred path for reactivity control considers immediate and long term reactivity control. The immediate method for reactivity control is performed by the reactor protection system (RPS). In addition to the rod control reactivity addition, the reactivity control function relies on the safety injection (SI) system for long term reactivity control.

Instrumentation - The N-40 nuclear instrumentation provides an IEEE-344 qualified nuclear instrument for monitoring neutron flux in the power range, intermediate range and source range. As a backup to the neutron flux monitor, reactivity is controlled by monitoring reactor coolant system (RCS) temperature to ensure positive reactivity is not inadvertently added due to cooldown. In addition, pressurizer level and refueling water storage tank (RWST) level may be monitored and compared to ensure positive reactivity is not inadvertently added due to RCS boron dilution.

4.2.2 Reactor Coolant Pressure Control

Systems - The pressure control function has several elements which should be accomplished to ensure that the RCS is operated properly:

- The RCS pressure should not exceed a maximum pressure.
- The pressure should be maintained within the RCS pressure-temperature limits of the plant's Technical Specifications to prevent reactor vessel brittle fracture.
- There should be sufficient subcooling margin, consistent with plant operating procedures or plant Technical Specifications, to avoid formation of a steam bubble within the reactor vessel and to promote natural circulation between the core and the steam generators.



- The differential pressure across the steam generator tubes should not exceed the pressure-temperature limits of the plant-specific Technical Specifications to prevent leaks and ruptures in these tubes.

The preferred path for reactor coolant pressure control considers both over-pressure protection and under-pressure protection. Over-pressure control is established using two methods. The first method attempts to use the steam generators (S/Gs), the Main Steam (MS) system and the Auxiliary Feedwater (AFW) system to control RCS pressure by controlling RCS temperature once the reactor trip has occurred. The second method relies on the RPS high-pressure reactor trip and the RCS safety valves to assure never reaching the maximum RCS pressure limit. Under-pressure protection is provided by isolating the Chemical and Volume Control System (CVCS) auxiliary spray to the pressurizer, and by completely isolating the S/G thus minimizing the chance of an undesired RCS cooldown. The SI system is used to mitigate underpressure transients.

Instrumentation - The instrumentation used to monitor the reactor coolant pressure control function are RCS pressure, pressurizer pressure instruments and the sub-cooling monitor. In addition, S/G level, S/G pressure, AFW flow rate and AFW pump suction pressure instrumentation are used to monitor the secondary side systems operation.

4.2.3 Reactor Coolant Inventory Control

Systems - The reactor coolant inventory control function is necessary to assure that the reactor core remains covered so that decay heat can be removed during and after the postulated earthquake. The RCS boundary valves and the reactor coolant pump (RCP) thermal barrier protection are used to minimize RCS leakage.



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

The Component Cooling Water (CCW) system provides cooling to the RCP thermal barrier. The SI system in conjunction with the RCS Gas Vent system provide the capability for RCS makeup water injection.

Instrumentation - The instrumentation used to monitor the reactor coolant inventory control function are pressurizer level and reactor vessel level instruments. The proper operation of the CCW system is monitored with the CCW surge tank level, CCW heat exchanger outlet temperature and RCP thermal barrier return temperature instruments. The SI pump discharge pressure and flow instruments are used to monitor SI system operation.

4.2.4 Decay Heat Removal

Systems - The decay heat removal function is accomplished by removing decay heat and stored heat from the reactor core and RCS at a rate such that overall RCS temperatures can be lowered to and maintained within acceptable limits. Reactor decay heat is transferred to the S/Gs and heat is removed from the S/Gs by the release of steam to the atmosphere via the S/G safety valves. The AFW system provides the makeup feedwater to the S/Gs.

Instrumentation - The instrumentation used to monitor the reactor decay heat removal function are the RCS core exit thermocouples, RCS pressure, RCS hot leg temperature, and RCS cold leg temperature instruments and the sub-cooling monitor. In addition, S/G level, S/G pressure, AFW flow and AFW pump suction pressure instruments are used to ensure the proper operation of the secondary side systems.



4.3 Relay Review Safe Shutdown Equipment List

The second part of the relay functionality review is to develop the R-SSEL. The R-SSEL is developed in accordance with the criteria in Section II.3, "Identification of Safe Shutdown Equipment," and Appendix A, "Procedure for Identification of Safe Shutdown Equipment," of the GIP, described in Section 3 of this report. The R-SSEL consists of only electrically powered or controlled equipment that could be affected by the malfunction of a relay. The equipment selected must operate or change state to accomplish the required safe shutdown function, or if not required to operate, may inadvertently operate, due to a relay malfunction, thus adversely affecting the accomplishment of a safe shutdown function. The R-SSEL, provided in Appendix A, lists the equipment selected for relay review. The list is sorted by system and equipment ID and provides the location (building, elevation and area) of the equipment, the equipment train and the safe shutdown function(s) that the equipment supports. A discussion of the SSE event and the expected plant response is provided in Appendix F.

4.4 Relay Functional Screening

The third part of the relay functionality review is the relay Functional Screening (FS). The relay FS is based on evaluating the consequences of a malfunction of the associated electrical relays on the system or component performance to determine if proper function of the relays is essential to safe shutdown. Relays whose malfunction is acceptable need not be seismically rugged. This screening process only screened out relays which were easily identifiable as "chatter acceptable." This screening process is intended to reduce the number of relays which are considered "essential" to plant safety in the event of an earthquake, and, therefore, to reduce the number of relays whose seismic functionality must be demonstrated.



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

The FS was performed by WE Relay Review Engineers with assistance from Science Applications International Corporation (SAIC) Relay Analysts. The FS is documented on the Relay Identification/Functional Screening Worksheet, Figure 4.4-1. The worksheet is based on the G.4 Form found in EPRI NP-7148, and contains all of the information required by the G.4 Form plus an additional section used to document cross references for seismic capacity screening.

4.4.1 Sort of Circuit Schematics

For each component on the R-SSEL, the applicable circuit schematics are identified. A complete listing of the schematics used for the review is contained in Section 6.0. The schematics are sorted by "primary" or "cascading" circuit type. A schematic is considered to be "primary" if it represents the direct control circuit of the particular component. If the schematic does not indicate corresponding coils for one or more associated device contacts, the coil may be indicated on an additional schematic; this type of schematic is referred to as "cascading."

4.4.2 Circuit Screening

The next step in the FS process is to perform a circuit analysis on the control circuits which contain the relay, and other contact device, contact-pairs in the control paths for the R-SSEL equipment. The analysis is performed on the direct control circuits shown on the primary schematics and the supporting control circuits shown on the cascading schematics. The purpose of this step is to develop an initial list of relays which affect operation of the safe shutdown equipment. For each relay the relay manufacturer and model, the relay location, the relay coil drawing, and the relay screening status code are documented on the Relay Identification / Functional Screening Worksheet. For the primary schematics, all of the relay contact-pairs and other contact devices are recorded.

**A-46 RELAY SCREENING AND EVALUATION
POINT BEACH NUCLEAR PLANT**

RELAY IDENTIFICATION/FUNCTIONAL SCREENING

SYSTEM _____ SUBSYSTEM/COMPONENT _____

PAGE _____ OF _____
UNIT _____ 1 _____ 2 _____ 0

NA¹ (Component *Not Affected* by relays)

Relay Drawing Review

Ref. Drawing (incl Rev #)	Contact/Contact Group	Relay Mfg. & Model	Location (Cab ID)	Relay Coil Drawing	Status ²

Cross-References

Relay	Relay Coil Drawing	Screening Cross-Reference (Comp. ID, MCC, SWGR, ...)

Prepared by _____ Date _____

Reviewed by _____ Date _____

¹ Provide brief description of component to explain use of NA.

² Identify status of contact/contact group using one of the following codes

- NV** *Not Vulnerable* (mechanically actuated contacts and solid state relay).
- SS** Requires *Seismic Screening* Attach SEISMIC CAPACITY ANALYSIS Form.
- CA** *Character Acceptable* per light functional screening results. Attach LIGHT FUNCTIONAL SCREENING NOTES form and provide brief explanation.
- CR** Relay evaluated via another component or screening method (e.g. MCC, SWGR). Provide information in the Cross-References table.
No entry required.

Figure 4.4-1 Relay Identification / Functional Screening Worksheet



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

For the cascading schematics, the relays that have all of their contact pairs controlling annunciators and/or alarm devices, or controlling only equipment not listed on the SSEL are screened out and not recorded on the Relay Identification / Functional Screening Worksheets.

Contact pairs that are listed on the Relay Identification / Functional Screening Worksheets are screened into one of four categories; 1) Not Vulnerable, 2) Chatter Acceptable, 3) Cross Referenced, or 4) Seismic Screening Required. The screening for each of these four categories is explained in the following sections.

4.4.3 Elimination of Seismically Rugged Devices

Solid state relays and mechanically actuated contacts / switches are considered inherently rugged. These devices are screened as not vulnerable (NV) in the Status column on the worksheets and require no additional evaluation [6.7, Section 3.3.1]. Examples of mechanically actuated contacts are torque switch and limit switch contacts and manual control switch contacts. The relay devices screened as NV are not included on the ARL.

4.4.4 Chatter Acceptable Relays

With the exception of two relay models, General Electric IJD (non 1E class) and English Electric YCG [6.7, Appendix E], relays are not considered to be permanently damaged as a result of the earthquake. The relay malfunction that is expected is contact chatter. As stated in the definitions in Section 1.5, the contact chatter is considered a malfunction if it results in a sustained electrical signal output for greater than or equal to 2 milliseconds. Each relay that is considered to be vulnerable to seismic excitation is analyzed to determine if contact chatter is acceptable. This analysis is based on the function of the relay in the control circuit. The bases and explanations for why relays were categorized



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

as chatter acceptable are found in Appendix B and Appendix F. For relays that are chatter acceptable, the chatter malfunction is only considered to occur during the 30 second period of earthquake strong motion. The relay is required to function after the earthquake. To ensure the relay and the associated control circuit are not permanently damaged as a result of the earthquake, the cabinet that the relay is located in is identified for seismic verification and included on the Seismic Review SSEL.

4.4.5 Essential Relay Seismic Capacity Screening

Relays which are not screened as being "not vulnerable" or "chatter acceptable" in the initial steps of the FS are required to have sufficient seismic capacity such that they will function as required during the period of strong motion. These relays are considered the "essential" relays and make up the essential relay list. The relay status is indicated as either Cross Referenced (CR) or Seismic Screening Required (SS) on the Relay Identification / Functional Screening Worksheet.

Cross reference screening of the relay is done for one of two reasons:

- 4.4.5.1 The relay is identified on another Relay Identification / Functional Screening Worksheet for a different subsystem or component with a status of seismic screening (SS) required. This cross referencing is done to eliminate duplicate entries of relays on the "associated" and "essential" relay lists. For this cross referencing, the other subsystem or component is listed in the Cross Reference table on the worksheet. This occurs when the same relay has multiple contact pairs and the different contact pairs are in the control circuits for more than one component. This may also occur on a "cascading" drawing where the circuit on the "cascading" drawing affects more than one "primary" drawing circuit.
- 4.4.5.2. **Switchgear "Rule-of-the-Box"** - The relay directly controls the operation of switchgear. This cross referencing is applicable when 1) the switchgear that the relay is in is shown to be seismically adequate in accordance with Section II.4, "Screening Verification and Walkdown," of the GIP, and



2) the relay is not one of the low ruggedness relays listed in Appendix E of EPRI NP-7148 [6.3, Section II.6.4.2]. The only relays seismically screened using the switchgear rule-of-the-box screening were the breaker X and Y coils and the breaker auxiliary contacts.

For the relays not cross referenced, relay seismic capacity screening is done as discussed in Section 4.5.

4.5 Relay Seismic Capacity Screening

This section summarizes the screening method for evaluating the seismic capacity of essential relays (those relays identified using the method described in Section 4.4, above) compared to the seismic load (demand) imposed upon them by an SSE seismic event. The seismic capacity screening is based on the guidance in the GIP [6.3], EPRI NP-7148-SL [6.7], USNRC Generic Letter 87-02, Supplement 1 [6.4] and EPRI NP-7148-SL, Volume 2: Addendum [6.8].

Under current design and licensing criteria for nuclear power plants, relays in safety-related systems are qualified by shake table tests, most often in the specific cabinet or panel arrangement in which they are mounted. This is generally not practical for older operating plants nor is it necessary since actual experience with power plants which have undergone strong earthquakes has not shown significant or widespread problems with standard power plant equipment, including most relays. Therefore, this alternative to formal qualification testing has been developed which uses available seismic test data and actual earthquake experience data to establish the seismic capacity of a wide variety of relay types. A method for determining the seismic demand on an essential relay in a cabinet is also included in this screening method [6.3, Section II.6.4].



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

A relay is considered to be seismically adequate if either one of the following conditions is met; 1) the relay is physically mounted on equipment which vibrates considerably during normal operation or 2) the relay's seismic capacity exceeds the seismic demand for the location where the relay is mounted.

Subsection 4.5.1 explains the judgement used for relays mounted on vibrating equipment. Subsections 4.5.2 and 4.5.3 describe the method for: 1) establishing the seismic capacity of relays, and 2) establishing the seismic demand on the relays and comparing this capacity to the seismic demand. The PBNP Seismic Capacity vs Demand Screening process is illustrated in Figure 4.5-1

4.5.1 Relays Mounted on Vibrating Equipment

Earthquake experience database equipment class 12, Air Compressors, and equipment class 17, Engine Generators, contain equipment which have control circuit components mounted in instrumentation and control cabinets that are mounted to a common skid with the air compressor or engine generator. The equipment class includes the control circuit components as "rule-of-the-box" with the equipment. Vibration of equipment in these classes during normal operation is considered to be more severe than the vibration induced by a seismic event. As a result, the components mounted in the instrumentation and control cabinets on the equipment skid are considered to be seismically adequate based on their requirement to function during normal operation of the equipment.

This screening of instrumentation and control circuit components for engine generators or air compressors is not specifically addressed in the guidance for the relay review found in the GIP [6.3]. However, it is determined to be appropriate based on the description of each of the equipment classes in Appendix B of the



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

GIP. For essential relays mounted on equipment class 12 and equipment class 17 equipment, a check for low ruggedness relays is not required.

4.5.2 Seismic Capacity of Relays

Three methods can be used to establish the seismic capacity of essential relays; 1) Generic seismic test data, 2) Earthquake experience data, and 3) Relay-specific test data. For the PBNP Relay Functionality Review all three methods are utilized, with the generic seismic test data being the most widely used.

Generic Seismic Test Data.

Available seismic test data on a variety of types of relays have been either gathered or generated, evaluated, and consolidated by SQUG. These data have been reduced to Generic Equipment Ruggedness Spectra (GERS). For relays, the GERS are documented in EPRI NP-7147-SL [6.12], EPRI NP-7147-SL, Volume 2: Addendum 1 [6.13], and EPRI NP-7147-SL, Volume 2: Addendum 2 [6.14]. For other relay devices not included in NP-7147, the GERS are documented in EPRI NP-5223-SL [6.14]. The GERS define seismic acceleration levels below which relays can be expected to function without chatter or other damage. The GERS are seismic response spectra within which a class or subclass of relays has functioned properly during shake-table tests. In some cases the GERS are based on "success" data (that is, seismic test spectra for which no relay malfunction occurred). In this case, the test spectra for one or more relays in a given class represent a lower bound of the seismic ruggedness of the class. In other cases, the GERS may be based on "fragility" data (that is, seismic response spectra in which failures or malfunctions occurred). In this case, the GERS represent an upper bound of the seismic ruggedness of the relay class. Where both success and fragility data are available for a given relay class, the GERS fall between the two spectra. Engineering judgment was used in developing the GERS level to



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW




Figure 4.5-1 - PBNP Seismic Capacity Screening Process Flowchart



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

smooth out sharp peaks and valleys in the test response spectra. EPRI NP-7147 and EPRI NP-5223 provide a detailed discussion of the GERS development. An example GERS for several auxiliary relay types is shown in Figure 4.5-2. A normalized GERS shape is illustrated at the top of this figure; GERS levels (i.e., the peak acceleration) for example relays are tabulated at the bottom of this figure. The GERS capacity is defined with both the GERS shape and the Peak Spectral Acceleration (PSA) value. For the seismic capacity screening, the relay capacity at both the PSA value between the 4 Hz and 16 Hz natural resonance frequencies, and the Zero Period Acceleration (ZPA) value associated with a natural resonance frequency greater than 33 Hz is required.

The GERS data package for a given relay or family of relays establishes a checklist of conditions which must be satisfied prior to assigning the GERS capacity value to the relay being evaluated. The checklist consists primarily of verifying that the make and model of the relay being evaluated match those included in the GERS data package test database. This is done based on relay information found on the electrical schematic drawings and when necessary, relay information recorded during the field walkdown as discussed in Section 4.7. Different GERS values are provided for each potential operating state of the relay: 1) non-operate normally open contacts, 2) non-operate normally closed contacts, 3) operate normally open contacts, and 4) operate normally closed contacts. Non-operate means that the relay coil is de-energized and operate means that the relay coil is energized. The FS performed in Section 4.4 above did not identify the operating state of the relay during normal plant operation. Therefore, as shown in Figure 4.5-1, for the purpose of the initial seismic capacity screening, the worst case (lowest) GERS relay capacity was assigned.




Earthquake Experience Data

Data have been obtained on relay performance, specific failures, relay vulnerabilities, and other information from actual earthquake experience in power plants and other facilities which have undergone significant earthquakes. This information has been used to identify unacceptable relay types, referred to as "bad actors" which are known to be susceptible to damage or chatter due to moderate shaking. Twenty three relay types have been identified as bad actors [6.7, Appendix E]. Two of these 23 relay types, the GE IJD (non 1E) and the English Electric YCG, have experienced permanent damage due to earthquakes and must be assumed to be inoperable following an SSE level earthquake. Based on earthquake experience data and on test data, solid state relays and mechanically-actuated switches are considered seismically rugged and need not be evaluated for relay chatter. A "bad actor" search is performed on the PBNP list of relays developed through the FS process in Section 4.4 above. The results of the "bad actor" search are discussed in Section 5.

Relay-Specific Test Data

The GERS and earthquake experience data discussed above apply to the majority of installed relay types in essential circuits. Relay-specific seismic test data, where available, is also used. This seismic testing is performed in accordance with IEEE Standard 344, "IEEE Recommended Practices for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations" and/or ANSI/IEEE Standard C37.98, "IEEE Standard Seismic Testing of Relays."

Normalized Relay GERS
Auxiliary, Industrial Type 2 (300V)



Type and Submodel Identification	GERS Level ¹		
	Non-Operate		Operate
	NO ²	NC ²	NO/NC ²
Make #1, Model A	10	9	10
Make #2, Model A	10	9	10
Make #2, Model B	10	- ³	10
Make #3, Model A	10	9	10
Make #4, Model A	10	5	10
Make #5, Model A	10	10	10

1 "GERS Level" is the spectral acceleration (g) from 4 to 16 Hz for 5% damping.

2 "NO" = Normally Open; "NC" = Normally Closed; "NO/NC" = Change State.

3 "-" = Data not available.

Figure 4.5-2 - GERS for Auxiliary Relays (Source: Ref 6.12)



4.5.3 Seismic Capacity Compared to Seismic Demand

The GIP and EPRI NP-7148 provide four methods for comparing the seismic capacity of an essential relay to the seismic demand imposed upon it. These are described below in a multi-level screening approach. The first level of screening uses an approximate, generic capacity screening criterion based on earthquake experience, test experience and analysis. The final screening level is a very detailed, relay-specific and installation-specific analysis and/or test. For each screening level, the capacity versus demand is required to be checked at both the Peak Spectral Acceleration (PSA) between the natural resonance frequencies of 4 Hz to 16 Hz, and at the Zero Period Acceleration (ZPA) associated with a natural resonance frequency greater than 33 Hz. The seismic adequacy of essential relays is verified at PBNP by the successful application of one of these screening methods.

In addition to this screening approach for use with relays in general, a special case is also described below for evaluating the seismic adequacy of relays which control the operation of a switchgear breaker as discussed earlier in Section 4.4.5 under Switchgear "Rule-of-the-Box".

Screening Level 1 - High Capacity Relays

This first screening level can be used if the following conditions are met:

- The plant is one of those for which USI A-46 applies and the largest horizontal component of the 5% damped, free-field, Safe Shutdown Earthquake (SSE) ground response spectrum, to which the nuclear plant is licensed, is enveloped by the Bounding Spectrum. Point Beach meets this condition.
- The equipment or cabinet containing the essential relay is mounted at an elevation in the plant which is no higher than about 40 feet above the effective grade of the plant. The effective grade for PBNP is at the 8' elevation above Lake Michigan lake level.



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

- The essential relay is not one of the low-ruggedness types listed in Appendix E of EPRI NP-7148.

If the above conditions are met, then an essential relay is sufficiently rugged when the relay is mounted in one of the types of structures defined below and the relay has a seismic capacity at least as large as that given below for each of these structure types:

- When the essential relay is mounted in a cabinet similar to a conventional motor control center (MCC), the relay should have a defined spectral acceleration capacity of 5g or higher. Guidelines for classifying cabinets as MCCs are given in Appendix I of EPRI NP-7148. GERS or relay-specific seismic data (e.g., IEEE-344 and/or IEEE-501 type tests) can be used to establish the spectral acceleration capacity of the essential relay.
- When the essential relay is mounted on an unsupported panel or in a typical conventional switchgear cabinet, or it is mounted on a control room panel or benchboard, the relay should have a defined spectral acceleration capacity of 8g or higher. Guidelines for classifying these types of cabinets and panels are given in Appendix I of EPRI NP-7148. GERS or relay-specific seismic qualification data (e.g., IEEE-344 and/or IEEE-501 type tests) can be used to establish the spectral acceleration capacity of the essential relay.

If the relay is not mounted in one of these types of structures, then the Screening Level 1 method cannot be used and one of the following screening methods should be used instead. Screening Level 1 was not used for any seismic screening (SS) at PBNP.

Screening Level 2 - Use of In-Cabinet Amplification Factors

The second screening level for comparing relay seismic capacity to demand is based on: 1) using an in-structure response spectrum (ISRS) at the base of the cabinet containing the relay, 2) multiplying this spectrum by both an appropriate factor of safety (FS) and by an in-cabinet amplification factor (AF), and



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

3) comparing this seismic demand to the relay seismic capacity (CAP) based on GERS or relay-specific seismic test data.

This comparison can be illustrated using the following equation:

$$CAP \geq ISRS \times FS \times AF$$

Where:

CAP = seismic capacity of an essential relay based on either:

- Relay GERS (from EPRI NP-7147 [6.12, 6.13, 6.14]) or
- Relay-specific test data using test methods such as IEEE-344 and/or IEEE-501.

ISRS = in-structure response spectrum at the base of the equipment. Using the guidelines given in Section II.4.2, "Seismic Capacity Compared to Seismic Demand," of the GIP, the in-structure response spectrum used at PBNP is a "conservative-design" in-structure SSE response spectrum. The PBNP ISRS have been reviewed by the NRC and are considered "conservative-design" ISRS [6.6].

FS = factor of safety to account for uncertainties in various types of in-structure response spectra as shown in Table 6-1, "Factors of Conservatism to be Applied to Different Types of In-Structure Response Spectra," of the GIP.

AF = in-cabinet amplification factor, as given in Table 6-2, "In-Cabinet Amplification Factors for Use with Level 2 Relay Screening Method," of the GIP, for various types of cabinets. The guidelines and criteria for identifying the various cabinet types are included in Appendix I of EPRI NP-7148.

The relays are considered seismically adequate if the seismic demand spectrum is bounded by the relay capacity spectrum in the frequency ranges from 4 - 16 Hz and from 33 Hz and above, i.e., the ZPA. The results of the seismic capacity



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

screening are discussed in Section 5. For a description of Screening Level 3 and Screening Level 4 refer to the GIP or EPRI NP-7148.

A special case is used for essential relays which directly control the operation of switchgear. To show that this type of essential relay is seismically adequate, it is not necessary to use the above screening methods. Instead the relay is shown to be adequate since: 1) the switchgear cabinet containing the relay has been shown to be seismically adequate using the seismic evaluation method given in Section II.4, "Seismic Verification and Walkdown," of the GIP and documented in the Seismic Evaluation Report for Point Beach Nuclear Plant [6.15], and 2) the essential relay is not one of the low-ruggedness types listed in Appendix E of EPRI NP-7148. The relays screened using this switchgear "rule of the box" must be located in the switchgear cabinet.

4.6 Relay Detailed Circuit Analysis

As discussed in Section 4.5, the initial relay seismic capacity used for the seismic capacity screening is based on the lowest capacity in the GERS or specific test data regardless of the normal operating mode or contact position. If the seismic capacity screening fails using this capacity, then the control circuit is re-evaluated in more detail to determine the actual operating mode of the relay, or determine if the relay may be chatter acceptable. The detailed circuit analysis is documented on the same Relay Identification/Functional Screening Worksheet as the initial functional screening. The initial screening results are lined out and initialed and the detailed circuit analysis results are recorded.

4.7 Relay Walkdown

Walkdowns were performed as part of the relay evaluation in accordance with the guidance in Section II.6, "Relay Functionality Review," of the GIP and EPRI NP-



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

7148. The purposes of the relay walkdowns are as follows and were accomplished separately during different walkdowns:

- Obtain information needed to determine cabinet types which house essential relays and to determine the in-cabinet amplification, where needed, for the seismic capacity screening described above.
- Verify the seismic adequacy of the cabinets or enclosures which support the essential relays.
- Spot check mountings of essential relays.
- Spot check the essential relays to verify their types and locations, including checks for vulnerable relays ("bad actors" as listed in Appendix E of EPRI NP-7148).

The first and second purposes were accomplished by the seismic review teams (SRTs) during the seismic verification walkdowns. All cabinets or panels which house relays are evaluated per Section II.4, "Seismic Verification and Walkdown," of the GIP, as if the relays are essential.

The third and fourth purposes of the relay walkdowns were conducted during a separate walkdown by the lead relay reviewer. The relay mountings were spot checked to confirm that the relays are mounted in accordance with manufacturer's recommendations. Proper relay label orientation, mounting bolts in place and tight, and whether the relay was snug in its mounting bracket were verified. No atypical mountings were found. In addition, the relay name plate information was verified against that recorded in the list of relays from the electrical schematics. These checks were done in the following areas of the plant:

- Control Room



RELAY EVALUATION REPORT

RELAY FUNCTIONALITY REVIEW

- Cable Spreading Room
- Switchgear rooms
- Diesel generator control panel area



5.0 RESULTS OF RELAY SCREENING AND EVALUATION

5.1 Introduction

This section documents the relay screening and evaluations for each of the equipment on the R-SSEL found in Appendix A. The Relay Identification / Functional Screening Worksheets, Figure 4.4.1, were used to summarize the relay review and provide a traceable record of the review.

5.2 Background

5.2.1 PBNP Safe Shutdown Earthquake Event

The safe shutdown earthquake (SSE) used for the design of PBNP is defined by the Housner Ground Response Spectrum (GRS) and the Olympia, Washington N80E, April 13, 1949 earthquake time history. A more detailed description of the earthquake input motion used for the equipment evaluation is provided in the Seismic Evaluation Report [6.16]. In the WE letter to the NRC dated September 21, 1992 [6.5], WE established that the Housner GRS and the associated PBNP in-structure response spectra (ISRS) are "conservative design." The NRC concurred with the WE classification of the Housner GRS and the PBNP ISRS in their letter to WE dated February 22, 1993 [6.6].

The earthquake is postulated to occur when PBNP Units 1 and 2 are operating at normal operating conditions and providing 100% of rated electrical power to the Wisconsin Electric electrical distribution grid. The earthquake strong motion is assumed to last for a period of 30 secs. As a result of the earthquake, the seismic class 3 or non-seismic equipment is not expected to function, dual unit reactor trips are expected and a loss of offsite power may or may not occur. The required PBNP earthquake response is driven by the sequence of events that occur on the PBNP electrical distribution and secondary plant systems. Appendix F of this



report and the Safe Shutdown Equipment List Report [6.10] provide more explanation on the expected PBNP electrical distribution system response.

5.2.2 Relay Cabinet Types and Locations

The safe shutdown equipment requiring a relay review is located primarily in the PBNP control building (CB) and the primary auxiliary building (PAB). The cabinets which house the essential relays associated with the safe shutdown equipment are also located in these buildings. There are a total of 44 different essential relay cabinets. Appendix E provides a listing of cabinets, which systems they are associated with, where they are located in the plant and the type of cabinet based on the definition of cabinet types in Appendix I of EPRI NP-7148. The in-cabinet amplification factors (AFs) from EPRI NP-7148 were used for determining the seismic demand for each relay with one exception. A cabinet specific amplification factor was determined for the 4160 VAC vital switchgear, 1A-05, 2A-05, 1A-06 (old) and 2A-06 (old), using a finite element analysis method [6.19]. An AF of 5.2 was calculated and used in the seismic capacity vs. demand check as compared to the AF of 7.0 from Appendix I of ERPI NP-7148.

e of
ted
ted
ancy
be
ating
ity

5.3 Results

The Relay Identification / Functional Screening Worksheets and the highlighted electrical schematic drawings provide a traceable record of the functional screening of the relays associated with each SSEL component requiring a relay review. The information from the worksheets was transferred to the Associated Relay List (ARL) found in Appendix B. Figure 5.3-1 provides a summary of the results of the relay functionality review. A total of 2370 relay devices were identified as associated relays.



5.0 RESULTS OF RELAY SCREENING AND EVALUATION

5.1 Introduction

This section documents the relay screening and evaluations for each of the equipment on the R-SSEL found in Appendix A. The Relay Identification / Functional Screening Worksheets, Figure 4.4.1, were used to summarize the relay review and provide a traceable record of the review.

5.2 Background

5.2.1 PBNP Safe Shutdown Earthquake Event

The safe shutdown earthquake (SSE) used for the design of PBNP is defined by the Housner Ground Response Spectrum (GRS) and the Olympia, Washington N80E, April 13, 1949 earthquake time history. A more detailed description of the earthquake input motion used for the equipment evaluation is provided in the Seismic Evaluation Report [6.16]. In the WE letter to the NRC dated September 21, 1992 [6.5], WE established that the Housner GRS and the associated PBNP in-structure response spectra (ISRS) are "conservative design." The NRC concurred with the WE classification of the Housner GRS and the PBNP ISRS in their letter to WE dated February 22, 1993 [6.6].

The earthquake is postulated to occur when PBNP Units 1 and 2 are operating at normal operating conditions and providing 100% of rated electrical power to the Wisconsin Electric electrical distribution grid. The earthquake strong motion is assumed to last for a period of 30 secs. As a result of the earthquake, the seismic class 3 or non-seismic equipment is not expected to function, dual unit reactor trips are expected and a loss of offsite power may or may not occur. The required PBNP earthquake response is driven by the sequence of events that occur on the PBNP electrical distribution and secondary plant systems. Appendix F of this



RELAY EVALUATION REPORT

RESULTS OF RELAY SCREENING
AND EVALUATION

report and the Safe Shutdown Equipment List Report [6.10] provide more explanation on the expected PBNP electrical distribution system response.

5.2.2 Relay Cabinet Types and Locations

The safe shutdown equipment requiring a relay review is located primarily in the PBNP control building (CB) and the primary auxiliary building (PAB). The cabinets which house the essential relays associated with the safe shutdown equipment are also located in these buildings. There are a total of 44 different essential relay cabinets. Appendix E provides a listing of cabinets, which systems they are associated with, where they are located in the plant and the type of cabinet based on the definition of cabinet types in Appendix I of EPRI NP-7148. The in-cabinet amplification factors (AFs) from EPRI NP-7148 were used for determining the seismic demand for each relay with one exception. A cabinet specific amplification factor was determined for the 4160 VAC vital switchgear, 1A-05, 2A-05, 1A-06 (old) and 2A-06 (old), using a finite element analysis method [6.19]. An AF of 5.2 was calculated and used in the seismic capacity vs. demand check as compared to the AF of 7.0 from Appendix I of EPRI NP-7148.

5.3 Results

The Relay Identification / Functional Screening Worksheets and the highlighted electrical schematic drawings provide a traceable record of the functional screening of the relays associated with each SSEL component requiring a relay review. The information from the worksheets was transferred to the Associated Relay List (ARL) found in Appendix B. Figure 5.3-1 provides a summary of the results of the relay functionality review. A total of 2370 relay devices were identified as associated relays.



RELAY EVALUATION REPORT

RESULTS OF RELAY SCREENING
AND EVALUATION

5.3.1 Chatter Acceptable Relays

Of those 2370 relay devices, 731 were functionally screened as either "chatter acceptable" or not vulnerable. Appendix B, Table B.1 provides the screening notes providing the basis for the chatter acceptable determination. In addition, Appendix F provides more detailed discussions of the functional screening for instances where a single note was insufficient.

5.3.2 Relays Requiring Seismic Capacity Screening

A total of 1639 relay devices were identified as essential relays for specific seismic capacity screening. These relays were screened by placing them in one of three categories as described in Section 4. 69 X and Y coil contactors associated with switchgear breakers were determined to be adequate based on the "switchgear rule-of-the-box" concept in Section II.6.4. 109 relays were mounted in cabinets and control panels which were in turn mounted on either an emergency diesel generator or a service air compressor. These relays were determined to be adequate based on demonstrating proper function while the equipment is operating and vibrating. 1461 relays were determined to require a specific seismic capacity screening. The results of the seismic capacity screening are as follows:

- * 1329 relays have sufficient seismic capacity.
- * 124 relays have an unknown seismic capacity and are considered outliers.
- * 8 Westinghouse ITH relays are low ruggedness relays and are considered outliers.



RELAY EVALUATION REPORT

RESULTS OF RELAY SCRE
AND EVALUATION




Figure 5.3-1 - PBNP Relay Evaluation Process / Results Summary Flowchart



RELAY EVALUATION REPORT

REFERENCES

6.0 REFERENCES

- 6.1 USNRC Generic Letter 87-02, "Verification of Seismic Adequacy of Mechanical and Electrical Equipment in Operating Reactors, Unresolved Safety Issue (USI) A-46," February 19, 1987.
- 6.2 Use of Seismic Experience and Test Data to Show Ruggedness of Equipment in Nuclear Power Plants; R. Kennedy, W. Von Riesemann, P. Ibanez, A. Schiff, L. A. Wylie; prepared for the SQUG and in cooperation with the Office of Nuclear Reactor Regulation - USNRC; Revision 4.0; SAND-92-0140 UC 52; February 28, 1991.
- 6.3 Seismic Qualification Utility Group (SQUG), Generic Implementation Procedure (GIP) for Seismic Verification of Nuclear Plant Equipment, Revision 2, February 14, 1992.
- 6.4 NRC Generic Letter 87-02, Supplement 1, "Transmittal of Supplemental Safety Evaluation Report No. 2 (SSER #2)," May 22, 1992.
- 6.5 Wisconsin Electric Letter, VPNPD-92-313, "Response to Generic Letter 87-02, Supplement 1 on SQUG Resolution of USI A-46, Point Beach Nuclear Plant, Units 1 and 2," September 21, 1992.
- 6.6 NRC Letter to Robert E. Link, "Evaluation of Point Beach Nuclear Plant 120-Day Response to Supplement No. 1 to Generic Letter 87-02 (TAC Nos. M69472 and M69473)," February 22, 1993.
- 6.7 EPRI NP-7148-SL, Procedure for Evaluating Nuclear Power Plant Relay Seismic Functionality, December 1990.
- 6.8 EPRI NP-7148-SL, Volume 2, Procedure for Evaluating Nuclear Power Plant Relay Seismic Functionality Volume 2: Addendum, September 1993.
- 6.9 IEEE Standard 344-1975, IEEE Recommended Practices for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations, December 20, 1974.
- 6.10 Wisconsin Electric Power Company, "USNRC Generic Letter 87-02 Unresolved Safety Issue A-46 Resolution Safe Shutdown Equipment List Report, Point Beach Nuclear Power Units 1 & 2," June 1995.



RELAY EVALUATION REPORT

REFERENCES

- 6.11 Point Beach Nuclear Plant, Technical Specifications, "Appendix A to Facility Operating License DPR-24 and Facility Operating License DPR-27 for Point Beach Nuclear Plant Unit Nos. 1 and 2."
- 6.12 EPRI NP-7147-SL, Seismic Ruggedness of Relays, August 1991.
- 6.13 EPRI NP-7147-SL, Volume 2, Seismic Ruggedness of Relays, Volume 2: Addendum 1, September 1993.
- 6.14 EPRI NP-7147-SL, Volume 2, Seismic Ruggedness of Relays, Volume 2: Addendum 2, April 1995.
- 6.15 EPRI NP-5223-SL, Generic Seismic Ruggedness of Power Plant Equipment, Revision 1, August 1991.
- 6.16 Wisconsin Electric Power Company, "USNRC Generic Letter 87-02 Unresolved Safety Issue A-46 Resolution, Seismic Evaluation Report, Point Beach Nuclear Plant Units 1 and 2," Revision 0, June 1995.
- 6.17 Toledo Edison Company Letter K83-1591 to the USNRC, Mr. James G. Keppler, transmitting "LER 346/81-037 Revision 2 and Revised Supplemental Information for LER NP-33-81-44," dated November 10, 1983.
- 6.18 USNRC, NUREG-1407, Procedural and Submittal Guidance for the Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities, June 1991.
- 6.19 Stevenson and Associates Calculation 91C6296-C-031, "Seismic Analysis of Relays Mounted on 1A-05 Cubicle 1A52-59," 6/22/95.
- 6.20 Point Beach Nuclear Plant, Final Safety Analysis Report (FSAR), June 1994.
- 6.21 Wisconsin Electric, Nuclear Power Department Calculation N-91-016, Revision 1, "PBNP Diesel Generator Loading Analysis," 8/31/94.



RELAY EVALUATION REPORT

REFERENCES

6.22 The following Reference Drawings were used during the Relay Functionality Review

Vendor	Drawing Number	Sheet Number	Revision Number
BECH	E-6	SH. 1	24
BECH	E-6	SH. 2	7
BECH	E-6	SH. 3	1
BECH	M-143	SH. 1	7
BECH	M-207	SH. 4	14
BECH	M-217	SH. 1	59
BECH	M-219	SH. 1	33
EMD	8413730	SH. A	14
FOXBORO	CD1-14	SH. 1	6
FOXBORO	CD2-14	SH. 2	8
S&W	12137	ESK-11A	7
S&W	12137	ESK-11C	3
Westinghouse	499B466	SH. 200	5
Westinghouse	499B466	SH. 201	9
Westinghouse	499B466	SH. 212	13
Westinghouse	499B466	SH. 213	13
Westinghouse	499B466	SH. 214	11
Westinghouse	499B466	SH. 218	10
Westinghouse	499B466	SH. 222	14
Westinghouse	499B466	SH. 223	14
Westinghouse	499B466	SH. 256	8
Westinghouse	499B466	SH. 263	19
Westinghouse	499B466	SH. 266	12
Westinghouse	499B466	SH. 268	7
Westinghouse	499B466	SH. 286	10
Westinghouse	499B466	SH. 293	19
Westinghouse	499B466	SH. 298	8
Westinghouse	499B466	SH. 303	11
Westinghouse	499B466	SH. 304	9
Westinghouse	499B466	SH. 305	12
Westinghouse	499B466	SH. 306	9
Westinghouse	499B466	SH. 309	13
Westinghouse	499B466	SH. 310	12
Westinghouse	499B466	SH. 311	11
Westinghouse	499B466	SH. 312	11
Westinghouse	499B466	SH. 316	15
Westinghouse	499B466	SH. 316A	5



RELAY EVALUATION REPORT

REFERENCES

Vendor	Drawing Number	Sheet Number	Revision Number
Westinghouse	499B466	SH. 317	10
Westinghouse	499B466	SH. 317A	1
Westinghouse	499B466	SH. 321	13
Westinghouse	499B466	SH. 322	10
Westinghouse	499B466	SH. 324	12
Westinghouse	499B466	SH. 329	10
Westinghouse	499B466	SH. 333	6
Westinghouse	499B466	SH. 335	18
Westinghouse	499B466	SH. 336	12
Westinghouse	499B466	SH. 336A	2
Westinghouse	499B466	SH. 337	15
Westinghouse	499B466	SH. 338	11
Westinghouse	499B466	SH. 340	14
Westinghouse	499B466	SH. 340A	3
Westinghouse	499B466	SH. 342	9
Westinghouse	499B466	SH. 342A	2
Westinghouse	499B466	SH. 343	10
Westinghouse	499B466	SH. 344	10
Westinghouse	499B466	SH. 344A	1
Westinghouse	499B466	SH. 345	10
Westinghouse	499B466	SH. 351	10
Westinghouse	499B466	SH. 352	11
Westinghouse	499B466	SH. 356	8
Westinghouse	499B466	SH. 358	14
Westinghouse	499B466	SH. 359	14
Westinghouse	499B466	SH. 364	14
Westinghouse	499B466	SH. 366	15
Westinghouse	499B466	SH. 366A	6
Westinghouse	499B466	SH. 369	15
Westinghouse	499B466	SH. 370	14
Westinghouse	499B466	SH. 371	11
Westinghouse	499B466	SH. 372	14
Westinghouse	499B466	SH. 373	1
Westinghouse	499B466	SH. 381	10
Westinghouse	499B466	SH. 382	11
Westinghouse	499B466	SH. 386	9
Westinghouse	499B466	SH. 388	13
Westinghouse	499B466	SH. 389	12
Westinghouse	499B466	SH. 394	13
Westinghouse	499B466	SH. 538	5



RELAY EVALUATION REPORT

REFERENCES

Vendor	Drawing Number	Sheet Number	Revision Number
Westinghouse	499B466	SH. 550	3
Westinghouse	499B466	SH. 551	3
Westinghouse	499B466	SH. 552	3
Westinghouse	499B466	SH. 553	3
Westinghouse	499B466	SH. 554	3
Westinghouse	499B466	SH. 555	3
Westinghouse	499B466	SH. 556	3
Westinghouse	499B466	SH. 596	9
Westinghouse	499B466	SH. 597	9
Westinghouse	499B466	SH. 598	5
Westinghouse	499B466	SH. 713	3
Westinghouse	499B466	SH. 715	9
Westinghouse	499B466	SH. 716	17
Westinghouse	499B466	SH. 717	9
Westinghouse	499B466	SH. 719	12
Westinghouse	499B466	SH. 720	15
Westinghouse	499B466	SH. 721	7
Westinghouse	499B466	SH. 724	10
Westinghouse	499B466	SH. 725	11
Westinghouse	499B466	SH. 726	8
Westinghouse	499B466	SH. 727	8
Westinghouse	499B466	SH. 728	6
Westinghouse	499B466	SH. 729	6
Westinghouse	499B466	SH. 730	8
Westinghouse	499B466	SH. 731	10
Westinghouse	499B466	SH. 732	11
Westinghouse	499B466	SH. 734	9
Westinghouse	499B466	SH. 735	10
Westinghouse	499B466	SH. 736	3
Westinghouse	499B466	SH. 739	2
Westinghouse	499B466	SH. 757	13
Westinghouse	499B466	SH. 757C	6
Westinghouse	499B466	SH. 757D	4
Westinghouse	499B466	SH. 758	11
Westinghouse	499B466	SH. 770	9
Westinghouse	499B466	SH. 779	13
Westinghouse	499B466	SH. 787A	4
Westinghouse	499B466	SH. 787B	5
Westinghouse	499B466	SH. 803	5
Westinghouse	499B466	SH. 804	11



RELAY EVALUATION REPORT

REFERENCES

Vendor	Drawing Number	Sheet Number	Revision Number
Westinghouse	499B466	SH. 805	5
Westinghouse	499B466	SH. 812	5
Westinghouse	499B466	SH. 812A	1
Westinghouse	499B466	SH. 812B	2
Westinghouse	499B466	SH. 814	18
Westinghouse	499B466	SH. 814A	3
Westinghouse	499B466	SH. 816	9
Westinghouse	499B466	SH. 818	5
Westinghouse	499B466	SH. 823	9
Westinghouse	499B466	SH. 826	7
Westinghouse	499B466	SH. 829	0
Westinghouse	499B466	SH. 841	6
Westinghouse	499B466	SH. 861	4
Westinghouse	499B466	SH. 862	7
Westinghouse	499B466	SH. 863	7
Westinghouse	499B466	SH. 868	12
Westinghouse	499B466	SH. 868A	2
Westinghouse	499B466	SH. 874	8
Westinghouse	499B466	SH. 877	18
Westinghouse	499B466	SH. 890	3
Westinghouse	499B466	SH. 1005	5
Westinghouse	499B466	SH. 1205	4
Westinghouse	499B466	SH. 1509	7
Westinghouse	499B466	SH. 1511	7
Westinghouse	499B466	SH. 1523	8
Westinghouse	499B466	SH. 1532	9
Westinghouse	499B466	SH. 1635	4
Westinghouse	499B466	SH. 1651	2
Westinghouse	499B466	SH. 1655	4
Westinghouse	499B466	SH. 1658	3
Westinghouse	499B466	SH. 1695	3
Westinghouse	499B466	SH. 1696	1
Westinghouse	110E163	SH. 2	8
Westinghouse	110E163	SH. 3	4
Westinghouse	110E163	SH. 4	11
Westinghouse	110E163	SH. 5	8
Westinghouse	110E163	SH. 6	7
Westinghouse	110E163	SH. 7	25
Westinghouse	110E163	SH. 7A	2
Westinghouse	110E163	SH. 8	14



RELAY EVALUATION REPORT

REFERENCES

Vendor	Drawing Number	Sheet Number	Revision Number
Westinghouse	110E163	SH. 9	17
Westinghouse	110E163	SH. 10	14
Westinghouse	110E163	SH. 11	6
Westinghouse	110E163	SH. 12	8
Westinghouse	110E163	SH. 12A	6
Westinghouse	110E163	SH. 12B	5
Westinghouse	110E163	SH. 17	4
Westinghouse	110E163	SH. 18	1
Westinghouse	617F354	SH. 10A1	0
Westinghouse	617F354	SH. 10A2	0
Westinghouse	617F354	SH. 10B1	0
Westinghouse	617F354	SH. 10B2	0
Westinghouse	617F354	SH. 4A1	0
Westinghouse	617F354	SH. 4A2	0
Westinghouse	617F354	SH. 4B1	0
Westinghouse	617F354	SH. 4B2	0
Westinghouse	617F354	SH. 6A	0
Westinghouse	617F354	SH. 6A1	0
Westinghouse	617F354	SH. 6A2	0
Westinghouse	617F354	SH. 6B1	0
Westinghouse	617F354	SH. 6B2	0
Westinghouse	617F354	SH. 7A1	0
Westinghouse	617F354	SH. 7B1	0
Westinghouse	617F354	SH. 7B2	0
Westinghouse	617F354	SH. 8A1	0
Westinghouse	617F354	SH. 8A2	0
Westinghouse	617F354	SH. 8B1	0
Westinghouse	617F354	SH. 8B2	0
Westinghouse	617F354	SH. 9A1	0
Westinghouse	617F354	SH. 9A2	0
Westinghouse	617F354	SH. 9B1	0
Westinghouse	617F354-2	SH. 10A1	0
Westinghouse	617F354-2	SH. 10A2	0
Westinghouse	617F354-2	SH. 10B1	0
Westinghouse	617F354-2	SH. 10B2	0
Westinghouse	617F354-2	SH. 4A1	0
Westinghouse	617F354-2	SH. 4A2	0
Westinghouse	617F354-2	SH. 4B1	0
Westinghouse	617F354-2	SH. 4B2	0
Westinghouse	617F354-2	SH. 6A1	0



RELAY EVALUATION REPORT

REFERENCES

Vendor	Drawing Number	Sheet Number	Revision Number
Westinghouse	617F354-2	SH. 6A2	0
Westinghouse	617F354-2	SH. 6B1	0
Westinghouse	617F354-2	SH. 6B2	0
Westinghouse	617F354-2	SH. 7A1	0
Westinghouse	617F354-2	SH. 7A2	0
Westinghouse	617F354-2	SH. 7B1	0
Westinghouse	617F354-2	SH. 7B2	0
Westinghouse	617F354-2	SH. 8A1	0
Westinghouse	617F354-2	SH. 8A2	0
Westinghouse	617F354-2	SH. 8B1	0
Westinghouse	617F354-2	SH. 8B2	0
Westinghouse	617F354-2	SH. 9A1	0
Westinghouse	617F354-2	SH. 9A2	0
Westinghouse	617F354-2	SH. 9B1	0
Westinghouse	617F354-2	SH. 9B2	0
Westinghouse	195A778	SH. 20	0
Westinghouse	195A778	SH. 21	0
Westinghouse	195A778	SH. 24	0
Westinghouse	195A778	SH. 30	0
Westinghouse	195A778	SH. 31	0
Westinghouse	195A778	SH. 34	0
Westinghouse	195A778	SH. 333	6
Westinghouse	195A778	SH. 333A	4
Westinghouse	195A778	SH. 333C	1
Westinghouse	195A778	SH. 334	3
Westinghouse	195A778	SH. 334A	1
Westinghouse	195A778	SH. 453	3
Westinghouse	195A778	SH. 454	3



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

The Relay Review Safe Shutdown Equipment List (R-SSEL) on the following pages provides a listing of equipment for which a relay review was conducted. The R-SSEL consists of only electrically powered or controlled equipment for which the required safe shutdown function could be affected by the malfunction of a relay. The equipment selection is discussed in Section 4 of this report.

The R-SSEL provides the equipment ID, the earthquake experience database equipment class the equipment belongs to, the system to which the equipment belongs, the equipment train (A, B or A/B if it is common to both trains) and the equipment description. In addition, the equipment location (building, floor elevation, and plant area) is provided. The list is sorted by system, then by equipment class and then by equipment ID.



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
1	16	A	D-07	125V / STATION BATTERY CHARGER	CB	8	AREA 3
2	16	B	D-08	125V / STATION BATTERY CHARGER	CB	8	AREA 3
3	16	A/B	D-09	125V / SWING STATION BATTERY CHARGER	CB	8	AREA 3
4	16	A	D-107	125V / STATION BATTERY CHARGER	PAB	26	AREA 6
5	16	B	D-108	125V / STATION BATTERY CHARGER	PAB	26	AREA 6
6	16	A/B	D-109	125V / SWING STATION BATTERY CHARGER	PAB	26	AREA 6
7	3	A	1A-05	4.16KV / 4.16 KV BUS SWITCHGEAR (SAFEGUARDS)	CB	8	AREA 3
8	3	B	1A-06 (old)	4.16KV / 4.16 KV BUS SWITCHGEAR (SAFEGUARDS)	CB	8	AREA 3
9	3	A	1A52-57	4.16KV / TIE TO BUS 1A-03 (1A00-38)	CB	8	AREA 3
10	3	A	1A52-58	4.16KV / PWR TO 1X-13 STATION SERVICE TRANSFORMER	CB	8	AREA 3
11	3	A	1A52-60	4.16KV / G-01 EMERGENCY DIESEL GENERATOR OUTPUT TO 1A-05	CB	8	AREA 3
12	3	A	1A52-61	4.16KV / TIE TO BUS 1A-06 (1A00-62)	CB	8	AREA 3
13	3	B	1A52-63	4.16KV / TIE TO BUS 1A-04 (1A00-54)	CB	8	AREA 3
14	3	B	1A52-64	4.16KV / PWR TO 1X-14 STATION SERVICE XFMR	CB	8	AREA 3
15	3	B	1A52-66	4.16KV / G-02 EMERGENCY DIESEL GENERATOR OUTPUT TO 1A-06	CB	8	AREA 3
16	4	A	1X-13	4.16KV / B-03 STATION SERVICE TRANSFORMER	CB	26	AREA 3
17	4	B	1X-14	4.16KV / B-04 STATION SERVICE TRANSFORMER	CB	26	AREA 3
18	3	A	2A-05	4.16KV / 4.16 KV BUS SWITCHGEAR (SAFEGUARDS)	CB	8	AREA 3
19	3	B	2A-06 (old)	4.16KV / 4.16 KV BUS SWITCHGEAR (SAFEGUARDS)	CB	8	AREA 3
20	3	B	2A52-67	4.16KV / G-02 EMERGENCY DIESEL GENERATOR OUTPUT TO 2A-06	CB	8	AREA 3
21	3	B	2A52-69	4.16KV / PWR TO 2X-14 STATION SERVICE XFMR	CB	8	AREA 3
22	3	B	2A52-70	4.16KV / TIE TO BUS 2A-04 (2A00-49)	CB	8	AREA 3
23	3	A	2A52-72	4.16KV / 2A-05/2A-06 BUS TIE	CB	8	AREA 3
24	3	A	2A52-73	4.16KV / G-01 EMERGENCY DIESEL GENERATOR OUTPUT TO 2A-05	CB	8	AREA 3
25	3	A	2A52-75	4.16KV / PWR TO 2X-13 STATION SERVICE TRANSFORMER	CB	8	AREA 3
26	3	A	2A52-76	4.16KV / TIE TO BUS 2A-03 (2A00-43)	CB	8	AREA 3
27	4	A	2X-13	4.16KV / B-03 STATION SERVICE TRANSFORMER	CB	26	AREA 3
28	4	B	2X-14	4.16KV / B-04 STATION SERVICE TRANSFORMER	CB	26	AREA 3
29	2	A	1B-03	480V / 480V SAFEGUARDS LOAD CENTER	CB	26	AREA 3
30	2	B	1B-04	480V / 480V SAFEGUARDS LOAD CENTER	CB	26	AREA 3
31	1	A	1B-32	480V / 480V MOTOR CONTROL CENTER PAB SAFEGUARDS	PAB	8	AREA 4

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Checked by: John A. Hinck 1/8/96 / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
32	14	A	1B-39	480V / 480V MOTOR CONTROL CENTER TRN A BATT CHARGER SUP	CB	8	AREA 3
33	1	B	1B-42	480V / 480V MOTOR CONTROL CENTER PAB SAFEGUARDS	PAB	26	AREA 5
34	14	B	1B-49	480V / 480V MOTOR CONTROL CENTER TRN B BATT CHARGER SUP	CB	8	AREA 3
35	14	A	1B42-3212H	480V / D-109 SWING CTN BATTERY CHGR TRAIN A CONTACTOR	PAB	26	AREA 6
36	14	A	1B42-391	480V / D-07 STATION BATTERY CHARGER TRAIN A CONTACTOR	CB	8	AREA 3
37	14	B	1B42-491	480V / D-09 SWING STN BATTERY CHARGER TRAIN B CONTACTOR	CB	8	AREA 3
38	14	B	1B42-494	480V / D-108 STATION BATTERY CHARGER TRAIN B CONTACTOR	PAB	26	AREA 6
39	2	A	1B52-10A	480V / PWR TO 1P-11A COMPONENT COOLING WATER PUMP	CB	26	AREA 3
40	2	A	1B52-10C	480V / PWR TO P-32A SERVICE WATER PUMP	CB	26	AREA 3
41	2	A	1B52-11B	480V / ALT PWR TO 1B-32 PAB SAFEGUARDS MCC	CB	26	AREA 3
42	2	A	1B52-11C	480V / NORMAL PWR TO 1B311C-B854D P-32B SW PUMP XFR SW	CB	26	AREA 3
43	2	A	1B52-12A	480V / NORM PWR TO 1B312A-B855B 1P-10A RHR PUMP XFR SW	CB	26	AREA 3
44	2	A	1B52-12B	480V / PWR TO PP-14 PZR BACKUP HEATER C GROUP PWR PANEL	CB	26	AREA 3
45	2	A	1B52-12C	480V / PWR TO P-38A AUX FEEDWATER MOTOR-DRIVEN PUMP	CB	26	AREA 3
46	2	A	1B52-13A	480V / NORM PWR TO 1B313A-B854B 1P-2A CHG PUMP XFR SW	CB	26	AREA 3
47	2	A	1B52-13B	480V / PWR TO 1B313B-2B337B CHG PUMP CROSSTIE PWR PANEL	CB	26	AREA 3
48	2	A	1B52-13C	480V / PWR TO 1B-39 TRAIN A BATTERY CHARGER SUPPLY MCC	CB	26	AREA 3
49	2	A	1B52-14A	480V / PWR TO 1P-14A CONTAINMENT SPRAY PUMP	CB	26	AREA 3
50	2	A	1B52-14B	480V / NORMAL PWR TO 1B-32 PAB SAFEGUARDS MCC	CB	26	AREA 3
51	2	A	1B52-15A	480V / PWR TO 1W-1A1 CONT ACCIDENT RECIRCULATION FAN	CB	26	AREA 3
52	2	A	1B52-15B	480V / PWR TO 1W-1B1 CONT ACCIDENT RECIRCULATION FAN	CB	26	AREA 3
53	2	A	1B52-15C	480V / TIE TO 1B00-4C ON 1B-01 BUS	CB	26	AREA 3
54	2	A	1B52-16B	480V / FEED TO 1B-03 FROM 1X-13 STATION SERVICE XFMR	CB	26	AREA 3
55	2	A	1B52-16C	480V / TIE TO 1B00-17C ON 1B-04 BUS	CB	26	AREA 3
56	2	B	1B52-17B	480V / FEED TO 1B-04 FROM 1X-14 STATION SERVICE XFMR	CB	26	AREA 3
57	2	B	1B52-18A	480V / PWR TO 1W-1C1 CONT ACCIDENT RECIRCULATION FAN	CB	26	AREA 3
58	2	B	1B52-18B	480V / PWR TO 1W-1D1 CONT ACCIDENT RECIRCULATION FAN	CB	26	AREA 3
59	2	B	1B52-18C	480V / TIE TO 1B00-5C ON 1B-02 BUS	CB	26	AREA 3
60	2	B	1B52-19A	480V / PWR TO 1P-14B CONTAINMENT SPRAY PUMP	CB	26	AREA 3

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/8/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
61	2	B	1B52-20A	480V / PWR TO 1P-2C CHARGING PUMP	CB	26	AREA 3
62	2	B	1B52-20C	480V / NORMAL PWR TO 1B420C-B957D P-32C SW PUMP XFR SW	CB	26	AREA 3
63	2	B	1B52-21A	480V / NORM PWR TO 1B421A-B855B 1P-10B RHR PUMP XFR SW	CB	26	AREA 3
64	2	B	1B52-21B	480V / PWR TO PP-13 PZR BACKUP HEATER D GROUP PWR PANEL	CB	26	AREA 3
65	2	B	1B52-21C	480V / PWR TO B-43 PRIMARY AUXILIARY BLDG MCC	CB	26	AREA 3
66	2	B	1B52-22A	480V / PWR TO K-3A SERVICE AIR COMPRESSOR	CB	26	AREA 3
67	2	B	1B52-22C	480V / PWR TO PP-12 PZR CONTROL HEATER E GROUP PWR PNL	CB	26	AREA 3
68	2	B	1B52-23A	480V / ALT PWR TO 1B-42 PAB SAFEGUARDS MCC	CB	26	AREA 3
69	2	B	1B52-23B	480V / PWR TO 1P-11B COMPONENT COOLING WATER PUMP	CB	26	AREA 3
70	2	B	1B52-23C	480V / NORMAL PWR TO 1B-42 PAB SAFEGUARDS MCC	CB	26	AREA 3
71	2	B	1B52-24C	480V / PWR TO 1B-49 TRAIN B BATTERY CHARGER SUPPLY MCC	CB	26	AREA 3
72	1	A	1B52-3210C	480V / PWR TO 1CV-285 ELHX OUTLET	PAB	8	AREA 4
73	1	A	1B52-3210F	480V / PWR TO 1SW-2907 CONT RECIRC HX EMERGENCY FCV	PAB	8	AREA 4
74	1	A	1B52-3210J	480V / PWR TO SW-2870 SOUTH HEADER TO WEST HEADER	PAB	8	AREA 4
75	1	A	1B52-3210M	480V / PWR TO SW-2891 SOUTH TO NORTH HEADER XCONNECT	PAB	8	AREA 4
76	1	A	1B52-3211J	480V / PWR TO SW-2816 SSB AC CHILLER INLET	PAB	8	AREA 4
77	1	A	1B52-3211M	480V / PWR TO SW-2930A SFP HX OUTLET	PAB	8	AREA 4
78	1	A	1B52-3212H	480V / PWR TO 1B42-3212H D-109 CHGR TRAIN A CONTACTOR	PAB	8	AREA 4
79	1	A	1B52-3213L	480V / PWR TO K-2A INSTRUMENT AIR COMPRESSOR	PAB	8	AREA 4
80	1	A	1B52-321F	480V / PWR TO 1SI-852A LOW HEAD SI CORE DELUGE ISOL	PAB	8	AREA 4
81	1	A	1B52-321J	480V / PWR TO 1SI-866A COLD LEG INJECTION LINE ISOL	PAB	8	AREA 4
82	1	A	1B52-321M	480V / PWR TO 1SI-860A CONT SPRAY PUMP A DISCHARGE ISOL	PAB	8	AREA 4
83	1	A	1B52-322C	480V / PWR TO 1SI-896A SI PUMP A SUCTION	PAB	8	AREA 4
84	1	A	1B52-322F	480V / PWR TO 1SI-878D SI PUMP A LOOP A INJECTION	PAB	8	AREA 4
85	1	A	1B52-322J	480V / PWR TO 1SI-878A SI PUMP B REACTOR VESSEL INJ	PAB	8	AREA 4
86	1	A	1B52-322M	480V / PWR TO 1SI-860C CONT SPRAY PUMP B DISCH ISOL	PAB	8	AREA 4
87	1	A	1B52-323C	480V / PWR TO 1SI-851A RHR PUMP A SUCT FROM CONT SUMP B	PAB	8	AREA 4
88	1	A	1B52-323M	480V / PWR TO 1SI-871A CONT SPY PMP A SUCT FROM 1HX-11A	PAB	8	AREA 4

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Checked by: John A. Hinck 1/2/96 / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
89	1	A	1B52-324C	480V / PWR TO 1SI-825A RWST OUTLET TO 1P-15A/B SI PUMPS	PAB	8	AREA 4
90	1	A	1B52-325F	480V / PWR TO 1SI-826C SI PUMP SUCT/BAST PARALLEL ISOL	PAB	8	AREA 4
91	1	A	1B52-326C	480V / PWR TO 1CC-754A RCP A CC INLET MOV	PAB	8	AREA 4
92	1	A	1B52-326F	480V / PWR TO 1CC-759A RCP A CC OUTLET MOV	PAB	8	AREA 4
93	1	A	1B52-326J	480V / PWR TO 1CC-754B RCP B CC INLET MOV	PAB	8	AREA 4
94	1	A	1B52-326M	480V / PWR TO 1CC-759B RCP B CC OUTLET MOV	PAB	8	AREA 4
95	1	A	1B52-327C	480V / PWR TO 1CV-313 RCP A/B #1 SEAL WTR RETURN ISOL	PAB	8	AREA 4
96	1	A	1B52-327F	480V / PWR TO 1RC-515 PZR 1RC-431C PORV ISOLATION	PAB	8	AREA 4
97	1	A	1B52-327M	480V / PWR TO 1CC-815 CC SURGE TK EMER MAKEUP WTR INLET	PAB	8	AREA 4
98	1	A	1B52-328C	480V / PWR TO AF-4009 AFP SUCTION FROM SERVICE WATER	PAB	8	AREA 4
99	1	A	1B52-328F	480V / PWR TO AF-4023 AFP DISCHARGE TO 1HX-1A SG	PAB	8	AREA 4
100	1	A	1B52-329H	480V / PWR TO W-12A G-01 ROOM EXHAUST FAN	PAB	8	AREA 4
101	14	A	1B52-391	480V / PWR TO 1B42-391 D-07 STN BATTERY CHARGER TRAIN A	CB	8	AREA 3
102	1	B	1B52-4210C	480V / PWR TO 1SW-2908 CONT RECIRC HX EMERGENCY FCV	PAB	26	AREA 5
103	1	B	1B52-4210F	480V / PWR TO 1SW-2880 TB COOLER SERVICE WATER INLET	PAB	26	AREA 5
104	1	B	1B52-421F	480V / PWR TO 1SI-852B LOW HEAD SI CORE DELUGE ISOL	PAB	26	AREA 5
105	1	B	1B52-421J	480V / PWR TO 1SI-866B CORE DELUGE INJ LINE OUTBD ISOL	PAB	26	AREA 5
106	1	B	1B52-421M	480V / PWR TO 1SI-860B CONT SPRAY PUMP DISCH REDUN ISOL	PAB	26	AREA 5
107	1	B	1B52-422C	480V / PWR TO 1SI-896B SI PUMP SUCTION	PAB	26	AREA 5
108	1	B	1B52-422F	480V / PWR TO 1SI-878C RV SAFETY INJECTION	PAB	26	AREA 5
109	1	B	1B52-422J	480V / PWR TO 1SI-878B COLD LEG INJ TO T-34B OUT ISOL	PAB	26	AREA 5
110	1	B	1B52-422M	480V / PWR TO 1SI-860D CONT SPRAY PUMP DISCH REDUN ISOL	PAB	26	AREA 5
111	1	B	1B52-423C	480V / PWR TO 1SI-851B RHR PUMP SUCT FROM CONT SUMP B	PAB	26	AREA 5
112	1	B	1B52-423M	480V / PWR TO 1SI-871E CONT SPRAY PUMP SUCT FROM HX-11B	PAB	26	AREA 5
113	1	B	1B52-424C	480V / PWR TO 1SI-825B RWST OUTLET TO P-15A/B SI PUMP	PAB	26	AREA 5
114	1	B	1B52-425F	480V / PWR TO 1SI-826A SI PUMP SUCTION/BAST SERIES ISOL	PAB	26	AREA 5
115	1	B	1B52-425J	480V / PWR TO 1SI-826B SI PUMP SUCT/BAST PARALLEL ISOL	PAB	26	AREA 5

Prepared by: Timothy J. Dykstra 12/22/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/8/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
116	1	B	1B52-426C	480V / PWR TO 1CC-719 CONT EQUIP CC SUP HDR OUTBD ISOL	PAB	26	AREA 5
117	1	B	1B52-426M	480V / PWR TO 1RC-427 LOOP B COLD LEG/CVCS LETDOWN ISOL	PAB	26	AREA 5
118	1	B	1B52-427F	480V / PWR TO 1RC-516 PZR RC-430 PWR-OPER RELIEF INLET	PAB	26	AREA 5
119	1	B	1B52-428C	480V / PWR TO AF-4021 AFP DISCHARGE TO 1HX-1B SG	PAB	26	AREA 5
120	1	B	1B52-428F	480V / PWR TO 1AF-4006 AFP SUCTION FROM SERVICE WATER	PAB	26	AREA 5
121	1	B	1B52-429M	480V / PWR TO W-12C G-02 ROOM EXHAUST FAN	PAB	26	AREA 5
122	14	B	1B52-491	480V / PWR TO 1B42-491 D-09 SWING STN BATT CHG TRAIN B	CB	8	AREA 3
123	14	B	1B52-494	480V / PWR TO 1B42-494 D-108 STN BATTERY CHARGER TRN B	CB	8	AREA 3
124	2	A	2B-03	480V / 480V SAFEGUARDS LOAD CENTER	CB	26	AREA 3
125	2	B	2B-04	480V / 480V SAFEGUARDS LOAD CENTER	CB	26	AREA 3
126	1	A	2B-32	480V / 480V MOTOR CONTROL CENTER PAB SAFEGUARDS	PAB	8	AREA 6
127	14	A	2B-39	480V / 480V MOTOR CONTROL CENTER TRN A BATT CHARGER SUP	CB	8	AREA 3
128	1	B	2B-42	480V / 480V MOTOR CONTROL CENTER PAB SAFEGUARDS	PAB	26	AREA 5
129	14	B	2B-49	480V / 480V MOTOR CONTROL CENTER TRN B BATT CHARGER SUP	CB	8	AREA 3
130	14	A	2B42-391	480V / D-09 SWING STN BATTERY CHARGER TRAIN A CONTACTOR	CB	8	AREA 3
131	14	A	2B42-394	480V / D-107 STATION BATTERY CHARGER TRAIN A CONTACTOR	PAB	26	AREA 6
132	14	B	2B42-4212B	480V / D-109 SWING STN BATTERY CHGR TRAIN B CONTACTOR	PAB	26	AREA 6
133	14	B	2B42-491	480V / D-08 STATION BATTERY CHARGER TRAIN B CONTACTOR	CB	8	AREA 3
134	2	B	2B52-25B	480V / FEED TO 2B-04 FROM 2X-14 STATION SERVICE XFMR	CB	26	AREA 3
135	2	B	2B52-26A	480V / PWR TO 2W-1C1 CONT ACCIDENT RECIRCULATION FAN	CB	26	AREA 3
136	2	B	2B52-26B	480V / PWR TO 2W-1D1 CONT ACCIDENT RECIRCULATION FAN	CB	26	AREA 3
137	2	B	2B52-26C	480V / TIE TO 2B00-44C ON 2B-02 BUS	CB	26	AREA 3
138	2	B	2B52-27A	480V / PWR TO 2P-14B CONTAINMENT SPRAY PUMP	CB	26	AREA 3
139	2	B	2B52-27B	480V / PWR TO P-32D SERVICE WATER PUMP	CB	26	AREA 3
140	2	B	2B52-27C	480V / NORMAL PWR TO 2B427C-B957D P-32E SW PUMP XFR SW	CB	260	AREA 3
141	2	B	2B52-28A	480V / PWR TO 2P-2C CHARGING PUMP	CB	26	AREA 3
142	2	B	2B52-28B	480V / PWR TO 2P-11B COMPONENT COOLING WATER PUMP	CB	26	AREA 3

Prepared by: Timothy J. Dykstra 12/27/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/8/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
143	2	B	2B52-28C	480V / PWR TO B-21 SOUTH SERVICE BLDG MCC	CB	26	AREA 3
144	2	B	2B52-29A	480V / NORM PWR TO 2B429A-B958B 2P-10B RHR PUMP XFR SW	CB	26	AREA 3
145	2	B	2B52-29B	480V / PWR TO PP-18 PZR BACKUP HEATER D GROUP PWR PANEL	CB	26	AREA 3
146	2	B	2B52-29C	480V / PWR TO K-3B SERVICE AIR COMPRESSOR	CB	26	AREA 3
147	2	B	2B52-30B	480V / PWR TO Z-14 TURBINE BLDG OVERHEAD CRANE	CB	26	AREA 3
148	2	E	2B52-30C	480V / PWR TO PP-17 PZR CONTROL HEATER E GROUP PWR PNL	CB	26	AREA 3
149	2	B	2B52-31A	480V / PWR TO 2B-49 TRAIN B BATTERY CHARGER SUPPLY MCC	CB	26	AREA 3
150	2	B	2B52-31B	480V / ALT PWR TO 2B-42 PAB SAFEGUARDS MCC	CB	26	AREA 3
151	2	B	2B52-31C	480V / PWR TO P-38B AUX FEEDWATER MOTOR-DRIVEN PUMP	CB	26	AREA 3
152	1	A	2B52-3210C	480V / PWR TO 2CV-285 ELHX OUTLET	PAB	8	AREA 6
153	1	A	2B52-3210F	480V / PWR TO 2SW-2907 CONT RECIRC HX EMERGENCY FCV	PAB	8	AREA 6
154	1	A	2B52-3213C	480V / PWR TO W-85 PAB BATTERY AND INVERTER RM VENT FAN	PAB	8	AREA 6
155	1	A	2B52-321F	480V / PWR TO 2SI-852A LOW HEAD SI CORE DELUGE ISOL	PAB	8	AREA 6
156	1	A	2B52-321J	480V / PWR TO 2SI-866A COLD LEG INJECTION LINE ISOL	PAB	8	AREA 6
157	1	A	2B52-321M	480V / PWR TO 2SI-860A CONT SPRAY PUMP A DISCHARGE ISOL	PAB	8	AREA 6
158	1	A	2B52-322C	480V / PWR TO 2SI-896A SI PUMP A SUCTION	PAB	8	AREA 6
159	1	A	2B52-322F	480V / PWR TO 2SI-878D SI PUMP A LOOP A INJECTION	PAB	8	AREA 6
160	1	A	2B52-322J	480V / PWR TO 2SI-878A SI PUMP B REACTOR VESSEL INJ	PAB	8	AREA 6
161	1	A	2B52-322M	480V / PWR TO 2SI-860C CONT SPRAY PUMP B DISCHARGE ISOL	PAB	8	AREA 6
162	1	A	2B52-323C	480V / PWR TO 2SI-851A RHR PUMP A SUCT FROM CONT SUMP B	PAB	8	AREA 6
163	1	A	2B52-323M	480V / PWR TO 2SI-871A CONT SPY PMP A SUCT FROM 2HX-11A	PAB	8	AREA 6
164	1	A	2B52-324C	480V / PWR TO 2SI-825A RWST OUTLET TO 2P-15A/B SI PUMPS	PAB	8	AREA 6
165	1	A	2B52-325F	480V / PWR TO 2SI-826C SI PUMP SUCT/BAST PARALLEL ISOL	PAB	8	AREA 6
166	1	A	2B52-326C	480V / PWR TO 2CC-754A RCP A CC INLET MOV	PAB	8	AREA 6
167	1	A	2B52-326F	480V / PWR TO 2CC-759A RCP A CC OUTLET MOV	PAB	8	AREA 6
168	1	A	2B52-326J	480V / PWR TO 2CC-754B RCP B CC INLET MOV	PAB	8	AREA 6
169	1	A	2B52-326M	480V / PWR TO 2CC-759B RCP B CC OUTLET MOV	PAB	8	AREA 6

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/8/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
170	1	A	2B52-327C	480V / PWR TO 2CV-313 RCP A/B #1 SEAL WTR RETURN ISOL	PAB	8	AREA 6
171	1	A	2B52-327F	480V / PWR TO 2RC-515 PZR 2RC-431C PORV ISOLATION	PAB	8	AREA 6
172	1	A	2B52-327J	480V / PWR TO 2CV-1299 ELHX INLET/RC LOOP A COLD LEG	PAB	8	AREA 6
173	1	A	2B52-327M	480V / PWR TO 2CC-815 CC SURGE TK EMER MAKEUP WTR INLET	PAB	8	AREA 6
174	1	A	2B52-328C	480V / PWR TO AF-4022 AFP DISCHARGE TO 2HX-1A SG	PAB	8	AREA 6
175	1	A	2B52-329H	480V / PWR TO W-12B G-01 ROOM EXHAUST FAN	PAB	8	AREA 6
176	2	B	2B52-32C	480V / NORMAL PWR TO 2B-42 PAB SAFEGUARDS MCC	CB	26	AREA 3
177	2	A	2B52-33C	480V / PWR TO 2PR-49 POWER RECEPTACLE	CB	26	AREA 3
178	2	A	2B52-34A	480V / PWR TO 2P-11A COMPONENT COOLING WATER PUMP	CB	26	AREA 3
179	2	A	2B52-34B	480V / NORMAL PWR TO 2B334B-B854D P-32F SW PUMP XFR SW	CB	26	AREA 3
180	2	A	2B52-35C	480V / ALT PWR TO 2B-32 PAB SAFEGUARDS MCC	CB	26	AREA 3
181	2	A	2B52-36A	480V / NORM PWR TO 2B336A-B958B 2P-10A RHR PUMP XFR SW	CB	26	AREA 3
182	2	A	2B52-36B	480V / PWR TO PP-19 PZR BACKUP HEATER C GROUP PWR PANEL	CB	26	AREA 3
183	2	A	2B52-36C	480V / PWR TO 2B-39 TRAIN A BATTERY CHARGER SUPPLY MCC	CB	26	AREA 3
184	2	A	2B52-37A	480V / NORM PWR TO 2B337A-B957B 2P-2A CHG PUMP XFR SW	CB	26	AREA 3
185	2	A	2B52-37B	480V / PWR TO 2B337B-1B313B CHG PUMP CROSSTIE PWR PANEL	CB	26	AREA 3
186	2	A	2B52-37C	480V / PWR TO B-33 PRIMARY AUXILIARY BLDG MCC	CB	26	AREA 3
187	2	A	2B52-38A	480V / PWR TO 2P-14A CONTAINMENT SPRAY PUMP	CB	26	AREA 3
188	2	A	2B52-38B	480V / NORMAL PWR TO 2B-32 PAB SAFEGUARDS MCC	CB	26	AREA 3
189	2	A	2B52-38C	480V / PWR TO 2B-31 PRIMARY AUXILIARY BLDG MCC	CB	26	AREA 3
190	2	A	2B52-39A	480V / PWR TO 2W-1A1 CONT ACCIDENT RECIRCULATION FAN	CB	26	AREA 3
191	2	A	2B52-39B	480V / PWR TO 2W-1B1 CONT ACCIDENT RECIRCULATION FAN	CB	26	AREA 3
192	2	A	2B52-39C	480V / TIE TO 2B00-45C ON 2B-01 BUS	CB	26	AREA 3
193	2	A	2B52-40B	480V / FEED TO 2B-03 FROM 2X-13 STATION SERVICE XFMR	CB	26	AREA 3
194	2	A	2B52-40C	480V / TIE TO 2B00-25C ON 2B-04 BUS	CB	26	AREA 3
195	1	B	2B52-4210C	480V / PWR TO 2SW-2908 CONT RECIRC HX EMERGENCY FCV	PAB	26	AREA 5
196	1	B	2B52-4210F	480V / PWR TO SW-2817 WT AREA CLG COIL INLET	PAB	26	AREA 5

Prepared by: Timothy J Dykstra 12/29/95 / Date
 Timothy J Dykstra / Date
 Checked by: John A. Hinck 1/3/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
197	1	B	2B52-4210J	480V / PWR TO SW-2869 NORTH HEADER TO WEST HEADER	PAB	26	AREA 5
198	1	B	2B52-4210M	480V / PWR TO SW-2890 NORTH HDR TO SOUTH HDR XCONNECT	PAB	26	AREA 5
199	1	B	2B52-4212B	480V / NORMAL PWR TO 2B4212B-B811M D-109 CHGR XFR SW	PAB	26	AREA 5
200	1	B	2B52-4212G	480V / PWR TO 2SW-2880 TB COOLER SERVICE WATER INLET	PAB	26	AREA 5
201	1	B	2B52-4212M	480V / PWR TO K-2B INSTRUMENT AIR COMPRESSOR	PAB	26	AREA 5
202	1	B	2B52-421F	480V / PWR TO 2SI-852B LOW HEAD SI CORE DELUGE ISOL	PAB	26	AREA 5
203	1	B	2B52-421J	480V / PWR TO 2SI-866B CORE DELUGE INJ LINE OUTBD ISOL	PAB	26	AREA 5
204	1	B	2B52-421M	480V / PWR TO 2SI-860B CONT SPRAY PUMP DISCH REDUN ISOL	PAB	26	AREA 5
205	1	B	2B52-422C	480V / PWR TO 2SI-896B SI PUMP SUCTION	PAB	26	AREA 5
206	1	B	2B52-422F	480V / PWR TO 2SI-878C RV SAFETY INJECTION	PAB	26	AREA 5
207	1	B	2B52-422J	480V / PWR TO 2SI-878B COLD LEG INJ TO T-34B OUT ISOL	PAB	26	AREA 5
208	1	B	2B52-422M	480V / PWR TO 2SI-860D CONT SPRAY PUMP DISCH REDUN ISOL	PAB	26	AREA 5
209	1	B	2B52-423C	480V / PWR TO 2SI-851B RHR PUMP SUCT FROM CONT SUMP B	PAB	26	AREA 5
210	1	B	2B52-423M	480V / PWR TO 2SI-871B CONT SPRAY PUMP SUCT FROM HX-11B	PAB	26	AREA 5
211	1	B	2B52-424C	480V / PWR TO 2SI-825B RWST OUTLET TO P-15A/B SI PUMP	PAB	26	AREA 5
212	1	B	2B52-425F	480V / PWR TO 2SI-826A SI PUMP SUCTION/BAST SERIES ISOL	PAB	26	AREA 5
213	1	B	2B52-425J	480V / PWR TO 2SI-826B SI PUMP SUCT/BAST PARALLEL ISOL	PAB	26	AREA 5
214	1	B	2B52-426C	480V / PWR TO 2CC-719 CONT EQUIP CC SUP HDR OUTBD ISOL	PAB	26	AREA 5
215	1	B	2B52-426J	480V / PWR TO W-86 PAB BATTERY AND INVERTER RM VENT FAN	PAB	26	AREA 5
216	1	B	2B52-426M	480V / PWR TO 2RC-427 LOOP B COLD LEG/CVCS LETDOWN ISOL	PAB	26	AREA 5
217	1	B	2B52-427F	480V / PWR TO 2RC-516 PZR RC-430 PWR-OPER RELIEF INLET	PAB	26	AREA 5
218	1	B	2B52-427M	480V / PWR TO 2AF-4006 AFP SUCTION FROM SERVICE WATER	PAB	26	AREA 5
219	1	B	2B52-428C	480V / PWR TO AF-4016 AFP SUCTION FROM SERVICE WATER	PAB	26	AREA 5
220	1	B	2B52-428F	480V / PWR TO AF-4020 AFP DISCHARGE TO 2HX-1B SG	PAB	26	AREA 5
221	1	B	2B52-429M	480V / PWR TO W-12D G-02 ROOM EXHAUST FAN	PAB	26	AREA 5
222	7	A	AF-4007	AF / P-38A AFP MINI RECIRC CONTROL	CB	8	AREA 3
223	7	A	AF-4007-S	AF / P-38A AFP MINI RECIRC CONTROL SOLENOID	CB	8	AREA 3

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/8/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
224	8	A	AF-4007A-S	AF / P-38A AFP COOLING WATER SOLENOID	CB	8	AREA 3
225	8	A	AF-4009	AF / P-38A AFP SUCTION FROM SERVICE WATER	CB	8	AREA 3
226	8	A	AF-4009-M	AF / P-38A AFP SUCTION FROM SERVICE WATER MOTOR	CB	8	AREA 3
227	7	B	AF-4014	AF / P-38B AFP MINI RECIRC CONTROL	CB	8	AREA 3
228	7	B	AF-4014-S	AF / P-38B AFP MINI RECIRC CONTROL SOLENOID	CB	8	AREA 3
229	8	B	AF-4014A-S	AF / P-38B AFP COOLING WATER SOLENOID	CB	8	AREA 3
230	8	B	AF-4016	AF / P-38B AFP SUCTION FROM SERVICE WATER	CB	8	AREA 3
231	8	B	AF-4016-M	AF / P-38B AFP SUCTION FROM SERVICE WATER MOTOR	CB	8	AREA 3
232	8	B	AF-4020	AF / P-38B AFP DISCHARGE TO 2HX-1B STEAM GENERATOR	CB	8	AREA 3
233	8	B	AF-4020-M	AF / P-38B AFP DISCHARGE TO 2HX-1B SG MOTOR	CB	8	AREA 3
234	8	B	AF-4021	AF / P-38B AFP DISCHARGE TO 1HX-1B STEAM GENERATOR	CB	8	AREA 3
235	8	B	AF-4021-M	AF / P-38B AFP DISCHARGE TO 1HX-1B SG MOTOR	CB	8	AREA 3
236	8	A	AF-4022	AF / P-38A AFP DISCHARGE TO 2HX-1A STEAM GENERATOR	CB	8	AREA 3
237	8	A	AF-4022-M	AF / P-38A AFP DISCHARGE TO 2HX-1A SG MOTOR	CB	8	AREA 3
238	8	A	AF-4023	AF / P-38A AFP DISCHARGE TO 1HX-1A STEAM GENERATOR	CB	8	AREA 3
239	8	A	AF-4023-M	AF / P-38A AFP DISCHARGE TO 1HX-1A SG MOTOR	CB	8	AREA 3
240	5	A	P-38A	AF / AUX FEEDWATER MOTOR-DRIVEN PUMP	CB	8	AREA 3
241	5	A	P-38A-M	AF / AUX FEEDWATER MOTOR-DRIVEN PUMP MOTOR	CB	8	AREA 3
242	5	B	P-38B	AF / AUX FEEDWATER MOTOR-DRIVEN PUMP	CB	8	AREA 3
243	5	B	P-38B-M	AF / AUX FEEDWATER MOTOR-DRIVEN PUMP MOTOR	CB	8	AREA 3
244	8	A/B	1AF-4000	AF / P-29 AFP DISCHARGE HX-1B SG INLET ISOLATION MOV	CB	8	AREA 3
245	8	A/B	1AF-4000-M	AF / P-29 AFP DISCH TO HX-1B INLET ISOL MOV MOTOR	CB	8	AREA 3
246	8	A/B	1AF-4001	AF / P-29 AFP DISCHARGE HX-1A SG INLET ISOLATION MOV	CB	8	AREA 3
247	8	A/B	1AF-4001-M	AF / P-29 AFP DISCH TO HX-1A INLET ISOL MOV MOTOR	CB	8	AREA 3
248	7	A/B	1AF-4002	AF / P-29 AFP MINI RECIRC CONTROL	CB	8	AREA 3
249	7	A/B	1AF-4002-S	AF / P-29 AFP MINI RECIRC CONTROL SOLENOID	CB	8	AREA 3
250	8	A/B	1AF-4006	AF / P-29 AFP SUCTION FROM SERVICE WATER	CB	8	AREA 3

Prepared by:

Timothy J. Dykstra 12/24/95
 Timothy J. Dykstra / Date

Checked by:

John A. Hinck 1/5/96
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
251	8	A/B	1AF-4006-M	AF / P-29 AFP SUCTION FROM SERVICE WATER MOTOR	CB	8	AREA 3
252	14	B	1SAF-4000	AF / P-29 AFP DISCH HX-1B SG INLET ISOL MOV STARTER	CB	8	AREA 3
253	14	A	1SAF-4001	AF / P-29 AFP DISCH HX-1A SG INLET ISOL MOV STARTER	CB	8	AREA 3
254	8	A/B	2AF-4000	AF / P-29 AFP DISCHARGE HX-1B SG INLET ISOLATION MOV	CB	8	AREA 3
255	8	A/B	2AF-4000-M	AF / P-29 AFP DISCH TO HX-1B INLET ISOL MOV MOTOR	CB	8	AREA 3
256	8	A/B	2AF-4001	AF / P-29 AFP DISCHARGE HX-1A SG INLET ISOLATION MOV	CB	8	AREA 3
257	8	A/B	2AF-4001-M	AF / P-29 AFP DISCH TO HX-1A INLET ISOL MOV MOTOR	CB	8	AREA 3
258	7	A/B	2AF-4002	AF / P-29 AFP MINI RECIRC CONTROL	CB	8	AREA 3
259	7	A/B	2AF-4002-S	AF / P-29 AFP MINI RECIRC CONTROL SOLENOID	CB	8	AREA 3
260	8	A/B	2AF-4006	AF / P-29 AFP SUCTION FROM SERVICE WATER	CB	8	AREA 3
261	8	A/B	2AF-4006-M	AF / P-29 AFP SUCTION FROM SERVICE WATER MOTOR	CB	8	AREA 3
262	14	B	2SAF-4000	AF / P-29 AFP DISCH HX-1B SG INLET ISOL MOV STARTER	CB	8	AREA 3
263	14	A	2SAF-4001	AF / P-29 AFP DISCH HX-1A SG INLET ISOL MOV STARTER	CB	8	AREA 3
264	7	A/B	CC-LW-63	CC / RADWASTE CC SUPPLY	PAB	8	AREA 6
265	7	A/B	CC-LW-63-S	CC / RADWASTE CC SUPPLY SOLENOID	PAB	8	AREA 6
266	7	A/B	CC-LW-64	CC / RADWASTE CC RETURN	PAB	8	AREA 6
267	7	A/B	CC-LW-64-S	CC / RADWASTE CC RETURN SOLENOID	PAB	8	AREA 6
268	8	A/B	1CC-719	CC / CONT EQUIP CC SUPPLY HEADER OUTBOARD ISOLATION	PAB	8	PIPE 2
269	8	A/B	1CC-719-M	CC / CONT EQUIP CC SUPPLY HEADER OUTBOARD ISOL MOTOR	PAB	8	PIPE 2
270	8	A/B	1CC-754A	CC / P-1A RCP CC INLET MOV	PAB	8	PIPE 2
271	8	A/B	1CC-754A-M	CC / P-1A RCP CC INLET MOV MOTOR	PAB	8	PIPE 2
272	8	A/B	1CC-754B	CC / P-1B RCP CC INLET MOV	PAB	8	PIPE 2
273	8	A/B	1CC-754B-M	CC / P-1B RCP CC INLET MOV MOTOR	PAB	8	PIPE 2
274	8	A/B	1CC-759A	CC / P-1A RCP CC OUTLET MOV	PAB	8	PIPE 2
275	8	A/B	1CC-759A-M	CC / P-1A RCP CC OUTLET MOV MOTOR	PAB	8	PIPE 2
276	8	A/B	1CC-759B	CC / P-1B RCP CC OUTLET MOV	PAB	8	PIPE 2
277	8	A/B	1CC-759B-M	CC / P-1B RCP CC OUTLET MOV MOTOR	PAB	8	PIPE 2

Prepared by: Timothy J. Dykstra 12/27/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/3/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
278	7	A/B	1CC-761A	CC / P-1A RCP THERMAL BARRIER COOLING RETURN	U1C	21	AREA 7
279	7	A/B	1CC-761A-S	CC / P-1A RCP THERMAL BARRIER COOLING RETURN SOLENOID	U1C	21	AREA 7
280	7	A/B	1CC-761B	CC / P-1B RCP THERMAL BARRIER COOLING RETURN	U1C	21	AREA 7
281	7	A/B	1CC-761B-S	CC / P-1B RCP THERMAL BARRIER COOLING RETURN SOLENOID	U1C	21	AREA 7
282	8	A/B	1CC-815	CC / T-12 CC SURGE TANK EMERGENCY MAKEUP WATER INLET	PAB	8	AREA 5
283	8	A/B	1CC-815-M	CC / T-12 CC SURGE TANK EMER MAKEUP WATER INLET MOTOR	PAB	8	AREA 5
284	5	A	1P-11A	CC / COMPONENT COOLING WATER PUMP	PAB	8	AREA 5
285	5	A	1P-11A-M	CC / COMPONENT COOLING WATER PUMP MOTOR	PAB	8	AREA 5
286	5	B	1P-11B	CC / COMPONENT COOLING WATER PUMP	PAB	8	AREA 5
287	5	B	1P-11B-M	CC / COMPONENT COOLING WATER PUMP MOTOR	PAB	8	AREA 5
288	8	A/B	2CC-719	CC / CONT EQUIP CC SUPPLY HEADER OUTBOARD ISOLATION	PAB	8	PIPE 3
289	8	A/B	2CC-719-M	CC / CONT EQUIP CC SUPPLY HEADER OUTBOARD ISOL MOTOR	PAB	8	PIPE 3
290	8	A/B	2CC-754A	CC / P-1A RCP CC INLET MOV	PAB	8	PIPE 3
291	8	A/B	2CC-754A-M	CC / P-1A RCP CC INLET MOV MOTOR	PAB	8	PIPE 3
292	8	A/B	2CC-754B	CC / P-1B RCP CC INLET MOV	PAB	8	PIPE 3
293	8	A/B	2CC-754B-M	CC / P-1B RCP CC INLET MOV MOTOR	PAB	8	PIPE 3
294	8	A/B	2CC-759A	CC / P-1A RCP CC OUTLET MOV	PAB	8	PIPE 3
295	8	A/P	2CC-759A-M	CC / P-1A RCP CC OUTLET MOV MOTOR	PAB	8	PIPE 3
296	8	A/B	2CC-759B	CC / P-1B RCP CC OUTLET MOV	PAB	8	PIPE 3
297	8	A/B	2CC-759B-M	CC / P-1B RCP CC OUTLET MOV MOTOR	PAB	8	PIPE 3
298	7	A/B	2CC-761A	CC / P-1A RCP THERMAL BARRIER COOLING RETURN	U2C	21	AREA 11
299	7	A/B	2CC-761A-S	CC / P-1A RCP THERMAL BARRIER COOLING RETURN SOLENOID	U2C	21	AREA 11
300	7	A/B	2CC-761B	CC / P-1B RCP THERMAL BARRIER COOLING RETURN	U2C	21	AREA 11
301	7	A/B	2CC-761B-S	CC / P-1B RCP THERMAL BARRIER COOLING RETURN SOLENOID	U2C	21	AREA 11
302	8	A/B	2CC-815	CC / T-12 CC SURGE TANK EMERGENCY MAKEUP WATER INLET	PAB	8	AREA 5
303	8	A/B	2CC-815-M	CC / T-12 CC SURGE TANK EMER MAKEUP WATER INLET MOTOR	PAB	8	AREA 5
304	5	A	2P-11A	CC / COMPONENT COOLING WATER PUMP	PAB	8	AREA 5

Prepared by: Timothy J. Dykstra 12/29/95 Checked by: John A. Hinck 1/8/96
 Timothy J. Dykstra / Date John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
305	5	A	2P-11A-M	CC / COMPONENT COOLING WATER PUMP MOTOR	PAB	8	AREA 5
306	5	B	2P-11B	CC / COMPONENT COOLING WATER PUMP	PAB	8	AREA 5
307	5	B	2P-11B-M	CC / COMPONENT COOLING WATER PUMP MOTOR	PAB	8	AREA 5
308	7	A	1CS-466	CS / HX-1A SG FEEDWATER REGULATOR CONTROL	TB-South	26	AREA 2
309	7	A	1CS-466A-S	CS / HX-1A SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-South	26	AREA 2
310	7	A	1CS-466B-S	CS / HX-1A SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-South	26	AREA 2
311	7	A	1CS-466C-S	CS / HX-1A SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-South	26	AREA 2
312	7	A	1CS-466D-S	CS / HX-1A SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-South	26	AREA 2
313	7	B	1CS-476	CS / HX-1B SG FEEDWATER REGULATOR CONTROL	TB-South	26	AREA 2
314	7	B	1CS-476A-S	CS / HX-1B SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-South	26	AREA 2
315	7	B	1CS-476B-S	CS / HX-1B SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-South	26	AREA 2
316	7	B	1CS-476C-S	CS / HX-1B SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-South	26	AREA 2
317	7	B	1CS-476D-S	CS / HX-1B SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-South	26	AREA 2
318	7	A	1CS-480	CS / HX-1A SG REGULATOR CONTROL BYPASS	TB-South	26	AREA 2
319	7	A	1CS-480-S	CS / HX-1A SG REGULATOR CONTROL BYPASS SOLENOID	TB-South	26	AREA 2
320	7	B	1CS-481	CS / HX-1B SG REGULATOR CONTROL BYPASS	TB-South	26	AREA 2
321	7	B	1CS-481-S	CS / HX-1B SG REGULATOR CONTROL BYPASS SOLENOID	TB-South	26	AREA 2
322	7	A	2CS-466	CS / HX-1A SG FEEDWATER REGULATOR CONTROL	TB-North	26	AREA 9
323	7	A	2CS-466A-S	CS / HX-1A SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-North	26	AREA 9
324	7	A	2CS-466B-S	CS / HX-1A SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-North	26	AREA 9
325	7	A	2CS-466C-S	CS / HX-1A SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-North	26	AREA 9
326	7	A	2CS-466D-S	CS / HX-1A SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-North	26	AREA 9
327	7	B	2CS-476	CS / HX-1B SG FEEDWATER REGULATOR CONTROL	TB-North	26	AREA 9
328	7	B	2CS-476A-S	CS / HX-1B SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-North	26	AREA 9
329	7	B	2CS-476B-S	CS / HX-1B SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-North	26	AREA 9
330	7	B	2CS-476C-S	CS / HX-1B SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-North	26	AREA 9
331	7	B	2CS-476D-S	CS / HX-1B SG FEEDWATER REGULATOR CONTROL SOLENOID	TB-North	26	AREA 9

Prepared by: Timothy J. Dykstra 1/29/95 Checked by: John A. Hinck 1/3/96
 Timothy J. Dykstra / Date John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
332	7	A	2CS-480	CS / HX-1A SG REGULATOR CONTROL BYPASS	TB-North	26	AREA 9
333	7	A	2CS-480-S	CS / HX-1A SG REGULATOR CONTROL BYPASS SOLENOID	TB-North	26	AREA 9
334	7	B	2CS-481	CS / HX-1B SG REGULATOR CONTROL BYPASS	TB-North	26	AREA 9
335	7	B	2CS-481-S	CS / HX-1B SG REGULATOR CONTROL BYPASS SOLENOID	TB-North	26	AREA 9
336	8	A/B	1CV-112B	CV / P-2A-C CHARGING PUMP REFUELING WATER SUCTION	PAB	8	AREA 4
337	8	A/B	1CV-112B-M	CV / P-2A-C CHG PUMP REFUELING WATER SUCTION MOTOR	PAB	8	AREA 4
338	7	A/B	1CV-200A	CV / LETDOWN ORIFICE A OUTLET CONTROL	U1C	21	AREA 7
339	7	A/B	1CV-200A-S	CV / LETDOWN ORIFICE A OUTLET CONTROL SLENOID	U1C	21	AREA 7
340	7	A/B	1CV-200B	CV / LETDOWN ORIFICE B OUTLET CONTROL	U1C	21	AREA 7
341	7	A/B	1CV-200B-S	CV / LETDOWN ORIFICE B OUTLET CONTROL SLENOID	U1C	21	AREA 7
342	7	A/B	1CV-200C	CV / LETDOWN ORIFICE C OUTLET CONTROL	U1C	21	AREA 7
343	7	A/B	1CV-200C-S	CV / LETDOWN ORIFICE C OUTLET CONTROL SLENOID	U1C	21	AREA 7
344	8	A/B	1CV-285	CV / HX-4 ELHX OUTLET	U1C	21	AREA 7
345	8	A/B	1CV-285-M	CV / HX-4 ELHX OUTLET MOTOR	U1C	21	AREA 7
346	7	A/B	1CV-296	CV / HX-2 REGEN HX TO AUXILIARY SPRAY	U1C	21	AREA 7
347	7	A/B	1CV-296-S	CV / HX-2 REGEN HX TO AUXILIARY SPRAY SOLENOID	U1C	21	AREA 7
348	8	A/B	1CV-313	CV / P-1A/B RCP #1 SEAL WATER RETURN ISOLATION	PAB	8	PIPE 2
349	8	A/B	1CV-313-M	CV / P-1A/B RCP #1 SEAL WATER RETURN ISOLATION MOTOR	PAB	8	PIPE 2
350	7	A/B	1CV-313A	CV / P-1A/B RCP #1 SEAL WATER RETURN ISOLATION	U1C	8	AREA 7
351	7	A/B	1CV-313A-S	CV / P-1A/B RCP #1 SEAL WATER RETURN ISOLATION SOL	U1C	8	AREA 7
352	7	A/B	1CV-371	CV / LETDOWN LINE CONTAINMENT ISOLATION	PAB	8	AREA 5
353	7	A/B	1CV-371-S	CV / LETDOWN LINE CONTAINMENT ISOLATION SOLENOID	PAB	8	PIPE 2
354	7	A/B	1CV-371A	CV / LETDOWN LINE CONTAINMENT ISOLATION	U1C	21	AREA 7
355	7	A/B	1CV-371A-S	CV / LETDOWN LINE CONTAINMENT ISOLATION SOLENOID	U1C	21	AREA 7
356	8	A/B	2CV-112B	CV / P-2A-C CHARGING PUMP REFUELING WATER SUCTION	PAB	8	AREA 6
357	8	A/B	2CV-112B-M	CV / P-2A-C CHG PUMP REFUELING WATER SUCTION MOTOR	PAB	8	AREA 6
358	7	A/B	2CV-200A	CV / LETDOWN ORIFICE A OUTLET CONTROL	U2C	21	AREA 11

Prepared by: Timothy J Dykstra 12/29/95 Checked by: John A. Hinck 1/3/96
 Timothy J. Dykstra / Date John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
359	7	A/B	2CV-200A-S	CV / LETDOWN ORIFICE A OUTLET CONTROL SLENOID	U2C	21	AREA 11
360	7	A/B	2CV-200B	CV / LETDOWN ORIFICE B OUTLET CONTROL	U2C	21	AREA 11
361	7	A/B	2CV-200B-S	CV / LETDOWN ORIFICE B OUTLET CONTROL SLENOID	U2C	21	AREA 11
362	7	A/B	2CV-200C	CV / LETDOWN ORIFICE C OUTLET CONTROL	U2C	21	AREA 11
363	7	A/B	2CV-200C-S	CV / LETDOWN ORIFICE C OUTLET CONTROL SLENOID	U2C	21	AREA 11
364	8	A/B	2CV-285	CV / HX-4 ELHX OUTLET	U2C	21	AREA 11
365	8	A/B	2CV-285-M	CV / HX-4 ELHX OUTLET MOTOR	U2C	21	AREA 11
366	7	A/B	2CV-296	CV / HX-2 REGEN HX TO AUXILIARY SPRAY	U2C	21	AREA 11
367	7	A/B	2CV-296-S	CV / HX-2 REGEN HX TO AUXILIARY SPRAY SOLENOID	U2C	21	AREA 11
368	8	A/B	2CV-313	CV / P-1A/B RCP #1 SEAL WATER RETURN ISOLATION	PAB	8	PIPE 3
369	8	A/B	2CV-313-M	CV / P-1A/B RCP #1 SEAL WATER RETURN ISOLATION MOTOR	PAB	8	PIPE 3
370	7	A/B	2CV-313A	CV / P-1A/B RCP #1 SEAL WATER RETURN ISOLATION	U2C	8	AREA 11
371	7	A/B	2CV-313A-S	CV / P-1A/B RCP #1 SEAL WATER RETURN ISOLATION SOL	U2C	8	AREA 11
372	7	A/B	2CV-371	CV / LETDOWN LINE CONTAINMENT ISOLATION	PAB	8	AREA 5
373	7	A/B	2CV-371-S	CV / LETDOWN LINE CONTAINMENT ISOLATION SOLENOID	PAB	8	PIPE 3
374	7	A/B	2CV-371A	CV / LETDOWN LINE CONTAINMENT ISOLATION	U2C	21	AREA 11
375	7	A/B	2CV-371A-S	CV / LETDOWN LINE CONTAINMENT ISOLATION SOLENOID	U2C	21	AREA 11
376	7	A	DA-6318A-S	DA / G-01 EDG RIGHT BANK STARTING AIR SOLENOID	CB	8	AREA 3
377	7	A	DA-6318B-S	DA / G-01 EDG LEFT BANK STARTING AIR SOLENOID	CB	8	AREA 3
378	7	B	DA-6319A-S	DA / G-02 EDG RIGHT BANK STARTING AIR SOLENOID	CB	8	AREA 3
379	7	B	DA-6319B-S	DA / G-02 EDG LEFT BANK STARTING AIR SOLENOID	CB	8	AREA 3
380	17	A	G-01	DG / EMERGENCY DIESEL GENERATOR	CB	8	AREA 3
381	17	B	G-02	DG / EMERGENCY DIESEL GENERATOR	CB	8	AREA 3
382	8	A	FO-3930	FO / T-31A DG DAY TANK INLET SECOND OFF ISOLATION	CB	8	AREA 3
383	8	A	FO-3930-M	FO / T-31A DG DAY TANK INLET SECOND OFF ISOL MOTOR	CB	8	AREA 3
384	8	B	FO-3931	FO / T-31B DG DAY TANK INLET SECOND OFF ISOLATION	CB	8	AREA 3
385	8	B	FO-3931-M	FO / T-31B DG DAY TANK INLET SECOND OFF ISOL MOTOR	CB	8	AREA 3

Prepared by: Timothy J. Dykstra 12/29/95 Checked by: John A. Hinck 1/5/96
 Timothy J. Dykstra / Date John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
386	7	B	1MS-2017	MS / HX-1B SG STEAM HEADER MAIN STEAM STOP CONTROL	U1F	85	AREA 7
387	18	B	1MS-2017A-S	MS / MS-2017 MAIN STEAM STOP SOLENOID	U1F	85	AREA 7
388	18	B	1MS-2017B-S	MS / MS-2017 MAIN STEAM STOP SOLENOID	U1F	85	AREA 7
389	18	B	1MS-2017C-S	MS / MS-2017 MAIN STEAM STOP SOLENOID	U1F	85	AREA 7
390	18	B	1MS-2017D-S	MS / MS-2017 MAIN STEAM STOP SOLENOID	U1F	85	AREA 7
391	7	A	1MS-2018	MS / HX-1A SG STEAM HEADER MAIN STEAM STOP CONTROL	U1F	85	AREA 7
392	18	A	1MS-2018A-S	MS / MS-2018 MAIN STEAM STOP SOLENOID	U1F	85	AREA 7
393	18	A	1MS-2018B-S	MS / MS-2018 MAIN STEAM STOP SOLENOID	U1F	85	AREA 7
394	18	A	1MS-2018C-S	MS / MS-2018 MAIN STEAM STOP SOLENOID	U1F	85	AREA 7
395	18	A	1MS-2018D-S	MS / MS-2018 MAIN STEAM STOP SOLENOID	U1F	85	AREA 7
396	8	B	1MS-2019	MS / HX-1B SG HEADER P-29 AFP STEAM SUPPLY MOV	PAB	46	AREA 5
397	8	B	1MS-2019-M	MS / HX-1B SG HEADER P-29 AFP STEAM SUPPLY MOV MOTOR	PAB	46	AREA 5
398	8	A	1MS-2020	MS / HX-1A SG HEADER P-29 AFP STEAM SUPPLY MOV	PAB	46	AREA 5
399	8	A	1MS-2020-M	MS / HX-1A SG HEADER P-29 AFP STEAM SUPPLY MOV MOTOR	PAB	46	AREA 5
400	7	A	1MS-2042	MS / HX-1A SG STEAM HEADER BLOWDOWN CONTROL	U1F	26	AREA 7
401	7	A	1MS-2042-S	MS / HX-1A SG STEAM HEADER BLOWDOWN CONTROL SOLENOID	U1F	26	AREA 7
402	7	B	1MS-2045	MS / HX-1B SG STEAM HEADER BLOWDOWN CONTROL	U1F	26	AREA 7
403	7	B	1MS-2045-S	MS / HX-1B SG STEAM HEADER BLOWDOWN CONTROL SOLENOID	U1F	26	AREA 7
404	7	A	1MS-2083	MS / HX-1A SG SAMPLE ISOLATION CONTROL	PAB	8	AREA 4
405	7	A	1MS-2083-S	MS / HX-1A SG SAMPLE ISOLATION CONTROL SOLENOID	PAB	8	AREA 4
406	7	B	1MS-2084	MS / HX-1B SG SAMPLE ISOLATION CONTROL	PAB	8	AREA 4
407	7	B	1MS-2084-S	MS / HX-1B SG SAMPLE ISOLATION CONTROL SOLENOID	PAB	8	AREA 4
408	7	A/B	1MS-2090	MS / P-29 AFP BEARING COOLING INLET	CB	8	AREA 3
409	7	A/B	1MS-2090-S	MS / P-29 AFP BEARING COOLING SOLENOID	CB	8	AREA 3
410	7	A	1MS-5958	MS / HX-1A SG BLOWDOWN ISOLATION	U1C	21	AREA 7
411	7	A	1MS-5958-S	MS / HX-1A SG BLOWDOWN ISOLATION SOLENOID	U1C	21	AREA 7
412	7	B	1MS-5959	MS / HX-1B SG BLOWDOWN ISOLATION	U1C	21	AREA 7

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/2/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
413	7	B	1MS-5959-S	MS / HX-1B SG BLOWDOWN ISOLATION SOLENOID	U1C	21	AREA 7
414	14	B	1SMS-2019	MS / HX-1B SG HDR P-29 AFP STEAM SUPPLY MOV STARTER	CB	8	AREA 3
415	14	A	1SMS-2020	MS / HX-1A SG HDR P-29 AFP STEAM SUPPLY MOV STARTER	CB	8	AREA 3
416	7	B	2MS-2017	MS / HX-1B SG STEAM HEADER MAIN STEAM STOP CONTROL	U2F	85	AREA 11
417	18	B	2MS-2017A-S	MS / MS-2017 MAIN STEAM STOP SOLENOID	U2F	85	AREA 11
418	18	B	2MS-2017B-S	MS / MS-2017 MAIN STEAM STOP SOLENOID	U2F	85	AREA 11
419	18	B	2MS-2017C-S	MS / MS-2017 MAIN STEAM STOP SOLENOID	U2F	85	AREA 11
420	18	B	2MS-2017D-S	MS / MS-2017 MAIN STEAM STOP SOLENOID	U2F	85	AREA 11
421	7	A	2MS-2018	MS / HX-1A SG STEAM HEADER MAIN STEAM STOP CONTROL	U2F	85	AREA 11
422	18	A	2MS-2018A-S	MS / MS-2018 MAIN STEAM STOP SOLENOID	U2F	85	AREA 11
423	18	A	2MS-2018B-S	MS / MS-2018 MAIN STEAM STOP SOLENOID	U2F	85	AREA 11
424	18	A	2MS-2018C-S	MS / MS-2018 MAIN STEAM STOP SOLENOID	U2F	85	AREA 11
425	18	A	2MS-2018D-S	MS / MS-2018 MAIN STEAM STOP SOLENOID	U2F	85	AREA 11
426	8	B	2MS-2019	MS / HX-1B SG HEADER P-29 AFP STEAM SUPPLY MOV	PAB	46	AREA 5
427	8	B	2MS-2019-M	MS / HX-1B SG HEADER P-29 AFP STEAM SUPPLY MOV MOTOR	PAB	46	AREA 5
428	8	A	2MS-2020	MS / HX-1A SG HEADER P-29 AFP STEAM SUPPLY MOV	PAB	46	AREA 5
429	8	A	2MS-2020-M	MS / HX-1A SG HEADER P-29 AFP STEAM SUPPLY MOV MOTOR	PAB	46	AREA 5
430	7	A	2MS-2042	MS / HX-1A SG STEAM HEADER BLOWDOWN CONTROL	U2F	26	AREA 11
431	7	A	2MS-2042-S	MS / HX-1A SG STEAM HEADER BLOWDOWN CONTROL SOLENOID	U2F	26	AREA 11
432	7	B	2MS-2045	MS / HX-1B SG STEAM HEADER BLOWDOWN CONTROL	U2F	26	AREA 11
433	7	B	2MS-2045-S	MS / HX-1B SG STEAM HEADER BLOWDOWN CONTROL SOLENOID	U2F	26	AREA 11
434	7	A	2MS-2083	MS / HX-1A SG SAMPLE ISOLATION CONTROL	PAB	8	AREA 6
435	7	A	2MS-2083-S	MS / HX-1A SG SAMPLE ISOLATION CONTROL SOLENOID	PAB	8	AREA 6
436	7	B	2MS-2084	MS / HX-1B SG SAMPLE ISOLATION CONTROL	PAB	8	AREA 6
437	7	B	2MS-2084-S	MS / HX-1B SG SAMPLE ISOLATION CONTROL SOLENOID	PAB	8	AREA 6
438	7	A/B	2MS-2090	MS / P-29 AFP BEARING COOLING INLET	CB	8	AREA 3
439	7	A/B	2MS-2090-S	MS / P-29 AFP BEARING COOLING SOLENOID	CB	8	AREA 3

Prepared by: Timothy J. Dykstra 12/27/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinch 1/8/96 / Date
 John A. Hinch / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
440	7	B	2MS-5958	MS / HX-1B SG BLOWDOWN ISOLATION	U2C	21	AREA 11
441	7	B	2MS-5958-S	MS / HX-1B SG BLOWDOWN ISOLATION SOLENOID	U2C	21	AREA 11
442	7	A	2MS-5959	MS / HX-1A SG BLOWDOWN ISOLATION	U2C	21	AREA 11
443	7	A	2MS-5959-S	MS / HX-1A SG BLOWDOWN ISOLATION SOLENOID	U2C	21	AREA 11
444	14	B	2SMS-2019	MS / HX-1B SG HDR P-29 AFP STEAM SUPPLY MOV STARTER	CB	8	AREA 3
445	14	A	2SMS-2020	MS / HX-1A SG HDR P-29 AFP STEAM SUPPLY MOV STARTER	CB	8	AREA 3
446	8	A/B	1RC-427	RC / RC LOOP B COLD LEG TO CVCS LETDOWN ISOLATION	U1C	21	AREA 7
447	8	A/B	1RC-427-M	RC / RC LOOP B COLD LEG TO CVCS LETDOWN ISOLATION MOT	U1C	21	AREA 7
448	7	A/B	1RC-430	RC / T-1 PZR POWER-OPERATED RELIEF	U1C	76	AREA 7
449	7	A/B	1RC-430-S	RC / T-1 PZR POWER-OPERATED RELIEF SOLENOID	U1C	76	AREA 7
450	7	A/B	1RC-431A	RC / T-1 PZR SPRAY LINE PRESSURE CONTROL	U1C	76	AREA 7
451	7	A/B	1RC-431A-S	RC / T-1 PZR SPRAY LINE PRESSURE CONTROL SOLENOID	U1C	76	AREA 7
452	7	A/B	1RC-431B	RC / T-1 PZR SPRAY LINE PRESSURE CONTROL	U1C	76	AREA 7
453	7	A/B	1RC-431B-S	RC / T-1 PZR SPRAY LINE PRESSURE CONTROL SOLENOID	U1C	76	AREA 7
454	7	A/B	1RC-431C	RC / T-1 PZR POWER-OPERATED RELIEF	U1C	76	AREA 7
455	7	A/B	1RC-431C-S	RC / T-1 PZR POWER-OPERATED RELIEF SOLENOID	U1C	76	AREA 7
456	8	A/B	1RC-515	RC / T-1 PZR RC-431C POWER-OPERATED RELIEF ISOLATION	U1C	76	AREA 7
457	8	A/B	1RC-515-M	RC / T-1 PZR RC-431C POWER-OPERATED RELIEF ISOL MOTOR	U1C	76	AREA 7
458	8	A/B	1RC-516	RC / T-1 PZR RC-430 POWER-OPERATED RELIEF ISOLATION	U1C	76	AREA 7
459	8	A/B	1RC-516-M	RC / T-1 PZR RC-430 POWER-OPERATED RELIEF ISOL MOTOR	U1C	76	AREA 7
460	8	A	1RC-570A	RC / R-1 RV HEAD VENT SOLENOID	U1C	66	AREA 7
461	8	B	1RC-570B	RC / R-1 RV HEAD VENT SOLENOID	U1C	66	AREA 7
462	8	A/B	1RC-575A	RC / R-1 RV/T-1 PZR VENT HEADER TO T-2 PRT SOLENOID	U1C	66	AREA 7
463	8	A/B	1RC-575B	RC / R-1 RV/T-1 PZR GAS VENT TO CONT STANDPIPE SOL	U1C	66	AREA 7
464	8	A	1RC-580A	RC / T-1 PZR VENT ISOLATION SOLENOID	U1C	66	AREA 7
465	8	B	1RC-580B	RC / T-1 PZR VENT ISOLATION SOLENOID	U1C	66	AREA 7
466	8	A/B	2RC-427	RC / RC LOOP B COLD LEG TO CVCS LETDOWN ISOLATION	U2C	21	AREA 11

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/8/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
467	8	A/B	2RC-427-M	RC / RC LOOP B COLD LEG TO CVCS LETDOWN ISOLATION MOT	U2C	21	AREA 11
468	7	A/B	2RC-430	RC / T-1 PZR POWER-OPERATED RELIEF	U2C	76	AREA 11
469	7	A/B	2RC-430-S	RC / T-1 PZR POWER-OPERATED RELIEF SOLENOID	U2C	76	AREA 11
470	7	A/B	2RC-431A	RC / T-1 PZR SPRAY LINE PRESSURE CONTROL	U2C	76	AREA 11
471	7	A/B	2RC-431A-S	RC / T-1 PZR SPRAY LINE PRESSURE CONTROL SOLENOID	U2C	76	AREA 11
472	7	A/B	2RC-431B	RC / T-1 PZR SPRAY LINE PRESSURE CONTROL	U2C	76	AREA 11
473	7	A/B	2RC-431B-S	RC / T-1 PZR SPRAY LINE PRESSURE CONTROL SOLENOID	U2C	76	AREA 11
474	7	A/B	2RC-431C	RC / T-1 PZR POWER-OPERATED RELIEF	U2C	76	AREA 11
475	7	A/B	2RC-431C-S	RC / T-1 PZR POWER-OPERATED RELIEF SOLENOID	U2C	76	AREA 11
476	8	A/B	2RC-515	RC / T-1 PZR RC-431C POWER-OPERATED RELIEF ISOLATION	U2C	76	AREA 11
477	8	A/B	2RC-515-M	RC / T-1 PZR RC-431C POWER-OPERATED RELIEF ISOL MOTOR	U2C	76	AREA 11
478	8	A/B	2RC-516	RC / T-1 PZR RC-430 POWER-OPERATED RELIEF ISOLATION	U2C	76	AREA 11
479	8	A/B	2RC-516-M	RC / T-1 PZR RC-430 POWER-OPERATED RELIEF ISOL MOTOR	U2C	76	AREA 11
480	8	A	2RC-570A	RC / R-1 RV HEAD VENT SOLENOID	U2C	66	AREA 11
481	8	B	2RC-570B	RC / R-1 RV HEAD VENT SOLENOID	U2C	66	AREA 11
482	8	A/B	2RC-575A	RC / R-1 RV/T-1 PZR VENT HEADER TO T-2 PRT SOLENOID	U2C	66	AREA 11
483	8	A/B	2RC-575B	RC / R-1 RV/T-1 PZR GAS VENT TO CONT STANDPIPE SOL	U2C	66	AREA 11
484	8	A	2RC-580A	RC / T-1 PZR VENT ISOLATION SOLENOID	U2C	66	AREA 11
485	8	B	2RC-580B	RC / T-1 PZR VENT ISOLATION SOLENOID	U2C	66	AREA 11
486	3	A	1-52/BYA	RP / REACTOR TRIP BYPASS BREAKER	PAB	46	AREA 4
487	3	B	1-52/BYB	RP / REACTOR TRIP BYPASS BREAKER	PAB	46	AREA 4
488	3	A	1-52/RTA	RP / REACTOR TRIP BREAKER	PAB	46	AREA 4
489	3	B	1-52/RTB	RP / REACTOR TRIP BREAKER	PAB	46	AREA 4
490	3	A	2-52/BYA	RP / REACTOR TRIP BYPASS BREAKER	PAB	46	AREA 6
491	3	B	2-52/BYB	RP / REACTOR TRIP BYPASS BREAKER	PAB	46	AREA 6
492	3	A	2-52/RTA	RP / REACTOR TRIP BREAKER	PAB	46	AREA 6
493	3	B	2-52/RTB	RP / REACTOR TRIP BREAKER	PAB	46	AREA 6

Prepared by: Timothy J Dykstra 12/29/95
 Timothy J Dykstra / Date
 Checked by: John A. Hinck 1/8/96
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
494	7	A/B	RS-SA-10	RS / UNIT 2 RADWASTE STEAM TRIP	PAB	46	AREA 5
495	7	A/B	RS-SA-10-1	RS / UNIT 2 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
496	7	A/B	RS-SA-10-2	RS / UNIT 2 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
497	7	A/B	RS-SA-10-3	RS / UNIT 2 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
498	7	A/B	RS-SA-10-4	RS / UNIT 2 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
499	7	A/B	RS-SA-10-5	RS / UNIT 2 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
500	7	A/B	RS-SA-10-6	RS / UNIT 2 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
501	7	A/B	RS-SA-10-7	RS / UNIT 2 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
502	7	A/B	RS-SA-9	RS / UNIT 1 RADWASTE STEAM TRIP	PAB	46	AREA 5
503	7	A/B	RS-SA-9-1	RS / UNIT 1 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
504	7	A/B	RS-SA-9-2	RS / UNIT 1 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
505	7	A/B	RS-SA-9-3	RS / UNIT 1 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
506	7	A/B	RS-SA-9-4	RS / UNIT 1 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
507	7	A/B	RS-SA-9-5	RS / UNIT 1 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
508	7	A/B	RS-SA-9-6	RS / UNIT 1 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
509	7	A/B	RS-SA-9-7	RS / UNIT 1 RADWASTE STEAM TRIP SOLENOID	PAB	46	AREA 5
510	7	A/B	1SC-951	SC / PZR STEAM SPACE SAMPLE CONTAINMENT ISOLATION	U1C	21	AREA 7
511	7	A/B	1SC-951-S	SC / PZR STEAM SPACE SAMPLE CONTAINMENT ISOL SOLENOID	U1C	21	AREA 7
512	7	A/B	1SC-953	SC / PZR LIQUID SPACE SAMPLE CONTAINMENT ISOLATION	U1C	21	AREA 7
513	7	A/B	1SC-953-S	SC / PZR LIQUID SPACE SAMPLE CONTAINMENT ISOL SOL	U1C	21	AREA 7
514	7	A/B	1SC-955	SC / RC HOT LEG SAMPLE ISOLATION	U1C	10	AREA 7
515	7	A/B	1SC-955-S	SC / RC HOT LEG SAMPLE ISOLATION SOLENOID	U1C	10	AREA 7
516	7	A/B	1SC-959	SC / RHR LOOP SAMPLE ISOLATION	PAB	8	AREA 5
517	7	A/B	1SC-959-S	SC / RHR LOOP SAMPLE ISOLATION SOLENOID	PAB	8	AREA 5
518	7	A/B	1SC-966C	SC / RC HOT LEG SAMPLE	PAB	8	AREA 4
519	7	A/B	1SC-966C-S	SC / RC HOT LEG SAMPLE SOLENOID	PAB	8	AREA 4
520	7	A/B	2SC-951	SC / PZR STEAM SPACE SAMPLE CONTAINMENT ISOLATION	U2C	21	AREA 11

Prepared by:

Timothy J. Dykstra 12/29/95
 Timothy J. Dykstra / Date

Checked by:

John A. Hinch 1/3/96
 John A. Hinch / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
521	7	A/B	2SC-951-S	SC / PZR STEAM SPACE SAMPLE CONTAINMENT ISOL SOLENOID	U2C	21	AREA 11
522	7	A/B	2SC-953	SC / PZR LIQUID SPACE SAMPLE CONTAINMENT ISOLATION	U2C	21	AREA 11
523	7	A/B	2SC-953-S	SC / PZR LIQUID SPACE SAMPLE CONTAINMENT ISOL SOL	U2C	21	AREA 11
524	7	A/B	2SC-955	SC / RC HOT LEG SAMPLE ISOLATION	U2C	10	AREA 11
525	7	A/B	2SC-955-S	SC / RC HOT LEG SAMPLE ISOLATION SOLENOID	U2C	10	AREA 11
526	7	A/B	2SC-959	SC / RHR LOOP SAMPLE ISOLATION	PAB	8	AREA 5
527	7	A/B	2SC-959-S	SC / RHR LOOP SAMPLE ISOLATION SOLENOID	PAB	8	AREA 5
528	7	A/B	2SC-966C	SC / RC HOT LEG SAMPLE	PAB	8	AREA 6
529	7	A/B	2SC-966C-S	SC / RC HOT LEG SAMPLE SOLENOID	PAB	8	AREA 6
530	5	A	1P-15A	SI / SAFETY INJECTION PUMP	PAB	8	AREA 5
531	5	A	1P-15A-M	SI / SAFETY INJECTION PUMP MOTOR	PAB	8	AREA 5
532	5	B	1P-15B	SI / SAFETY INJECTION PUMP	PAB	8	AREA 5
533	5	B	1P-15B-M	SI / SAFETY INJECTION PUMP MOTOR	PAB	8	AREA 5
534	8	A/B	1SI-825A	SI / T-13 RWST OUTLET TO P-15A/B SI PUMP	PAB	8	AREA 5
535	8	A/B	1SI-825A-M	SI / T-13 RWST OUTLET TO P-15A/B SI PUMP MOTOR	PAB	8	AREA 5
536	8	A/B	1SI-825B	SI / T-13 RWST OUTLET TO P-15A/B SI PUMP	PAB	8	AREA 5
537	8	A/B	1SI-825B-M	SI / T-13 RWST OUTLET TO P-15A/B SI PUMP MOTOR	PAB	8	AREA 5
538	8	A/B	1SI-826A	SI / P-15A/B SI PUMP SUCTION FROM BAST SERIES ISOL	PAB	8	AREA 5
539	8	A/B	1SI-826A-M	SI / P-15A/B SI PUMP SUCTION FROM BAST SERIES ISOL MOTOR	PAB	8	AREA 5
540	8	A/B	1SI-826B	SI / P-15A/B SI PUMP SUCTION FROM BAST PARALLEL ISOL	PAB	8	AREA 5
541	8	A/B	1SI-826B-M	SI / P-15A/B SI PMP SUCTION FROM BAST PARALLEL ISOL MTR	PAB	8	AREA 5
542	8	A/B	1SI-826C	SI / P-15A/B SI PUMP SUCTION FROM BAST PARALLEL ISOL	PAB	8	AREA 5
543	8	A/B	1SI-826C-M	SI / P-15A/B SI PMP SUCTION FROM BAST PARALLEL ISOL MTR	PAB	8	AREA 5
544	7	A	1SI-835A	SI / T-34A SI ACCUMULATOR FILL FROM COLD LEG SI	U1C	21	AREA 7
545	7	A	1SI-835A-S	SI / T-34A SI ACCUMULATOR FILL FROM COLD LEG SI SOL	U1C	21	AREA 7
546	7	B	1SI-835B	SI / T-34B SI ACCUMULATOR FILL FROM COLD LEG SI	U1C	21	AREA 7
547	7	B	1SI-835B-S	SI / T-34B SI ACCUMULATOR FILL FROM COLD LEG SI SOL	U1C	21	AREA 7

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Checked by: John A. Hinck 1/8/96 / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
548	7	A/B	1SI-839A	SI / T-34A SI ACCUM OUTLET TO SI TEST LINE ISOLATION	U1C	21	AREA 7
549	7	A/B	1SI-839A-S	SI / T-34A SI ACCUM OUTLET TO SI TEST LINE ISOL SOL	U1C	21	AREA 7
550	7	A/B	1SI-839B	SI / SI A COLD LEG TO SI TEST LINE ISOLATION	U1C	21	AREA 7
551	7	A/B	1SI-839B-S	SI / SI A COLD LEG TO SI TEST LINE ISOLATION SOLENOID	U1C	21	AREA 7
552	7	A/B	1SI-839C	SI / T-34B SI ACCUM OUTLET TO SI TEST LINE ISOLATION	U1C	21	AREA 7
553	7	A/B	1SI-839C-S	SI / T-34B SI ACCUM OUTLET TO SI TEST LINE ISOL SOL	U1C	21	AREA 7
554	7	A/B	1SI-839D	SI / SI B COLD LEG TO SI TEST LINE ISOLATION	U1C	21	AREA 7
555	7	A/B	1SI-839D-S	SI / SI B COLD LEG TO SI TEST LINE ISOLATION SOLENOID	U1C	21	AREA 7
556	8	A/B	1SI-851A	SI / P-10A RHR PUMP SUCTION FROM CONTAINMENT SUMP B	PAB	-5	AREA 8
557	8	A/B	1SI-851A-M	SI / P-10A RHR PUMP SUCTION FROM CONT SUMP B MOTOR	PAB	-5	AREA 8
558	8	A/B	1SI-851B	SI / P-10B RHR PUMP SUCTION FROM CONTAINMENT SUMP B	PAB	-5	AREA 8
559	8	A/B	1SI-851B-M	SI / P-10B RHR PUMP SUCTION FROM CONT SUMP B MOTOR	PAB	-5	AREA 8
560	8	A	1SI-852A	SI / LOW HEAD SI CORE DELUGE ISOLATION	U1C	46	AREA 7
561	8	A	1SI-852A-M	SI / LOW HEAD SI CORE DELUGE ISOLATION MOTOR	U1C	46	AREA 7
562	8	B	1SI-852B	SI / LOW HEAD SI CORE DELUGE ISOLATION	U1C	21	AREA 7
563	8	B	1SI-852B-M	SI / LOW HEAD SI CORE DELUGE ISOLATION MOTOR	U1C	21	AREA 7
564	8	A/B	1SI-860A	SI / P-14A CONT SPRAY PUMP DISCHARGE REDUNDANT ISOL	PAB	8	AREA 5
565	8	A/B	1SI-860A-M	SI / P-14A CONT SPRAY PUMP DISCH REDUNDANT ISOL MOTOR	PAB	8	AREA 5
566	8	A/B	1SI-860B	SI / P-14A CONT SPRAY PUMP DISCHARGE REDUNDANT ISOL	PAB	8	AREA 5
567	8	A/B	1SI-860B-M	SI / P-14A CONT SPRAY PUMP DISCH REDUNDANT ISOL MOTOR	PAB	8	AREA 5
568	8	A/B	1SI-860C	SI / P-14B CONT SPRAY PUMP DISCHARGE REDUNDANT ISOL	PAB	8	AREA 5
569	8	A/B	1SI-860C-M	SI / P-14B CONT SPRAY PUMP DISCH REDUNDANT ISOL MOTOR	PAB	8	AREA 5
570	8	A/B	1SI-860D	SI / P-14B CONT SPRAY PUMP DISCHARGE REDUNDANT ISOL	PAB	8	AREA 5
571	8	A/B	1SI-860D-M	SI / P-14B CONT SPRAY PUMP DISCH REDUNDANT ISOL MOTOR	PAB	8	AREA 5
572	8	A	1SI-866A	SI / COLD LEG INJECTION LINE ISOLATION	PAB	8	PIPE 1
573	8	A	1SI-866A-M	SI / COLD LEG INJECTION LINE ISOLATION MOTOR	PAB	8	PIPE 1
574	8	B	1SI-866B	SI / CORE DELUGE INJECTION LINE ISOLATION	PAB	8	PIPE 1

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/3/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
575	8	B	1SI-866B-M	SI / CORE DELUGE INJECTION LINE ISOLATION MOTOR	PAB	8	PIPE 1
576	8	A	1SI-871A	SI / P-14A CONT SPRAY PUMP SUCTION FROM HX-11A RHR HX	PAB	8	AREA 5
577	8	A	1SI-871A-M	SI / P-14A CONT SPRAY PUMP SUCTION FROM HX-11A MOTOR	PAB	8	AREA 5
578	8	B	1SI-871B	SI / P-14B CONT SPRAY PUMP SUCTION FROM HX-11B RHR HX	PAB	8	AREA 5
579	8	B	1SI-871B-M	SI / P-14B CONT SPRAY PUMP SUCTION FROM HX-11B MOTOR	PAB	8	AREA 5
580	8	B	1SI-878A	SI / P-15B SI PUMP R-1 REACTOR VESSEL INJECTION	U1C	21	AREA 7
581	8	B	1SI-878A-M	SI / P-15B SI PUMP R-1 REACTOR VESSEL INJECTION MOTOR	U1C	21	AREA 7
582	8	A	1SI-878B	SI / P-15A SI PUMP LOOP B INJECTION	U1C	21	AREA 7
583	8	A	1SI-878B-M	SI / P-15A SI PUMP LOOP B INJECTION MOTOR	U1C	21	AREA 7
584	8	B	1SI-878C	SI / P-15B SI PUMP R-1 REACTOR VESSEL INJECTION	U1C	21	AREA 7
585	8	B	1SI-878C-M	SI / P-15B SI PUMP R-1 REACTOR VESSEL INJECTION MOTOR	U1C	21	AREA 7
586	8	A	1SI-878D	SI / P-15A SI PUMP LOOP A INJECTION	U1C	21	AREA 7
587	8	A	1SI-878D-M	SI / P-15A SI PUMP LOOP A INJECTION MOTOR	U1C	21	AREA 7
588	8	A	1SI-896A	SI / P-15A SI PUMP SUCTION	PAB	8	AREA 5
589	8	A	1SI-896A-M	SI / P-15A SI PUMP SUCTION MOTOR	PAB	8	AREA 5
590	8	B	1SI-896B	SI / P-15B SI PUMP SUCTION	PAB	8	AREA 5
591	8	B	1SI-896B-M	SI / P-15B SI PUMP SUCTION MOTOR	PAB	8	AREA 5
592	5	A	2P-15A	SI / SAFETY INJECTION PUMP	PAB	8	AREA 5
593	5	A	2P-15A-M	SI / SAFETY INJECTION PUMP MOTOR	PAB	8	AREA 5
594	5	B	2P-15B	SI / SAFETY INJECTION PUMP	PAB	8	AREA 5
595	5	B	2P-15B-M	SI / SAFETY INJECTION PUMP MOTOR	PAB	8	AREA 5
596	8	A/B	2SI-825A	SI / T-13 RWST OUTLET TO P-15A/B SI PUMP	PAB	8	AREA 5
597	8	A/B	2SI-825A-M	SI / T-13 RWST OUTLET TO P-15A/B SI PUMP MOTOR	PAB	8	AREA 5
598	8	A/B	2SI-825B	SI / T-13 RWST OUTLET TO P-15A/B SI PUMP	PAB	8	AREA 5
599	8	A/B	2SI-825B-M	SI / T-13 RWST OUTLET TO P-15A/B SI PUMP MOTOR	PAB	8	AREA 5
600	8	A/B	2SI-826A	SI / P-15A/B SI PUMP SUCTION FROM BAST SERIES ISOL	PAB	8	AREA 5
601	8	A/B	2SI-826A-M	SI / P-15A/B SI PUMP SUCTION FROM BAST SERIES ISOL MOTOR	PAB	8	AREA 5

Prepared by: Timothy J. Dykstra 12/23/95
 Timothy J. Dykstra / Date

Checked by: John A. Hinch 1/8/96
 John A. Hinch / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
602	8	A/B	2SI-826B	SI / P-15A/B SI PUMP SUCTION FROM BAST PARALLEL ISOL	PAB	8	AREA 5
603	8	A/B	2SI-826B-M	SI / P-15A/B SI PMP SUCT FROM BAST PARALLEL ISOL MTR	PAB	8	AREA 5
604	8	A/B	2SI-826C	SI / P-15A/B SI PUMP SUCTION FROM BAST PARALLEL ISOL	PAB	8	AREA 5
605	8	A/B	2SI-826C-M	SI / P-15A/B SI PMP SUCT FROM BAST PARALLEL ISOL MTR	PAB	8	AREA 5
606	7	A	2SI-835A	SI / T-34A SI ACCUMULATOR FILL FROM COLD LEG SI	U2C	21	AREA 11
607	7	A	2SI-835A-S	SI / T-34A SI ACCUMULATOR FILL FROM COLD LEG SI SOL	U2C	21	AREA 11
608	7	B	2SI-835B	SI / T-34B SI ACCUMULATOR FILL FROM COLD LEG SI	U2C	21	AREA 11
609	7	B	2SI-835B-S	SI / T-34B SI ACCUMULATOR FILL FROM COLD LEG SI SOL	U2C	21	AREA 11
610	7	A/B	2SI-839A	SI / T-34A SI ACCUM OUTLET TO SI TEST LINE ISOLATION	U2C	21	AREA 11
611	7	A/B	2SI-839A-S	SI / T-34A SI ACCUM OUTLET TO SI TEST LINE ISOL SOL	U2C	21	AREA 11
612	7	A/B	2SI-839B	SI / SI A COLD LEG TO SI TEST LINE ISOLATION	U2C	21	AREA 11
613	7	A/B	2SI-839B-S	SI / SI A COLD LEG TO SI TEST LINE ISOLATION SOLENOID	U2C	21	AREA 11
614	7	A/B	2SI-839C	SI / T-34B SI ACCUM OUTLET TO SI TEST LINE ISOLATION	U2C	21	AREA 11
615	7	A/B	2SI-839C-S	SI / T-34B SI ACCUM OUTLET TO SI TEST LINE ISOL SOL	U2C	21	AREA 11
616	7	A/B	2SI-839D	SI / SI B COLD LEG TO SI TEST LINE ISOLATION	U2C	21	AREA 11
617	7	A/B	2SI-839D-S	SI / SI B COLD LEG TO SI TEST LINE ISOLATION SOLENOID	U2C	21	AREA 11
618	8	A/B	2SI-851A	SI / P-10A RHR PUMP SUCTION FROM CONTAINMENT SUMP B	PAB	-5	AREA 8
619	8	A/B	2SI-851A-M	SI / P-10A RHR PUMP SUCTION FROM CONT SUMP B MOTOR	PAB	-5	AREA 8
620	8	A/B	2SI-851B	SI / P-10B RHR PUMP SUCTION FROM CONTAINMENT SUMP B	PAB	-5	AREA 8
621	8	A/B	2SI-851B-M	SI / P-10B RHR PUMP SUCTION FROM CONT SUMP B MOTOR	PAB	-5	AREA 8
622	8	A	2SI-852A	SI / LOW HEAD SI CORE DELUGE ISOLATION	U2C	46	AREA 11
623	8	A	2SI-852A-M	SI / LOW HEAD SI CORE DELUGE ISOLATION MOTOR	U2C	46	AREA 11
624	8	B	2SI-852B	SI / LOW HEAD SI CORE DELUGE ISOLATION	U2C	21	AREA 11
625	8	B	2SI-852B-M	SI / LOW HEAD SI CORE DELUGE ISOLATION MOTOR	U2C	21	AREA 11
626	8	A/B	2SI-860A	SI / P-14A CONT SPRAY PUMP DISCHARGE REDUNDANT ISOL	PAB	8	AREA 5
627	8	A/B	2SI-860A-M	SI / P-14A CONT SPRAY PUMP DISCH REDUNDANT ISOL MOTOR	PAB	8	AREA 5
628	8	A/B	2SI-860B	SI / P-14A CONT SPRAY PUMP DISCHARGE REDUNDANT ISOL	PAB	8	AREA 5

Prepared by: Timothy J. Dykstra 12/29/95 Checked by: John A. Hinck 1/3/96
 Timothy J. Dykstra / Date John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
629	8	A/B	2SI-860B-M	SI / P-14A CONT SPRAY PUMP DISCH REDUNDANT ISOL MOTOR	PAB	8	AREA 5
630	8	A/B	2SI-860C	SI / P-14B CONT SPRAY PUMP DISCHARGE REDUNDANT ISOL	PAB	8	AREA 5
631	8	A/B	2SI-860C-M	SI / P-14B CONT SPRAY PUMP DISCH REDUNDANT ISOL MOTOR	PAB	8	AREA 5
632	8	A/B	2SI-860D	SI / P-14B CONT SPRAY PUMP DISCHARGE REDUNDANT ISOL	PAB	8	AREA 5
633	8	A/B	2SI-860D-M	SI / P-14B CONT SPRAY PUMP DISCH REDUNDANT ISOL MOTOR	PAB	8	AREA 5
634	8	A	2SI-866A	SI / COLD LEG INJECTION LINE ISOLATION	PAB	8	PIPE 4
635	8	A	2SI-866A-M	SI / COLD LEG INJECTION LINE ISOLATION MOTOR	PAB	8	PIPE 4
636	8	B	2SI-866B	SI / CORE DELUGE INJECTION LINE ISOLATION	PAB	8	PIPE 4
637	8	B	2SI-866B-M	SI / CORE DELUGE INJECTION LINE ISOLATION MOTOR	PAB	8	PIPE 4
638	8	A	2SI-871A	SI / P-14A CONT SPRAY PUMP SUCTION FROM HX-11A RHR HX	PAB	8	AREA 5
639	8	A	2SI-871A-M	SI / P-14A CONT SPRAY PUMP SUCTION FROM HX-11A MOTOR	PAB	8	AREA 5
640	8	B	2SI-871B	SI / P-14B CONT SPRAY PUMP SUCTION FROM HX-11B RHR HX	PAB	8	AREA 5
641	8	B	2SI-871B-M	SI / P-14B CONT SPRAY PUMP SUCTION FROM HX-11B MOTOR	PAB	8	AREA 5
642	8	B	2SI-878A	SI / P-15B SI PUMP R-1 REACTOR VESSEL INJECTION	U2C	21	AREA 11
643	8	B	2SI-878A-M	SI / P-15B SI PUMP R-1 REACTOR VESSEL INJECTION MOTOR	U2C	21	AREA 11
644	8	A	2SI-878B	SI / P-15A SI PUMP LOOP B INJECTION	U2C	21	AREA 11
645	8	A	2SI-878B-M	SI / P-15A SI PUMP LOOP B INJECTION MOTOR	U2C	21	AREA 11
646	8	B	2SI-878C	SI / P-15B SI PUMP R-1 REACTOR VESSEL INJECTION	U2C	21	AREA 11
647	8	B	2SI-878C-M	SI / P-15B SI PUMP R-1 REACTOR VESSEL INJECTION MOTOR	U2C	21	AREA 11
648	8	A	2SI-878D	SI / P-15A SI PUMP LOOP A INJECTION	U2C	21	AREA 11
649	8	A	2SI-878D-M	SI / P-15A SI PUMP LOOP A INJECTION MOTOR	U2C	21	AREA 11
650	8	A	2SI-896A	SI / P-15A SI PUMP SUCTION	PAB	8	AREA 5
651	8	A	2SI-896A-M	SI / P-15A SI PUMP SUCTION MOTOR	PAB	8	AREA 5
652	8	B	2SI-896B	SI / P-15B SI PUMP SUCTION	PAB	8	AREA 5
653	8	B	2SI-896B-M	SI / P-15B SI PUMP SUCTION MOTOR	PAB	8	AREA 5
654	6	A	P-32A	SW / SERVICE WATER PUMP	CWPH	8	
655	6	A	P-32A-M	SW / SERVICE WATER PUMP MOTOR	CWPH	8	

Prepared by :

Timothy J. Dykstra 12/27/95
Timothy J. Dykstra / Date

Checked by :

John A. Hinck 1/2/96
John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
656	6	A	P-32B	SW / SERVICE WATER PUMP	CWPH	8	
657	6	A	P-32B-M	SW / SERVICE WATER PUMP MOTOR	CWPH	8	
658	6	B	P-32C	SW / SERVICE WATER PUMP	CWPH	8	
659	6	B	P-32C-M	SW / SERVICE WATER PUMP MOTOR	CWPH	8	
660	6	B	P-32D	SW / SERVICE WATER PUMP	CWPH	8	
661	6	B	P-32D-M	SW / SERVICE WATER PUMP MOTOR	CWPH	8	
662	6	B	P-32E	SW / SERVICE WATER PUMP	CWPH	8	
663	6	B	P-32E-M	SW / SERVICE WATER PUMP MOTOR	CWPH	8	
664	6	A	P-32F	SW / SERVICE WATER PUMP	CWPH	8	
665	6	A	P-32F-M	SW / SERVICE WATER PUMP MOTOR	CWPH	8	
666	8	A/B	SW-2816	SW / HX-28A SSB AC CHILLER INLET	PAB	26	AREA 5
667	8	A/B	SW-2816-M	SW / HX-28A SSB AC CHILLER INLET MOTOR	PAB	26	AREA 5
668	8	A/B	SW-2817	SW / HX-79 WT AREA CLG COIL INLET	CB	8	AREA 3
669	8	A/B	SW-2817-M	SW / HX-79 WT AREA CLG COIL INLET MOTOR	CB	8	AREA 3
670	7	B	SW-2838	SW / HX-55B1/B2 COOLANT HX OUTLET CONTROL	CB	8	AREA 3
671	7	B	SW-2838-S	SW / HX-55B1/B2 COOLANT HX OUTLET CONTROL SOLENOID	CB	8	AREA 3
672	7	A	SW-2839	SW / HX-55A1/A2 COOLANT HX OUTLET CONTROL	CB	8	AREA 3
673	7	A	SW-2839-S	SW / HX-55A1/A2 COOLANT HX OUTLET CONTROL SOLENOID	CB	8	AREA 3
674	8	A/B	SW-2869	SW / NORTH HEADER TO WEST HEADER	PAB	26	AREA 5
675	8	A/B	SW-2869-M	SW / NORTH HEADER TO WEST HEADER MOTOR	PAB	26	AREA 5
676	8	A/B	SW-2870	SW / SOUTH HEADER TO WEST HEADER	PAB	26	AREA 5
677	8	A/B	SW-2870-M	SW / SOUTH HEADER TO WEST HEADER MOTOR	PAB	26	AREA 5
678	8	A/B	SW-2890	SW / NORTH HEADER TO SOUTH HEADER CROSSCONNECT	CWPH	8	
679	8	A/B	SW-2890-M	SW / NORTH HEADER TO SOUTH HEADER CROSSCONNECT MOTOR	CWPH	8	
680	8	A/B	SW-2891	SW / SOUTH HEADER TO NORTH HEADER CROSSCONNECT	CWPH	8	
681	8	A/B	SW-2891-M	SW / SOUTH HEADER TO NORTH HEADER CROSSCONNECT MOTOR	CWPH	8	
682	7	A/B	SW-LW-61	SW / 1HX-150/2HX-150/HX-142/143 INLET TEMP CONTROL	PAB	26	AREA 5

Prepared by: Timothy J. Dykstra 12/29/95 Checked by: John A. Hinck 1/8/96
 Timothy J. Dykstra / Date John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
683	7	A/B	SW-LW-61-S	SW / 1HX-150/2HX-150/HX-142/143 INLET TEMP CTL SOL	PAB	26	AREA 5
684	7	A/B	SW-LW-62	SW / 1HX-150/2HX-150/HX-142/143 OUTLET TEMP CONTROL	PAB	26	AREA 5
685	7	A/B	SW-LW-62-S	SW / 1HX-150/2HX-150/HX-142/143 OUTLET TEMP CTL SOL	PAB	26	AREA 5
686	8	A/B	1SW-2880	SW / TURBINE BLDG COOLER SERVICE WATER INLET	CB	8	AREA 3
687	8	A/B	1SW-2880-M	SW / TURBINE BLDG COOLER SERVICE WATER INLET MOTOR	CB	8	AREA 3
688	8	A/B	1SW-2907	SW / HX-15A-D CONT RECIRC HX EMERGENCY FCV	PAB	26	AREA 5
689	8	A/B	1SW-2907-M	SW / HX-15A-D CONT RECIRC HX EMERGENCY FCV MOTOR	PAB	26	AREA 5
690	8	A/B	1SW-2908	SW / HX-15A-D CONT RECIRC HX EMERGENCY FCV	PAB	26	AREA 5
691	8	A/B	1SW-2908-M	SW / HX-15A-D CONT RECIRC HX EMERGENCY FCV MOTOR	PAB	26	AREA 5
692	8	A/B	2SW-2880	SW / TURBINE BLDG COOLER SERVICE WATER INLET	CB	8	AREA 3
693	8	A/B	2SW-2880-M	SW / TURBINE BLDG COOLER SERVICE WATER INLET MOTOR	CB	8	AREA 3
694	8	A/B	2SW-2907	SW / HX-15A-D CONT RECIRC HX EMERGENCY FCV	PAB	26	AREA 5
695	8	A/B	2SW-2907-M	SW / HX-15A-D CONT RECIRC HX EMERGENCY FCV MOTOR	PAB	26	AREA 5
696	8	A/B	2SW-2908	SW / HX-15A-D CONT RECIRC HX EMERGENCY FCV	PAB	26	AREA 5
697	8	A/B	2SW-2908-M	SW / HX-15A-D CONT RECIRC HX EMERGENCY FCV MOTOR	PAB	26	AREA 5
698	10	A	W-85	VNBI / PAB BATTERY AND INVERTER ROOM VENT FAN	PAB	35	AREA 6
699	10	A	W-85-M	VNBI / PAB BATTERY AND INVERTER ROOM VENT FAN MOTOR	PAB	35	AREA 6
700	10	B	W-86	VNBI / PAB BATTERY AND INVERTER ROOM VENT FAN	PAB	35	AREA 6
701	10	B	W-86-M	VNBI / PAB BATTERY AND INVERTER ROOM VENT FAN MOTOR	PAB	35	AREA 6
702	10	A/B	1W-1A1	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN	U1C	66	AREA 7
703	10	A/B	1W-1A1-M	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN MOTOR	U1C	66	AREA 7
704	10	A/B	1W-1B1	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN	U1C	46	AREA 7
705	10	A/B	1W-1B1-M	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN MOTOR	U1C	46	AREA 7
706	10	A/B	1W-1C1	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN	U1C	21	AREA 7
707	10	A/B	1W-1C1-M	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN MOTOR	U1C	21	AREA 7
708	10	A/B	1W-1D1	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN	U1C	21	AREA 7
709	10	A/B	1W-1D1-M	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN MOTOR	U1C	21	AREA 7

Prepared by: Timothy J. Dykstra 12/27/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/3/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
710	10	A/B	2W-1A1	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN	U2C	66	AREA 11
711	10	A/B	2W-1A1-M	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN MOTOR	U2C	66	AREA 11
712	10	A/B	2W-1B1	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN	U2C	66	AREA 11
713	10	A/B	2W-1B1-M	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN MOTOR	U2C	66	AREA 11
714	10	A/B	2W-1C1	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN	U2C	46	AREA 11
715	10	A/B	2W-1C1-M	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN MOTOR	U2C	46	AREA 11
716	10	A/B	2W-1D1	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN	U2C	21	AREA 11
717	10	A/B	2W-1D1-M	VNCC / CONTAINMENT ACCIDENT RECIRCULATION FAN MOTOR	U2C	21	AREA 11
718	10	A	VNDG-4883	VNDG / W-12A & B G-01 RM EXHAUST FANS FIRE CURTAIN	CB	26	AREA 3
719	10	A	VNDG-4883A-S	VNDG / W-12A G-01 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
720	10	A	VNDG-4883B-S	VNDG / W-12A G-01 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
721	10	A	VNDG-4883C-S	VNDG / W-12A G-01 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
722	10	A	VNDG-4883D-S	VNDG / W-12B G-01 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
723	10	A	VNDG-4883E-S	VNDG / W-12B G-01 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
724	10	A	VNDG-4883F-S	VNDG / W-12B G-01 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
725	10	A	VNDG-4883G-S	VNDG / W-12B G-01 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
726	10	A	VNDG-4883H-S	VNDG / W-12B G-01 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
727	10	B	VNDG-4884	VNDG / W-12C & D G-01 RM EXHAUST FANS FIRE CURTAIN	CB	26	AREA 3
728	10	B	VNDG-4884A-S	VNDG / W-12C G-02 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
729	10	B	VNDG-4884B-S	VNDG / W-12C G-02 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
730	10	B	VNDG-4884C-S	VNDG / W-12C G-02 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
731	10	B	VNDG-4884D-S	VNDG / W-12C G-02 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
732	10	B	VNDG-4884E-S	VNDG / W-12D G-02 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
733	10	B	VNDG-4884F-S	VNDG / W-12D G-02 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
734	10	B	VNDG-4884G-S	VNDG / W-12D G-02 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
735	10	B	VNDG-4884H-S	VNDG / W-12D G-02 RM EXHAUST FAN FIRE CURTAIN SOLENOID	CB	26	AREA 3
736	9	A	W-12A	VNDG / G-01 ROOM EXHAUST FAN	CB	8	AREA 3

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/8/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

RELAY REVIEW SSEL

Line No.	Equip Class	Train	Equipment ID	System / Equipment Description	Building	Floor Elev	Location
737	9	A	W-12A-M	VNDG / G-01 ROOM EXHAUST FAN MOTOR	CB	8	AREA 3
738	9	A	W-12B	VNDG / G-01 ROOM EXHAUST FAN	CB	8	AREA 3
739	9	A	W-12B-M	VNDG / G-01 ROOM EXHAUST FAN MOTOR	CB	8	AREA 3
740	9	B	W-12C	VNDG / G-02 ROOM EXHAUST FAN	CB	8	AREA 3
741	9	B	W-12C-M	VNDG / G-02 ROOM EXHAUST FAN MOTOR	CB	8	AREA 3
742	9	B	W-12D	VNDG / G-02 ROOM EXHAUST FAN	CB	8	AREA 3
743	9	B	W-12D-M	VNDG / G-02 ROOM EXHAUST FAN MOTOR	CB	8	AREA 3
744	14	A	83/DY-0C	Y / DY-0C WHITE Y-203 INVERTER STATIC TRANSFER SW	PAB	26	AREA 6
745	14	B	83/DY-0D	Y / DY-0D YELLOW Y-204 INVERTER STATIC TRANSFER SW	PAB	26	AREA 6
746	16	A	DY-0A	Y / RED 125V DC/120V AC ALTERNATE INVERTER	CB	26	AREA 3
747	16	B	DY-0B	Y / BLUE 125V DC/120V AC ALTERNATE INVERTER	CB	26	AREA 3
748	14	A	1-83/DY-03	Y / 1DY-03 WHITE 1Y-203 INVERTER STATIC TRANSFER SW	PAB	26	AREA 6
749	14	B	1-83/DY-04	Y / 1DY-04 YELLOW 1Y-204 INVERTER STATIC TRANSFER SW	PAB	26	AREA 6
750	16	A	1DY-01	Y / RED 125V DC/120V AC INVERTER	CB	26	AREA 3
751	16	B	1DY-02	Y / BLUE 125V DC/120V AC INVERTER	CB	26	AREA 3
752	14	A	2-83/DY-03	Y / 2DY-03 WHITE 2Y-203 INVERTER STATIC TRANSFER SW	PAB	26	AREA 6
753	14	B	2-83/DY-04	Y / 2DY-04 YELLOW 2Y-204 INVERTER STATIC TRANSFER SW	PAB	26	AREA 6
754	16	A	2DY-01	Y / RED 125V DC/120V AC INVERTER	CB	26	AREA 3
755	16	B	2DY-02	Y / BLUE 125V DC/120V AC INVERTER	CB	26	AREA 3

Prepared by: Timothy J. Dykstra 12/29/95 / Date
 Timothy J. Dykstra / Date
 Checked by: John A. Hinck 1/8/96 / Date
 John A. Hinck / Date



RELAY EVALUATION REPORT

ASSOCIATED RELAY LIST

The Associated Relay List (ARL) on the following pages provides a listing of the relays associated with the PBNP safe shutdown equipment. The list is sorted by "System", then by "R-SSEL Component" and then by "Relay ID". This list provides the system and R-SSEL component that the relay is associated with, and then the relay make and model. The "location" field provides the location of the relay as indicated on the corresponding electrical schematic drawing. The "relay cabinet id" field provides the equipment identification number corresponding to the host component that was verified during the seismic walkdowns. The "screening code" field is the code used by the relay analyst to indicate the results of the functional screening. Some screening codes are followed by a number. This number corresponds to the note in Table B-2 at the end of this appendix. The different screening codes are:

- SS# seismic screening required - followed by a note # when required
- CA# chatter acceptable - followed by a note # when required
- SWGR switchgear "rule of the box" applies

The "screening" field provides screening status used by the seismic capability engineer to perform the seismic capacity screening.



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1	125VDC	D-07	1B42-391	CONTACTOR	1B42-391	1B39-1	ELEM 550	SS	Relay GERS or Specific Qualification
2	125VDC	D-07	1SI-10X1	ASEA RXMA1	2C-20	2C-20	ELEM 1635	SS	Relay GERS or Specific Qualification
3	125VDC	D-07	27-AC/D-07	W BF44	D-07	D-07	BECH E-6 SH. 1	CA4	Circuit/Relay Malfunction Acceptable
4	125VDC	D-07	27-DC/D-07		D-07	D-07	BECH E-6 SH. 1	CA4	Circuit/Relay Malfunction Acceptable
5	125VDC	D-07	2SI-10X1	ASEA RXMA1	2C-20	2C-20	ELEM 1635	SS	Relay GERS or Specific Qualification
6	125VDC	D-07	42Y-1391	SQD 8501 HO-33	1B42-391	1B42-391	ELEM 550	SS	Relay GERS or Specific Qualification
7	125VDC	D-07	64/D-07		D-07	D-07	BECH E-6 SH. 1	CA4	Circuit/Relay Malfunction Acceptable
8	125VDC	D-08	1SI-20X1	ASEA RXMA1	2C-20	2C-20	ELEM 1635	SS	Relay GERS or Specific Qualification
9	125VDC	D-08	27-AC/D-08	W BF44	D-08	D-08	BECH E-6 SH. 1	CA4	Circuit/Relay Malfunction Acceptable
10	125VDC	D-08	27-DC/D-08		D-08	D-08	BECH E-6 SH. 1	CA4	Circuit/Relay Malfunction Acceptable
11	125VDC	D-08	2B42-491	CONTACTOR	2B42-491	2B49-1	ELEM 553	SS	Relay GERS or Specific Qualification
12	125VDC	D-08	2SI-20X1	ASEA RXMA1	2C-20	2C-20	ELEM 1635	SS	Relay GERS or Specific Qualification
13	125VDC	D-08	42Y-2491	SQD 8501 HO-33	2B42-491	2B42-491	ELEM 553	SS	Relay GERS or Specific Qualification
14	125VDC	D-08	64/D-08		D-08	D-08	BECH E-6 SH. 1	CA4	Circuit/Relay Malfunction Acceptable
15	125VDC	D-09	1B42-491	CONTACTOR	1B42-491	1B49-1	ELEM 552	SS	Relay GERS or Specific Qualification
16	125VDC	D-09	27-AC/D-09	W BF44	D-09	D-09	BECH E-6 SH.3	CA4	Circuit/Relay Malfunction Acceptable
17	125VDC	D-09	27-DC/D-09		D-09	D-09	BECH E-6 SH.3	CA4	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
18	125VDC	D-09	2B42-391	CONTACTOR	2B42-391	2B39-1	ELEM 551	SS	Relay GERS or Specific Qualification
19	125VDC	D-09	42X-1491	ASEA RXMA1	2C-20	2C-20	ELEM 552	SS	Relay GERS or Specific Qualification
20	125VDC	D-09	42X-2391	ASEA RXMA1	2C-20	2C-20	ELEM 551	SS	Relay GERS or Specific Qualification
21	125VDC	D-09	42Y-1491	SQD 8501 HO-33	1B42-491	1B42-491	ELEM 552	SS	Relay GERS or Specific Qualification
22	125VDC	D-09	42Y-2391	SQD 8501 HO-33	2B42-391	2B42-391	ELEM 551	SS	Relay GERS or Specific Qualification
23	125VDC	D-09	64/D-09		D-09	D-09	BECH E-6 SH.3	CA4	Circuit/Relay Malfunction Acceptable
24	125VDC	D-107	27-AC/D-107		D-107	D-107	BECH E-6 SH.2	CA4	Circuit/Relay Malfunction Acceptable
25	125VDC	D-107	27-DC/D-107		D-107	D-107	BECH E-6 SH.2	CA4	Circuit/Relay Malfunction Acceptable
26	125VDC	D-107	2B42-394	CONTACTOR	2B42-394	2B39-4	ELEM 554	SS	Relay GERS or Specific Qualification
27	125VDC	D-107	42Y-2394	SQD 8501 HO-33	2B42-394	2B42-394	ELEM 554	SS	Relay GERS or Specific Qualification
28	125VDC	D-107	59-DC/D-107		D-107	D-107	BECH E-6 SH.2	CA4	Circuit/Relay Malfunction Acceptable
29	125VDC	D-107	64/D-107		D-107	D-107	BECH E-6 SH.2	CA4	Circuit/Relay Malfunction Acceptable
30	125VDC	D-108	1B42-494	CONTACTOR	1B42-494	1B49-4	ELEM 1635	SS	Relay GERS or Specific Qualification
31	125VDC	D-108	27-AC/D-108		D-108	D-108	BECH E-6 SH.2	CA4	Circuit/Relay Malfunction Acceptable
32	125VDC	D-108	27-DC/D-108		D-108	D-108	BECH E-6 SH.2	CA4	Circuit/Relay Malfunction Acceptable
33	125VDC	D-108	42Y-1494	SQD 8501 HO-33	1B42-494	1B42-494	ELEM 1635	SS	Relay GERS or Specific Qualification
34	125VDC	D-108	59-DC/D-108		D-108	D-108	BECH E-6 SH.2	CA4	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
35	125VDC	D-108	64/D-108		D-108	D-108	BECH E-6 SH. 2	CA4	Circuit/Relay Malfunction Acceptable
36	125VDC	D-109	1B42-3212H	CONTACTOR	1B42-3212H	1B42-3212H	ELEM 555	SS	Relay GERS or Specific Qualification
37	125VDC	D-109	27-AC/D-109		D-109	D-109	BECH E-6 SH. 2	CA4	Circuit/Relay Malfunction Acceptable
38	125VDC	D-109	27-DC/D-109		D-109	D-109	BECH E-6 SH. 2	CA4	Circuit/Relay Malfunction Acceptable
39	125VDC	D-109	2B42-4212B	CONTACTOR	2B42-4212B	2B42-4212B	ELEM 556	SS	Relay GERS or Specific Qualification
40	125VDC	D-109	42X-13212H	ASEA RXMA1	2C-20	2C-20	ELEM 555	SS	Relay GERS or Specific Qualification
41	125VDC	D-109	42X-24212B	ASEA RXMA1	2C-20	2C-20	ELEM 556	SS	Relay GERS or Specific Qualification
42	125VDC	D-109	42Y-13212H	SQD 8501 HO-33	1B-32	1B32-12H	ELEM 555	SS	Relay GERS or Specific Qualification
43	125VDC	D-109	42Y-24212B	SQD 8501 HO-33	2B-42	2B42-12B	ELEM 556	SS	Relay GERS or Specific Qualification
44	125VDC	D-109	59-DC/D-109		D-109	D-109	BECH E-6 SH.2	CA4	Circuit/Relay Malfunction Acceptable
45	125VDC	D-109	64/D-109		D-109	D-109	BECH E-6 SH. 2	CA4	Circuit/Relay Malfunction Acceptable
46	4160V	1A-05	1-74/A05FM	LINE ELEC. AGH1D	1A-05	1A-05	ELEM 268	CA4	Circuit/Relay Malfunction Acceptable
47	4160V	1A-05	1-86/A05	ELECTROSWITCH SERIES 24 CATALOG 7807D	1A-05	1A-05	ELEM 268	SS	Relay GERS or Specific Qualification
48	4160V	1A-05	1-86X/A05	W SG (DE,NO)	1A-05	1A-05	ELEM 268	SS	Relay GERS or Specific Qualification
49	4160V	1A-05	1-87A/A05	W CA-16	1A-05	1A-05	ELEM 268	SS	Relay GERS or Specific Qualification
50	4160V	1A-05	1-87B/A05	W CA-16	1A-05	1A-05	ELEM 268	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
51	4160V	1A-05	1-87C/A05	W CA-16	1A-05	1A-05	ELEM 268	SS	Relay GERS or Specific Qualification
52	4160V	1A-06	1-74/A06FM	LINE ELEC. AGH1D	1A-06	1A-06	ELEM 268	CA4	Circuit/Relay Malfunction Acceptable
53	4160V	1A-06	1-86/A06	W WL	1A-06	1A-06	ELEM 268	SS	Relay GERS or Specific Qualification
54	4160V	1A-06	1-86X/A06	W SG (DE,NO)	1A-06	1A-06	ELEM 268	SS	Relay GERS or Specific Qualification
55	4160V	1A-06	1-87A/A06	W CA-16	1A-06	1A-06	ELEM 268	SS	Relay GERS or Specific Qualification
56	4160V	1A-06	1-87B/A06	W CA-16	1A-06	1A-06	ELEM 268	SS	Relay GERS or Specific Qualification
57	4160V	1A-06	1-87C/A06	W CA-16	1A-06	1A-06	ELEM 268	SS	Relay GERS or Specific Qualification
58	4160V	1A52-58	50G/1A52-58	W ITH	1A-05	1A52-58	ELEM 200	SS	Relay GERS or Specific Qualification
59	4160V	1A52-58	51/50A/1A52-58	W CO	1A-05	1A52-58	ELEM 200	SS	Relay GERS or Specific Qualification
60	4160V	1A52-58	51/50B/1A52-58	W CO	1A-05	1A52-58	ELEM 200	SS	Relay GERS or Specific Qualification
61	4160V	1A52-58	51/50C/1A52-58	W CO	1A-05	1A52-58	ELEM 200	SS	Relay GERS or Specific Qualification
62	4160V	1A52-58	86/1A52-58	W MG-6	1A-05	1A52-58	ELEM 256	SS16	Relay GERS or Specific Qualification
63	4130V	1A52-58	HC-252/1A52-58	AMMETER	1A-05	1A52-58	ELEM 200	CA3	Circuit/Relay Malfunction Acceptable
64	4160V	1A52-58	X/1A52-58	W Life Line Contactor	1A-05	1A52-58	ELEM 256	SWGR	Relays directly control Switchgear
65	4160V	1A52-58	Y/1A52-58	W Life Line Contactor	1A-05	1A52-58	ELEM 256	SWGR	Relays directly control Switchgear
66	4160V	1A52-61	X/1A52-61	W Life Line Contactor	1A-05	1A52-61	ELEM 266	SWGR	Relays directly control Switchgear
67	4160V	1A52-61	Y/1A52-61	W Life Line Contactor	1A-05	1A52-61	ELEM 266	SWGR	Relays directly control Switchgear



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
68	4160V	1A52-64	50G/1A52-64	W ITH	1A-06	1A52-64	ELEM 200	SS	Relay GERS or Specific Qualification
69	4160V	1A52-64	51/50A/1A52-64	W CO	1A-06	1A52-64	ELEM 200	SS	Relay GERS or Specific Qualification
70	4160V	1A52-64	51/50B/1A52-64	W CO	1A-06	1A52-64	ELEM 200	SS	Relay GERS or Specific Qualification
71	4160V	1A52-64	51/50C/1A52-64	W CO	1A-06	1A52-64	ELEM 200	SS	Relay GERS or Specific Qualification
72	4160V	1A52-64	86/1A52-64	W MG-6	1A-06	1A52-64	ELEM 256	SS16	Relay GERS or Specific Qualification
73	4160V	1A52-64	HC-252/1A52-64	AMMETER	1A-06	1A52-64	ELEM 200	CA3	Circuit/Relay Malfunction Acceptable
74	4160V	1A52-64	X/1A52-64	W Life Line Contactor	1A-06	1A52-64	ELEM 256	SWGR	Relays directly control Switchgear
75	4160V	1A52-64	Y/1A52-64	W Life Line Contactor	1A-06	1A52-64	ELEM 256	SWGR	Relays directly control Switchgear
76	4160V	2A-05	2-74/A05FM	LINE ELEC. AGH1D	2A-05	2A-05	ELEM 298	CA4	Circuit/Relay Malfunction Acceptable
77	4160V	2A-05	2-86/A05	W WL	2A-05	2A-05	ELEM 298	SS	Relay GERS or Specific Qualification
78	4160V	2A-05	2-86X/A05	W SG (DE,NO)	2A-05	2A-05	ELEM 298	SS	Relay GERS or Specific Qualification
79	4160V	2A-05	2-87A/A05	W CA-16	2A-05	2A-05	ELEM 298	SS	Relay GERS or Specific Qualification
80	4160V	2A-05	2-87B/A05	W CA-16	2A-05	2A-05	ELEM 298	SS	Relay GERS or Specific Qualification
81	4160V	2A-05	2-87C/A05	W CA-16	2A-05	2A-05	ELEM 298	SS	Relay GERS or Specific Qualification
82	4160V	2A-06	2-74/A06FM	LINE ELEC. AGH1D	2A-06	2A-06	ELEM 298	CA4	Circuit/Relay Malfunction Acceptable
83	4160V	2A-06	2-86/A06	W WL	2A-06	2A-06	ELEM 298	SS	Relay GERS or Specific Qualification
84	4160V	2A-06	2-86X/A06	W SG (DE,NO)	2A-06	2A-06	ELEM 298	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
85	4160V	2A-06	2-87A/A06	W CA-16	2A-06	2A-06	ELEM 298	SS	Relay GERS or Specific Qualification
86	4160V	2A-06	2-87B/A06	W CA-16	2A-06	2A-06	ELEM 298	SS	Relay GERS or Specific Qualification
87	4160V	2A-06	2-87C/A06	W CA-16	2A-06	2A-06	ELEM 298	SS	Relay GERS or Specific Qualification
88	4160V	2A52-69	50G/2A52-69	W ITH	2A-06	2A52-69	ELEM 200	SS	Relay GERS or Specific Qualification
89	4160V	2A52-69	51/50A/2A52-69	W CO	2A-06	2A52-69	ELEM 200	SS	Relay GERS or Specific Qualification
90	4160V	2A52-69	51/50B/2A52-69	W CO	2A-06	2A52-69	ELEM 200	SS	Relay GERS or Specific Qualification
91	4160V	2A52-69	51/50C/2A52-69	W CO	2A-06	2A52-69	ELEM 200	SS	Relay GERS or Specific Qualification
92	4160V	2A52-69	86/2A52-69	W MG-6	2A-06	2A52-69	ELEM 286	SS16	Relay GERS or Specific Qualification
93	4160V	2A52-69	HC-252/2A52-69	AMMETER	2A-06	2A52-69	ELEM 200	CA3	Circuit/Relay Malfunction Acceptable
94	4160V	2A52-69	X/2A52-69	W Life Line Contactor	2A-06	2A52-69	ELEM 286	SWGR	Relays directly control Switchgear
95	4160V	2A52-69	Y/2A52-69	W Life Line Contactor	2A-06	2A52-69	ELEM 286	SWGR	Relays directly control Switchgear
96	4160V	2A52-72	X/2A52-72	W Life Line Contactor	2A-06	2A52-72	ELEM 296	SWGR	Relays directly control Switchgear
97	4160V	2A52-72	Y/2A52-72	W Life Line Contactor	2A-06	2A52-72	ELEM 296	SWGR	Relays directly control Switchgear
98	4160V	2A52-75	50G/2A52-75	W ITH	2A-05	2A52-75	ELEM 200	SS	Relay GERS or Specific Qualification
99	4160V	2A52-75	51/50A/2A52-75	W CO	2A-05	2A52-75	ELEM 200	SS	Relay GERS or Specific Qualification
100	4160V	2A52-75	51/50B/2A52-75	W CO	2A-05	2A52-75	ELEM 200	SS	Relay GERS or Specific Qualification
101	4160V	2A52-75	51/50C/2A52-75	W CO	2A-05	2A52-75	ELEM 200	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
102	4160V	2A52-75	86/2A52-75	W MG-6	2A-05	2A52-75	ELEM 286	SS16	Relay GERS or Specific Qualification
103	4160V	2A52-75	HC-252/2A52-75	AMMETER	2A-05	2A52-75	ELEM 200	CA3	Circuit/Relay Malfunction Acceptable
104	4160V	2A52-75	X/2A52-75	W Life Line Contactor	2A-05	2A52-75	ELEM 286	SWGR	Relays directly control Switchgear
105	4160V	2A52-75	Y/2A52-75	W Life Line Contactor	2A-05	2A52-75	ELEM 286	SWGR	Relays directly control Switchgear
106	480V	1B-03	1-74/B03FM		C-01-1(2)C-04	C-01	ELEM 342	CA4	Circuit/Relay Malfunction Acceptable
107	480V	1B-03	1-86/B03	W WL	C-01-1(2)C-04	C-01	ELEM 342	SS	Relay GERS or Specific Qualification
108	480V	1B-03	1-86X/B03	W Nbfd65NR	1B-03	1B-03	ELEM 342A	SS	Relay GERS or Specific Qualification
109	480V	1B-04	1-74/B04FM		C-01-1(2)C-04	C-01	ELEM 343	CA4	Circuit/Relay Malfunction Acceptable
110	480V	1B-04	1-86/B04	W WL	C-01-1(2)C-04	C-01	ELEM 343	SS	Relay GERS or Specific Qualification
111	480V	1B-04	1-86X/B04	W Nbfd65NR	1B-04	1B-04	ELEM 342A	SS	Relay GERS or Specific Qualification
112	480V	1B52-11B	X/1B52-11B	W Type M	1B-03	1B52-11B	ELEM 329	SWGR	Relays directly control Switchgear
113	480V	1B52-12A	74/1B52-12A	W BFD22S	C-01-1(2)C-04	1C-03	ELEM 321	CA4	Circuit/Relay Malfunction Acceptable
114	480V	1B52-12A	X/1B52-12A	W Type M	1B-03	1B52-12A	ELEM 321	SWGR	Relays directly control Switchgear
115	480V	1B52-12B	86/1B52-12B	W MG-6	1B-03	1B52-12B	ELEM 324	SS16	Relay GERS or Specific Qualification
116	480V	1B52-13A	1-62/P2A	AGASTAT 2412PC	1B-03	1B52-13A	ELEM 316	SS	Relay GERS or Specific Qualification
117	480V	1B52-13A	86/1B52-13A	W MG-6	1B-03	1B52-13A	ELEM 316	CA16	Circuit/Relay Malfunction Acceptable
118	480V	1B52-13A	ETIX/1B52-13A	W BFD11S	1N-04	1N-04	ELEM 316	CA3	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
119	480V	1B52-13A	X/1B52-13A	W Type M	1B-03	1B52-13A	ELEM 316	SWGR	Relays directly control Switchgear
120	480V	1B52-13B	1-62/P2B	AGASTAT 2412PC	1B-03	1B52-13B	ELEM 316	SS	Relay GERS or Specific Qualification
121	480V	1B52-13B	86/1B52-13B	W MG-6	1B-03	1B52-13B	ELEM 316	SS16	Relay GERS or Specific Qualification
122	480V	1B52-13B	ETIX/1B52-13B	W NBF11S	1N-04	1N-04	ELEM 316	CA3	Circuit/Relay Malfunction Acceptable
123	480V	1B52-13B	X/1B52-13B	W Type M	1B-03	1B52-13B	ELEM 316	SWGR	Relays directly control Switchgear
124	480V	1B52-13C	X/1B52-13C	W Type M	1B-03	1B52-13C	ELEM 329	SWGR	Relays directly control Switchgear
125	480V	1B52-14A	74/1B52-14A	W BFD22S	C-01-1(2)C-04	C-01	ELEM 322	CA4	Circuit/Relay Malfunction Acceptable
126	480V	1B52-14A	X/1B52-14A	W Type M	1B-03	1B52-14A	ELEM 322	SWGR	Relays directly control Switchgear
127	480V	1B52-14B	X/1B52-14B	W Type M	1B-03	1B52-14B	ELEM 356	SWGR	Relays directly control Switchgear
128	480V	1B52-16B	74/1B52-16B	W BFD22S	1B-03	1B52-16B	ELEM 351	CA4	Circuit/Relay Malfunction Acceptable
129	480V	1B52-16B	X/1B52-16B	W Type M	1B-03	1B52-16B	ELEM 351	SWGR	Relays directly control Switchgear
130	480V	1B52-17B	74/1B52-17B	W BFD22S	1B-04	1B52-17B	ELEM 352	CA4	Circuit/Relay Malfunction Acceptable
131	480V	1B52-17B	X/1B52-17B	W Type M	1B-04	1B52-17B	ELEM 352	SWGR	Relays directly control Switchgear
132	480V	1B52-19A	74/1B52-19A	W BFD22S	C-01-1(2)C-04	C-01	ELEM 322	CA4	Circuit/Relay Malfunction Acceptable
133	480V	1B52-19A	X/1B52-19A	W Type M	1B-04	1B52-19A	ELEM 322	SWGR	Relays directly control Switchgear
134	480V	1B52-20A	1-62/P2C	AGASTAT 2412PC	1B-04	1B52-20A	ELEM 316A	SS	Relay GERS or Specific Qualification
135	480V	1B52-20A	86/1B52-20A	W MG-6	1B-04	1B52-20A	ELEM 316A	SS16	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
136	480V	1B52-20A	L7IX/1B52-20A	ASEA RXMA1	1N-11	1N-11	ELEM 316A	CA3	Circuit/Relay Malfunction Acceptable
137	480V	1B52-20A	X/1B52-20A	W Type M	1B-04	1B52-20A	ELEM 316A	SWGR	Relays directly control Switchgear
138	480V	1B52-21A	74/1B52-21A	W BFD22S	C-01-1(2)C-04	1C-03	ELEM 321	CA4	Circuit/Relay Malfunction Acceptable
139	480V	1B52-21A	X/1B52-21A	W Type M	1B-04	1B52-21A	ELEM 321	SWGR	Relays directly control Switchgear
140	480V	1B52-21B	86/1B52-21B	W MG-6	1B-04	1B52-21B	ELEM 324A	SS16	Relay GERS or Specific Qualification
141	480V	1B52-22A	TR	W BFD44S	N-06	N-06	ELEM 366	SS	Relay GERS or Specific Qualification
142	480V	1B52-23A	X/1B52-23A	W Type M	1B-04	1B52-23A	ELEM 329	SWGR	Relays directly control Switchgear
143	480V	1B52-23C	X/1B52-23C	W Type M	1B-04	1B52-23C	ELEM 356	SWGR	Relays directly control Switchgear
144	480V	1B52-24C	X/1B52-24C	W Type M	1B-04	1B52-24C	ELEM 329	SWGR	Relays directly control Switchgear
145	480V	1B52-3213L	1B42-3213L	CONTACTOR	1B-32	1B-32	ELEM 538	SS	Relay GERS or Specific Qualification
146	480V	1B52-3213L	27-13213L	W BF22F	1B-32	1B-32	ELEM 538	SS	Relay GERS or Specific Qualification
147	480V	2B-03	2-74/B03FM		C-01-1(2)C-04	C-01	ELEM 344	CA4	Circuit/Relay Malfunction Acceptable
148	480V	2B-03	2-86/B03	W WL	C-01-1(2)C-04	C-01	ELEM 344	SS	Relay GERS or Specific Qualification
149	480V	2B-03	2-86X/B03	W NBDF65NR	2B-0?	2B-03	ELEM 344A	SS	Relay GERS or Specific Qualification
150	480V	2B-04	2-74/B04FM		C-01-1(2)C-04	C-01	ELEM 345	CA4	Circuit/Relay Malfunction Acceptable
151	480V	2B-04	2-86/B04	W WL	C-01-1(2)C-04	C-01	ELEM 345	SS	Relay GERS or Specific Qualification
152	480V	2B-04	2-86X/B04	W NBDF65NR	2B-04	2B-04	ELEM 344A	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
153	480V	2B52-25B	74/2B52-25B	W BFD22S	C-01-1(2)C-04	C-02	ELEM 382	CA4	Circuit/Relay Malfunction Acceptable
154	480V	2B52-25B	X/2B52-25B	W Type M	2B-04	2B52-25B	ELEM 382	SWGR	Relays directly control Switchgear
155	480V	2B52-27A	74/2B52-27A	W BFD22S	C-01-1(2)C-04	C-01	ELEM 338	CA4	Circuit/Relay Malfunction Acceptable
156	480V	2B52-27A	X/2B52-27A	W Type M	2B-04	2B52-27A	ELEM 338	SWGR	Relays directly control Switchgear
157	480V	2B52-28A	2-62/P2C		2B-04	2B52-28A	ELEM 333	CA14	Circuit/Relay Malfunction Acceptable
158	480V	2B52-28A	2CX/P2C	W NBFD11S	2N-11	2N-11	ELEM 333	CA3	Circuit/Relay Malfunction Acceptable
159	480V	2B52-28A	86/2B52-28A	W MG-6	2B-04	2B52-28A	ELEM 333	SS16	Relay GERS or Specific Qualification
160	480V	2B52-28A	X/2B52-28A	W Type M	2B-04	2B52-28A	ELEM 333	SWGR	Relays directly control Switchgear
161	480V	2B52-29A	74/2B52-29A	W BFD22S	C-01-1(2)C-04	2C-03	ELEM 337	CA4	Circuit/Relay Malfunction Acceptable
162	480V	2B52-29A	X/2B52-29A	W Type M	2B-04	2B52-29A	ELEM 337	SWGR	Relays directly control Switchgear
163	480V	2B52-29B	86/2B52-29B	W MG-6	2B-04	2B52-29B	ELEM 340	SS16	Relay GERS or Specific Qualification
164	480V	2B52-29C	2CR		K-3B	C-54	ELEM 366A	CA21	Circuit/Relay Malfunction Acceptable
165	480V	2B52-29C	3CR	PB KRP11D	K-3B	C-54	ELEM 366A	SS	Relays mounted on Diesel Generator or Air Compressor
166	480V	2B52-31A	X/2B52-31A	W Type M	2B-04	2B52-31A	ELEM 329	SWGR	Relays directly control Switchgear
167	480V	2B52-31B	X/2B52-31B	W Type M	2B-04	2B52-31B	ELEM 329	SWGR	Relays directly control Switchgear
168	480V	2B52-32C	X/2B52-32C	W Type M	2B-04	2B52-32C	ELEM 386	SWGR	Relays directly control Switchgear
169	480V	2B52-33C	X/2B52-33C	W Type M	2B-03	2B52-33C	ELEM 371	SWGR	Relays directly control Switchgear



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
170	480V	2B52-35C	X/2B52-35C	W Type M	2B-03	2B52-35C	ELEM 329	SWGR	Relays directly control Switchgear
171	480V	2B52-36A	74/2B52-36A	W BFD22S	C-01-1(2)C-04	2C-03	ELEM 337	CA4	Circuit/Relay Malfunction Acceptable
172	480V	2B52-36A	X/2B52-36A	W Type M	2B-03	2B52-36A	ELEM 337	SWGR	Relays directly control Switchgear
173	480V	2B52-36B	86/2B52-36B	W MG-6	2B-03	2B52-36B	ELEM 340A	SS16	Relay GERS or Specific Qualification
174	480V	2B52-36C	X/2B52-36C	W Type M	2B-03	2B52-36C	ELEM 329	SWGR	Relays directly control Switchgear
175	480V	2B52-37A	2-62/P2A	AGASTAT 2412PC	2B-03	2B52-37A	ELEM 335	SS	Relay GERS or Specific Qualification
176	480V	2B52-37A	86/2B52-37A	W MG-6	2B-03	2B52-37A	ELEM 335	SS16	Relay GERS or Specific Qualification
177	480V	2B52-37A	ETIX/2B52-37A	ASCO 2126311G	2N-04	2N-04	ELEM 335	CA3	Circuit/Relay Malfunction Acceptable
178	480V	2B52-37A	X/2B52-37A	W Type M	2B-03	2B52-37A	ELEM 335	SWGR	Relays directly control Switchgear
179	480V	2B52-37B	2-62/P2B	AGASTAT 2412PC	2B-03	2B52-37B	ELEM 335	SS	Relay GERS or Specific Qualification
180	480V	2B52-37B	86/2B52-37B	W MG-6	2B-03	2B52-37B	ELEM 335	SS16	Relay GERS or Specific Qualification
181	480V	2B52-37B	ETIX/2B52-37B	ASCO 2126311G	2N-04	2N-04	ELEM 335	CA3	Circuit/Relay Malfunction Acceptable
182	480V	2B52-37B	X/2B52-37B	W Type M	2B-03	2B52-37B	ELEM 335	SWGR	Relays directly control Switchgear
183	480V	2B52-38A	74/2B52-38A	W BFD22S	C-01-1(2)C-04	C-01	ELEM 338	CA4	Circuit/Relay Malfunction Acceptable
184	480V	2B52-38A	X/2B52-38A	W Type M	2B-03	2B52-38A	ELEM 338	SWGR	Relays directly control Switchgear
185	480V	2B52-38B	X/2B52-38B	W Type M	2B-03	2B52-38B	ELEM 386	SWGR	Relays directly control Switchgear
186	480V	2B52-40B	74/2B52-40B	W BFD22S	C-01-1(2)C-04	C-02	ELEM 381	CA4	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
187	480V	2B52-40B	X/2B52-40B	W Type M	2B-03	2B52-40B	ELEM 381	SWGR	Relays directly control Switchgear
188	480V	2B52-4212M	27-24212M	W BF22F	2B-42	2B-42	ELEM 538	SS	Relay GERS or Specific Qualification
189	480V	2B52-4212M	2B42-4212M	CONTACTOR	2B-42	2B42-12M	ELEM 538	SS	Relay GERS or Specific Qualification
190	AF	1AF-4002-S	1-62/NC005	AGASTAT 2422PE	C-01-1(2)C-04	1C-03	ELEM 816	CA5	Circuit/Relay Malfunction Acceptable
191	AF	1AF-4002-S	1-74/2082	W NBFD22	C-01-1(2)C-04	1C-03	ELEM 816	CA4	Circuit/Relay Malfunction Acceptable
192	AF	1AF-4002-S	1DPIS-4002	FOXBORO 43E TYPE 70	1DPIS-4002	1P-29	BECH M-217	CA23	Circuit/Relay Malfunction Acceptable
193	AF	1AF-4006-M	1B42-428F	CONTACTOR	1B-42	1B42-8F	ELEM 818	SS	Relay GERS or Specific Qualification
194	AF	2AF-4002-S	2-62/NC005	AGASTAT 2422PE	C-01-1(2)C-04	2C-03	ELEM 869	CA5	Circuit/Relay Malfunction Acceptable
195	AF	2AF-4002-S	2-74/2082	W NBFD22	C-01-1(2)C-04	2C-03	ELEM 869	CA4	Circuit/Relay Malfunction Acceptable
196	AF	2AF-4002-S	2DPIS-4002	FOXBORO 43E TYPE 70	2DPIS-4002	2P-29	BECH M-217	CA23	Circuit/Relay Malfunction Acceptable
197	AF	2AF-4006-M	2B42-427M	CONTACTOR	2B-42	2B42-7M	ELEM 863	SS	Relay GERS or Specific Qualification
198	AF	AF-4007-S	62/P38A	AGASTAT 2422PF	N-01	N-01	ELEM 372	CA11	Circuit/Relay Malfunction Acceptable
199	AF	AF-4007-S	DPIS-4007	FOXBORO 43E TYPE 70	DPIS-4007	P-38A	BECH M-217	CA23	Circuit/Relay Malfunction Acceptable
200	AF	AF-4009-M	1B42-328C	CONTACTOR	1B-32	1B32-8C	ELEM 812	SS	Relay GERS or Specific Qualification
201	AF	AF-4014-S	62/P38B	AGASTAT 2422PF	N-02	N-02	ELEM 372	CA11	Circuit/Relay Malfunction Acceptable
202	AF	AF-4014-S	DPIS-4014	FOXBORO 43E TYPE 70	DPIS-4014	P-38B	BECH M-217	CA23	Circuit/Relay Malfunction Acceptable
203	AF	AF-4016-M	2B42-428C	CONTACTOR	2B-42	2B42-8C	ELEM 812	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
204	AF	AF-4020-M	2B42-428F	CONTACTOR	2B-42	2B42-8F	ELEM 812B	SS	Relay GERS or Specific Qualification
205	AF	AF-4020-M	2LC-461B-XB	W BF57F	2C-161-165	2C-161	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
206	AF	AF-4020-M	2LC-461B-YB	W BF57F	2C-161-165	2C-161	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
207	AF	AF-4020-M	2LC-462A-XB	W BF57F	2C-161-165	2C-163	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
208	AF	AF-4020-M	2LC-462A-YB	W BF57F	2C-161-165	2C-163	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
209	AF	AF-4020-M	2LC-463C-XB	W BF57F	2C-161-165	2C-164	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
210	AF	AF-4020-M	2LC-463C-YB	W BF57F	2C-161-165	2C-164	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
211	AF	AF-4020-M	2LC-471B-XB	W BF57F	2C-161-165	2C-164	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
212	AF	AF-4020-M	2LC-471B-YB	W BF57F	2C-161-165	2C-164	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
213	AF	AF-4020-M	2LC-472A-XB	W BF57F	2C-161-165	2C-161	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
214	AF	AF-4020-M	2LC-472A-YB	W BF57F	2C-161-165	2C-161	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
215	AF	AF-4020-M	2LC-473C-XB	W BF57F	2C-161-165	2C-162	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
216	AF	AF-4020-M	2LC-473C-YB	W BF57F	2C-161-165	2C-162	W 617F354-2 SH.7B2	SS	Relay GERS or Specific Qualification
217	AF	AF-4020-M	2LCAB	W BFD44S	C-01-1(2)C-04	2C-03	ELEM 1532	SS	Relay GERS or Specific Qualification
218	AF	AF-4020-M	2LCBB	W BFD44S	C-01-1(2)C-04	2C-03	ELEM 1532	SS	Relay GERS or Specific Qualification
219	AF	AF-4020-M	4020X	W N8FD65NR	C-01-1(2)C-04	C-01	ELEM 370	SS	Relay GERS or Specific Qualification
220	AF	AF-4020-M	P38B-2X	W BFD31S	C-01-1(2)C-04	C-01	ELEM 370	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
221	AF	AF-4021-M	1B42-428C	CONTACTOR	1B-42	1B42-8C	ELEM 812A	SS	Relay GERS or Specific Qualification
222	AF	AF-4021-M	1LC-461B-XB	W BF57F	1C-161-165	1C-161	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
223	AF	AF-4021-M	1LC-461B-YB	W BF57F	1C-161-165	1C-161	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
224	AF	AF-4021-M	1LC-462A-XB	W BF57F	1C-161-165	1C-163	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
225	AF	AF-4021-M	1LC-462A-YB	W BF57F	1C-161-165	1C-163	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
226	AF	AF-4021-M	1LC-463C-XB	W BF57F	1C-161-165	1C-164	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
227	AF	AF-4021-M	1LC-463C-YB	W BF57F	1C-161-165	1C-164	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
228	AF	AF-4021-M	1LC-471B-XB	W BF57F	1C-161-165	1C-164	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
229	AF	AF-4021-M	1LC-471B-YB	W BF57F	1C-161-165	1C-164	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
230	AF	AF-4021-M	1LC-472A-XB	W BF57F	1C-161-165	1C-161	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
231	AF	AF-4021-M	1LC-472A-YB	W BF57F	1C-161-165	1C-161	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
232	AF	AF-4021-M	1LC-473C-XB	W BF57F	1C-161-165	1C-162	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
233	AF	AF-4021-M	1LC-473C-YB	W BF57F	1C-161-165	1C-162	W 617F354 SH.7B2	SS	Relay GERS or Specific Qualification
234	AF	AF-4021-M	1LCAB	W BFD44S	C-01-1(2)C-04	1C-03	ELEM 1523	SS	Relay GERS or Specific Qualification
235	AF	AF-4021-M	1LCBB	W BFD44S	C-01-1(2)C-04	1C-03	ELEM 1523	SS	Relay GERS or Specific Qualification
236	AF	AF-4021-M	4021X	W Nbfd65NR	C-01-1(2)C-04	C-01	ELEM 370	SS	Relay GERS or Specific Qualification
237	AF	AF-4021-M	P38B-1X	W BFD31S	C-01-1(2)C-04	C-01	ELEM 370	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
238	AF	AF-4022-M	2B42-328C	CONTACTOR	2B-32	2B32-8C	ELEM 812B	SS	Relay GERS or Specific Qualification
239	AF	AF-4022-M	2LC-461B-XA	W BF57F	2C-151-155	2C-151	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
240	AF	AF-4022-M	2LC-461B-YA	W BF57F	2C-151-155	2C-151	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
241	AF	AF-4022-M	2LC-462A-XA	W BF57F	2C-151-155	2C-153	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
242	AF	AF-4022-M	2LC-462A-YA	W BF57F	2C-151-155	2C-153	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
243	AF	AF-4022-M	2LC-463C-XA	W BF57F	2C-151-155	2C-154	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
244	AF	AF-4022-M	2LC-463C-YA	W BF57F	2C-151-155	2C-154	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
245	AF	AF-4022-M	2LC-471B-XA	W BF57F	2C-151-155	2C-154	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
246	AF	AF-4022-M	2LC-471B-YA	W BF57F	2C-151-155	2C-154	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
247	AF	AF-4022-M	2LC-472A-XA	W BF57F	2C-151-155	2C-151	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
248	AF	AF-4022-M	2LC-472A-YA	W BF57F	2C-151-155	2C-151	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
249	AF	AF-4022-M	2LC-473C-XA	W BF57F	2C-151-155	2C-152	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
250	AF	AF-4022-M	2LC-473C-YA	W BF57F	2C-151-155	2C-152	W 617F354-2 SH.7A2	SS	Relay GERS or Specific Qualification
251	AF	AF-4022-M	2LCAA	W BFD44S	C-01-1(2)C-04	2C-03	ELEM 1532	SS	Relay GERS or Specific Qualification
252	AF	AF-4022-M	2LCBA	W BFD44S	C-01-1(2)C-04	2C-03	ELEM 1532	SS	Relay GERS or Specific Qualification
253	AF	AF-4022-M	4022X	W Nbfd65NR	C-01-1(2)C-04	C-01	ELEM 370	SS	Relay GERS or Specific Qualification
254	AF	AF-4022-M	P38A-2X	W BFD31S	C-01-1(2)C-04	C-01	ELEM 370	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
255	AF	AF-4023-M	1B42-328F	CONTACTOR	1B-32	1B32-8F	ELEM 812A	SS	Relay GERS or Specific Qualification
256	AF	AF-4023-M	1LC-461B-XA	W BF57F	1C-151-155	1C-151	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
257	AF	AF-4023-M	1LC-461B-YA	W BF57F	1C-151-155	1C-151	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
258	AF	AF-4023-M	1LC-462A-XA	W BF57F	1C-151-155	1C-153	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
259	AF	AF-4023-M	1LC-462A-YA	W BF57F	1C-151-155	1C-153	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
260	AF	AF-4023-M	1LC-463C-XA	W BF57F	1C-151-155	1C-154	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
261	AF	AF-4023-M	1LC-463C-YA	W BF57F	1C-151-155	1C-154	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
262	AF	AF-4023-M	1LC-471B-XA	W BF57F	1C-151-155	1C-154	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
263	AF	AF-4023-M	1LC-471B-YA	W BF57F	1C-151-155	1C-154	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
264	AF	AF-4023-M	1LC-472A-XA	W BF57F	1C-151-155	1C-151	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
265	AF	AF-4023-M	1LC-472A-YA	W BF57F	1C-151-155	1C-151	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
266	AF	AF-4023-M	1LC-473C-XA	W BF57F	1C-151-155	1C-152	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
267	AF	AF-4023-M	1LC-473C-YA	W BF57F	1C-151-155	1C-152	W 617F354 SH.7A2	SS	Relay GERS or Specific Qualification
268	AF	AF-4023-M	1LCAA	W BFD44S	C-01-1(2)C-04	1C-03	ELEM 1523	SS	Relay GERS or Specific Qualification
269	AF	AF-4023-M	1LCBA	W BFD44S	C-01-1(2)C-04	1C-03	ELEM 1523	SS	Relay GERS or Specific Qualification
270	AF	AF-4023-M	4023X	W NBF65NR	C-01-1(2)C-04	C-01	ELEM 370	SS	Relay GERS or Specific Qualification
271	AF	AF-4023-M	P38A-1X	W BFD31S	C-01-1(2)C-04	C-01	ELEM 370	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
272	AF	P-38A-M	62/4042	AGASTAT 7014PC	C-01-1(2)C-04	C-01	ELEM 373	SS	Relay GERS or Specific Qualification
273	AF	P-38A-M	74/P38A	W BFD22S	C-01-1(2)C-04	C-01	ELEM 372	CA4	Circuit/Relay Malfunction Acceptable
274	AF	P-38A-M	P38A-3X	W BFD66S	C-01-1(2)C-04	C-01	ELEM 373	SS	Relay GERS or Specific Qualification
275	AF	P-38A-M	PY-4042-LL	FOXBORO NO152CK - N-2AO-L2C-R	1C-170-173	1C-171	FOXBORO CD1-14	SS	Relay GERS or Specific Qualification
276	AF	P-38A-M	X/1B52-12C	W Type M	1B-03	1B52-12C	ELEM 369	SWGR	Relays directly control Switchgear
277	AF	P-38B-M	62/4043	AGASTAT 7014PC	C-01-1(2)C-04	C-01	ELEM 373	SS	Relay GERS or Specific Qualification
278	AF	P-38B-M	74/P38B	W BFD22S	C-01-1(2)C-04	C-01	ELEM 372	CA4	Circuit/Relay Malfunction Acceptable
279	AF	P-38B-M	P38B-3X	W BFD66S	C-01-1(2)C-04	C-01	ELEM 373	SS	Relay GERS or Specific Qualification
280	AF	P-38B-M	PY-4043-LL	FOXBORO NO152CK - N-2AO-L2C-R	2C-170-173	2C-173	FOXBORO CD2-14	SS	Relay GERS or Specific Qualification
281	AF	P-38B-M	X/2B52-31C	W Type M	2B-04	2B52-31C	ELEM 369	SWGR	Relays directly control Switchgear
282	CC	1CC-719-M	1B42-426C	CONTACTOR	1B-42	1B42-6C	ELEM 716	SS	Relay GERS or Specific Qualification
283	CC	1CC-754A-M	1B42-326C	CONTACTOR	1B-32	1B32-6C	ELEM 721	SS	Relay GERS or Specific Qualification
284	CC	1CC-754B-M	1B42-326J	CONTACTOR	1B-32	1B32-6J	ELEM 721	SS	Relay GERS or Specific Qualification
285	CC	1CC-759A-M	1B42-326F	CONTACTOR	1B-32	1B32-6F	ELEM 721	SS	Relay GERS or Specific Qualification
286	CC	1CC-759B-M	1B42-326M	CONTACTOR	1B-32	1B32-6M	ELEM 721	SS	Relay GERS or Specific Qualification
287	CC	1CC-761A-S	1FIC-609		1RK51	1RK51	W 110E018 SH.2	CA11	Circuit/Relay Malfunction Acceptable
288	CC	1CC-761B-S	1FIC-613		1RK51	1RK51	W 110E013 SH.2	CA11	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
289	CC	1CC-815-M	1B42-327M	CONTACTOR	1B-32	1B32-7M	ELEM 716	SS	Relay GERS or Specific Qualification
290	CC	1P-11A-M	1PC-639 X1	W BFD24S	1C-158/166/167	1C-158	W 195A778 SH.24	SS	Relay GERS or Specific Qualification
291	CC	1P-11A-M	1PIC-639	BARTON Model 288A	1PIC-639	1PIC-639	W 110E018 SH3	SS24	Relay GERS or Specific Qualification
292	CC	1P-11A-M	74/1B52-10A	W BFD22S	C-01-1(2)C-04	1C-03	ELEM 317	CA4	Circuit/Relay Malfunction Acceptable
293	CC	1P-11A-M	86/1B52-10A	W MG-6	1D-03	1B52-10A	ELEM 317	SS	Relay GERS or Specific Qualification
294	CC	1P-11A-M	X/1B52-10A	W Type M	1B-03	1B52-10A	ELEM 317	SWGR	Relays directly control Switchgear
295	CC	1P-11B-M	1PC-639-X2	W BFD11S	C-01-1(2)C-04	1C-03	W 195A778 SH.24	SS	Relay GERS or Specific Qualification
296	CC	1P-11B-M	74/1B52-23B	W BFD22S	C-01-1(2)C-04	1C-03	ELEM 317A	CA4	Circuit/Relay Malfunction Acceptable
297	CC	1P-11B-M	86/1B52-23B	W MG-6	1B-04	1B52-23B	ELEM 317A	SS	Relay GERS or Specific Qualification
298	CC	1P-11B-M	X/1B52-23B	W Type M	1B-04	1B52-23B	ELEM 317	SWGR	Relays directly control Switchgear
299	CC	2CC-719-M	2B42-426C	CONTACTOR	2B-42	2B42-6C	ELEM 716	SS	Relay GERS or Specific Qualification
300	CC	2CC-754A-M	2B42-326C	CONTACTOR	2B-32	2B32-6C	ELEM 721	SS	Relay GERS or Specific Qualification
301	CC	2CC-754B-M	2B42-326J	CONTACTOR	2B-32	2B32-6J	ELEM 721	SS	Relay GERS or Specific Qualification
302	CC	2CC-759A-M	2B42-326F	CONTACTOR	2B-32	2B32-6F	ELEM 721	SS	Relay GERS or Specific Qualification
303	CC	2CC-759B-M	2B42-326M	CONTACTOR	2B-32	2B32-6M	ELEM 721	SS	Relay GERS or Specific Qualification
304	CC	2CC-761A-S	2FIC-609		2RK51	2RK51	W 110E018 SH.2	CA11	Circuit/Relay Malfunction Acceptable
305	CC	2CC-761B-S	2FIC-613		2RK51	2RK51	W 110E018 SH.2	CA11	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
306	CC	2CC-815-M	2B42-327M	CONTACTOR	2B-32	2B32-7M	ELEM 716	SS	Relay GERS or Specific Qualification
307	CC	2P-11A-M	2PC-639-X1	W BFD24S	2C-156-158	2C-158	W 195A778 SH.34	SS	Relay GERS or Specific Qualification
308	CC	2P-11A-M	2PIC-639	BARTON Model 288A	2PIC-639	2PIC-639	W 110E029 SH3	SS24	Relay GERS or Specific Qualification
309	CC	2P-11A-M	74/2B52-34A	W BFD22S	C-01-1(2)C-04	2C-03	ELEM 336	CA4	Circuit/Relay Malfunction Acceptable
310	CC	2P-11A-M	86/2B52-34A	W MG-6	2B-03	2B52-34A	ELEM 336	SS	Relay GERS or Specific Qualification
311	CC	2P-11A-M	X/2B52-34A	W Type M	2B-03	2B52-34A	ELEM 336	SWGR	Relays directly control Switchgear
312	CC	2P-11B-M	2PC-639-X2	W BFD11S	C-01-1(2)C-04	2C-03	W 195A778 SH.34	SS	Relay GERS or Specific Qualification
313	CC	2P-11B-M	74/2B52-28B	W BFD22S	C-01-1(2)C-04	2C-03	ELEM 336A	CA4	Circuit/Relay Malfunction Acceptable
314	CC	2P-11B-M	86/2B52-28B	W MG-6	2B-04	2B52-28B	ELEM 336A	SS	Relay GERS or Specific Qualification
315	CC	2P-11B-M	X/2B52-28B	W Type M	2B-04	2B52-28B	ELEM 336	SWGR	Relays directly control Switchgear
316	CC	CC-LW-63-S	2CI	W NBFD65NR	C-01-1(2)C-04	2C-03	ELEM 713	CA11	Circuit/Relay Malfunction Acceptable
317	CC	CC-LW-63-S	2CI-12-X1	W NBFD08S	C-01-1(2)C-04	C-01	ELEM 1695	CA11	Circuit/Relay Malfunction Acceptable
318	CC	CC-LW-63-S	2CI-21-X1	W NBFD08S	C-01-1(2)C-04	C-01	ELEM 1695	CA11	Circuit/Relay Malfunction Acceptable
319	CC	CC-LW-63-S	33/LW63X	W NBFD65NR	C-01-1(2)C-04	2C-03	ELEM 713	CA3	Circuit/Relay Malfunction Acceptable
320	CC	CC-LW-64-S	33/LW64X	W NBFD65NR	C-01-1(2)C-04	2C-03	ELEM 713	CA3	Circuit/Relay Malfunction Acceptable
321	CS	1CS-466A-S	1FW/X1	W BF33F	1C-158/166/167	1C-158	ELEM 1005	CA11	Circuit/Relay Malfunction Acceptable
322	CS	1CS-466B-S	1FW/X2	W BF33F	1C-158/166/167	1C-158	ELEM 1005	CA11	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
323	CS	1CS-466C-S	1FW/X3	W BF33F	1C-158/166/167	1C-158	ELEM 1005	CA11	Circuit/Relay Malfunction Acceptable
324	CS	1CS-476C-S	1FW/X4	W BF33F	1C-158/166/167	1C-158	ELEM 1005	CA11	Circuit/Relay Malfunction Acceptable
325	CS	1CS-480-S	X/1-V480	W BF22S	C-01-1(2)C-04	1C-03	ELEM 779	CA3	Circuit/Relay Malfunction Acceptable
326	CS	1CS-481-S	X/1-V481	W BF22S	C-01-1(2)C-04	1C-03	ELEM 780	CA3	Circuit/Relay Malfunction Acceptable
327	CS	2CS-466A-S	2FW/X1	W BF33F	2C-156-158	2C-158	ELEM 1205	CA11	Circuit/Relay Malfunction Acceptable
328	CS	2CS-466B-S	2FW/X2	W BF33F	2C-156-158	2C-158	ELEM 1205	CA11	Circuit/Relay Malfunction Acceptable
329	CS	2CS-466C-S	2FW/X3	W BF33F	2C-156-158	2C-158	ELEM 1205	CA11	Circuit/Relay Malfunction Acceptable
330	CS	2CS-476C-S	2FW/X4	W BF33F	2C-156-158	2C-158	ELEM 1205	CA11	Circuit/Relay Malfunction Acceptable
331	CS	2CS-480-S	X/2-V480	W BF11S	C-01-1(2)C-04	2C-03	ELEM 779	CA3	Circuit/Relay Malfunction Acceptable
332	CS	2CS-481-S	X/2-V481	W BF11S	C-01-1(2)C-04	2C-03	ELEM 780	CA3	Circuit/Relay Malfunction Acceptable
333	CV	1CV-112B-M	1B42-3213C	CONTACTOR	1B-32	1B32-13C	ELEM 717	SS	Relay GERS or Specific Qualification
334	CV	1CV-112B-M	1LC-112B-X	W BF24F	1C-158/166/167	1C-158	W 195A778 SH. 21	SS	Relay GERS or Specific Qualification
335	CV	1CV-112B-M	1LC-141B-X	W BF24F	1C-158/166/167	1C-158	W 195A778 SH. 21	SS	Relay GERS or Specific Qualification
336	CV	1CV-200A-S	1B52-13A(a)		1B-03	1B52-13A	ELEM 316	CA11	Circuit/Relay Malfunction Acceptable
337	CV	1CV-200A-S	1B52-13B(a)		1B-03	1B52-13B	ELEM 316	CA11	Circuit/Relay Malfunction Acceptable
338	CV	1CV-200A-S	1B52-20A(a)		1B-04	1B52-20A	ELEM 316A	CA11	Circuit/Relay Malfunction Acceptable
339	CV	1CV-285-M	1B42-3210C	CONTACTOR	1B-32	1B32-10C	ELEM 715	CA2	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
340	CV	1CV-313-M	1B42-327C	CONTACTOR	1B-32	1B32-7C	ELEM 719	CA13	Circuit/Relay Malfunction Acceptable
341	CV	1CV-371-S	X/1-V371	W Nbfd55	C-01-1(2)C-04	1C-04	ELEM 758	CA3	Circuit/Relay Malfunction Acceptable
342	CV	1CV-371A-S	X/1-V371A	W BFD55	C-01-1(2)C-04	1C-04	ELEM 890	CA3	Circuit/Relay Malfunction Acceptable
343	CV	2CV-112B-M	2B42-3210J	CONTACTOR	2B-32	2B32-10J	ELEM 717	SS	Relay GERS or Specific Qualification
344	CV	2CV-112B-M	2LC-112B-X	W BF24F	2C-156-158	2C-158	W 195A778 SH. 31	SS	Relay GERS or Specific Qualification
345	CV	2CV-112B-M	2LC-141B-X	W BF24F	2C-156-158	2C-158	W 195A778 SH. 31	SS	Relay GERS or Specific Qualification
346	CV	2CV-200A-S	2B52-37A(a)		2B-03	2B52-37A	ELEM 335	CA11	Circuit/Relay Malfunction Acceptable
347	CV	2CV-200A-S	2B52-37B(a)		2B-03	2B52-37B	ELEM 335	CA11	Circuit/Relay Malfunction Acceptable
348	CV	2CV-200A-S	2MX/P2C	W BFD44S	2B-04	2B-04	ELEM 333	CA11	Circuit/Relay Malfunction Acceptable
349	CV	2CV-285-M	2B42-3210C	CONTACTOR	2B-32	2B32-10C	ELEM 715	CA2	Circuit/Relay Malfunction Acceptable
350	CV	2CV-313-M	2B42-327C	CONTACTOR	2B-32	2B32-7C	ELEM 719	CA13	Circuit/Relay Malfunction Acceptable
351	CV	2CV-371-S	X/2-V371	W Nbfd55	C-01-1(2)C-04	2C-04	ELEM 758	CA3	Circuit/Relay Malfunction Acceptable
352	CV	2CV-371A-S	X/2-V371A	W BFD55	C-01-1(2)C-04	2C-04	ELEM 890	CA3	Circuit/Relay Malfunction Acceptable
353	DG	1A52-60	1-74/A60FM		1A-05	1A52-60	ELEM 263	CA4	Circuit/Relay Malfunction Acceptable
354	DG	1A52-60	51/1A52-60	W CO-5	1A-05	1A52-60	ELEM 263	SS	Relay GERS or Specific Qualification
355	DG	1A52-60	86/1A52-60	W MG-6	1A-05	1A52-60	ELEM 263	SS16	Relay GERS or Specific Qualification
356	DG	1A52-60	X/1A52-60	W Life Line Contactor	1A-05	1A52-60	ELEM 263	SWGR	Relays directly control Switchgear



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
357	DG	1A52-60	Y/1A52-60	W Life Line Contactor	1A-05	1A52-60	ELEM 263	SWGR	Relays directly control Switchgear
358	DG	1A52-66	1-74/A66FM		1A-06	1A52-66	ELEM 263	CA4	Circuit/Relay Malfunction Acceptable
359	DG	1A52-66	51/1A52-66	W CO-5	1A-06	1A52-66	ELEM 263	SS	Relay GERS or Specific Qualification
360	DG	1A52-66	86/1A52-66	W MG-6	1A-06	1A52-66	ELEM 263	SS16	Relay GERS or Specific Qualification
361	DG	1A52-66	X/1A52-66	W Life Line Contactor	1A-06	1A52-66	ELEM 263	SWGR	Relays directly control Switchgear
362	DG	1A52-66	Y/1A52-66	W Life Line Contactor	1A-06	1A52-66	ELEM 263	SWGR	Relays directly control Switchgear
363	DG	2A52-67	2-74/A67FM		2A-06	2A52-67	ELEM 293	CA4	Circuit/Relay Malfunction Acceptable
364	DG	2A52-67	51/2A52-67	W CO-5	2A-06	2A52-67	ELEM 293	SS	Relay GERS or Specific Qualification
365	DG	2A52-67	86/2A52-67	W MG-6	2A-06	2A52-67	ELEM 293	SS16	Relay GERS or Specific Qualification
366	DG	2A52-67	X/2A52-67	W Life Line Contactor	2A-06	2A52-67	ELEM 293	SWGR	Relays directly control Switchgear
367	DG	2A52-67	Y/2A52-67	W Life Line Contactor	2A-06	2A52-67	ELEM 293	SWGR	Relays directly control Switchgear
368	DG	2A52-73	2-74/A73FM		2A-05	2A52-73	ELEM 293	CA4	Circuit/Relay Malfunction Acceptable
369	DG	2A52-73	51/2A52-73	W CO-5	2A-05	2A52-73	ELEM 293	SS	Relay GERS or Specific Qualification
370	DG	2A52-73	86/2A52-73	W MG-6	2A-05	2A52-73	ELEM 293	SS16	Relay GERS or Specific Qualification
371	DG	2A52-73	X/2A52-73	W Life Line Contactor	2A-05	2A52-73	ELEM 1509	SV/GR	Relays directly control Switchgear
372	DG	2A52-73	Y/2A52-73	W Life Line Contactor	2A-05	2A52-73	ELEM 293	SWGR	Relays directly control Switchgear
373	DG	G-01	40T/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
374	DG	G-01	4CV/G01	W AV	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
375	DG	G-01	51C/G01	W CO-5	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
376	DG	G-01	52V/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
377	DG	G-01	51A/G01	W CO-5	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
378	DG	G-01	51B/G01	W CO-5	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
379	DG	G-01	67P1/G01	W CW	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
380	DG	G-01	67P3/G01	W CW	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
381	DG	G-01	67RP/G01	W CW	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
382	DG	G-01	AC CONT./G01	SQ D FAL	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
383	DG	G-01	AIR COMP./G01		G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
384	DG	G-01	ALARM CONT./G01	SQ D FAL	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
385	DG	G-01	ALCP/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
386	DG	G-01	ALM/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
387	DG	G-01	AP/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
388	DG	G-01	AP1/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
389	DG	G-01	AP2/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
390	DG	G-01	CB FT/G01	SQ D FAL	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
391	DG	G-01	CKTMAL/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
392	DG	G-01	CO/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
393	DG	G-01	COPS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
394	DG	G-01	CP/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
395	DG	G-01	CPM/G01	SQ D FAL	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
396	DG	G-01	CPMC/G01	CH MODEL 6	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
397	DG	G-01	CPS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
398	DG	G-01	DC CONTROL/G01	SQ D FAL	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
399	DG	G-01	DCCP/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
400	DG	G-01	ECR/G01	AGASTAT 2412	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
401	DG	G-01	ECRA/G01	SQ D TYPE FSD022	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
402	DG	G-01	ESR1/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
403	DG	G-01	ESR2/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
404	DG	G-01	ESTD/G01	AGASTAT 2422	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
405	DG	G-01	ESTR/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
406	DG	G-01	ESTX/G01	W MG-6	C-34	C-34	ELEM 1509	SS20	Relay GERS or Specific Qualification
407	DG	G-01	ETS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
408	DG	G-01	EXC/G01	SQ D FAL	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
409	DG	G-01	FFC/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
410	DG	G-01	FFCO/G01	W SV	C-34	C-34	EMD 8413730	CA22	Circuit/Relay Malfunction Acceptable
411	DG	G-01	FFV/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
412	DG	G-01	FP/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
413	DG	G-01	FPD/G01	SQ D TYPE EQ	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
414	DG	G-01	FPR/G01	VC 12-8336	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
415	DG	G-01	FSR1/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
416	DG	G-01	FSR2/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
417	DG	G-01	FSX/G01	W MG-6	C-34	C-34	ELEM 1509	SS20	Relay GERS or Specific Qualification
418	DG	G-01	FT/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
419	DG	G-01	FTC1/G01	CH MODEL 6	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
420	DG	G-01	FTC2/G01	CH MODEL 6	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
421	DG	G-01	FTH/G01	VC 36530082-01	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
422	DG	G-01	FTL/G01	VC 36530082-01	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
423	DG	G-01	FTSH/G01	MAGNETROL	G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
424	DG	G-01	FTSL/G01	MAGNETROL	G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
425	DG	G-01	FTSN/G01	MAGNETROL	G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
426	DG	G-01	FTT/G01	W BF42F	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
427	DG	G-01	GB/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
428	DG	G-01	GBA/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
429	DG	G-01	GCS L/G01		G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
430	DG	G-01	GCS R/G01		G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
431	DG	G-01	GOV. SOL/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
432	DG	G-01	GP/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
433	DG	G-01	GPA/G01	W BFD22S	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
434	DG	G-01	GS/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
435	DG	G-01	HE/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
436	DG	G-01	HS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
437	DG	G-01	IHC/G01	CH 9560ED139	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
438	DG	G-01	LFP1/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
439	DG	G-01	LFP2/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
440	DG	G-01	LOL/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
441	DG	G-01	LOT/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
442	DG	G-01	LOTS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
443	DG	G-01	LS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
444	DG	G-01	LW/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
445	DG	G-01	LWD/G01	AGASTAT 2412	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
446	DG	G-01	LWS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
447	DG	G-01	MB1/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
448	DG	G-01	MB2/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
449	DG	G-01	MB3/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
450	DG	G-01	MB4/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
451	DG	G-01	MBX1/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
452	DG	G-01	MBX2/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
453	DG	G-01	MFP1/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
454	DG	G-01	MFP2/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
455	DG	G-01	MSR1/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
456	DG	G-01	MSR2/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
457	DG	G-01	MVST1/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
458	DG	G-01	MVST2/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
459	DG	G-01	NFLD/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
460	DG	G-01	NFLDA/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
461	DG	G-01	NOT AUTO/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
462	DG	G-01	NVR/G01	VC 36530082-01	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
463	DG	G-01	OC/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
464	DG	G-01	OL CPM/G01	DELTA CONTROLS	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
465	DG	G-01	OL SPM/G01	THERMAL OL	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
466	DG	G-01	OL/G01	THERMAL OL	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
467	DG	G-01	OL1/G01	THERMAL OL	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
468	DG	G-01	OL2/G01	THERMAL OL	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
469	DG	G-01	OLIH/G01	THERMAL OL	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
470	DG	G-01	OP/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
471	DG	G-01	OT/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
472	DG	G-01	OTR/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
473	DG	G-01	OTS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
474	DG	G-01	PFD1/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
475	DG	G-01	PFD2/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
476	DG	G-01	PFDA1/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
477	DG	G-01	PFDA2/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
478	DG	G-01	RAW WATER/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
479	DG	G-01	RESET/G01		G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
480	DG	G-01	RP/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
481	DG	G-01	RWS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
482	DG	G-01	SCR/G01	SQ D TYPE EQ	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
483	DG	G-01	SF/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
484	DG	G-01	SFA/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
485	DG	G-01	SFB1/G01	AGASTAT 7012	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
486	DG	G-01	SFB2/G01	AGASTAT 7012	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
487	DG	G-01	SFD1/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
488	DG	G-01	SFD2/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
489	DG	G-01	SPMC/G01	CH TYPE M	G-01	C-64	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
490	DG	G-01	SSP1/G01	EMD	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
491	DG	G-01	SSP2/G01	EMD	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
492	DG	G-01	START1/G01	SQ D FAL	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
493	DG	G-01	START2/G01	SQ D FAL	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
494	DG	G-01	STCP1/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
495	DG	G-01	STCP2/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
496	DG	G-01	STL01/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
497	DG	G-01	STL02/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
498	DG	G-01	STR1/G01	VC 36530082-01	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
499	DG	G-01	STR2/G01	VC 12-8336	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
500	DG	G-01	TB/G01	TEMP SW	G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
501	DG	G-01	TO/G01	DELTA CONTROLS	G-01	C-64A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
502	DG	G-01	TOS/G01		G-01	G-01	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
503	DG	G-01	VSD1/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
504	DG	G-01	VSD2/G01	SQ D TYPE EQ	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
505	DG	G-01	VSR1/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
506	DG	G-01	VSR2/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
507	DG	G-01	ZSR1/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
508	DG	G-01	ZSR2/G01	SQ D TYPE PO	C-34	C-34	EMD 8413730	SS	Relay GERS or Specific Qualification
509	DG	G-02	40T/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
510	DG	G-02	40V/G02	W AV	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
511	DG	G-02	51C/G02	W CO-5	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
512	DG	G-02	52V/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
513	DG	G-02	51A/G02	W CO-5	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
514	DG	G-02	51B/G02	W CO-5	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
515	DG	G-02	67P1/G02	W CW	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
516	DG	G-02	67P3/G02	W CW	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
517	DG	G-02	67RP/G02	W CW	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
518	DG	G-02	AC CONT./G02	SQ D FAL	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
519	DG	G-02	AIR COMP./G02		G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
520	DG	G-02	ALARM CONT./G02	SQ D FAL	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
521	DG	G-02	ALCP/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
522	DG	G-02	ALM/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
523	DG	G-02	AP/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
524	DG	G-02	AP1/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
525	DG	G-02	AP2/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
526	DG	G-02	CB FT/G02	SQ D FAL	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
527	DG	G-02	CKTMAL/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
528	DG	G-02	CO/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
529	DG	G-02	COPS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
530	DG	G-02	CP/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
531	DG	G-02	CPM/G02	SQ D FAL	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
532	DG	G-02	CPMC/G02	CH MODEL 6	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
533	DG	G-02	CPS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
534	DG	G-02	DC CONTROL/G02	SQ D FAL	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
535	DG	G-02	DCCP/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
536	DG	G-02	ECR/G02	AGASTAT 2412	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
537	DG	G-02	ECRA/G02	SQ D TYPE FSD022	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
538	DG	G-02	ESR1/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
539	DG	G-02	ESR2/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
540	DG	G-02	ESTD/G02	AGASTAT 2422	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
541	DG	G-02	ESTR/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
542	DG	G-02	ESTX/G02	W MG-6	C-35	C-35	ELEM 1509	SS20	Relay GERS or Specific Qualification
543	DG	G-02	ETS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
544	DG	G-02	EXC/G02	SQ D FAL	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
545	DG	G-02	FFC/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
546	DG	G-02	FFCO/G02	W SV	C-35	C-35	EMD 8413730	CA22	Circuit/Relay Malfunction Acceptable
547	DG	G-02	FFV/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
548	DG	G-02	FP/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
549	DG	G-02	FPD/G02	SQ D TYPE EQ	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
550	DG	G-02	FPR/G02	VC 12-8336	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
551	DG	G-02	FSR1/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
552	DG	G-02	FSR2/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
553	DG	G-02	FSX/G02	W MG-6	C-35	C-35	ELEM 1509	SS20	Relay GERS or Specific Qualification
554	DG	G-02	FT/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
555	DG	G-02	FTC1/G02	CH MODEL 6	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
556	DG	G-02	FTC2/G02	CH MODEL 6	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
557	DG	G-02	FTH/G02	VC 36530082-01	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
558	DG	G-02	FTL/G02	VC 36530082-01	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
559	DG	G-02	FTSH/G02	MAGNETROL	G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
560	DG	G-02	FTSL/G02	MAGNETROL	G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
561	DG	G-02	FTSN/G02	MAGNETROL	G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
562	DG	G-02	FTT/G02	W BF42F	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
563	DG	G-02	GB/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
564	DG	G-02	GBA/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
565	DG	G-02	GCS L/G02		G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
566	DG	G-02	GCS R/G02		G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
567	DG	G-02	GOV. SOL/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
568	DG	G-02	GP/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
569	DG	G-02	GPA/G02	W BFD22S	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
570	DG	G-02	GS/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
571	DG	G-02	HE/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
572	DG	G-02	HS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
573	DG	G-02	IHC/G02	CH 9560ED139	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
574	DG	G-02	LFP1/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
575	DG	G-02	LFP2/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
576	DG	G-02	LOL/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
577	DG	G-02	LOT/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
578	DG	G-02	LOTS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
579	DG	G-02	LS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
580	DG	G-02	LW/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
581	DG	G-02	LWD/G02	AGASTAT 2412	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
582	DG	G-02	LWS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
583	DG	G-02	MB1/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
584	DG	G-02	MB2/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
585	DG	G-02	MB3/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
586	DG	G-02	MB4/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
587	DG	G-02	MBX1/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
588	DG	G-02	MBX2/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
589	DG	G-02	MFP1/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
590	DG	G-02	MFP2/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
591	DG	G-02	MSR1/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
592	DG	G-02	MSR2/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
593	DG	G-02	MVST1/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
594	DG	G-02	MVST2/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
595	DG	G-02	NFLD/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
596	DG	G-02	NFLDA/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
597	DG	G-02	NOT AUTO/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
598	DG	G-02	NVR/G02	VC 36530082-01	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
599	DG	G-02	OC/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
600	DG	G-02	OL CPM/G02	DELTA CONTROLS	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
601	DG	G-02	OL SPM/G02	THERMAL OL	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
602	DG	G-02	OL/G02	THERMAL OL	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
603	DG	G-02	OL1/G02	THERMAL OL	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
604	DG	G-02	OL2/G02	THERMAL OL	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
605	DG	G-02	OLIH/G02	THERMAL OL	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
606	DG	G-02	OP/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
607	DG	G-02	OT/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
608	DG	G-02	OTR/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
609	DG	G-02	OTS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
610	DG	G-02	PFD1/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
611	DG	G-02	PFD2/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
612	DG	G-02	PFDA1/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
613	DG	G-02	PFDA2/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
614	DG	G-02	RAW WATER/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
615	DG	G-02	RESET/G02		G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
616	DG	G-02	RP/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
617	DG	G-02	RWS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
618	DG	G-02	SCR/G02	SQ D TYPE EQ	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
619	DG	G-02	SF/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
620	DG	G-02	SFA/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
621	DG	G-02	SFB1/G02	AGASTAT 7012	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
622	DG	G-02	SFB2/G02	AGASTAT 7012	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
623	DG	G-02	SFD1/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
624	DG	G-02	SFD2/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
625	DG	G-02	SPMC/G02	CH TYPE M	G-02	C-65	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
626	DG	G-02	SSP1/G02	EMD	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
627	DG	G-02	SSP2/G02	EMD	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
628	DG	G-02	START1/G02	SQ D FAL	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
629	DG	G-02	START2/G02	SQ D FAL	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
630	DG	G-02	STCP1/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
631	DG	G-02	STCP2/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
632	DG	G-02	STLO1/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
633	DG	G-02	STLO2/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
634	DG	G-02	STR1/G02	VC 36530082-01	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
635	DG	G-02	STR2/G02	VC 12-8336	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
636	DG	G-02	TB/G02	TEMP SW	G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
637	DG	G-02	TO/G02	DELTA CONTROLS	G-02	C-65A	EMD 8413730	CA4	Circuit/Relay Malfunction Acceptable
638	DG	G-02	TOS/G02		G-02	G-02	EMD 8413730	SS	Relays mounted on Diesel Generator or Air Compressor
639	DG	G-02	VSD1/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
640	DG	G-02	VSD2/G02	SQ D TYPE EQ	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
641	DG	G-02	VSR1/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
642	DG	G-02	VSR2/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
643	DG	G-02	ZSR1/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
644	DG	G-02	ZSR2/G02	SQ D TYPE PO	C-35	C-35	EMD 8413730	SS	Relay GERS or Specific Qualification
645	ESF		1-71A/BAT	W BFD44S	1C-156-157	1C-157	W 110E163 SH.11	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
646	ESF		1-71B/BAT	W BFD44S	1C-158/166/167	1C-167	W 110E163 SH.11	SS	Relay GERS or Specific Qualification
647	ESF		1-74/TBA	W BFD02S	1C-156-157	1C-157	W 110E163 SH.12	CA4	Circuit/Relay Malfunction Acceptable
648	ESF		1-74/TBB	W BFD02S	1C-158/166/167	1C-167	W 110E163 SH.12	CA4	Circuit/Relay Malfunction Acceptable
649	ESF		1-74/XA	W BFD22S	1C-156-157	1C-157	W 110E163 SH.8	CA4	Circuit/Relay Malfunction Acceptable
650	ESF		1-74/XB	W BFD22S	1C-158/166/167	1C-167	W 110E163 SH.8	CA4	Circuit/Relay Malfunction Acceptable
651	ESF		1-74X/A3	ASEA RXMA1	1C-20	1C-20	ELEM 1651	CA18	Circuit/Relay Malfunction Acceptable
652	ESF		1-74X/B3	ASEA RXMA1	1C-20	1C-20	ELEM 1651	CA18	Circuit/Relay Malfunction Acceptable
653	ESF		1AFW-12X	W BFD22S	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
654	ESF		1AFW-22X	W BFD22S	1C-158/166/167	1C-166	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
655	ESF		1CI-10X	W BFD48S	1C-156-157	1C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
656	ESF		1CI-11X	W BFD48S	1C-156-157	1C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
657	ESF		1CI-12X	W BFD48S	1C-156-157	1C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
658	ESF		1CI-20X	W BFD48S	1C-158/166/167	1C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
659	ESF		1CI-21X	W BFD48S	1C-158/166/167	1C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
660	ESF		1CI-22X	W BFD48S	1C-158/166/167	1C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
661	ESF		1CI-A	W MG-6	1C-156-157	1C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
662	ESF		1CI-B	W MG-6	1C-158/166/167	1C-166	W 110E163 SH.9	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
663	ESF		1CIR-A	W BFD22S	1C-156-157	1C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
664	ESF		1CIR-B	W BFD22S	1C-158/166/167	1C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
665	ESF		1CP-A	W Nbfd65NR	1C-156-157	1C-157	W 110E163 SH.7A	SS	Relay GERS or Specific Qualification
666	ESF		1CP-A-X	W Nbfd65NR	C-01-1(2)C-04	1C-03	W 110E163 SH.7A	SS	Relay GERS or Specific Qualification
667	ESF		1CP-B	W Nbfd65NR	1C-158/166/167	1C-167	W 110E163 SH.7A	SS	Relay GERS or Specific Qualification
668	ESF		1CP-B-X	W Nbfd65NR	C-01-1(2)C-04	1C-03	W 110E163 SH.7A	SS	Relay GERS or Specific Qualification
669	ESF		1CS-10X	W BFD64S	1C-156-157	1C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
670	ESF		1CS-20X	W BFD64S	1C-158/166/167	1C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
671	ESF		1CS-A	W MG-6	1C-156-157	1C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
672	ESF		1CS-B	W MG-6	1C-158/166/167	1C-166	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
673	ESF		1F-10X	W BFD33S	1C-156-157	1C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
674	ESF		1F-20X	W BFD33S	1C-158/166/167	1C-167	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
675	ESF		1F-30X	W BFD33S	1C-156-157	1C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
676	ESF		1F-40X	W BFD33S	1C-158/166/167	1C-167	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
677	ESF		1FA-1	W MG-6	1C-156-157	1C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
678	ESF		1FA-2	W MG-6	1C-156-157	1C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
679	ESF		1FB-1	W MG-6	1C-158/166/167	1C-166	W 110E163 SH.10	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
680	ESF		1FB-2	W MG-6	1C-158/166/167	1C-166	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
681	ESF		1FC-464A-XA	W BF44F	1C-156-157	1C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
682	ESF		1FC-464A-XB	W BF44F	1C-158/166/167	1C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
683	ESF		1FC-464B-XA	W BF44F	1C-156-157	1C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
684	ESF		1FC-464B-XB	W BF44F	1C-158/166/167	1C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
685	ESF		1FC-465A-XA	W BF44F	1C-156-157	1C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
686	ESF		1FC-465A-XB	W BF44F	1C-158/166/167	1C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
687	ESF		1FC-465B-XA	W BF44F	1C-156-157	1C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
688	ESF		1FC-465B-XB	W BF44F	1C-158/166/167	1C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
689	ESF		1FC-474A-XA	W BF44F	1C-156-157	1C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
690	ESF		1FC-474A-XB	W BF44F	1C-158/166/167	1C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
691	ESF		1FC-474B-XA	W BF44F	1C-156-157	1C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
692	ESF		1FC-474B-XB	W BF44F	1C-158/166/167	1C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
693	ESF		1FC-475A-XA	W BF44F	1C-156-157	1C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
694	ESF		1FC-475A-XB	W BF44F	1C-158/166/167	1C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
695	ESF		1FC-475B-XA	W BF44F	1C-156-157	1C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
696	ESF		1FC-475B-XB	W BF44F	1C-158/166/167	1C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
697	ESF		1LC-102C-XA	W BF42F	1C-156-157	1C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
698	ESF		1LC-102C-XB	W BF42F	1C-158/166/167	1C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
699	ESF		1LC-106C-XA	W BF42F	1C-156-157	1C-156	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
700	ESF		1LC-106C-XB	W BF42F	1C-158/166/167	1C-166	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
701	ESF		1LC-171C-XA	W BF42F	1C-156-157	1C-156	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
702	ESF		1LC-171C-XB	W BF42F	1C-158/166/167	1C-166	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
703	ESF		1LC-172C-XA	W BF42F	1C-156-157	1C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
704	ESF		1LC-172C-XB	W BF42F	1C-158/166/167	1C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
705	ESF		1LC-189C-XA	W BF42F	1C-156-157	1C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
706	ESF		1LC-189C-XB	W BF42F	1C-158/166/167	1C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
707	ESF		1LC-190C-XA	W BF42F	1C-156-157	1C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
708	ESF		1LC-190C-XB	W BF42F	1C-158/166/167	1C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
709	ESF		1LC-426B-XA	W BF46F	1C-156-157	1C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
710	ESF		1LC-426B-XB	W BF46F	1C-158/166/167	1C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
711	ESF		1LC-427C-XA	W BF46F	1C-156-157	1C-157	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
712	ESF		1LC-427C-XB	W BF46F	1C-158/166/167	1C-167	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
713	ESF		1LC-428E-XA	W BF46F	1C-156-157	1C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
714	ESF		1LC-428E-XB	W BF46F	1C-158/166/167	1C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
715	ESF		1LC-461A-XA	W BF44F	1C-156-157	1C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
716	ESF		1LC-461A-XB	W BF44F	1C-158/166/167	1C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
717	ESF		1LC-462B-XA	W BF55F	1C-156-157	1C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
718	ESF		1LC-462B-XB	W BF55F	1C-158/166/167	1C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
719	ESF		1LC-463D-XA	W BF55F	1C-156-157	1C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
720	ESF		1LC-463D-XB	W BF55F	1C-158/166/167	1C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
721	ESF		1LC-471A-XA	W BF44F	1C-156-157	1C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
722	ESF		1LC-471A-XB	W BF44F	1C-158/166/167	1C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
723	ESF		1LC-472B-XA	W BF55F	1C-156-157	1C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
724	ESF		1LC-472B-XB	W BF55F	1C-158/166/167	1C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
725	ESF		1LC-473D-XA	W BF55F	1C-156-157	1C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
726	ESF		1LC-473D-XB	W BF55F	1C-158/166/167	1C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
727	ESF		1MS-A1	W BFD33S	1C-156-157	1C-157	W 110E163 SH.8	SS	Relay GERS or Specific Qualification
728	ESF		1MS-A2	W BFD33S	1C-156-157	1C-157	W 110E163 SH.8	SS	Relay GERS or Specific Qualification
729	ESF		1MS-B1	W BFD33S	1C-158/166/167	1C-167	W 110E163 SH.8	SS	Relay GERS or Specific Qualification
730	ESF		1MS-B2	W BFD33S	1C-158/166/167	1C-167	W 110E163 SH.8	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
731	ESF		1P32A-XA	W BF62F	1C-156-157	1C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
732	ESF		1P32A-XB	W BF62F	1C-158/166/167	1C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
733	ESF		1P32B-XA	W BF62F	1C-156-157	1C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
734	ESF		1P32B-XB	W BF62F	1C-158/166/167	1C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
735	ESF		1P32C-XA	W BF62F	1C-156-157	1C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
736	ESF		1P32C-XB	W BF62F	1C-158/166/167	1C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
737	ESF		1P32D-XA	W BF62F	1C-156-157	1C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
738	ESF		1P32D-XB	W BF62F	1C-158/166/167	1C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
739	ESF		1P32E-XA	W BF62F	1C-156-157	1C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
740	ESF		1P32E-XB	W BF62F	1C-158/166/167	1C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
741	ESF		1P32F-XA	W BF62F	1C-156-157	1C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
742	ESF		1P32F-XB	W BF62F	1C-158/166/167	1C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
743	ESF		1PC-428B-XA	W BF53F	1C-156-157	1C-156	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
744	ESF		1PC-428B-XB	W BF53F	1C-158/166/167	1C-166	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
745	ESF		1PC-429C-XA	W BF46F	1C-156-157	1C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
746	ESF		1PC-429C-XB	W BF46F	1C-158/166/167	1C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
747	ESF		1PC-430E-XA	W BF46F	1C-156-157	1C-157	W 110E163 SH.2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
748	ESF		1PC-430E-XB	W BF46F	1C-158/166/167	1C-167	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
749	ESF		1PC-430F-XA	W BF66F	1C-156-157	1C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
750	ESF		1PC-430F-XB	W BF66F	1C-158/166/167	1C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
751	ESF		1PC-431G-XA	W BF46F	1C-156-157	1C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
752	ESF		1PC-431G-XB	W BF46F	1C-158/166/167	1C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
753	ESF		1PC-431I-XA	W BF66F	1C-156-157	1C-156	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
754	ESF		1PC-431I-XB	W BF66F	1C-158/166/167	1C-166	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
755	ESF		1PC-468A-XA	W BF46F	1C-156-157	1C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
756	ESF		1PC-468A-XB	W BF46F	1C-156-157	1C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
757	ESF		1PC-469A-XA	W BF48F	1C-156-157	1C-157	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
758	ESF		1PC-469A-XB	W BF48F	1C-158/166/167	1C-167	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
759	ESF		1PC-478A-XA	W BF46F	1C-156-157	1C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
760	ESF		1PC-478A-XB	W BF46F	1C-158/166/167	1C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
761	ESF		1PC-479A-XA	W BF48F	1C-156-157	1C-157	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
762	ESF		1PC-479A-XB	W BF48F	1C-158/166/167	1C-167	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
763	ESF		1PC-482A-XA	W BF48F	1C-156-157	1C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
764	ESF		1PC-482A-XB	W BF48F	1C-158/166/167	1C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
765	ESF		1PC-483A-XA	W BF48F	1C-156-157	1C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
766	ESF		1PC-483A-XB	W BF48F	1C-158/166/167	1C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
767	ESF		1PC-628-XA	W BF22F	1C-156-157	1C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
768	ESF		1PC-629-XB	W BF22F	1C-158/166/167	1C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
769	ESF		1PC-945A-XA	W BF46F	1C-156-157	1C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
770	ESF		1PC-945A-XB	W BF46F	1C-158/166/167	1C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
771	ESF		1PC-945B-XA	W BF44F	1C-156-157	1C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
772	ESF		1PC-945B-XB	W BF44F	1C-158/166/167	1C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
773	ESF		1PC-946A-XA	W BF46F	1C-156-157	1C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
774	ESF		1PC-946A-XB	W BF46F	1C-158/166/167	1C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
775	ESF		1PC-946B-XA	W BF44F	1C-156-157	1C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
776	ESF		1PC-946B-XB	W BF44F	1C-158/166/167	1C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
777	ESF		1PC-947A-XA	W BF48F	1C-156-157	1C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
778	ESF		1PC-947A-XB	W BF48F	1C-158/166/167	1C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
779	ESF		1PC-947B-XA	W BF55F	1C-156-157	1C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
780	ESF		1PC-947B-XB	W BF55F	1C-158/166/167	1C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
781	ESF		1PC-948A-XA	W BF48F	1C-156-157	1C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
782	ESF		1PC-948A-XB	W BF48F	1C-158/166/167	1C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
783	ESF		1PC-948B-XA	W BF55F	1C-156-157	1C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
784	ESF		1PC-948B-XB	W BF55F	1C-158/166/167	1C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
785	ESF		1PC-949A-XA	W BF48F	1C-156-157	1C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
786	ESF		1PC-949A-XB	W BF48F	1C-158/166/167	1C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
787	ESF		1PC-949B-XA	W BF55F	1C-156-157	1C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
788	ESF		1PC-949B-XB	W BF55F	1C-158/166/167	1C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
789	ESF		1PC-950A-XA	W BF48F	1C-156-157	1C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
790	ESF		1PC-950A-XB	W BF48F	1C-158/166/167	1C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
791	ESF		1PC-950B-XA	W BF55F	1C-156-157	1C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
792	ESF		1PC-950B-XB	W BF55F	1C-158/166/167	1C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
793	ESF		1SI-10X	W BFD84S	1C-156-157	1C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
794	ESF		1SI-11X	W BFD84S	1C-156-157	1C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
795	ESF		1SI-12X	W BFD84S	1C-156-157	1C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
796	ESF		1SI-13X	W BFD84S	1C-156-157	1C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
797	ESF		1SI-14X	W BFD84S	1C-156-157	1C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
798	ESF		1SI-20X	W BFD84S	1C-158/166/167	1C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
799	ESF		1SI-21X	W BFD84S	1C-158/166/167	1C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
800	ESF		1SI-22X	W BFD84S	1C-158/166/167	1C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
801	ESF		1SI-23X	W BFD84S	1C-158/163/167	1C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
802	ESF		1SI-24X	W BFD84S	1C-158/166/167	1C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
803	ESF		1SIA-A	W MG-6	1C-156-157	1C-156	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
804	ESF		1SIA-B	W MG-6	1C-158/166/167	1C-166	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
805	ESF		1SIB-A	W BFD75S	1C-156-157	1C-156	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
806	ESF		1SIB-B	W BFD75S	1C-158/166/167	1C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
807	ESF		1SIM-A	W MG-6	1C-156-157	1C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
808	ESF		1SIM-B	W MG-6	1C-158/166/167	1C-166	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
809	ESF		1SIR-A	W Nbfd65NR	1C-156-157	1C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
810	ESF		1SIR-B	W Nbfd65NR	1C-158/166/167	1C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
811	ESF		1SW-A	W BFD22S	1C-156-157	1C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
812	ESF		1SW-AX	W BFD42S	1C-156-157	1C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
813	ESF		1SW-B	W BFD22S	1C-158/166/167	1C-167	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
814	ESF		1SW-BX	W BFD42S	1C-158/166/167	1C-167	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
815	ESF		1TC-401D-XA	W BF66F	1C-156-157	1C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
816	ESF		1TC-401D-XB	W BF66F	1C-158/166/167	1C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
817	ESF		1TC-402D-XA	W BF66F	1C-156-157	1C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
818	ESF		1TC-402D-XB	W BF66F	1C-158/166/167	1C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
819	ESF		1TC-403D-XA	W BF66F	1C-156-157	1C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
820	ESF		1TC-403D-XB	W BF66F	1C-158/166/167	1C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
821	ESF		1TC-404D-XA	W BF66F	1C-156-157	1C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
822	ESF		1TC-404D-XB	W BF66F	1C-158/166/167	1C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
823	ESF		1TDR-10	AGASTAT 2412PD	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
824	ESF		1TDR-11	AGASTAT 2412PD	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
825	ESF		1TDR-12	AGASTAT 2412PE	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
826	ESF		1TDR-13	AGASTAT 2412PD	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
827	ESF		1TDR-14	AGASTAT 2412PD	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
828	ESF		1TDR-15	AGASTAT 2412PE	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
829	ESF		1TDR-16	AGASTAT 2412PE	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
830	ESF		1TDR-17	AGASTAT 2412PE	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
831	ESF		1TDR-18	AGASTAT 2412PD	1C-156-157	1C-156	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
832	ESF		1TDR-19	AGASTAT 2412PE	1C-156-157	1C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
833	ESF		1TDR-20	AGASTAT 2412PD	1C-158/166/167	1C-166	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
834	ESF		1TDR-21	AGASTAT 2412PD	1C-158/166/167	1C-166	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
835	ESF		1TDR-22	AGASTAT 2412PE	1C-158/166/167	1C-166	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
836	ESF		1TDR-23	AGASTAT 2412PD	1C-158/166/167	1C-166	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
837	ESF		1TDR-24	AGASTAT 2412PD	1C-158/166/167	1C-166	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
838	ESF		1TDR-25	AGASTAT 2412PE	1C-158/166/167	1C-166	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
839	ESF		1TDR-26	AGASTAT 2412PE	1C-158/166/167	1C-166	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
840	ESF		1TDR-27	AGASTAT 2412PE	1C-158/166/167	1C-166	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
841	ESF		1TDR-28	AGASTAT 2412PD	1C-158/166/167	1C-166	W 110E163 SH.12B	SS	Relay GERS or Specific Qualification
842	ESF		1TDR-29	AGASTAT 2412PE	1C-158/166/167	1C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
843	ESF		1V-10X	W BFD24S	1C-156-157	1C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
844	ESF		1V-20X	W BFD24S	1C-158/166/167	1C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
845	ESF		1VA	W MG-6	1C-156-157	1C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
846	ESF		1VB	W MG-6	1C-158/166/167	1C-166	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
847	ESF		1XAT1	W BFD11S	1C-156-157	1C-157	W 110E163 SH.11	SS	Relay GERS or Specific Qualification
848	ESF		1XAT2	W BFD11S	1C-156-157	1C-157	W 110E163 SH.11	SS	Relay GERS or Specific Qualification
849	ESF		1XBT1	W BFD11S	1C-158/166/167	1C-167	W 110E163 SH.11	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
850	ESF		1XBT2	W BFD11S	1C-158/166/167	1C-167	W 110E163 SH.11	SS	Relay GERS or Specific Qualification
851	ESF		2-71A/BAT	W BFD44S	2C-156-158	2C-157	W 110E163 SH.11	SS	Relay GERS or Specific Qualification
852	ESF		2-71B/BAT	W BFD44S	2C-166-167	2C-167	W 110E163 SH.11	SS	Relay GERS or Specific Qualification
853	ESF		2-74/TBA	W BFD02S	2C-156-158	2C-157	W 110E163 SH.12	CA4	Circuit/Relay Malfunction Acceptable
854	ESF		2-74/TBB	W BFD02S	2C-166-167	2C-167	W 110E163 SH.12	CA4	Circuit/Relay Malfunction Acceptable
855	ESF		2-74/Xf.	W BFD22S	2C-156-158	2C-157	W 110E163 SH.8	CA4	Circuit/Relay Malfunction Acceptable
856	ESF		2-74/XB	W BFD22S	2C-166-167	2C-167	W 110E163 SH.8	CA4	Circuit/Relay Malfunction Acceptable
857	ESF		2-74X/A3	ASEA RXMA1	2C-20	2C-20	ELEM 1651	CA18	Circuit/Relay Malfunction Acceptable
858	ESF		2-74X/B3	ASEA RXMA1	2C-20	2C-20	ELEM 1651	CA18	Circuit/Relay Malfunction Acceptable
859	ESF		2AFW-12X	W BFD22S	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
860	ESF		2AFW-22X	W BFD22S	2C-166-167	2C-166	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
861	ESF		2CI-10X	W BFD48S	2C-156-158	2C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
862	ESF		2CI-11X	W BFD48S	2C-156-158	2C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
863	ESF		2CI-12X	W BFD48S	2C-156-158	2C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
864	ESF		2CI-20X	W BFD48S	2C-166-167	2C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
865	ESF		2CI-21X	W BFD48S	2C-166-167	2C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
866	ESF		2CI-22X	W BFD48S	2C-166-167	2C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
867	ESF		2CI-A	W MG-6	2C-156-158	2C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
868	ESF		2CI-B	W MG-6	2C-166-167	2C-166	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
869	ESF		2CIR-A	W BFD22S	2C-156-158	2C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
870	ESF		2CIR-B	W BFD22S	2C-166-167	2C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
871	ESF		2CP-A	W NBFD65NR	2C-156-158	2C-157	W 110E163 SH.7A	SS	Relay GERS or Specific Qualification
872	ESF		2CP-A-X	W NBFD65NR	C-01-1(2)C-04	2C-03	W 110E163 SH.7A	SS	Relay GERS or Specific Qualification
873	ESF		2CP-B	W NBFD65NR	2C-166-167	2C-167	W 110E163 SH.7A	SS	Relay GERS or Specific Qualification
874	ESF		2CP-B-X	W NBFD65NR	C-01-1(2)C-04	2C-03	W 110E163 SH.7A	SS	Relay GERS or Specific Qualification
875	ESF		2CS-10X	W BFD64S	2C-156-158	2C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
876	ESF		2CS-20X	W BFD64S	2C-166-167	2C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
877	ESF		2CS-A	W MG-6	2C-156-158	2C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
878	ESF		2CS-B	W MG-6	2C-166-167	2C-166	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
879	ESF		2F-10X	W BFD33S	2C-156-158	2C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
880	ESF		2F-20X	W BFD33S	2C-166-167	2C-167	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
881	ESF		2F-30X	W BFD33S	2C-156-158	2C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
882	ESF		2F-40X	W BFD33S	2C-166-167	2C-167	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
883	ESF		2FA-1	W MG-6	2C-156-158	2C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
884	ESF		2FA-2	W MG-6	2C-156-158	2C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
885	ESF		2FB-1	W MG-6	2C-166-167	2C-166	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
886	ESF		2FB-2	W MG-6	2C-166-167	2C-166	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
887	ESF		2FC-464A-XA	W BF44F	2C-156-158	2C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
888	ESF		2FC-464A-XB	W BF44F	2C-166-167	2C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
889	ESF		2FC-464B-XA	W BF44F	2C-156-158	2C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
890	ESF		2FC-464B-XB	W BF44F	2C-166-167	2C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
891	ESF		2FC-465A-XA	W BF44F	2C-156-158	2C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
892	ESF		2FC-465A-XB	W BF44F	2C-166-167	2C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
893	ESF		2FC-465B-XA	W BF44F	2C-156-158	2C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
894	ESF		2FC-465B-XB	W BF44F	2C-166-167	2C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
895	ESF		2FC-474A-XA	W BF44F	2C-156-158	2C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
896	ESF		2FC-474A-XB	W BF44F	2C-166-167	2C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
897	ESF		2FC-474B-XA	W BF44F	2C-156-158	2C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
898	ESF		2FC-474B-XB	W BF44F	2C-166-167	2C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
899	ESF		2FC-475A-XA	W BF44F	2C-156-158	2C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
900	ESF		2FC-475A-XB	W BF44F	2C-166-167	2C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
901	ESF		2FC-475B-XA	W BF44F	2C-156-158	2C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
902	ESF		2FC-475B-XB	W BF44F	2C-166-167	2C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
903	ESF		2LC-102C-XA	W BF42F	2C-156-158	2C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
904	ESF		2LC-102C-XB	W BF42F	2C-166-167	2C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
905	ESF		2LC-106C-XA	W BF42F	2C-156-158	2C-156	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
906	ESF		2LC-106C-XB	W BF42F	2C-166-167	2C-166	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
907	ESF		2LC-171C-XA	W BF42F	2C-156-158	2C-156	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
908	ESF		2LC-171C-XB	W BF42F	2C-166-167	2C-166	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
909	ESF		2LC-172C-XA	W BF42F	2C-156-158	2C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
910	ESF		2LC-172C-XB	W BF42F	2C-166-167	2C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
911	ESF		2LC-189C-XA	W BF42F	2C-156-158	2C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
912	ESF		2LC-189C-XB	W BF42F	2C-166-167	2C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
913	ESF		2LC-190C-XA	W BF42F	2C-156-158	2C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
914	ESF		2LC-190C-XB	W BF42F	2C-166-167	2C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
915	ESF		2LC-426B-XA	W BF46F	2C-156-158	2C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
916	ESF		2LC-426B-XB	W BF46F	2C-166-167	2C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
917	ESF		2LC-427C-XA	W BF46F	2C-156-158	2C-157	W 110E163 SH.2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
918	ESF		2LC-427C-XB	W BF46F	2C-166-167	2C-167	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
919	ESF		2LC-428E-XA	W BF46F	2C-156-158	2C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
920	ESF		2LC-428E-XB	W BF46F	2C-166-167	2C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
921	ESF		2LC-461A-XA	W BF44F	2C-156-158	2C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
922	ESF		2LC-461A-XB	W BF44F	2C-166-167	2C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
923	ESF		2LC-462B-XA	W BF55F	2C-156-158	2C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
924	ESF		2LC-462B-XB	W BF55F	2C-166-167	2C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
925	ESF		2LC-463D-XA	W BF55F	2C-156-158	2C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
926	ESF		2LC-463D-XB	W BF55F	2C-166-167	2C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
927	ESF		2LC-471A-XA	W BF44F	2C-156-158	2C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
928	ESF		2LC-471A-XB	W BF44F	2C-166-167	2C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
929	ESF		2LC-472B-XA	W BF55F	2C-156-158	2C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
930	ESF		2LC-472B-XB	W BF55F	2C-166-167	2C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
931	ESF		2LC-473D-XA	W BF55F	2C-156-158	2C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
932	ESF		2LC-473D-XB	W BF55F	2C-166-167	2C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
933	ESF		2MS-A1	W BFD33S	2C-156-158	2C-157	W 110E163 SH.8	SS	Relay GERS or Specific Qualification
934	ESF		2MS-A2	W BFD33S	2C-156-158	2C-157	W 110E163 SH.8	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
935	ESF		2MS-B1	W BFD33S	2C-166-167	2C-167	W 110E163 SH.8	SS	Relay GERS or Specific Qualification
936	ESF		2MS-B2	W BFD33S	2C-166-167	2C-167	W 110E163 SH.8	SS	Relay GERS or Specific Qualification
937	ESF		2P32A-XA	W BF62F	2C-156-158	2C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
938	ESF		2P32A-XB	W BF62F	2C-166-167	2C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
939	ESF		2P32B-XA	W BF62F	2C-156-158	2C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
940	ESF		2P32B-XB	W BF62F	2C-166-167	2C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
941	ESF		2P32C-XA	W BF62F	2C-156-158	2C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
942	ESF		2P32C-XB	W BF62F	2C-166-167	2C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
943	ESF		2P32D-XA	W BF62F	2C-156-158	2C-156	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
944	ESF		2P32D-XB	W BF62F	2C-166-167	2C-166	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
945	ESF		2P32E-XA	W BF62F	2C-156-158	2C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
946	ESF		2P32E-XB	W BF62F	2C-166-167	2C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
947	ESF		2P32F-XA	W BF62F	2C-156-158	2C-157	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
948	ESF		2P32F-XB	W BF62F	2C-166-167	2C-167	W 110E163 SH.6	SS	Relay GERS or Specific Qualification
949	ESF		2PC-428B-XA	W BF53F	2C-156-158	2C-156	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
950	ESF		2PC-428B-XB	W BF53F	2C-166-167	2C-166	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
951	ESF		2PC-429C-XA	W BF46F	2C-156-158	2C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
952	ESF		2PC-429C-XB	W BF46F	2C-166-167	2C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
953	ESF		2PC-430E-XA	W BF46F	2C-156-158	2C-157	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
954	ESF		2PC-430E-XB	W BF46F	2C-166-167	2C-167	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
955	ESF		2PC-430F-XA	W BF66F	2C-156-158	2C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
956	ESF		2PC-430F-XB	W BF66F	2C-166-167	2C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
957	ESF		2PC-431G-XA	W BF46F	2C-156-158	2C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
958	ESF		2PC-431G-XB	W BF46F	2C-166-167	2C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
959	ESF		2PC-431I-XA	W BF66F	2C-156-158	2C-156	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
960	ESF		2PC-431I-XB	W BF66F	2C-166-167	2C-166	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
961	ESF		2PC-468A-XA	W BF46F	2C-156-158	2C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
962	ESF		2PC-468A-XB	W BF46F	2C-166-167	2C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
963	ESF		2PC-469A-XA	W BF48F	2C-156-158	2C-157	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
964	ESF		2PC-469A-XB	W BF48F	2C-166-167	2C-167	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
965	ESF		2PC-478A-XA	W BF46F	2C-156-158	2C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
966	ESF		2PC-478A-XB	W BF46F	2C-166-167	2C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
967	ESF		2PC-479A-XA	W BF48F	2C-156-158	2C-157	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
968	ESF		2PC-479A-XB	W BF48F	2C-166-167	2C-167	W 110E163 SH.2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
969	ESF		2PC-482A-XA	W BF48F	2C-156-158	2C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
970	ESF		2PC-482A-XB	W BF48F	2C-166-167	2C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
971	ESF		2PC-483A-XA	W BF48F	2C-156-158	2C-156	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
972	ESF		2PC-483A-XB	W BF48F	2C-166-167	2C-166	W 110E163 SH.2	SS	Relay GERS or Specific Qualification
973	ESF		2PC-628-XA	W BF22F	2C-156-158	2C-157	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
974	ESF		2PC-629-XB	W BF22F	2C-166-167	2C-167	W 110E163 SH.5	SS	Relay GERS or Specific Qualification
975	ESF		2PC-945A-XA	W BF46F	2C-156-158	2C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
976	ESF		2PC-945A-XB	W BF46F	2C-166-167	2C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
977	ESF		2PC-945B-XA	W BF44F	2C-156-158	2C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
978	ESF		2PC-945B-XB	W RF44F	2C-166-167	2C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
979	ESF		2PC-946A-XA	W BF46F	2C-156-158	2C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
980	ESF		2PC-946A-XB	W BF46F	2C-166-167	2C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
981	ESF		2PC-946B-XA	W BF44F	2C-156-158	2C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
982	ESF		2PC-946B-XB	W BF44F	2C-166-167	2C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
983	ESF		2PC-947A-XA	W BF48F	2C-156-158	2C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
984	ESF		2PC-947A-XB	W BF48F	2C-166-167	2C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
985	ESF		2PC-947B-XA	W BF55F	2C-156-158	2C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
986	ESF		2PC-947B-XB	W BF55F	2C-166-167	2C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
987	ESF		2PC-948A-XA	W BF48F	2C-156-158	2C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
988	ESF		2PC-948A-XB	W BF48F	2C-166-167	2C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
989	ESF		2PC-948B-XA	W BF55F	2C-156-158	2C-156	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
990	ESF		2PC-948B-XB	W BF55F	2C-166-167	2C-166	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
991	ESF		2PC-949A-XA	W BF48F	2C-156-158	2C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
992	ESF		2PC-949A-XB	W BF48F	2C-166-167	2C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
993	ESF		2PC-949B-XA	W BF55F	2C-156-158	2C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
994	ESF		2PC-949B-XB	W BF55F	2C-166-167	2C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
995	ESF		2PC-950A-XA	W BF48F	2C-156-158	2C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
996	ESF		2PC-950A-XB	W BF48F	2C-166-167	2C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
997	ESF		2PC-950B-XA	W BF55F	2C-156-158	2C-157	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
998	ESF		2PC-950B-XB	W BF55F	2C-166-167	2C-167	W 110E163 SH.4	SS	Relay GERS or Specific Qualification
999	ESF		2SI-10X	W BFD84S	2C-156-158	2C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1000	ESF		2SI-11X	W BFD84S	2C-156-158	2C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1001	ESF		2SI-12X	W BFD84S	2C-156-158	2C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1002	ESF		2SI-13X	W BFD84S	2C-156-158	2C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1003	ESF		2SI-14X	W BFD84S	2C-156-158	2C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1004	ESF		2SI-20X	W BFD84S	2C-166-167	2C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1005	ESF		2SI-21X	W BFD84S	2C-166-167	2C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1006	ESF		2SI-22X	W BFD84S	2C-166-167	2C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1007	ESF		2SI-23X	W BFD84S	2C-166-167	2C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1008	ESF		2SI-24X	W BFD84S	2C-166-167	2C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1009	ESF		2SIA-A	W MG-6	2C-156-158	2C-156	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1010	ESF		2SIA-B	W MG-6	2C-166-167	2C-166	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1011	ESF		2SIB-A	W BFD75S	2C-156-158	2C-156	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1012	ESF		2SIB-B	W BFD75S	2C-166-167	2C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1013	ESF		2SIM-A	W MG-6	2C-156-158	2C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1014	ESF		2SIM-B	W MG-6	2C-166-167	2C-166	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1015	ESF		2SIR-A	W Nbfd65NR	2C-156-158	2C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1016	ESF		2SIR-B	W Nbfd65NR	2C-166-167	2C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1017	ESF		2SW-A	W BFD22S	2C-156-158	2C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
1018	ESF		2SW-AX	W BFD42S	2C-156-158	2C-157	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
1019	ESF		2SW-B	W BFD22S	2C-166-167	2C-167	W 110E163 SH.10	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1020	ESF		2SW-BX	W BFD42S	2C-166-167	2C-167	W 110E163 SH.10	SS	Relay GERS or Specific Qualification
1021	ESF		2TC-401D-XA	W BF66F	2C-156-158	2C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
1022	ESF		2TC-401D-XB	W BF66F	2C-166-167	2C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
1023	ESF		2TC-402D-XA	W BF66F	2C-156-158	2C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
1024	ESF		2TC-402D-XB	W BF66F	2C-166-167	2C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
1025	ESF		2TC-403D-XA	W BF66F	2C-156-158	2C-156	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
1026	ESF		2TC-403D-XB	W BF66F	2C-166-167	2C-166	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
1027	ESF		2TC-404D-XA	W BF66F	2C-156-158	2C-157	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
1028	ESF		2TC-404D-XB	W BF66F	2C-166-167	2C-167	W 110E163 SH.3	SS	Relay GERS or Specific Qualification
1029	ESF		2TDR-10	AGASTAT 2412PD	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1030	ESF		2TDR-11	AGASTAT 2412PD	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1031	ESF		2TDR-12	AGASTAT 2412PE	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1032	ESF		2TDR-13	AGASTAT 2412PD	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1033	ESF		2TDR-14	AGASTAT 2412PD	2C-156-158	2C-156	W 110F163 SH.12A	SS	Relay GERS or Specific Qualification
1034	ESF		2TDR-15	AGASTAT 2412PE	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1035	ESF		2TDR-16	AGASTAT 2412PE	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1036	ESF		2TDR-17	AGASTAT 2412PE	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1037	ESF		2TDR-18	AGASTAT 2412PD	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1038	ESF		2TDR-19	AGASTAT 2412PE	2C-156-158	2C-157	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1039	ESF		2TDR-20	AGASTAT 2412PD	2C-166-167	2C-166	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1040	ESF		2TDR-21	AGASTAT 2412PD	2C-166-167	2C-166	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1041	ESF		2TDR-22	AGASTAT 2412PE	2C-166-167	2C-166	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1042	ESF		2TDR-23	AGASTAT 2412PD	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1043	ESF		2TDR-24	AGASTAT 2412PD	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1044	ESF		2TDR-25	AGASTAT 2412PE	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1045	ESF		2TDR-26	AGASTAT 2412PE	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1046	ESF		2TDR-27	AGASTAT 2412PE	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1047	ESF		2TDR-28	AGASTAT 2412PD	2C-156-158	2C-156	W 110E163 SH.12A	SS	Relay GERS or Specific Qualification
1048	ESF		2TDR-29	AGASTAT 2412PE	2C-166-167	2C-167	W 110E163 SH.7	SS	Relay GERS or Specific Qualification
1049	ESF		2V-10X	W BFD24S	2C-156-158	2C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
1050	ESF		2V-20X	W BFD24S	2C-166-167	2C-167	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
1051	ESF		2VA	W MG-6	2C-156-158	2C-157	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
1052	ESF		2VB	W MG-6	2C-166-167	2C-166	W 110E163 SH.9	SS	Relay GERS or Specific Qualification
1053	ESF		2XAT1	W BFD11S	2C-156-158	2C-157	W 110E163 SH.11	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1054	ESF		2XAT2	W BFD11S	2C-156-158	2C-157	W 110E163 SH.11	SS	Relay GERS or Specific Qualification
1055	ESF		2XBT1	W BFD11S	2C-166-167	2C-167	W 110E163 SH.11	SS	Relay GERS or Specific Qualification
1056	ESF		2XBT2	W BFD11S	2C-166-167	2C-167	W 110E163 SH.11	SS	Relay GERS or Specific Qualification
1057	FO	FO-3930-M	2B42-3210M	CONTACTOR	2B-32	2B32-10M	ELEM 829	SS	Relay GERS or Specific Qualification
1058	FO	FO-3930-M	LS/3930A		T-31A	T-31A	BECH M-219	CA	Circuit/Relay Malfunction Acceptable
1059	FO	FO-3930-M	LS/3930AX	W BFD44S	C-01-1(2)C-04	C-01	ELEM 1511	SS	Relay GERS or Specific Qualification
1060	FO	FO-3930-M	LS/3930BX	W BFD44S	C-01-1(2)C-04	C-01	ELEM 1511	CA9	Circuit/Relay Malfunction Acceptable
1061	FO	FO-3930-M	LS/3931BX	W BFD44S	C-01-1(2)C-04	C-01	ELEM 1511	CA9	Circuit/Relay Malfunction Acceptable
1062	FO	FO-3931-M	1B42-4210M	CONTACTOR	1B-42	1B42-10M	ELEM 829	SS	Relay GERS or Specific Qualification
1063	FO	FO-3931-M	LS/3931A		T-31B	T-31B	BECH M-219	CA	Circuit/Relay Malfunction Acceptable
1064	FO	FO-3931-M	LS/3931AX	W BFD44S	C-01-1(2)C-04	C-01	ELEM 1511	SS	Relay GERS or Specific Qualification
1065	MS	1MS-2017A-S	1-74/MSA	W BFD31S	1C-156-157	1C-157	ELEM 823	CA4	Circuit/Relay Malfunction Acceptable
1066	MS	1MS-2017B-S	1-74/MSB	W BFD31S	1C-158/166/167	1C-167	ELEM 823	CA4	Circuit/Relay Malfunction Acceptable
1067	MS	1MS-2019-M	1-2019X	W BFD66S	C-01-1(2)C-04	1C-03	ELEM 814A	SS	Relay GERS or Specific Qualification
1068	MS	1MS-2019-M	1-62/4044A	AGASTAT 7014 PC	C-01-1(2)C-04	1C-03	ELEM 814A	SS	Relay GERS or Specific Qualification
1069	MS	1MS-2019-M	162A	AGASTAT 2412 PC	1A-02	1A-02	ELEM 1523	CA15	Circuit/Relay Malfunction Acceptable
1070	MS	1MS-2019-M	1B42/S-2019	CONTACTOR	1SMS-2019	1S-2019	ELEM 814	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1071	MS	1MS-2019-M	1PY-4044-LLA	FOXBORO NO152CK - N-2AO-L2C-R	1C-170-173	1C-171	FOXBORO CD1-15	SS	Relay GERS or Specific Qualification
1072	MS	1MS-2020-M	1-2020X	W BFD66S	C-01-1(2)C-04	1C-03	ELEM 814A	SS	Relay GERS or Specific Qualification
1073	MS	1MS-2020-M	1-62/4044B	AGASTAT 7014 PC	C-01-1(2)C-04	1C-03	ELEM 814A	SS	Relay GERS or Specific Qualification
1074	MS	1MS-2020-M	162B	AGASTAT 2412 PC	1A-02	1A-02	ELEM 1523	CA15	Circuit/Relay Malfunction Acceptable
1075	MS	1MS-2020-M	1B42/S-2020	CONTACTOR	1SMS-2020	1S-2020	ELEM 814	SS	Relay GERS or Specific Qualification
1076	MS	1MS-2020-M	1PY-4044-LLB	FOXBORO NO152CK - N-2AO-L2C-R	1C-170-173	1C-171	FOXBORO CD1-15	SS	Relay GERS or Specific Qualification
1077	MS	1MS-2042-S	1-2045X	W BF40F	C-01-1(2)C-04	1C-03	ELEM 826	CA11	Circuit/Relay Malfunction Acceptable
1078	MS	1MS-2042-S	1B52-12C(b)		1B-03	1B52-12C	ELEM 369	CA11	Circuit/Relay Malfunction Acceptable
1079	MS	1MS-2042-S	1CI-12-X3	W Nbfd65NR	C-01-1(2)C-04	C-01	ELEM 1696	CA11	Circuit/Relay Malfunction Acceptable
1080	MS	1MS-2042-S	1CI-21-X3	W Nbfd65NR	C-01-1(2)C-04	C-01	ELEM 1696	CA11	Circuit/Relay Malfunction Acceptable
1081	MS	1MS-2042-S	1PS-5955				ELEM 826	CA11	Circuit/Relay Malfunction Acceptable
1082	MS	1MS-2042-S	1RC-19X	W BF66F	1C-158/166/167	1C-158	W 195A778 SH.24	CA11	Circuit/Relay Malfunction Acceptable
1083	MS	1MS-2042-S	1RC-22X	W BF66F	1C-158/166/167	1C-158	W 195A778 SH.24	CA11	Circuit/Relay Malfunction Acceptable
1084	MS	1MS-2042-S	2B52-31C(b)		2B-04	2B52-31C	ELEM 369	CA11	Circuit/Relay Malfunction Acceptable
1085	MS	1MS-2083-S	1CI-12-X1	W Nbfd65NR	C-01-1(2)C-04	C-01	ELEM 1696	CA11	Circuit/Relay Malfunction Acceptable
1086	MS	1MS-2083-S	1CI-21-X1	W Nbfd65NR	C-01-1(2)C-04	C-01	ELEM 1696	CA11	Circuit/Relay Malfunction Acceptable
1087	MS	2MS-2017A-S	2-74/MSA	W BFD31S	2C-156-158	2C-157	ELEM 874	CA4	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1088	MS	2MS-2017B-S	2-74/MSB	W BFD31S	2C-166-167	2C-167	ELEM 874	CA4	Circuit/Relay Malfunction Acceptable
1089	MS	2MS-2019-M	2-2019X	W BFD66S	C-01-1(2)C-04	2C-03	ELEM 868A	SS	Relay GERS or Specific Qualification
1090	MS	2MS-2019-M	2-62/4044A	AGASTAT 7014 PC	C-01-1(2)C-04	2C-03	ELEM 868A	SS	Relay GERS or Specific Qualification
1091	MS	2MS-2019-M	262A	AGASTAT 2412 PC	2A-02	2A-02	ELEM 1532	CA15	Circuit/Relay Malfunction Acceptable
1092	MS	2MS-2019-M	2B42/S-2019	CONTACTOR	2SMS-2019	2S-2019	ELEM 868	SS	Relay GERS or Specific Qualification
1093	MS	2MS-2019-M	2PY-4044-LLA	FOXBORO N0152CK - N-2AO-L2C-R	2C-170-173	2C-171	FOXBORO CD2-15	SS	Relay GERS or Specific Qualification
1094	MS	2MS-2020-M	2-2020X	W BFD66S	C-01-1(2)C-04	2C-03	ELEM 868A	SS	Relay GERS or Specific Qualification
1095	MS	2MS-2020-M	2-62/4044B	AGASTAT 7014PC	C-01-1(2)C-04	2C-03	ELEM 868A	SS	Relay GERS or Specific Qualification
1096	MS	2MS-2020-M	262B	AGASTAT 2412 PC	2A-02	2A-02	ELEM 1532	CA15	Circuit/Relay Malfunction Acceptable
1097	MS	2MS-2020-M	2B42/S-2020	CONTACTOR	2SMS-2020	2S-2020	ELEM 868	SS	Relay GERS or Specific Qualification
1098	MS	2MS-2020-M	2PY-4044-LLB	FOXBORO N0152CK - N-2AO-L2C-R	2C-170-173	2C-171	FOXBORO CD2-15	SS	Relay GERS or Specific Qualification
1099	MS	2MS-2042-S	2-2045X	W BF40F	C-01-1(2)C-04	2C-03	ELEM 877	CA11	Circuit/Relay Malfunction Acceptable
1100	MS	2MS-2042-S	2PS-5955				ELEM 877	CA11	Circuit/Relay Malfunction Acceptable
1101	MS	2MS-2042-S	2RC-19X	W BF66F	2C-156-158	2C-158	W 195A778 SH.34	CA11	Circuit/Relay Malfunction Acceptable
1102	MS	2MS-2042-S	2RC-22X	W BF66F	2C-156-158	2C-158	W 195A778 SH.34	CA11	Circuit/Relay Malfunction Acceptable
1103	RC	1RC-427-M	1B42-426M	CONTACTOR	1B-42	1B42-6M	ELEM 720	CA13	Circuit/Relay Malfunction Acceptable
1104	RC	1RC-427-M	1LC-427B-X2	W BF22F	C-01-1(2)C-04	1C-03	W 195A778 SH.24	CA13	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1105	RC	1RC-427-M	1LC-428D-X2	W BF22F	C-01-1(2)C-04	1C-03	W 195A778 SH.24	CA13	Circuit/Relay Malfunction Acceptable
1106	RC	1RC-427-M	33X/1-V427	W BF40	1B-42	1B42-6M	ELEM 720	CA13	Circuit/Relay Malfunction Acceptable
1107	RC	1RC-430-S	1CX	W BF22F	C-01-1(2)C-04	1C-04	W 195A778 SH.333A	CA11	Circuit/Relay Malfunction Acceptable
1108	RC	1RC-430-S	1PC-429B-X	W BF84F	C-01-1(2)C-04	1C-03	W 195A778 SH.333	CA11	Circuit/Relay Malfunction Acceptable
1109	RC	1RC-430-S	1PC-430B-X	W BF22F	C-01-1(2)C-04	1C-03	W 195A778 SH.334	CA11	Circuit/Relay Malfunction Acceptable
1110	RC	1RC-430-S	1V-516X	W BF22F	C-01-1(2)C-04	1C-04	W 195A778 SH.454	CA3	Circuit/Relay Malfunction Acceptable
1111	RC	1RC-430-S	D13	P&B KRP11DN	C-01-1(2)C-04	1C-04	ELEM 757D	CA3	Circuit/Relay Malfunction Acceptable
1112	RC	1RC-431C-S	1AX	W BF22F	C-01-1(2)C-04	1C-04	W 195A778 SH.453	CA11	Circuit/Relay Malfunction Acceptable
1113	RC	1RC-431C-S	1PC-431B-X	W BF22F	1C-158/166/167	1C-158	W 195A778 SH.24	CA11	Circuit/Relay Malfunction Acceptable
1114	RC	1RC-431C-S	1PC-449B-X	W BF84F	1C-158/166/167	1C-158	W 195A778 SH.20	CA11	Circuit/Relay Malfunction Acceptable
1115	RC	1RC-431C-S	1V-515X	W BF22F	C-01-1(2)C-04	1C-04	W 195A778 SH.453	CA11	Circuit/Relay Malfunction Acceptable
1116	RC	1RC-431C-S	D10	P&B KRP11DN	C-01-1(2)C-04	1C-04	ELEM 757	CA3	Circuit/Relay Malfunction Acceptable
1117	RC	1RC-515-M	1B42-327F	CONTACTOR	1B-32	1B32-7F	ELEM 716	CA13	Circuit/Relay Malfunction Acceptable
1118	RC	1RC-516-M	1B42-427F	CONTACTOR	1B-42	1B42-7F	ELEM 716	CA13	Circuit/Relay Malfunction Acceptable
1119	RC	2RC-427-M	2B42-426M	CONTACTOR	2B-42	2B42-6M	ELEM 720	CA13	Circuit/Relay Malfunction Acceptable
1120	RC	2RC-427-M	2LC-427B-X2	W BF22F	C-01-1(2)C-04	2C-04	W 195A778 SH.34	CA13	Circuit/Relay Malfunction Acceptable
1121	RC	2RC-427-M	2LC-428D-X2	W BF22F	C-01-1(2)C-04	2C-04	W 195A778 SH.34	CA13	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1122	RC	2RC-427-M	33X/2-V427	W BF40	2B-42	2B42-6M	ELEM 720	CA13	Circuit/Relay Malfunction Acceptable
1123	RC	2RC-430-S	2CX	W BF22F	C-01-1(2)C-04	2C-04	W 195A778 SH.333A	CA11	Circuit/Relay Malfunction Acceptable
1124	RC	2RC-430-S	2PC-429B-X	W BF84F	C-01-1(2)C-04	2C-04	W 195A778 SH.333C	CA11	Circuit/Relay Malfunction Acceptable
1125	RC	2RC-430-S	2PC-430B-X	W BF22F	C-01-1(2)C-04	2C-04	W 195A778 SH.334A	CA11	Circuit/Relay Malfunction Acceptable
1126	RC	2RC-430-S	2V-516X	W BF22F	C-01-1(2)C-04	2C-04	W 195A778 SH.454	CA3	Circuit/Relay Malfunction Acceptable
1127	RC	2RC-430-S	C39	P&B KRP11DN	C-01-1(2)C-04	2C-04	ELEM 757D	CA3	Circuit/Relay Malfunction Acceptable
1128	RC	2RC-431C-S	2AX	W BF22F	C-01-1(2)C-04	2C-04	W 195A778 SH.453	CA11	Circuit/Relay Malfunction Acceptable
1129	RC	2RC-431C-S	2PC-431B-X	W BF22F	2C-156-158	2C-158	W 195A778 SH.34	CA11	Circuit/Relay Malfunction Acceptable
1130	RC	2RC-431C-S	2PC-449B-X	W BF84F	2C-156-158	2C-158	W 195A778 SH.30	CA11	Circuit/Relay Malfunction Acceptable
1131	RC	2RC-431C-S	2V-515X	W BF22F	C-01-1(2)C-04	2C-04	W 195A778 SH.454	CA3	Circuit/Relay Malfunction Acceptable
1132	RC	2RC-431C-S	C36	P&B KRP11DN	C-01-1(2)C-04	2C-04	ELEM 757	CA3	Circuit/Relay Malfunction Acceptable
1133	RC	2RC-515-M	2B42-327F	CONTACTOR	2B-32	2B32-7F	ELEM 716	CA13	Circuit/Relay Malfunction Acceptable
1134	RC	2RC-516-M	2B42-427F	CONTACTOR	2B-42	2B42-7F	ELEM 716	CA13	Circuit/Relay Malfunction Acceptable
1135	RP		1-1/N-31B-XA	W BF66F	1C-151-155	1C-151	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1136	RP		1-1/N-31B-XB	W BF66F	1C-161-165	1C-161	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1137	RP		1-1/N-31B-YA	W BF22F	1C-151-155	1C-151	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1138	RP		1-1/N-31B-YB	W BF22F	1C-161-165	1C-161	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1139	RP		1-1/N-31B-ZA	W BF30F	1C-151-155	1C-151	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1140	RP		1-1/N-31B-ZB	W BF30F	1C-161-165	1C-161	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1141	RP		1-1/N-32B-XA	W BF66F	1C-151-155	1C-152	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1142	RP		1-1/N-32B-XB	W BF66F	1C-161-165	1C-162	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1143	RP		1-1/N-32B-YA	W BF22F	1C-151-155	1C-152	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1144	RP		1-1/N-32B-YB	W BF22F	1C-161-165	1C-162	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1145	RP		1-1/N-32B-ZA	W BF30F	1C-151-155	1C-152	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1146	RP		1-1/N-32B-ZB	W BF30F	1C-161-165	1C-162	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1147	RP		1-1/N-33A-XA	W BF66F	1C-151-155	1C-153	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1148	RP		1-1/N-33A-YA	W BF22F	1C-151-155	1C-153	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1149	RP		1-1/N-33A-ZA	W BF30F	1C-151-155	1C-153	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1150	RP		1-1/N-33B-XB	W BF66F	1C-161-165	1C-163	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1151	RP		1-1/N-33B-YB	W BF22F	1C-161-165	1C-163	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1152	RP		1-1/N-33B-ZB	W BF30F	1C-161-165	1C-163	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1153	RP		1-1/N-35A-XA	W BF66F	1C-151-155	1C-151	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1154	RP		1-1/N-35A-XB	W BF66F	1C-161-165	1C-161	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1155	RP		1-1/N-35A-YA	W BF22F	1C-151-155	1C-151	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1156	RP		1-1/N-35A-YB	W BF22F	1C-161-165	1C-161	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1157	RP		1-1/N-35A-ZA	W BF30F	1C-151-155	1C-151	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1158	RP		1-1/N-35A-ZB	W BF30F	1C-161-165	1C-161	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1159	RP		1-1/N-36A-XA	W BF66F	1C-151-155	1C-152	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1160	RP		1-1/N-36A-XB	W BF66F	1C-161-165	1C-162	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1161	RP		1-1/N-36A-YA	W BF22F	1C-151-155	1C-152	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1162	RP		1-1/N-36A-YB	W BF22F	1C-161-165	1C-162	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1163	RP		1-1/N-36A-ZA	W BF30F	1C-151-155	1C-152	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1164	RP		1-1/N-36A-ZB	W BF30F	1C-161-165	1C-162	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1165	RP		1-1/N-38A-XA	W BF66F	1C-151-155	1C-153	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1166	RP		1-1/N-38A-YA	W BF22F	1C-151-155	1C-153	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1167	RP		1-1/N-38A-ZA	W BF30F	1C-151-155	1C-153	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1168	RP		1-1/N-38B-XB	W BF66F	1C-161-165	1C-163	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1169	RP		1-1/N-38B-YB	W BF22F	1C-161-165	1C-163	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1170	RP		1-1/N-38B-ZB	W BF30F	1C-161-165	1C-163	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1171	RP		1-1/N-39A-XA	W Nbfd66S	1C-151-155	1C-151	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1172	RP		1-1/N-39A-XB	W Nbfd66S	1C-161-165	1C-161	617F354 SH6B2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1173	RP		1-1/N-39A-YA	W BF22F	1C-151-155	1C-151	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1174	RP		1-1/N-39A-YB	W BF22F	1C-161-165	1C-161	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1175	RP		1-1/N-39B-XA	W Nbfd66S	1C-151-155	1C-151	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1176	RP		1-1/N-39B-XB	W Nbfd66S	1C-161-165	1C-161	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1177	RP		1-1/N-39B-YA	W BF22F	1C-151-155	1C-151	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1178	RP		1-1/N-39B-YB	W BF22F	1C-161-165	1C-161	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1179	RP		1-1/N-41K-XA	W BF66F	1C-151-155	1C-151	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1180	RP		1-1/N-41K-XB	W BF66F	1C-161-165	1C-161	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1181	RP		1-1/N-42K-XA	W BF66F	1C-151-155	1C-152	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1182	RP		1-1/N-42K-XB	W BF66F	1C-161-165	1C-162	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1183	RP		1-1/N-43K-XA	W BF66F	1C-151-155	1C-153	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1184	RP		1-1/N-43K-XB	W BF66F	1C-161-165	1C-163	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1185	RP		1-1/N-44K-XA	W BF66F	1C-151-155	1C-154	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1186	RP		1-1/N-44K-XB	W BF66F	1C-161-165	1C-164	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1187	RP		1-1/N-47A-XA	W BF66F	1C-151-155	1C-154	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1188	RP		1-1/N-47A-YA	W BF22F	1C-151-155	1C-154	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1189	RP		1-1/N-47A-ZA	W BF30F	1C-151-155	1C-154	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1190	RP		1-1/N-47B-XB	W BF66F	1C-161-165	1C-164	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1191	RP		1-1/N-47B-YB	W BF22F	1C-161-165	1C-164	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1192	RP		1-1/N-47B-ZB	W BF30F	1C-161-165	1C-164	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1193	RP		1-273/A01-XA	W Nbfd66S	1C-151-155	1C-151	617F354 SH10A1	SS	Relay GERS or Specific Qualification
1194	RP		1-273/A01-XB	W Nbfd66S	1C-161-165	1C-161	617F354 SH10B1	SS	Relay GERS or Specific Qualification
1195	RP		1-273/A01-YA	W BF22F	1C-151-155	1C-151	617F354 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1196	RP		1-273/A01-YB	W BF22F	1C-161-165	1C-161	617F354 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1197	RP		1-273/A02-XA	W Nbfd66S	1C-151-155	1C-153	617F354 SH10A1	SS	Relay GERS or Specific Qualification
1198	RP		1-273/A02-XB	W Nbfd66S	1C-161-165	1C-163	617F354 SH10B1	SS	Relay GERS or Specific Qualification
1199	RP		1-273/A02-YA	W BF22F	1C-151-155	1C-153	617F354 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1200	RP		1-273/A02-YB	W BF22F	1C-161-165	1C-163	617F354 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1201	RP		1-274/A01-XA	W Nbfd66S	1C-151-155	1C-152	617F354 SH10A1	SS	Relay GERS or Specific Qualification
1202	RP		1-274/A01-XB	W Nbfd66S	1C-161-165	1C-162	617F354 SH10B1	SS	Relay GERS or Specific Qualification
1203	RP		1-274/A01-YA	W BF22F	1C-151-155	1C-152	617F354 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1204	RP		1-274/A01-YB	W BF22F	1C-161-165	1C-162	617F354 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1205	RP		1-274/A02-XA	W Nbfd66S	1C-151-155	1C-154	617F354 SH10A1	SS	Relay GERS or Specific Qualification
1206	RP		1-274/A02-XB	W Nbfd66S	1C-161-165	1C-164	617F354 SH10B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1207	RP		1-274/A02-YA	W BF22F	1C-151-155	1C-154	617F354 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1208	RP		1-274/A02-YB	W BF22F	1C-161-165	1C-164	617F354 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1209	RP		1-33AC-SL-XA	W Nbfd66S	1C-151-155	1C-153	617F354 SH10A2	SS	Relay GERS or Specific Qualification
1210	RP		1-33AC-SL-XB	W Nbfd66S	1C-161-165	1C-163	617F354 SH10B2	SS	Relay GERS or Specific Qualification
1211	RP		1-33AC-SL-YA	W BF22F	1C-151-155	1C-153	617F354 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1212	RP		1-33AC-SL-YB	W BF22F	1C-161-165	1C-163	617F354 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1213	RP		1-33AC-SR-XA	W Nbfd66S	1C-151-155	1C-154	617F354 SH10A2	SS	Relay GERS or Specific Qualification
1214	RP		1-33AC-SR-XB	W Nbfd66S	1C-161-165	1C-164	617F354 SH10B2	SS	Relay GERS or Specific Qualification
1215	RP		1-33AC-SR-YA	W BF22F	1C-151-155	1C-154	617F354 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1216	RP		1-33AC-SR-YB	W BF22F	1C-161-165	1C-164	617F354 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1217	RP		1-63/AST3-XA	W Nbfd66S	1C-151-155	1C-152	617F354 SH10A2	SS	Relay GERS or Specific Qualification
1218	RP		1-63/AST3-XB	W Nbfd66S	1C-161-165	1C-162	617F354 SH10B2	SS	Relay GERS or Specific Qualification
1219	RP		1-63/AST3-YA	W BF22F	1C-151-155	1C-152	617F354 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1220	RP		1-63/AST3-YB	W BF22F	1C-161-165	1C-162	617F354 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1221	RP		1-63/AST4-XA	W Nbfd66S	1C-151-155	1C-153	617F354 SH10A2	SS	Relay GERS or Specific Qualification
1222	RP		1-63/AST4-XB	W Nbfd66S	1C-161-165	1C-163	617F354 SH10B2	SS	Relay GERS or Specific Qualification
1223	RP		1-63/AST4-YA	W BF22F	1C-151-155	1C-153	617F354 SH10A2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1224	RP		1-63/AST4-YB	W BF22F	1C-161-165	1C-163	617F354 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1225	RP		1-63/AST5-XA	W Nbfd66S	1C-151-155	1C-154	617F354 SH10A2	SS	Relay GERS or Specific Qualification
1226	RP		1-63/AST5-XB	W Nbfd66S	1C-161-165	1C-164	617F354 SH10B2	SS	Relay GERS or Specific Qualification
1227	RP		1-63/AST5-YA	W BF22F	1C-151-155	1C-154	617F354 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1228	RP		1-63/AST5-YB	W BF22F	1C-161-165	1C-164	617F354 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1229	RP		1A52-06-XA	W Nbfd66S	1C-151-155	1C-153	617F354 SH10A2	SS	Relay GERS or Specific Qualification
1230	RP		1A52-06-XB	W Nbfd66S	1C-161-165	1C-163	617F354 SH10B2	SS	Relay GERS or Specific Qualification
1231	RP		1A52-06-YA	W BF22F	1C-151-155	1C-153	617F354 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1232	RP		1A52-06-YB	W BF22F	1C-161-165	1C-163	617F354 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1233	RP		1A52-12-XA	W Nbfd66S	1C-151-155	1C-154	617F354 SH10A2	SS	Relay GERS or Specific Qualification
1234	RP		1A52-12-XB	W Nbfd66S	1C-161-165	1C-164	617F354 SH10B2	SS	Relay GERS or Specific Qualification
1235	RP		1A52-12-YA	W BF22F	1C-151-155	1C-154	617F354 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1236	RP		1A52-12-YB	W BF22F	1C-161-165	1C-164	617F354 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1237	RP		1FC-411-XA	W BF66F	1C-151-155	1C-151	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1238	RP		1FC-411-XB	W BF66F	1C-161-165	1C-161	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1239	RP		1FC-411-YA	W BF22F	1C-151-155	1C-151	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1240	RP		1FC-411-YB	W BF22F	1C-161-165	1C-161	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1241	RP		1FC-412-XA	W BF66F	1C-151-155	1C-152	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1242	RP		1FC-412-XB	W BF66F	1C-161-165	1C-162	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1243	RP		1FC-412-YA	W BF22F	1C-151-155	1C-152	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1244	RP		1FC-412-YB	W BF22F	1C-161-165	1C-162	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1245	RP		1FC-413-XA	W BF66F	1C-151-155	1C-153	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1246	RP		1FC-413-XB	W BF66F	1C-161-165	1C-163	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1247	RP		1FC-413-YA	W BF22F	1C-151-155	1C-153	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1248	RP		1FC-413-YB	W BF22F	1C-161-165	1C-163	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1249	RP		1FC-414-XA	W BF66F	1C-151-155	1C-151	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1250	RP		1FC-414-XB	W BF66F	1C-161-165	1C-161	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1251	RP		1FC-414-YA	W BF22F	1C-151-155	1C-151	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1252	RP		1FC-414-YB	W BF22F	1C-161-165	1C-161	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1253	RP		1FC-415-XA	W BF66F	1C-151-155	1C-153	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1254	RP		1FC-415-XB	W BF66F	1C-161-165	1C-163	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1255	RP		1FC-415-YA	W BF22F	1C-151-155	1C-153	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1256	RP		1FC-415-YB	W BF22F	1C-161-165	1C-163	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1257	RP		1FC-416-XA	W BF66F	1C-151-155	1C-154	617F354 SH9A1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1258	RP		1FC-416-XB	W BF66F	1C-161-165	1C-164	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1259	RP		1FC-416-YA	W BF22F	1C-151-155	1C-154	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1260	RP		1FC-416-YB	W BF22F	1C-161-165	1C-164	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1261	RP		1FC-466C-XA	W BF66F	1C-151-155	1C-151	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1262	RP		1FC-466C-XB	W BF66F	1C-161-165	1C-161	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1263	RP		1FC-466C-YA	W BF22F	1C-151-155	1C-151	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1264	RP		1FC-466C-YB	W BF22F	1C-161-165	1C-161	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1265	RP		1FC-467B-XA	W BF66F	1C-151-155	1C-152	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1266	RP		1FC-467B-XB	W BF66F	1C-161-165	1C-162	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1267	RP		1FC-467B-YA	W BF22F	1C-151-155	1C-152	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1268	RP		1FC-467B-YB	W BF22F	1C-161-165	1C-162	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1269	RP		1FC-476C-XA	W BF66F	1C-151-155	1C-153	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1270	RP		1FC-476C-XB	W BF66F	1C-161-165	1C-163	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1271	RP		1FC-476C-YA	W BF66F	1C-151-155	1C-153	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1272	RP		1FC-476C-YB	W BF22F	1C-161-165	1C-163	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1273	RP		1FC-477B-XA	W BF66F	1C-151-155	1C-154	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1274	RP		1FC-477B-XB	W BF66F	1C-161-165	1C-164	617F354 SH7B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1275	RP		1FC-477B-YA	W BF22F	1C-151-155	1C-154	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1276	RP		1FC-477B-YB	W BF22F	1C-161-165	1C-164	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1277	RP		1IRB-1A	W Nbfd66S	1C-151-155	1C-153	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1278	RP		1IRB-1B	W Nbfd66S	1C-161-165	1C-163	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1279	RP		1IRB-2A	W Nbfd66S	1C-151-155	1C-153	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1280	RP		1IRB-2B	W Nbfd66S	1C-161-165	1C-163	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1281	RP		1LC-426A-XA	W BF66F	1C-151-155	1C-151	617F354 SH8A2	SS	Relay GERS or Specific Qualification
1282	RP		1LC-426A-XB	W BF66F	1C-161-165	1C-161	617F354 SH8B2	SS	Relay GERS or Specific Qualification
1283	RP		1LC-426A-YA	W BF22F	1C-151-155	1C-151	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1284	RP		1LC-426A-YB	W BF22F	1C-161-165	1C-161	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1285	RP		1LC-427A-XA	W BF66F	1C-151-155	1C-152	617F354 SH8A2	SS	Relay GERS or Specific Qualification
1286	RP		1LC-427A-XB	W BF66F	1C-161-165	1C-162	617F354 SH8B2	SS	Relay GERS or Specific Qualification
1287	RP		1LC-427A-YA	W BF22F	1C-151-155	1C-152	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1288	RP		1LC-427A-YB	W BF22F	1C-161-165	1C-162	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1289	RP		1LC-428A-XA	W BF66F	1C-151-155	1C-153	617F354 SH8A2	SS	Relay GERS or Specific Qualification
1290	RP		1LC-428A-XB	W BF66F	1C-161-165	1C-163	617F354 SH8B2	SS	Relay GERS or Specific Qualification
1291	RP		1LC-428A-YA	W BF22F	1C-151-155	1C-153	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1292	RP		1LC-428A-YB	W BF22F	1C-161-165	1C-163	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1293	RP		1LC-461B-XA	W BF57F	1C-151-155	1C-151	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1294	RP		1LC-461B-XB	W BF57F	1C-161-165	1C-161	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1295	RP		1LC-461B-YA	W BF57F	1C-151-155	1C-151	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1296	RP		1LC-461B-YB	W BF57F	1C-161-165	1C-161	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1297	RP		1LC-462A-XA	W BF57F	1C-151-155	1C-153	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1298	RP		1LC-462A-XB	W BF57F	1C-161-165	1C-163	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1299	RP		1LC-462A-YA	W BF57F	1C-151-155	1C-153	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1300	RP		1LC-462A-YB	W BF57F	1C-161-165	1C-163	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1301	RP		1LC-462C-XA	W BF66F	1C-151-155	1C-153	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1302	RP		1LC-462C-XB	W BF66F	1C-161-165	1C-163	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1303	RP		1LC-462C-YA	W BF22F	1C-151-155	1C-153	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1304	RP		1LC-462C-YB	W BF22F	1C-161-165	1C-163	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1305	RP		1LC-463C-XA	W BF57F	1C-151-155	1C-154	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1306	RP		1LC-463C-XB	W BF57F	1C-161-165	1C-164	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1307	RP		1LC-463C-YA	W BF57F	1C-151-155	1C-154	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1308	RP		1LC-463C-YB	W BF57F	1C-161-165	1C-164	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1309	RP		1LC-463E-XA	W BF66F	1C-151-155	1C-154	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1310	RP		1LC-463E-XB	W BF66F	1C-161-165	1C-164	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1311	RP		1LC-463E-YA	W BF22F	1C-151-155	1C-154	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1312	RP		1LC-463E-YB	W BF22F	1C-161-165	1C-164	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1313	RP		1LC-471B-XA	W BF57F	1C-151-155	1C-154	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1314	RP		1LC-471B-XB	W BF57F	1C-161-165	1C-164	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1315	RP		1LC-471B-YA	W BF57F	1C-151-155	1C-154	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1316	RP		1LC-471B-YB	W BF57F	1C-161-165	1C-164	617F354 CH7B2	CA19	Circuit/Relay Malfunction Acceptable
1317	RP		1LC-472A-XA	W BF57F	1C-151-155	1C-151	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1318	RP		1LC-472A-XB	W BF57F	1C-161-165	1C-161	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1319	RP		1LC-472A-YA	W BF57F	1C-151-155	1C-151	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1320	RP		1LC-472A-YB	W BF57F	1C-161-165	1C-161	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1321	RP		1LC-472C-XA	W BF66F	1C-151-155	1C-151	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1322	RP		1LC-472C-XB	W BF66F	1C-161-165	1C-161	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1323	RP		1LC-472C-YA	W BF22F	1C-151-155	1C-151	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1324	RP		1LC-472C-YB	W BF22F	1C-161-165	1C-161	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1325	RP		1LC-473C-XA	W BF57F	1C-151-155	1C-152	617F354 SH7A2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1326	RP		1LC-473C-XB	W BF57F	1C-161-165	1C-162	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1327	RP		1LC-473C-YA	W BF57F	1C-151-155	1C-152	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1328	RP		1LC-473C-YB	W BF57F	1C-161-165	1C-162	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1329	RP		1LC-473E-XA	W BF66F	1C-151-155	1C-152	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1330	RP		1LC-473E-XB	W BF66F	1C-161-165	1C-162	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1331	RP		1LC-473E-YA	W BF22F	1C-151-155	1C-152	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1332	RP		1LC-473E-YB	W BF22F	1C-161-165	1C-162	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1333	RP		1NC-31D-XA	W BF66F	1C-151-155	1C-151	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1334	RP		1NC-31D-XB	W BF66F	1C-161-165	1C-161	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1335	RP		1NC-31D-YA	W BF22F	1C-151-155	1C-151	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1336	RP		1NC-31D-YB	W BF22F	1C-161-165	1C-161	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1337	RP		1NC-32D-XA	W BF66F	1C-151-155	1C-152	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1338	RP		1NC-32D-XB	W BF66F	1C-161-165	1C-162	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1339	RP		1NC-32D-YA	W BF22F	1C-151-155	1C-152	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1340	RP		1NC-32D-YB	W BF22F	1C-161-165	1C-162	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1341	RP		1NC-35D-XA	W BF66F	1C-151-155	1C-151	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1342	RP		1NC-35D-XB	W BF66F	1C-161-165	1C-161	617F354 SH6B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1343	RP		1NC-35D-YA	W BF22F	1C-151-155	1C-151	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1344	RP		1NC-35D-YB	W BF22F	1C-161-165	1C-161	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1345	RP		1NC-35D-ZA	W BF30F	1C-151-155	1C-151	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1346	RP		1NC-35D-ZB	W BF30F	1C-161-165	1C-161	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1347	RP		1NC-35F-XA	W BF66F	1C-151-155	1C-151	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1348	RP		1NC-35F-XB	W BF66F	1C-161-165	1C-161	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1349	RP		1NC-35F-YA	W BF22F	1C-151-155	1C-151	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1350	RP		1NC-35F-YB	W BF22F	1C-161-165	1C-161	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1351	RP		1NC-35F-ZA	W BF30F	1C-151-155	1C-151	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1352	RP		1NC-35F-ZB	W BF30	1C-161-165	1C-161	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1353	RP		1NC-36D-XA	W BF66F	1C-151-155	1C-152	617F354 SH6A1	SS	Relay GERS or Specific Qualification
1354	RP		1NC-36D-XB	W BF66F	1C-161-165	1C-162	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1355	RP		1NC-36D-YA	W BF22F	1C-151-155	1C-152	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1356	RP		1NC-36D-YB	W BF22F	1C-161-165	1C-162	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1357	RP		1NC-36D-ZA	W BF30F	1C-151-155	1C-152	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1358	RP		1NC-36D-ZB	W BF30F	1C-161-165	1C-162	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1359	RP		1NC-36F-XA	W BF66F	1C-151-155	1C-152	617F354 SH6A1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1360	RP		1NC-36F-XB	W BF66F	1C-161-165	1C-162	617F354 SH6B1	SS	Relay GERS or Specific Qualification
1361	RP		1NC-36F-YA	W BF22F	1C-151-155	1C-152	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1362	RP		1NC-36F-YB	W BF22F	1C-161-165	1C-162	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1363	RP		1NC-36F-ZA	W BF30F	1C-151-155	1C-152	617F354 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1364	RP		1NC-36F-ZB	W BF30F	1C-161-165	1C-162	617F354 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1365	RP		1NC-41K-XA	W BF66F	1C-151-155	1C-151	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1366	RP		1NC-41K-XB	W BF66F	1C-161-165	1C-161	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1367	RP		1NC-41M-XA	W BF66F	1C-151-155	1C-151	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1368	RP		1NC-41M-XB	W BF66F	1C-161-165	1C-161	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1369	RP		1NC-41M-YA	W BF22F	1C-151-155	1C-151	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1370	RP		1NC-41M-YB	W BF22F	1C-161-165	1C-161	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1371	RP		1NC-41M-ZA	W BF30F	1C-151-155	1C-151	617F354 SH6A2	CA19	Circuit/Relay Malfunction: Acceptable
1372	RP		1NC-41M-ZB	W BF30F	1C-161-165	1C-161	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1373	RP		1NC-41N-XA	W BF66F	1C-151-155	1C-151	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1374	RP		1NC-41N-XB	W BF66F	1C-161-165	1C-161	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1375	RP		1NC-41N-YA	W BF22F	1C-151-155	1C-151	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1376	RP		1NC-41N-YB	W BF22F	1C-161-165	1C-161	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1377	RP		1NC-41P-XA	W BF66F	1C-151-15E	1C-151	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1378	RP		1NC-41P-XB	W BF66F	1C-161-165	1C-161	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1379	RP		1NC-41P-YA	W BF22F	1C-151-155	1C-151	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1380	RP		1NC-41P-YB	W BF22F	1C-161-165	1C-161	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1381	RP		1NC-41P-ZA	W BF30F	1C-151-155	1C-151	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1382	RP		1NC-41P-ZB	W BF30F	1C-161-165	1C-161	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1383	RP		1NC-41R-XA	W BF66F	1C-151-155	1C-151	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1384	RP		1NC-41R-XB	W BF66F	1C-161-165	1C-161	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1385	RP		1NC-41R-YA	W BF22F	1C-151-155	1C-151	617F354 SH8A1	CA19	Circuit/Relay Malfunction Acceptable
1386	RP		1NC-41R-YB	W BF22F	1C-161-165	1C-161	617F354 SH8B1	CA19	Circuit/Relay Malfunction Acceptable
1387	RP		1NC-41S-XA	W BF66F	1C-151-155	1C-151	617F354 SH10A1	SS	Relay GERS or Specific Qualification
1388	RP		1NC-41S-XB	W BF66F	1C-161-165	1C-161	617F354 SH10B1	SS	Relay GERS or Specific Qualification
1389	RP		1NC-41S-YA	W BF22F	1C-151-155	1C-151	617F354 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1390	RP		1NC-41S-YB	W BF22F	1C-161-165	1C-161	617F354 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1391	RP		1NC-42K-XA	W BF66F	1C-151-155	1C-152	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1392	RP		1NC-42K-XB	W BF66F	1C-161-165	1C-162	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1393	RP		1NC-42M-XA	W BF66F	1C-151-155	1C-152	617F354 SH6A2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1394	RP		1NC-42M-XB	W BF66F	1C-161-165	1C-162	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1395	RP		1NC-42M-YA	W BF22F	1C-151-155	1C-152	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1396	RP		1NC-42M-YB	W BF22F	1C-161-165	1C-162	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1397	RP		1NC-42M-ZA	W BF30F	1C-151-155	1C-152	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1398	RP		1NC-42M-ZB	W BF30F	1C-161-165	1C-162	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1399	RP		1NC-42N-XA	W BF66F	1C-151-155	1C-152	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1400	RP		1NC-42N-XB	W BF66F	1C-161-165	1C-162	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1401	RP		1NC-42N-YA	W BF22F	1C-151-155	1C-152	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1402	RP		1NC-42N-YB	W BF22F	1C-161-165	1C-162	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1403	RP		1NC-42P-XA	W BF66F	1C-151-155	1C-152	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1404	RP		1NC-42P-XB	W BF66F	1C-161-165	1C-162	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1405	RP		1NC-42P-YA	W BF22F	1C-151-155	1C-152	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1406	RP		1NC-42P-YB	W BF22F	1C-161-165	1C-162	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1407	RP		1NC-42P-ZA	W BF30F	1C-151-155	1C-152	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1408	RP		1NC-42P-ZB	W BF30F	1C-161-165	1C-162	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1409	RP		1NC-42R-XA	W BF66F	1C-151-155	1C-152	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1410	RP		1NC-42R-XB	W BF66F	1C-161-165	1C-162	617F354 SH8B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1411	RP		1NC-42R-YA	W BF22F	1C-151-155	1C-152	617F354 SH8A1	CA19	Circuit/Relay Malfunction Acceptable
1412	RP		1NC-42R-YB	W BF22F	1C-161-165	1C-162	617F354 SH8B1	CA19	Circuit/Relay Malfunction Acceptable
1413	RP		1NC-42S-XA	W BF66F	1C-151-155	1C-152	617F354 SH10A1	SS	Relay GERS or Specific Qualification
1414	RP		1NC-42S-XB	W BF66F	1C-161-165	1C-162	617F354 SH10B1	SS	Relay GERS or Specific Qualification
1415	RP		1NC-42S-YA	W BF22F	1C-151-155	1C-152	617F354 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1416	RP		1NC-42S-YB	W BF22F	1C-161-165	1C-162	617F354 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1417	RP		1NC-43K-XA	W BF66F	1C-151-155	1C-153	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1418	RP		1NC-43K-XB	W BF66F	1C-161-165	1C-163	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1419	RP		1NC-43M-XA	W BF66F	1C-151-155	1C-153	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1420	RP		1NC-43M-XB	W BF66F	1C-161-165	1C-163	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1421	RP		1NC-43M-YA	W BF22F	1C-151-155	1C-153	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1422	RP		1NC-43M-YB	W BF22F	1C-161-165	1C-163	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1423	RP		1NC-43M-ZA	W BF30F	1C-151-155	1C-153	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1424	RP		1NC-43M-ZB	W BF30F	1C-161-165	1C-163	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1425	RP		1NC-43N-XA	W BF66F	1C-151-155	1C-153	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1426	RP		1NC-43N-XB	W BF66F	1C-161-165	1C-163	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1427	RP		1NC-43N-YA	W BF22F	1C-151-155	1C-153	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1428	RP		1NC-43N-YB	W BF22F	1C-161-165	1C-163	617F354 SH9E1	CA19	Circuit/Relay Malfunction Acceptable
1429	RP		1NC-43P-XA	W BF66F	1C-151-155	1C-153	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1430	RP		1NC-43P-XB	W BF66F	1C-161-165	1C-163	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1431	RP		1NC-43P-YA	W BF22F	1C-151-155	1C-153	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1432	RP		1NC-43P-YB	W BF22F	1C-161-165	1C-163	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1433	RP		1NC-43P-ZA	W BF30F	1C-151-155	1C-153	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1434	RP		1NC-43P-ZB	W BF30F	1C-161-165	1C-163	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1435	RP		1NC-43R-XA	W BF66F	1C-151-155	1C-153	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1436	RP		1NC-43R-XB	W BF66F	1C-161-165	1C-163	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1437	RP		1NC-43R-YA	W BF22F	1C-151-155	1C-153	617F354 SH8A1	CA19	Circuit/Relay Malfunction Acceptable
1438	RP		1NC-43R-YB	W BF22F	1C-161-165	1C-163	617F354 SH8B1	CA19	Circuit/Relay Malfunction Acceptable
1439	RP		1NC-43S-XA	W BF66F	1C-151-155	1C-153	617F354 SH10A1	SS	Relay GERS or Specific Qualification
1440	RP		1NC-43S-XB	W BF66F	1C-161-165	1C-163	617F354 SH10B1	SS	Relay GERS or Specific Qualification
1441	RP		1NC-43S-YA	W BF22F	1C-151-155	1C-153	617F354 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1442	RP		1NC-43S-YB	W BF22F	1C-161-165	1C-163	617F354 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1443	RP		1NC-44K-XA	W BF66F	1C-151-155	1C-154	617F354 SH8A1	SS	Relay GERS or Specific Qualification
1444	RP		1NC-44K-XB	W BF66F	1C-161-165	1C-164	617F354 SH8B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1445	RP		1NC-44M-XA	W BF66F	1C-151-155	1C-154	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1446	RP		1NC-44M-XB	W BF66F	1C-161-165	1C-164	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1447	RP		1NC-44M-YA	W BF22F	1C-151-155	1C-154	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1448	RP		1NC-44M-YB	W BF22F	1C-161-165	1C-164	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1449	RP		1NC-44M-ZA	W BF30F	1C-151-155	1C-154	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1450	RP		1NC-44M-ZB	W BF30F	1C-161-165	1C-164	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1451	RP		1NC-44N-XA	W BF66F	1C-151-155	1C-154	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1452	RP		1NC-44N-XB	W BF66F	1C-161-165	1C-164	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1453	RP		1NC-44N-YA	W BF22F	1C-151-155	1C-154	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1454	RP		1NC-44N-YB	W BF22F	1C-161-165	1C-164	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1455	RP		1NC-44P-XA	W BF66F	1C-151-155	1C-154	617F354 SH6A2	SS	Relay GERS or Specific Qualification
1456	RP		1NC-44P-XB	W BF66F	1C-161-165	1C-164	617F354 SH6B2	SS	Relay GERS or Specific Qualification
1457	RP		1NC-44P-YA	W BF22F	1C-151-155	1C-154	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1458	RP		1NC-44P-YB	W BF22F	1C-161-165	1C-164	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1459	RP		1NC-44P-ZA	W BF30F	1C-151-155	1C-154	617F354 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1460	RP		1NC-44P-ZB	W BF30F	1C-161-165	1C-164	617F354 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1461	RP		1NC-44R-XA	W BF66F	1C-151-155	1C-154	617F354 SH8A1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1462	RP		1NC-44R-XB	W BF66F	1C-161-165	1C-164	617F354 SH8B1	SS	Relay GERS or Specific Qualification
1463	RP		1NC-44R-YA	W BF22F	1C-151-155	1C-154	617F354 SH8A1	CA19	Circuit/Relay Malfunction Acceptable
1464	RP		1NC-44R-YB	W BF22F	1C-161-165	1C-164	617F354 SH8B1	CA19	Circuit/Relay Malfunction Acceptable
1465	RP		1NC-44S-XA	W BF66F	1C-151-155	1C-154	617F354 SH10A1	SS	Relay GERS or Specific Qualification
1466	RP		1NC-44S-XB	W BF66F	1C-161-165	1C-164	617F354 SH10B1	SS	Relay GERS or Specific Qualification
1467	RP		1NC-44S-YA	W BF22F	1C-151-155	1C-154	617F354 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1468	RP		1NC-44S-YB	W BF22F	1C-161-165	1C-164	617F354 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1469	RP		1P07-1A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1470	RP		1P07-1B	W Nbfd84S	1C-161-165	1C-164	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1471	RP		1P07-2A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1472	RP		1P07-2B	W Nbfd84S	1C-161-165	1C-164	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1473	RP		1P07-3A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1474	RP		1P07-3B	W Nbfd84S	1C-161-165	1C-164	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1475	RP		1P08-1A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1476	RP		1P08-1B	W Nbfd66S	1C-161-165	1C-164	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1477	RP		1P08-2A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1478	RP		1P08-2B	W Nbfd66S	1C-161-165	1C-164	617F354 SH4B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1479	RP		1P09-1A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1480	RP		1P09-1B	W Nbfd66S	1C-161-165	1C-164	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1481	RP		1P09-2A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1482	RP		1P09-2B	W Nbfd66S	1C-161-165	1C-164	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1483	RP		1P10-1A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1484	RP		1P10-1B	W Nbfd66S	1C-161-165	1C-164	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1485	RP		1P10-2A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1486	RP		1P10-2B	W Nbfd66S	1C-161-165	1C-164	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1487	RP		1PC-429A-XA	W BF66F	1C-151-155	1C-151	617F354 SH8A2	SS	Relay GERS or Specific Qualification
1488	RP		1PC-429A-XB	W BF66F	1C-161-165	1C-161	617F354 SH8B2	SS	Relay GERS or Specific Qualification
1489	RP		1PC-429A-YA	W BF22F	1C-151-155	1C-151	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1490	RP		1PC-429A-YB	W BF22F	1C-161-165	1C-161	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1491	RP		1PC-429E-XA	W BF66F	1C-151-155	1C-151	617F354 SH8A2	SS	Relay GERS or Specific Qualification
1492	RP		1PC-429E-XB	W BF66F	1C-161-165	1C-161	617F354 SH8B2	SS	Relay GERS or Specific Qualification
1493	RP		1PC-429E-YA	W BF22F	1C-151-155	1C-151	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1494	RP		1PC-429E-YB	W BF22F	1C-161-165	1C-161	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1495	RP		1PC-430A-XA	W BF66F	1C-151-155	1C-152	617F354 SH8A2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1496	RP		1PC-430A-XB	W BF66F	1C-161-165	1C-162	617F354 SH8B2	SS	Relay GERS or Specific Qualification
1497	RP		1PC-430A-YA	W BF22F	1C-151-155	1C-152	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1498	RP		1PC-430A-YB	W BF22F	1C-161-165	1C-162	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1499	RP		1PC-430H-XA	W BF66F	1C-151-155	1C-152	617F354 SH8A2	SS	Relay GERS or Specific Qualification
1500	RP		1PC-430H-XB	W BF66F	1C-161-165	1C-162	617F354 SH8B2	SS	Relay GERS or Specific Qualification
1501	RP		1PC-430H-YA	W BF22F	1C-151-155	1C-152	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1502	RP		1PC-430H-YB	W BF22F	1C-161-165	1C-162	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1503	RP		1PC-431A-XA	W BF66F	1C-151-155	1C-153	617F354 SH8A2	SS	Relay GERS or Specific Qualification
1504	RP		1PC-431A-XB	W BF66F	1C-161-165	1C-163	617F354 SH8B2	SS	Relay GERS or Specific Qualification
1505	RP		1PC-431A-YA	W BF22F	1C-151-155	1C-153	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1506	RP		1PC-431A-YB	W BF22F	1C-161-165	1C-163	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1507	RP		1PC-431J-XA	W BF66F	1C-151-155	1C-153	617F354 SH8A2	SS	Relay GERS or Specific Qualification
1508	RP		1PC-431J-XB	W BF66F	1C-161-165	1C-163	617F354 SH8B2	SS	Relay GERS or Specific Qualification
1509	RP		1PC-431J-YA	W BF22F	1C-151-155	1C-153	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1510	RP		1PC-431J-YB	W BF22F	1C-161-165	1C-163	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1511	RP		1PC-449A-XA	W BF66F	1C-151-155	1C-154	617F354 SH8A2	SS	Relay GERS or Specific Qualification
1512	RP		1PC-449A-XB	W BF66F	1C-161-165	1C-164	617F354 SH8B2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1513	RP		1PC-449A-YA	W BF22F	1C-151-155	1C-154	617F354 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1514	RP		1PC-449A-YB	W BF22F	1C-161-165	1C-164	617F354 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1515	RP		1PC-494A-XA	W Nbfd66S	1C-151-155	1C-154	617F354 SH10A2	SS	Relay GERS or Specific Qualification
1516	RP		1PC-484A-XB	W Nbfd66S	1C-161-165	1C-164	617F354 SH10B2	SS	Relay GERS or Specific Qualification
1517	RP		1PC-484A-YA	W BF22F	1C-151-155	1C-154	617F354 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1518	RP		1PC-484A-YB	W BF22F	1C-161-165	1C-164	617F354 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1519	RP		1PC-485A-XA	W BF66F	1C-151-155	1C-152	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1520	RP		1PC-485A-XB	W BF66F	1C-161-165	1C-162	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1521	RP		1PC-485A-YA	W BF22F	1C-151-155	1C-152	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1522	RP		1PC-485A-YB	W BF22F	1C-161-165	1C-162	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1523	RP		1PC-486A-XA	W BF66F	1C-151-155	1C-153	617F354 SH9A1	SS	Relay GERS or Specific Qualification
1524	RP		1PC-486A-XB	W BF66F	1C-161-165	1C-163	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1525	RP		1PC-486A-YA	W BF22F	1C-151-155	1C-153	617F354 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1526	RP		1PC-486A-YB	W BF22F	1C-161-165	1C-163	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1527	RP		1PRB-1A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1528	RP		1PRB-1B	W Nbfd66S	1C-161-165	1C-164	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1529	RP		1PRB-2A	W Nbfd66S	1C-151-155	1C-154	617F354 SH4A2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1530	RP		1PRB-2B	W Nbfd66S	1C-161-165	1C-164	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1531	RP		1RC-1A	W Nbfd42S	1C-151-155	1C-152	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1532	RP		1RC-1B	W Nbfd42S	1C-161-165	1C-162	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1533	RP		1RC-2A	W Nbfd42S	1C-151-155	1C-152	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1534	RP		1RC-2B	W Nbfd42S	1C-161-165	1C-162	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1535	RP		1RC-3A	W Nbfd42S	1C-151-155	1C-153	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1536	RP		1RC-3B	W Nbfd42S	1C-161-165	1C-163	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1537	RP		1RC-4A	W Nbfd42S	1C-151-155	1C-153	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1538	RP		1RC-4B	W Nbfd42S	1C-161-165	1C-163	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1539	RP		1RCP-A-XA	W Nbfd66S	1C-151-155	1C-151	617F354 SH9A2	SS	Relay GERS or Specific Qualification
1540	RP		1RCP-A-XB	W Nbfd66S	1C-161-165	1C-161	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1541	RP		1RCP-A-YA	W BF22F	1C-151-155	1C-151	617F354 SH9A2	CA19	Circuit/Relay Malfunction Acceptable
1542	RP		1RCP-A-YB	W BF22F	1C-161-165	1C-161	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1543	RP		1RCP-B-XA	W Nbfd66S	1C-151-155	1C-152	617F354 SH9A2	SS	Relay GERS or Specific Qualification
1544	RP		1RCP-B-XB	W Nbfd66S	1C-161-165	1C-162	617F354 SH9B1	SS	Relay GERS or Specific Qualification
1545	RP		1RCP-B-YA	W BF22F	1C-151-155	1C-152	617F354 SH9A2	CA19	Circuit/Relay Malfunction Acceptable
1546	RP		1RCP-B-YB	W BF22F	1C-161-165	1C-162	617F354 SH9B1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1547	RP		1RT-10A	W Nbfd31S	1C-151-155	1C-154	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1548	RP		1RT-10B	W Nbfd31S	1C-161-165	1C-164	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1549	RP		1RT-11A	W Nbfd31S	1C-151-155	1C-154	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1550	RP		1RT-11B	W Nbfd31S	1C-161-165	1C-164	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1551	RP		1RT-12A	W Nbfd31S	1C-151-155	1C-154	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1552	RP		1RT-12B	W Nbfd31S	1C-161-165	1C-164	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1553	RP		1RT-1A	W Nbfd31S	1C-151-155	1C-151	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1554	RP		1RT-1B	W Nbfd31S	1C-161-165	1C-161	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1555	RP		1RT-2A	W Nbfd31S	1C-151-155	1C-151	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1556	RP		1RT-2B	W Nbfd31S	1C-161-165	1C-161	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1557	RP		1RT-3A	W Nbfd31S	1C-151-155	1C-152	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1558	RP		1RT-3B	W Nbfd31S	1C-161-165	1C-162	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1559	RP		1RT-4A	W Nbfd31S	1C-151-155	1C-152	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1560	RP		1RT-4B	W Nbfd31S	1C-161-165	1C-162	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1561	RP		1RT-5A	W Nbfd31S	1C-151-155	1C-153	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1562	RP		1RT-5B	W Nbfd31S	1C-161-165	1C-163	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1563	RP		1RT-6A	W Nbfd31S	1C-151-155	1C-153	617F354 SH4A2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1564	RP		1RT-6B	W Nbfd31S	1C-161-165	1C-163	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1565	RP		1RT-7A	W Nbfd31S	1C-151-155	1C-153	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1566	RP		1RT-7B	W Nbfd31S	1C-161-165	1C-163	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1567	RP		1RT-8A	W Nbfd31S	1C-151-155	1C-153	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1568	RP		1RT-8B	W Nbfd31S	1C-161-165	1C-163	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1569	RP		1RT-9A	W Nbfd31S	1C-151-155	1C-154	617F354 SH4A1	SS	Relay GERS or Specific Qualification
1570	RP		1RT-9B	W Nbfd31S	1C-161-165	1C-164	617F354 SH4B1	SS	Relay GERS or Specific Qualification
1571	RP		1SI-11X-AXA	W Nbfd66S	1C-151-155	1C-153	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1572	RP		1SI-11X-AXB	W Nbfd66S	1C-161-165	1C-163	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1573	RP		1SI-11X-AYA	W BF22F	1C-151-155	1C-153	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1574	RP		1SI-11X-AYB	W BF22F	1C-161-165	1C-163	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1575	RP		1SI-21X-BXA	W Nbfd66S	1C-151-155	1C-154	617F354 SH7A2	SS	Relay GERS or Specific Qualification
1576	RP		1SI-21X-BXB	W Nbfd66S	1C-161-165	1C-164	617F354 SH7B2	SS	Relay GERS or Specific Qualification
1577	RP		1SI-21X-BYA	W BF22F	1C-151-155	1C-154	617F354 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1578	RP		1SI-21X-BYB	W BF22F	1C-161-165	1C-164	617F354 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1579	RP		1SRB-1A	W Nbfd66S	1C-151-155	1C-152	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1580	RP		1SRB-1B	W Nbfd66S	1C-161-165	1C-162	617F354 SH4B2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1581	RP		1SRB-2A	W Nbfd66S	1C-151-155	1C-152	617F354 SH4A2	SS	Relay GERS or Specific Qualification
1582	RP		1SRB-2B	W Nbfd66S	1C-161-165	1C-162	617F354 SH4B2	SS	Relay GERS or Specific Qualification
1583	RP		1TC-405A-XA	W BF66F	1C-151-155	1C-151	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1584	RP		1TC-405A-XB	W BF66F	1C-161-165	1C-161	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1585	RP		1TC-405A-YA	W BF22F	1C-151-155	1C-151	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1586	RP		1TC-405A-YB	W BF22F	1C-161-165	1C-161	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1587	RP		1TC-405C-XA	W BF66F	1C-151-155	1C-151	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1588	RP		1TC-405C-XB	W BF66F	1C-161-165	1C-161	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1589	RP		1TC-405C-YA	W BF22F	1C-151-155	1C-151	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1590	RP		1TC-405C-YB	W BF22F	1C-161-165	1C-161	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1591	RP		1TC-406A-XA	W BF66F	1C-151-155	1C-152	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1592	RP		1TC-406A-XB	W BF66F	1C-161-165	1C-162	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1593	RP		1TC-406A-YA	W BF22F	1C-151-155	1C-152	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1594	RP		1TC-406A-YB	W BF22F	1C-161-165	1C-162	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1595	RP		1TC-406C-XA	W BF66F	1C-151-155	1C-152	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1596	RP		1TC-406C-XB	W BF66F	1C-161-165	1C-162	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1597	RP		1TC-406C-YA	W BF22F	1C-151-155	1C-152	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DR. WING	SCREENING CODE (w/ note #)	SCREENING
1598	RP		1TC-406C-YB	W BF22F	1C-161-165	1C-162	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1599	RP		1TC-407A-XA	W BF66F	1C-151-155	1C-153	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1600	RP		1TC-407A-XB	W BF66F	1C-161-165	1C-163	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1601	RP		1TC-407A-YA	W BF22F	1C-151-155	1C-153	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1602	RP		1TC-407A-YB	W BF22F	1C-161-165	1C-163	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1603	RP		1TC-407C-XA	W BF66F	1C-151-155	1C-153	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1604	RP		1TC-407C-XB	W BF66F	1C-161-165	1C-163	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1605	RP		1TC-407C-YA	W BF22F	1C-151-155	1C-153	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1606	RP		1TC-407C-YB	W BF22F	1C-161-165	1C-163	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1607	RP		1TC-408A-XA	W BF66F	1C-151-155	1C-154	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1608	RP		1TC-408A-XB	W BF66F	1C-161-165	1C-164	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1609	RP		1TC-408A-YA	W BF22F	1C-151-155	1C-154	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1610	RP		1TC-408A-YB	W BF22F	1C-161-165	1C-164	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1611	RP		1TC-408C-XA	W BF66F	1C-151-155	1C-154	617F354 SH7A1	SS	Relay GERS or Specific Qualification
1612	RP		1TC-408C-XB	W BF66F	1C-161-165	1C-164	617F354 SH7B1	SS	Relay GERS or Specific Qualification
1613	RP		1TC-408C-YA	W BF22F	1C-151-155	1C-154	617F354 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1614	RP		1TC-408C-YB	W BF22F	1C-161-165	1C-164	617F354 SH7B1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1615	RP		2-1/N-31B-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1616	RP		2-1/N-31B-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1617	RP		2-1/N-31B-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1618	RP		2-1/N-31B-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1619	RP		2-1/N-31B-ZA	W BF30F	2C-151-155	2C-151	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1620	RP		2-1/N-31B-ZB	W BF30F	2C-161-165	2C-161	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1621	RP		2-1/N-32B-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1622	RP		2-1/N-32B-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1623	RP		2-1/N-32B-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1624	RP		2-1/N-32B-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1625	RP		2-1/N-32B-ZA	W BF30F	2C-151-155	2C-152	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1626	RP		2-1/N-32B-ZB	W BF30F	2C-161-165	2C-162	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1627	RP		2-1/N-33A-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1628	RP		2-1/N-33A-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1629	RP		2-1/N-33A-ZA	W BF30F	2C-151-155	2C-153	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1630	RP		2-1/N-33B-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1631	RP		2-1/N-33B-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1632	RP		2-1/N-33B-ZB	W BF30F	2C-161-165	2C-163	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1633	RP		2-1/N-35A-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1634	RP		2-1/N-35A-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1635	RP		2-1/N-35A-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1636	RP		2-1/N-35A-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1637	RP		2-1/N-35A-ZA	W BF30F	2C-151-155	2C-151	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1638	RP		2-1/N-35A-ZB	W BF30F	2C-161-165	2C-161	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1639	RP		2-1/N-36A-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1640	RP		2-1/N-36A-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1641	RP		2-1/N-36A-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1642	RP		2-1/N-36A-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1643	RP		2-1/N-36A-ZA	W BF30F	2C-151-155	2C-152	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1644	RP		2-1/N-36A-ZB	W BF30F	2C-161-165	2C-162	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1645	RP		2-1/N-38A-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1646	RP		2-1/N-38A-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1647	RP		2-1/N-38A-ZA	W BF30F	2C-151-155	2C-153	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1648	RP		2-1/N-38B-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1649	RP		2-1/N-38B-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1650	RP		2-1/N-38B-ZB	W BF30F	2C-161-165	2C-163	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1651	RP		2-1/N-39A-XA	W Nbfd66S	2C-151-155	2C-151	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1652	RP		2-1/N-39A-XB	W Nbfd66S	2C-161-165	2C-161	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1653	RP		2-1/N-39A-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1654	RP		2-1/N-39A-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1655	RP		2-1/N-39B-XA	W Nbfd66S	2C-151-155	2C-151	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1656	RP		2-1/N-39B-XB	W Nbfd66S	2C-161-165	2C-161	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1657	RP		2-1/N-39B-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1658	RP		2-1/N-39B-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1659	RP		2-1/N-41K-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1660	RP		2-1/N-41K-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1661	RP		2-1/N-42K-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1662	RP		2-1/N-42K-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1663	RP		2-1/N-43K-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1664	RP		2-1/N-43K-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1665	RP		2-1/N-44K-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1666	RP		2-1/N-44K-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1667	RP		2-1/N-47A-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1668	RP		2-1/N-47A-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1669	RP		2-1/N-47A-ZA	W BF30F	2C-151-155	2C-154	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1670	RP		2-1/N-47B-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1671	RP		2-1/N-47B-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1672	RP		2-1/N-47B-ZB	W BF30F	2C-161-165	2C-164	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1673	RP		2-273/A01-XA	W Nbfd66S	2C-151-155	2C-151	617F354-2 SH10A1	SS	Relay GERS or Specific Qualification
1674	RP		2-273/A01-XB	W Nbfd66S	2C-161-165	2C-161	617F354-2 SH10B1	SS	Relay GERS or Specific Qualification
1675	RP		2-273/A01-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1676	RP		2-273/A01-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1677	RP		2-273/A02-XA	W Nbfd66S	2C-151-155	2C-153	617F354-2 SH10A1	SS	Relay GERS or Specific Qualification
1678	RP		2-273/A02-XB	W Nbfd66S	2C-161-165	2C-163	617F354-2 SH10B1	SS	Relay GERS or Specific Qualification
1679	RP		2-273/A02-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1680	RP		2-273/A02-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1681	RP		2-274/A01-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH10A1	SS	Relay GERS or Specific Qualification
1682	RP		2-274/A01-XB	W Nbfd66S	2C-161-165	2C-162	617F354-2 SH10B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1683	RP		2-274/A01-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1684	RP		2-274/A01-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1685	RP		2-274/A02-XA	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH10A1	SS	Relay GERS or Specific Qualification
1686	RP		2-274/A02-XB	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH10B1	SS	Relay GERS or Specific Qualification
1687	RP		2-274/A02-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1688	RP		2-274/A02-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1689	RP		2-33AC-SL-XA	W Nbfd66S	2C-151-155	2C-153	617F354-2 SH10A2	SS	Relay GERS or Specific Qualification
1690	RP		2-33AC-SL-XB	W Nbfd66S	2C-161-165	2C-163	617F354-2 SH10B2	SS	Relay GERS or Specific Qualification
1691	RP		2-33AC-SL-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1692	RP		2-33AC-SL-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1693	RP		2-33AC-SR-XA	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH10A2	SS	Relay GERS or Specific Qualification
1694	RP		2-33AC-SR-XB	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH10B2	SS	Relay GERS or Specific Qualification
1695	RP		2-33AC-SR-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1696	RP		2-33AC-SR-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1697	RP		2-63/AST3-XA	W Nbfd66S	2C-151-155	2C-152	617F354-2 SH10A2	SS	Relay GERS or Specific Qualification
1698	RP		2-63/AST3-XB	W Nbfd66S	2C-161-165	2C-162	617F354-2 SH10B2	SS	Relay GERS or Specific Qualification
1699	RP		2-63/AST3-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH10A2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1700	RP		2-63/AST3-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1701	RP		2-63/AST4-XA	W Nbfd66S	2C-151-155	2C-153	617F354-2 SH10A2	SS	Relay GERS or Specific Qualification
1702	RP		2-63/AST4-XB	W Nbfd66S	2C-161-165	2C-163	617F354-2 SH10B2	SS	Relay GERS or Specific Qualification
1703	RP		2-63/AST4-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1704	RP		2-63/AST4-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1705	RP		2-63/AST5-XA	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH10A2	SS	Relay GERS or Specific Qualification
1706	RP		2-63/AST5-XB	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH10B2	SS	Relay GERS or Specific Qualification
1707	RP		2-63/AST5-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1708	RP		2-63/AST5-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1709	RP		2A52-06-XA	W Nbfd66S	2C-151-155	2C-153	617F354-2 SH10A2	SS	Relay GERS or Specific Qualification
1710	RP		2A52-06-XB	W Nbfd66S	2C-161-165	2C-163	617F354-2 SH10B2	SS	Relay GERS or Specific Qualification
1711	RP		2A52-06-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1712	RP		2A52-06-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1713	RP		2A52-12-XA	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH10A2	SS	Relay GERS or Specific Qualification
1714	RP		2A52-12-XB	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH10B2	SS	Relay GERS or Specific Qualification
1715	RP		2A52-12-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1716	RP		2A52-12-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH10B2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1717	RP		2FC-411-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
1718	RP		2FC-411-XB	W BF66F	2C-161-165	2C-151	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1719	RP		2FC-411-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1720	RP		2FC-411-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1721	RP		2FC-412-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
1722	RP		2FC-412-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1723	RP		2FC-412-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1724	RP		2FC-412-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1725	RP		2FC-413-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
1726	RP		2FC-413-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1727	RP		2FC-413-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1728	RP		2FC-413-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1729	RP		2FC-414-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
1730	RP		2FC-414-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1731	RP		2FC-414-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1732	RP		2FC-414-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1733	RP		2FC-415-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1734	RP		2FC-415-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1735	RP		2FC-415-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1736	RP		2FC-415-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1737	RP		2FC-416-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
1738	RP		2FC-416-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1739	RP		2FC-416-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1740	RP		2FC-416-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1741	RP		2FC-466C-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
1742	RP		2FC-466C-XB	W BF66F	2C-161-155	2C-161	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
1743	RP		2FC-466C-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1744	RP		2FC-466C-YB	W BF22F	2C-161-135	2C-161	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1745	RP		2FC-467B-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
1746	RP		2FC-467B-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH7B1	SS	Relay GERS or Spe Qualification
1747	RP		2FC-467B-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1748	RP		2FC-467B-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1749	RP		2FC-476C-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
1750	RP		2FC-476C-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1751	RP		2FC-476C-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1752	RP		2FC-476C-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1753	RP		2FC-477B-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
1754	RP		2FC-477B-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
1755	RP		2FC-477B-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
1756	RP		2FC-477B-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
1757	RP		2IRB-1A	W Nbfd66S	2C-151-155	2C-153	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
1758	RP		2IRB-1B	W Nbfd66S	2C-161-165	2C-163	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
1759	RP		2IRB-2A	W Nbfd66S	2C-151-155	2C-153	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
1760	RP		2IRB-2B	W Nbfd66S	2C-161-165	2C-163	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
1761	RP		2LC-426A-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification
1762	RP		2LC-426A-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification
1763	RP		2LC-426A-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1764	RP		2LC-426A-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1765	RP		2LC-427A-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification
1766	RP		2LC-427A-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification
1767	RP		2LC-427A-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH8A2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1768	RP		2LC-427A-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1769	RP		2LC-428A-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification
1770	RP		2LC-428A-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification
1771	RP		2LC-428A-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1772	RP		2LC-428A-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1773	RP		2LC-461B-XA	W BF57F	2C-151-155	2C-151	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
1774	RP		2LC-461B-XB	W BF57F	2C-161-165	2C-161	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1775	RP		2LC-461B-YA	W BF57F	2C-151-155	2C-151	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1776	RP		2LC-461B-YB	W BF57F	2C-161-165	2C-161	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1777	RP		2LC-462A-XA	W BF57F	2C-151-155	2C-153	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
1778	RP		2LC-462A-XB	W BF57F	2C-161-165	2C-163	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1779	RP		2LC-462A-YA	W BF57F	2C-151-155	2C-153	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1780	RP		2LC-462A-YB	W BF57F	2C-161-165	2C-163	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1781	RP		2LC-462C-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
1782	RP		2LC-462C-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1783	RP		2LC-462C-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1784	RP		2LC-462C-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1785	RP		2LC-463C-XA	W BF57F	2C-151-155	2C-154	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
1786	RP		2LC-463C-XB	W BF57F	2C-161-165	2C-164	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1787	RP		2LC-463C-YA	W BF57F	2C-151-155	2C-154	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1788	RP		2LC-463C-YB	W BF57F	2C-161-165	2C-164	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1789	RP		2LC-463E-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
1790	RP		2LC-463E-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1791	RP		2LC-463E-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1792	RP		2LC-463E-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1793	RP		2LC-471B-XA	W BF57F	2C-151-155	2C-154	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
1794	RP		2LC-471B-XB	W BF57F	2C-161-165	2C-164	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1795	RP		2LC-471B-YA	W BF57F	2C-151-155	2C-154	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1796	RP		2LC-471B-YB	W BF57F	2C-161-165	2C-164	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1797	RP		2LC-472A-XA	W BF57F	2C-151-155	2C-151	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
1798	RP		2LC-472A-XB	W BF57F	2C-161-165	2C-161	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1799	RP		2LC-472A-YA	W BF57F	2C-151-155	2C-151	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1800	RP		2LC-472A-YB	W BF57F	2C-161-165	2C-161	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1801	RP		2LC-472C-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1802	RP		2LC-472C-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1803	RP		2LC-472C-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1804	RP		2LC-472C-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1805	RP		2LC-473C-XA	W BF57F	2C-151-155	2C-152	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
1806	RP		2LC-473C-XB	W BF57F	2C-161-165	2C-162	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1807	RP		2LC-473C-YA	W BF57F	2C-151-155	2C-152	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1808	RP		2LC-473C-YB	W BF57F	2C-161-165	2C-162	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1809	RP		2LC-473E-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
1810	RP		2LC-473E-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
1811	RP		2LC-473E-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
1812	RP		2LC-473E-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
1813	RP		2NC-31D-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1814	RP		2NC-31D-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1815	RP		2NC-31D-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1816	RP		2NC-31D-YB	W BF13F	2C-151-165	2C-161	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1817	RP		2NC-32D-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1818	RP		2NC-32D-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1819	RP		2NC-32D-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1820	RP		2NC-32D-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1821	RP		2NC-35D-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1822	RP		2NC-35D-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1823	RP		2NC-35D-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1824	RP		2NC-35D-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1825	RP		2NC-35D-ZA	W BF30F	2C-151-155	2C-151	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1826	RP		2NC-35D-ZB	W NBFD31S	2C-161-165	2C-161	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1827	RP		2NC-35F-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1828	RP		2NC-35F-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1829	RP		2NC-35F-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1830	RP		2NC-35F-YB	W BF13F	2C-161-165	2C-161	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1831	RP		2NC-35F-ZA	W BF30F	2C-151-155	2C-151	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1832	RP		2NC-35F-ZB	W BF30F	2C-161-165	2C-161	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1833	RP		2NC-36D-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1834	RP		2NC-36D-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1835	RP		2NC-36D-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1836	RP		2NC-36D-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1837	RP		2NC-36D-ZA	W BF30F	2C-151-155	2C-152	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1838	RP		2NC-36D-ZB	W BF30F	2C-161-165	2C-162	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1839	RP		2NC-36F-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH6A1	SS	Relay GERS or Specific Qualification
1840	RP		2NC-36F-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH6B1	SS	Relay GERS or Specific Qualification
1841	RP		2NC-36F-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1842	RP		2NC-36F-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1843	RP		2NC-36F-ZA	W BF30F	2C-151-155	2C-152	617F354-2 SH6A1	CA19	Circuit/Relay Malfunction Acceptable
1844	RP		2NC-36F-ZB	W BF30F	2C-161-165	2C-162	617F354-2 SH6B1	CA19	Circuit/Relay Malfunction Acceptable
1845	RP		2NC-41K-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1846	RP		2NC-41K-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1847	RP		2NC-41M-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1848	RP		2NC-41M-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1849	RP		2NC-41M-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1850	RP		2NC-41M-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1851	RP		2NC-41M-ZA	W BF30F	2C-151-155	2C-151	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1852	RP		2NC-41M-ZB	W BF30F	2C-161-165	2C-161	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1853	RP		2NC-41N-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
1854	RP		2NC-41N-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1855	RP		2NC-41N-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1856	RP		2NC-41N-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1857	RP		2NC-41P-XA	W BF57F	2C-151-155	2C-151	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1858	RP		2NC-41P-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1859	RP		2NC-41P-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1860	RP		2NC-41P-YB	W BF13F	2C-161-165	2C-161	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1861	RP		2NC-41P-ZA	W BF30F	2C-151-155	2C-151	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1862	RP		2NC-41P-ZB	W BF30F	2C-161-165	2C-161	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1863	RP		2NC-41R-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1864	RP		2NC-41R-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1865	RP		2NC-41R-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH8A1	CA19	Circuit/Relay Malfunction Acceptable
1866	RP		2NC-41R-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH8B1	CA19	Circuit/Relay Malfunction Acceptable
1867	RP		2NC-41S-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH10A1	SS	Relay GERS or Specific Qualification
1868	RP		2NC-41S-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH10B1	SS	Relay GERS or Specific Qualification
1869	RP		2NC-41S-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH10A1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1870	RP		2NC-41S-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1871	RP		2NC-42K-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1872	RP		2NC-42K-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1873	RP		2NC-42M-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1874	RP		2NC-42M-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1875	RP		2NC-42M-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1876	RP		2NC-42M-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1877	RP		2NC-42M-ZA	W BF30F	2C-151-155	2C-152	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1878	RP		2NC-42M-ZB	W BF30F	2C-161-165	2C-162	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1879	RP		2NC-42N-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
1880	RP		2NC-42N-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1881	RP		2NC-42N-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1882	RP		2NC-42N-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1883	RP		2NC-42P-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1884	RP		2NC-42P-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1885	RP		2NC-42P-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1886	RP		2NC-42P-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1887	RP		2NC-42P-ZA	W BF30F	2C-151-155	2C-152	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1888	RP		2NC-42P-ZB	W BF30F	2C-161-165	2C-162	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1889	RP		2NC-42R-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1890	RP		2NC-42R-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1891	RP		2NC-42R-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH8A1	CA19	Circuit/Relay Malfunction Acceptable
1892	RP		2NC-42R-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH8B1	CA19	Circuit/Relay Malfunction Acceptable
1893	RP		2NC-42S-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH10A1	SS	Relay GERS or Specific Qualification
1894	RP		2NC-42S-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH10B1	SS	Relay GERS or Specific Qualification
1895	RP		2NC-42S-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1896	RP		2NC-42S-YB	W BF22F	2C-151-155	2C-152	617F354-2 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1897	RP		2NC-43K-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1898	RP		2NC-43K-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1899	RP		2NC-43M-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1900	RP		2NC-43M-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1901	RP		2NC-43M-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1902	RP		2NC-43M-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1903	RP		2NC-43M-ZA	W BF30F	2C-151-155	2C-153	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1904	RP		2NC-43M-ZB	W BF30F	2C-161-165	2C-163	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1905	RP		2NC-43N-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
1906	RP		2NC-43N-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1907	RP		2NC-43N-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1908	RP		2NC-43N-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1909	RP		2NC-43P-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1910	RP		2NC-43P-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1911	RP		2NC-43P-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1912	RP		2NC-43P-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1913	RP		2NC-43P-ZA	W BF30F	2C-151-155	2C-153	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1914	RP		2NC-43P-ZB	W BF30F	2C-161-165	2C-163	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1915	RP		2NC-43R-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1916	RP		2NC-43R-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1917	RP		2NC-43R-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH8A1	CA19	Circuit/Relay Malfunction Acceptable
1918	RP		2NC-43R-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH8B1	CA19	Circuit/Relay Malfunction Acceptable
1919	RP		2NC-43S-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH10A1	SS	Relay GERS or Specific Qualification
1920	RP		2NC-43S-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH10B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1921	RP		2NC-43S-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1922	RP		2NC-43S-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1923	RP		2NC-44K-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1924	RP		2NC-44K-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1925	RP		2NC-44M-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1926	RP		2NC-44M-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1927	RP		2NC-44M-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1928	RP		2NC-44M-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1929	RP		2NC-44M-ZA	W BF30F	2C-151-155	2C-154	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1930	RP		2NC-44M-ZB	W BF30F	2C-161-165	2C-164	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1931	RP		2NC-44N-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
1932	RP		2NC-44N-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
1933	RP		2NC-44N-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
1934	RP		2NC-44N-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
1935	RP		2NC-44P-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH6A2	SS	Relay GERS or Specific Qualification
1936	RP		2NC-44P-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH6B2	SS	Relay GERS or Specific Qualification
1937	RP		2NC-44P-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1938	RP		2NC-44P-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1939	RP		2NC-44P-ZA	W BF30F	2C-151-155	2C-154	617F354-2 SH6A2	CA19	Circuit/Relay Malfunction Acceptable
1940	RP		2NC-44P-ZB	W BF30F	2C-161-165	2C-164	617F354-2 SH6B2	CA19	Circuit/Relay Malfunction Acceptable
1941	RP		2NC-44R-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH8A1	SS	Relay GERS or Specific Qualification
1942	RP		2NC-44R-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH8B1	SS	Relay GERS or Specific Qualification
1943	RP		2NC-44R-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH8A1	CA19	Circuit/Relay Malfunction Acceptable
1944	RP		2NC-44R-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH8B1	CA19	Circuit/Relay Malfunction Acceptable
1945	RP		2NC-44S-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH10A1	SS	Relay GERS or Specific Qualification
1946	RP		2NC-44S-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH10B1	SS	Relay GERS or Specific Qualification
1947	RP		2NC-44S-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH10A1	CA19	Circuit/Relay Malfunction Acceptable
1948	RP		2NC-44S-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH10B1	CA19	Circuit/Relay Malfunction Acceptable
1949	RP		2P07-1A	W Nbfd84S	2C-151-155	2C-154	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
1950	RP		2P07-1B	W Nbfd84D	2C-161-165	2C-164	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
1951	RP		2P07-2A	W Nbfd84S	2C-151-155	2C-154	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
1952	RP		2P07-2B	W Nbfd84D	2C-161-165	2C-164	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
1953	RP		2P07-3A	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
1954	RP		2P07-3B	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1955	RP		2P08-1A	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
1956	RP		2P08-1B	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
1957	RP		2P08-2A	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
1958	RP		2P08-2B	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
1959	RP		2P09-1A	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
1960	RP		2P09-1B	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
1961	RP		2P09-2A	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
1962	RP		2P09-2B	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
1963	RP		2P10-1A	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
1964	RP		2P10-1B	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
1965	RP		2P10-2A	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
1966	RP		2P10-2B	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
1967	RP		2PC-429A-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification
1968	RP		2PC-429A-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification
1969	RP		2PC-429A-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH3A2	CA19	Circuit/Relay Malfunction Acceptable
1970	RP		2PC-429A-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1971	RP		2PC-429E-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1972	RP		2PC-429E-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification
1973	RP		2PC-429E-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1974	RP		2PC-429E-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1975	RP		2PC-430A-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification
1976	RP		2PC-430A-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification
1977	RP		2PC-430A-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1978	RP		2PC-430A-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1979	RP		2PC-430H-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification
1980	RP		2PC-430H-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification
1981	RP		2PC-430H-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1982	RP		2PC-430H-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1983	RP		2PC-431A-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification
1984	RP		2PC-431A-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification
1985	RP		2PC-431A-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1986	RP		2PC-431A-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1987	RP		2PC-431J-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification
1988	RP		2PC-431J-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
1989	RP		2PC-431J-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1990	RP		2PC-431J-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1991	RP		2PC-449A-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH8A2	SS	Relay GERS or Specific Qualification
1992	RP		2PC-449A-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH8B2	SS	Relay GERS or Specific Qualification
1993	RP		2PC-449A-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH8A2	CA19	Circuit/Relay Malfunction Acceptable
1994	RP		2PC-449A-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH8B2	CA19	Circuit/Relay Malfunction Acceptable
1995	RP		2PC-484A-XA	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH10A2	SS	Relay GERS or Specific Qualification
1996	RP		2PC-484A-XB	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH10B2	SS	Relay GERS or Specific Qualification
1997	RP		2PC-484A-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH10A2	CA19	Circuit/Relay Malfunction Acceptable
1998	RP		2PC-484A-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH10B2	CA19	Circuit/Relay Malfunction Acceptable
1999	RP		2PC-485A-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
2000	RP		2PC-485A-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
2001	RP		2PC-485A-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable
2002	RP		2PC-485A-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
2003	RP		2PC-486A-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH9A1	SS	Relay GERS or Specific Qualification
2004	RP		2PC-486A-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH9B1	SS	Relay GERS or Specific Qualification
2005	RP		2PC-486A-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH9A1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2006	RP		2PC-486A-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH9B1	CA19	Circuit/Relay Malfunction Acceptable
2007	RP		2PRB-1A	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2008	RP		2PRB-1B	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2009	RP		2PRB-2A	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2010	RP		2PRB-2B	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2011	RP		2RC-1A	W Nbfd42S	2C-151-155	2C-152	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
2012	RP		2RC-1B	W Nbfd42S	2C-161-165	2C-161	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
2013	RP		2RC-2A	W Nbfd42S	2C-151-155	2C-152	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
2014	RP		2RC-2B	W Nbfd42S	2C-161-165	2C-161	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
2015	RP		2RC-3A	W Nbfd42S	2C-151-155	2C-153	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
2016	RP		2RC-3B	W Nbfd42S	2C-161-165	2C-162	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
2017	RP		2RC-4A	W Nbfd42S	2C-151-155	2C-153	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
2018	RP		2RC-4B	W Nbfd42S	2C-161-165	2C-162	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
2019	RP		2RCP-A-XA	W Nbfd66S	2C-151-155	2C-151	617F354-2 SH9A2	SS	Relay GERS or Specific Qualification
2020	RP		2RCP-A-XB	W Nbfd66S	2C-161-165	2C-161	617F354-2 SH9B2	SS	Relay GERS or Specific Qualification
2021	RP		2RCP-A-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH9A2	CA19	Circuit/Relay Malfunction Acceptable
2022	RP		2RCP-A-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH9B2	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2023	RP		2RCP-B-XA	W Nbfd66S	2C-151-155	2C-152	617F354-2 SH9A2	SS	Relay GERS or Specific Qualification
2024	RP		2RCP-B-XB	W Nbfd66S	2C-161-165	2C-162	617F354-2 SH9B2	SS	Relay GERS or Specific Qualification
2025	RP		2RCP-B-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH9A2	CA19	Circuit/Relay Malfunction Acceptable
2026	RP		2RCP-B-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH9B2	CA19	Circuit/Relay Malfunction Acceptable
2027	RP		2RT-10A	W Nbfd31S	2C-151-155	2C-154	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
2028	RP		2RT-10B	W Nbfd31S	2C-161-165	2C-164	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
2029	RP		2RT-11A	W Nbfd31S	2C-151-155	2C-154	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2030	RP		2RT-11B	W Nbfd31S	2C-161-165	2C-164	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2031	RP		2RT-12A	W Nbfd31S	2C-151-155	2C-154	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2032	RP		2RT-12B	W Nbfd31S	2C-161-165	2C-164	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2033	RP		2RT-1A	W Nbfd31S	2C-151-155	2C-151	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2034	RP		2RT-1B	W Nbfd31S	2C-161-165	2C-161	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2035	RP		2RT-2A	W Nbfd31S	2C-151-155	2C-151	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2036	RP		2RT-2B	W Nbfd31S	2C-161-165	2C-161	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2037	RP		2RT-3A	W Nbfd31S	2C-151-155	2C-152	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2038	RP		2RT-3B	W Nbfd31S	2C-161-165	2C-162	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2039	RP		2RT-4A	W Nbfd31S	2C-151-155	2C-152	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2040	RP		2RT-4B	W Nbfd31S	2C-161-165	2C-162	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2041	RP		2RT-5A	W Nbfd31S	2C-151-155	2C-153	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2042	RP		2RT-5B	W Nbfd31S	2C-161-165	2C-163	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2043	RP		2RT-6A	W Nbfd31S	2C-151-155	2C-153	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2044	RP		2RT-6B	W Nbfd31S	2C-161-165	2C-163	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2045	RP		2RT-7A	W Nbfd31S	2C-151-155	2C-153	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
2046	RP		2RT-7B	W Nbfd31S	2C-161-165	2C-163	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
2047	RP		2RT-8A	W Nbfd31S	2C-151-155	2C-153	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
2048	RP		2RT-8B	W Nbfd31S	2C-161-165	2C-163	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
2049	RP		2RT-9A	W Nbfd31S	2C-151-155	2C-154	617F354-2 SH4A1	SS	Relay GERS or Specific Qualification
2050	RP		2RT-9B	W Nbfd31S	2C-161-165	2C-164	617F354-2 SH4B1	SS	Relay GERS or Specific Qualification
2051	RP		2SI-11X-AXA	W Nbfd66S	2C-151-155	2C-153	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
2052	RP		2SI-11X-AXB	W Nbfd56S	2C-161-165	2C-163	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification
2053	RP		2SI-11X-AYA	W BF22F	2C-151-155	2C-153	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
2054	RP		2SI-11X-AYB	W BF22F	2C-161-165	2C-163	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
2055	RP		2SI-21X-BXA	W Nbfd66S	2C-151-155	2C-154	617F354-2 SH7A2	SS	Relay GERS or Specific Qualification
2056	RP		2SI-21X-BXB	W Nbfd66S	2C-161-165	2C-164	617F354-2 SH7B2	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2057	RP		2SI-21X-BYA	W BF22F	2C-151-155	2C-154	617F354-2 SH7A2	CA19	Circuit/Relay Malfunction Acceptable
2058	RP		2SI-21X-BYB	W BF22F	2C-161-165	2C-164	617F354-2 SH7B2	CA19	Circuit/Relay Malfunction Acceptable
2059	RP		2SRB-1A	W Nbfd66S	2C-151-155	2C-152	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2060	RP		2SRB-1B	W Nbfd66S	2C-161-165	2C-162	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2061	RP		2SRB-2A	W Nbfd66S	2C-151-155	2C-152	617F354-2 SH4A2	SS	Relay GERS or Specific Qualification
2062	RP		2SRB-2B	W Nbfd66S	2C-161-165	2C-162	617F354-2 SH4B2	SS	Relay GERS or Specific Qualification
2063	RP		2TC-405A-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
2064	RP		2TC-405A-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
2065	RP		2TC-405A-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
2066	RP		2TC-405A-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
2067	RP		2TC-405C-XA	W BF66F	2C-151-155	2C-151	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
2068	RP		2TC-405C-XB	W BF66F	2C-161-165	2C-161	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
2069	RP		2TC-405C-YA	W BF22F	2C-151-155	2C-151	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
2070	RP		2TC-405C-YB	W BF22F	2C-161-165	2C-161	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
2071	RP		2TC-406A-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
2072	RP		2TC-406A-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
2073	RP		2TC-406A-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2074	RP		2TC-406A-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
2075	RP		2TC-406C-XA	W BF66F	2C-151-155	2C-152	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
2076	RP		2TC-406C-XB	W BF66F	2C-161-165	2C-162	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
2077	RP		2TC-406C-YA	W BF22F	2C-151-155	2C-152	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
2078	RP		2TC-406C-YB	W BF22F	2C-161-165	2C-162	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
2079	RP		2TC-407A-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
2080	RP		2TC-407A-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
2081	RP		2TC-407A-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
2082	RP		2TC-407A-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
2083	RP		2TC-407C-XA	W BF66F	2C-151-155	2C-153	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
2084	RP		2TC-407C-XB	W BF66F	2C-161-165	2C-163	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
2085	RP		2TC-407C-YA	W BF22F	2C-151-155	2C-153	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
2086	RP		2TC-407C-YB	W BF22F	2C-161-165	2C-163	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
2087	RP		2TC-408A-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
2088	RP		2TC-408A-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
2089	RP		2TC-408A-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
2090	RP		2TC-408A-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2091	RP		2TC-408C-XA	W BF66F	2C-151-155	2C-154	617F354-2 SH7A1	SS	Relay GERS or Specific Qualification
2092	RP		2TC-408C-XB	W BF66F	2C-161-165	2C-164	617F354-2 SH7B1	SS	Relay GERS or Specific Qualification
2093	RP		2TC-408C-YA	W BF22F	2C-151-155	2C-154	617F354-2 SH7A1	CA19	Circuit/Relay Malfunction Acceptable
2094	RP		2TC-408C-YB	W BF22F	2C-161-165	2C-164	617F354-2 SH7B1	CA19	Circuit/Relay Malfunction Acceptable
2095	RS	RS-SA-10-7	3W-GWSPA				S&W 12137-ESK-11A	CA13	Circuit/Relay Malfunction Acceptable
2096	RS	RS-SA-9-7	3W-GWSPB				S&W 12137-ESK-11C	CA13	Circuit/Relay Malfunction Acceptable
2097	SC	1SC-951-S	1-951-3-5-X	W NBF0405	1N-07	1N-07	ELEM 787A	CA11	Circuit/Relay Malfunction Acceptable
2098	SC	1SC-966A-S	1CI-12-X4	W Nbfd65NR	C-01-1(2)C-04	C-01	ELEM 1696	CA11	Circuit/Relay Malfunction Acceptable
2099	SC	1SC-966A-S	1CI-21-X4	W Nbfd65NR	C-01-1(2)C-04	C-01	ELEM 1696	CA11	Circuit/Relay Malfunction Acceptable
2100	SC	2SC-951-S	2-951-3-5-X	W NBF0405	2N-07	2N-07	ELEM 787B	CA11	Circuit/Relay Malfunction Acceptable
2101	SC	2SC-966A-S	2CI-12-X2	W Nbfd66S	C-01-1(2)C-04	C-01	ELEM 1695	CA11	Circuit/Relay Malfunction Acceptable
2102	SC	2SC-966A-S	2CI-21-X2	W Nbfd66S	C-01-1(2)C-04	C-01	ELEM 1695	CA11	Circuit/Relay Malfunction Acceptable
2103	SI	1P-15A-M	1-74/A59FM	LINE ELEC AG-1D	1A-05	1A52-59	ELEM 222	CA4	Circuit/Relay Malfunction Acceptable
2104	SI	1P-15A-M	1A52-59		1A-05	1A52-59	ELEM 222	SWGR	Relays directly control Switchgear
2105	SI	1P-15A-M	50G/1A52-59	W ITH	1A-05	1A52-59	ELEM 201	SS	Relay GERS or Specific Qualification
2106	SI	1P-15A-M	51/50A/1A52-59	W COM 5	1A-05	1A52-59	ELEM 201	SS	Relay GERS or Specific Qualification
2107	SI	1P-15A-M	51/50B/1A52-59	W COM 5	1A-05	1A52-59	ELEM 201	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2108	SI	1P-15A-M	51/50C/1A52-59	W COM 5	1A-05	1A52-59	ELEM 201	SS	Relay GERS or Specific Qualification
2109	SI	1P-15A-M	74/A52-59	W SG	1A-05	1A59	ELEM 222	CA4	Circuit/Relay Malfunction Acceptable
2110	SI	1P-15A-M	86/A52-59	W MG-6	1A-05	1A52-59	ELEM 222	SS	Relay GERS or Specific Qualification
2111	SI	1P-15B-M	1-74/A65FM	LINE ELEC AG-1D	1A-06	1A52-65	ELEM 222	CA4	Circuit/Relay Malfunction Acceptable
2112	SI	1P-15B-M	1A52-65		1A-06	1A52-65	ELEM 222	SWGR	Relays directly control Switchgear
2113	SI	1P-15B-M	50G/1A52-65	W ITH	1A-06	1A52-65	ELEM 201	SS	Relay GERS or Specific Qualification
2114	SI	1P-15B-M	51/50A/1A52-65	W COM 5	1A-06	1A52-65	ELEM 201	SS	Relay GERS or Specific Qualification
2115	SI	1P-15B-M	51/50B/1A52-65	W COM 5	1A-06	1A52-65	ELEM 201	SS	Relay GERS or Specific Qualification
2116	SI	1P-15B-M	51/50C/1A52-65	W COM 5	1A-06	1A52-65	ELEM 201	SS	Relay GERS or Specific Qualification
2117	SI	1P-15B-M	74/A52-65	W SG	1A-06	1A65	ELEM 222	CA4	Circuit/Relay Malfunction Acceptable
2118	SI	1P-15B-M	86/A52-65	W MG-6	1A-06	1A52-65	ELEM 222	SS	Relay GERS or Specific Qualification
2119	SI	1SI-825A-M	1B42-324C	CONTACTOR	1B-32	1B32-4C	ELEM 728	SS	Relay GERS or Specific Qualification
2120	SI	1SI-825A-M	33X/1-V826A	W BF40F	C-01-1(2)C-04	C-01	ELEM 736	CA9	Circuit/Relay Malfunction Acceptable
2121	SI	1SI-825A-M	33X/1-V826B	W BF22F	C-01-1(2)C-04	C-01	ELEM 726	CA9	Circuit/Relay Malfunction Acceptable
2122	SI	1SI-825A-M	33X/1-V826C	W BF22F	C-01-1(2)C-04	C-01	ELEM 726	CA9	Circuit/Relay Malfunction Acceptable
2123	SI	1SI-825A-M	62SI/825A	AGASTAT 2412AC	C-01-1(2)C-04	C-01	ELEM 728	CA9	Circuit/Relay Malfunction Acceptable
2124	SI	1SI-825B-M	1B42-424C	CONTACTOR	1B-42	1B42-4C	ELEM 728	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2125	SI	1SI-825B-M	62SI/825B	AGASTAT 2412AC	C-01-1(2)C-04	C-01	ELEM 728	CA9	Circuit/Relay Malfunction Acceptable
2126	SI	1SI-826A-M	1B42-425F	CONTACTOR	1B-42	1B42-5F	ELEM 736	CA13	Circuit/Relay Malfunction Acceptable
2127	SI	1SI-826B-M	1B42-425J	CONTACTOR	1B-42	1B42-5J	ELEM 726	SS	Relay GERS or Specific Qualification
2128	SI	1SI-826C-M	1B42-325F	CONTACTOR	1B-32	1B32-5F	ELEM 726	SS	Relay GERS or Specific Qualification
2129	SI	1SI-851A-M	1B42-323C	CONTACTOR	1B-32	1B32-3C	ELEM 734	SS	Relay GERS or Specific Qualification
2130	SI	1SI-851A-M	33X/1-V851A	W BF44F	C-01-1(2)C-04	C-01	ELEM 734	CA3	Circuit/Relay Malfunction Acceptable
2131	SI	1SI-851A-M	33X/1-V897A	W BFD62S	C-01-1(2)C-04	C-01	ELEM 770	SS	Relay GERS or Specific Qualification
2132	SI	1SI-851A-M	33X/1-V897B	W BFD62S	C-01-1(2)C-04	C-01	ELEM 770	SS	Relay GERS or Specific Qualification
2133	SI	1SI-851B-M	1B42-423C	CONTACTOR	1B-42	1B42-3C	ELEM 734	SS	Relay GERS or Specific Qualification
2134	SI	1SI-851B-M	33X/1-V851B	W BF44F	C-01-1(2)C-04	C-01	ELEM 734	CA3	Circuit/Relay Malfunction Acceptable
2135	SI	1SI-852A-M	1B42-321F	CONTACTOR	1B-32	1B32-1F	ELEM 725	SS	Relay GERS or Specific Qualification
2136	SI	1SI-852B-M	1B42-421F	CONTACTOR	1B-42	1B42-1F	ELEM 725	SS	Relay GERS or Specific Qualification
2137	SI	1SI-860A-M	1B42-321M	CONTACTOR	1B-32	1B32-1M	ELEM 725	SS	Relay GERS or Specific Qualification
2138	SI	1SI-860B-M	1B42-421M	CONTACTOR	1B-42	1B42-1M	ELEM 725	SS	Relay GERS or Specific Qualification
2139	SI	1SI-860C-M	1B42-322M	CONTACTOR	1B-32	1B32-2M	ELEM 725	SS	Relay GERS or Specific Qualification
2140	SI	1SI-860D-M	1B42-422M	CONTACTOR	1B-42	1B42-2M	ELEM 725	SS	Relay GERS or Specific Qualification
2141	SI	1SI-866A-M	1B42-321J	CONTACTOR	1B-32	1B32-1J	ELEM 735	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2142	SI	1SI-866B-M	1B42-421J	CONTACTOR	1B-42	1B42-1J	ELEM 735	SS	Relay GERS or Specific Qualification
2143	SI	1SI-871A-M	1B42-323M	CONTACTOR	1B-32	1B32-3M	ELEM 731	SS	Relay GERS or Specific Qualification
2144	SI	1SI-871A-M	33X/1-V870A	W BF82F	C-01-1(2)C-04	C-01	ELEM 731	SS	Relay GERS or Specific Qualification
2145	SI	1SI-871B-M	1B42-423M	CONTACTOR	1B-42	1B42-3M	ELEM 732	SS	Relay GERS or Specific Qualification
2146	SI	1SI-871B-M	33X/1-V870B	W BF82F	C-01-1(2)C-04	C-01	ELEM 739	SS	Relay GERS or Specific Qualification
2147	SI	1SI-878A-M	1B42-322J	CONTACTOR	1B-32	1B32-2J	ELEM 724A	SS	Relay GERS or Specific Qualification
2148	SI	1SI-878B-M	1B42-422J	CONTACTOR	1B-42	1B42-2J	ELEM 724	SS	Relay GERS or Specific Qualification
2149	SI	1SI-878C-M	1B42-422F	CONTACTOR	1B-42	1B42-2F	ELEM 724A	SS	Relay GERS or Specific Qualification
2150	SI	1SI-878D-M	1B42-322F	CONTACTOR	1B-32	1B32-2F	ELEM 724	SS	Relay GERS or Specific Qualification
2151	SI	1SI-896A-M	1B42-322C	CONTACTOR	1B-32	1B32-2C	ELEM 735	SS	Relay GERS or Specific Qualification
2152	SI	1SI-896B-M	1B42-422C	CONTACTOR	1B-42	1B42-2C	ELEM 735	SS	Relay GERS or Specific Qualification
2153	SI	2P-15A-M	2-74/A74FM	LINE ELEC AG-1D	2A-05	2A52-74	ELEM 223	CA4	Circuit/Relay Malfunction Acceptable
2154	SI	2P-15A-M	2A52-74		2A-05	2A52-74	ELEM 223	SWGR	Relays directly control Switchgear
2155	SI	2P-15A-M	50G/2A52-74	WITH	2A-05	2A52-74	ELEM 201	SS	Relay GERS or Specific Qualification
2156	SI	2P-15A-M	51/50A/2A52-74	W COM 5	2A-05	2A52-74	ELEM 201	SS	Relay GERS or Specific Qualification
2157	SI	2P-15A-M	51/50B/2A52-74	W COM 5	2A-05	2A52-74	ELEM 201	SS	Relay GERS or Specific Qualification
2158	SI	2P-15A-M	51/50C/2A52-74	W COM 5	2A-05	2A52-74	ELEM 201	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2159	SI	2P-15A-M	74/A52-74	W SG	2A-05	2A74	ELEM 223	CA4	Circuit/Relay Malfunction Acceptable
2160	SI	2P-15A-M	86/A52-74	W MG-6	2A-05	2A52-74	ELEM 223	SS	Relay GERS or Specific Qualification
2161	SI	2P-15B-M	2-74/A68FM	LINE ELEC AG-1D	2A-06	2A52-68	ELEM 223	CA4	Circuit/Relay Malfunction Acceptable
2162	SI	2P-15B-M	2A52-68		2A-06	2A52-68	ELEM 223	SWGR	Relays directly control Switchgear
2163	SI	2P-15B-M	50G/2A52-68	W ITH	2A-06	2A52-68	ELEM 201	SS	Relay GERS or Specific Qualification
2164	SI	2P-15B-M	51/50A/2A52-68	W COM 5	2A-06	2A52-68	ELEM 201	SS	Relay GERS or Specific Qualification
2165	SI	2P-15B-M	51/50B/2A52-68	W COM 5	2A-06	2A52-68	ELEM 201	SS	Relay GERS or Specific Qualification
2166	SI	2P-15B-M	51/50C/2A52-68	W COM 5	2A-06	2A52-68	ELEM 201	SS	Relay GERS or Specific Qualification
2167	SI	2P-15B-M	74/A52-68	W SG	2A-06	2A68	ELEM 223	CA4	Circuit/Relay Malfunction Acceptable
2168	SI	2P-15B-M	86/A52-68	W MG-6	2A-06	2A52-68	ELEM 223	SS	Relay GERS or Specific Qualification
2169	SI	2SI-825A-M	2B42-324C	CONTACTOR	2B-32	2B32-4C	ELEM 729	SS	Relay GERS or Specific Qualification
2170	SI	2SI-825A-M	33X/2-V826A	W BF22F	C-01-1(2)C-04	C-01	ELEM 736	CA9	Circuit/Relay Malfunction Acceptable
2171	SI	2SI-825A-M	33X/2-V826B	W BF22F	C-01-1(2)C-04	C-01	ELEM 727	CA9	Circuit/Relay Malfunction Acceptable
2172	SI	2SI-825A-M	33X/2-V826C	W BF22F	C-01-1(2)C-04	C-01	ELEM 727	CA9	Circuit/Relay Malfunction Acceptable
2173	SI	2SI-825B-M	2B42-424C	CONTACTOR	2B-42	2B42-4C	ELEM 729	SS	Relay GERS or Specific Qualification
2174	SI	2SI-826A-M	2B42-425F	CONTACTOR	2B-42	2B42-5F	ELEM 736	CA13	Circuit/Relay Malfunction Acceptable
2175	SI	2SI-826B-M	2B42-425J	CONTACTOR	2B-42	2B42-5J	ELEM 727	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2176	SI	2SI-826C-M	2B42-325F	CONTACTOR	2B-32	2B32-5F	ELEM 727	SS	Relay GERS or Specific Qualification
2177	SI	2SI-851A-M	2B42-323C	CONTACTOR	2B-32	2B32-3C	ELEM 734	SS	Relay GERS or Specific Qualification
2178	SI	2SI-851A-M	33X/2-V851A	W BF44F	C-01-1(2)C-04	C-01	ELEM 734	CA3	Circuit/Relay Malfunction Acceptable
2179	SI	2SI-851A-M	33X/2-V897A	W BFD62S	C-01-1(2)C-04	C-01	ELEM 770	SS	Relay GERS or Specific Qualification
2180	SI	2SI-851A-M	33X/2-V897B	W BFD62S	C-01-1(2)C-04	C-01	ELEM 770	SS	Relay GERS or Specific Qualification
2181	SI	2SI-851B-M	2B42-423C	CONTACTOR	2B-42	2B42-3C	ELEM 734	SS	Relay GERS or Specific Qualification
2182	SI	2SI-851B-M	33X/2-V851B	W BF44F	C-01-1(2)C-04	C-01	ELEM 734	CA3	Circuit/Relay Malfunction Acceptable
2183	SI	2SI-852A-M	2B42-321F	CONTACTOR	2B-32	2B32-1F	ELEM 725	SS	Relay GERS or Specific Qualification
2184	SI	2SI-852B-M	2B42-421F	CONTACTOR	2B-42	2B42-1F	ELEM 725	SS	Relay GERS or Specific Qualification
2185	SI	2SI-860A-M	2B42-321M	CONTACTOR	2B-32	2B32-1M	ELEM 725	SS	Relay GERS or Specific Qualification
2186	SI	2SI-860B-M	2B42-421M	CONTACTOR	2B-42	2B42-1M	ELEM 725	SS	Relay GERS or Specific Qualification
2187	SI	2SI-860C-M	2B42-322M	CONTACTOR	2B-32	2B32-2M	ELEM 725	SS	Relay GERS or Specific Qualification
2188	SI	2SI-860D-M	2B42-422M	CONTACTOR	2B-42	2B42-2M	ELEM 725	SS	Relay GERS or Specific Qualification
2189	SI	2SI-866A-M	2B42-321J	CONTACTOR	2B-32	2B32-1J	ELEM 735	SS	Relay GERS or Specific Qualification
2190	SI	2SI-866B-M	2B42-421J	CONTACTOR	2B-42	2B42-1J	ELEM 735	SS	Relay GERS or Specific Qualification
2191	SI	2SI-871A-M	2B42-323M	CONTACTOR	2B-32	2B32-3M	ELEM 731	SS	Relay GERS or Specific Qualification
2192	SI	2SI-871A-M	33X/2-V870A	W BF82F	C-01-1(2)C-04	C-01	ELEM 730	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2193	SI	2SI-871B-M	2B42-423M	CONTACTOR	2B-42	2B42-3M	ELEM 732	SS	Relay GERS or Specific Qualification
2194	SI	2SI-871B-M	33X/2-V87GB	W BF82F	C-01-1(2)C-04	C-01	ELEM 739	SS	Relay GERS or Specific Qualification
2195	SI	2SI-878A-M	2B42-322J	CONTACTOR	2B-32	2B32-2J	ELEM 724A	SS	Relay GERS or Specific Qualification
2196	SI	2SI-878B-M	2B42-422J	CONTACTOR	2B-42	2B42-2J	ELEM 724	SS	Relay GERS or Specific Qualification
2197	SI	2SI-878C-M	2B42-422F	CONTACTOR	2B-42	2B42-2F	ELEM 724A	SS	Relay GERS or Specific Qualification
2198	SI	2SI-878D-M	2B42-322F	CONTACTOR	2B-32	2B32-2F	ELEM 724	SS	Relay GERS or Specific Qualification
2199	SI	2SI-896A-M	2B42-322C	CONTACTOR	2B-32	2B32-2C	ELEM 735	SS	Relay GERS or Specific Qualification
2200	SI	2SI-896B-M	2B42-422C	CONTACTOR	2B-42	2B42-2C	ELEM 735	SS	Relay GERS or Specific Qualification
2201	SW	1SW-2880-M	1B42-4210F	CONTACTOR	1B-42	1B42-10F	ELEM 804	SS	Relay GERS or Specific Qualification
2202	SW	1SW-2907-M	1B42-3210F	CONTACTOR	1B-32	1B32-10F	ELEM 803	SS	Relay GERS or Specific Qualification
2203	SW	1SW-2908-M	1B42-4210C	CONTACTOR	1B-42	1B42-10C	ELEM 803	SS	Relay GERS or Specific Qualification
2204	SW	2SW-2880-M	2B42-4212G	CONTACTOR	2B-42	2B42-12G	ELEM 804	SS	Relay GERS or Specific Qualification
2205	SW	2SW-2907-M	2B42-3210F	CONTACTOR	2B-32	2B32-10F	ELEM 861	SS	Relay GERS or Specific Qualification
2206	SW	2SW-2908-M	2B42-4210C	CONTACTOR	2B-42	2B42-10C	ELEM 861	SS	Relay GERS or Specific Qualification
2207	SW	P-32A-M	74/1B52-10C	W BF22S	C-01-1(2)C-04	C-01	ELEM 364	CA4	Circuit/Relay Malfunction Acceptable
2208	SW	P-32B-M	74/1B52-11C	W BF22S	C-01-1(2)C-04	C-01	ELEM 364	CA4	Circuit/Relay Malfunction Acceptable
2209	SW	P-32C-M	74/1B52-20C	W BF22S	C-01-1(2)C-04	C-01	ELEM 364	CA4	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2210	SW	P-32D-M	74/2B52-27B	W BF22S	C-01-1(2)C-04	C-01	ELEM 394	CA4	Circuit/Relay Malfunction Acceptable
2211	SW	P-32E-M	74/2B52-27C	W BF22S	C-01-1(2)C-04	C-01	ELEM 394	CA4	Circuit/Relay Malfunction Acceptable
2212	SW	P-32F-M	74/2B52-34B	W BF22S	C-01-1(2)C-04	C-01	ELEM 394	CA4	Circuit/Relay Malfunction Acceptable
2213	SW	SW-2816-M	1B42-3211J	CONTACTOR	1B-32	1B32-11J	ELEM 804	SS	Relay GERS or Specific Qualification
2214	SW	SW-2817-M	2B42-4210F	CONTACTOR	2B-42	2B42-10F	ELEM 804	SS	Relay GERS or Specific Qualification
2215	SW	SW-2838-S	2FS-2896		2FS-2896	2FS-2896	BECH M-207 SH.4	CA3	Circuit/Relay Malfunction Acceptable
2216	SW	SW-2838-S	2FS-2898		2FS-2898	2FS-2898	BECH M-207 SH.4	CA3	Circuit/Relay Malfunction Acceptable
2217	SW	SW-2838-S	2FS-2900		2FS-2900	2FS-2900	BECH M-207 SH.4	CA3	Circuit/Relay Malfunction Acceptable
2218	SW	SW-2838-S	2FS-2902		2FS-2902	2FS-2902	BECH M-207 SH.4	CA3	Circuit/Relay Malfunction Acceptable
2219	SW	SW-2838-S	62/G02	AGASTAT 7022AE	G-02	C-65	ELEM 862	CA3	Circuit/Relay Malfunction Acceptable
2220	SW	SW-2838-S	ESR1/G02	SQ D PO 7001	C-35	C-35	EMD 8413730	CA11	Circuit/Relay Malfunction Acceptable
2221	SW	SW-2838-S	ESR2/G02	SQ D PO 7001	C-35	C-35	EMD 8413730	CA11	Circuit/Relay Malfunction Acceptable
2222	SW	SW-2839-S	1FS-2896		1FS-2896	1FS-2896	BECH M-207 SH.4	CA3	Circuit/Relay Malfunction Acceptable
2223	SW	SW-2839-S	1FS-2898		1FS-2898	1FS-2898	BECH M-207 SH.4	CA3	Circuit/Relay Malfunction Acceptable
2224	SW	SW-2839-S	1FS-2900		1FS-2900	1FS-2900	BECH M-207 SH.4	CA3	Circuit/Relay Malfunction Acceptable
2225	SW	SW-2839-S	1FS-2902		1FS-2902	1FS-2902	BECH M-207 SH.4	CA3	Circuit/Relay Malfunction Acceptable
2226	SW	SW-2839-S	62/G01	AGASTAT 7022AE	G-01	C-64	ELEM 806	CA3	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2227	SW	SW-2839-S	ESR1/G01	SQ D PO 7001	C-34	C-34	EMD 8413730	CA11	Circuit/Relay Malfunction Acceptable
2228	SW	SW-2839-S	ESR2/G01	SQ D PO 7001	C-34	C-34	EMD 8413730	CA11	Circuit/Relay Malfunction Acceptable
2229	SW	SW-2869-M	2B42-4210J	CONTACTOR	2B-42	2B42-10J	ELEM 805	SS	Relay GERS or Specific Qualification
2230	SW	SW-2870-M	1B42-3210J	CONTACTOR	1B-32	1B32-10J	ELEM 805	SS	Relay GERS or Specific Qualification
2231	SW	SW-2890-M	2B42-4210M	CONTACTOR	2B-42	2B42-10M	ELEM 805	SS	Relay GERS or Specific Qualification
2232	SW	SW-2891-M	1B42-3210M	CONTACTOR	1B-32	1B32-10M	ELEM 805	SS	Relay GERS or Specific Qualification
2233	UV	1A-05	1-271/A05	ITE-27D	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2234	UV	1A-05	1-271X1/A05	W MG-6	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2235	UV	1A-05	1-271X2/A05	W MG-6	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2236	UV	1A-05	1-272/A05	ITE-27D	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2237	UV	1A-05	1-272X1/A05	W MG-6	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2238	UV	1A-05	1-272X2/A05	W MG-6	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2239	UV	1A-05	1-273/A05	ITE-27D	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2240	UV	1A-05	1-274/A05	ITE-27D	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2241	UV	1A-05	1-275/A05	ITE-27D	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2242	UV	1A-05	1TDRA/A05	AGASTAT 7014	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2243	UV	1A-05	1TDRB/A05	AGASTAT 7014	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE {w/ note #}	SCREENING
2244	UV	1A-05	1TDRC/A05	AGASTAT 7014	1A-05	1A-05	ELEM 212	SS	Relay GERS or Specific Qualification
2245	UV	1A-06	1-271/A06	ITE-27D	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2246	UV	1A-06	1-271X1/A06	W MG-6	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2247	UV	1A-06	1-271X2/A06	W MG-6	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2248	UV	1A-06	1-272/A06	ITE-27D	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2249	UV	1A-06	1-272X1/A06	W MG-6	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2250	UV	1A-06	1-272X2/A06	W MG-6	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2251	UV	1A-06	1-273/A06	ITE-27D	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2252	UV	1A-06	1-274/A06	ITE-27D	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2253	UV	1A-06	1-275/A06	ITE-27D	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2254	UV	1A-06	1TDRA/A06	AGASTAT 7014	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2255	UV	1A-06	1TDRB/A06	AGASTAT 7014	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2256	UV	1A-06	1TDRC/A06	AGASTAT 7014	1A-06	1A-06	ELEM 214	SS	Relay GERS or Specific Qualification
2257	UV	1B-03	1-271/B03	ITE-27D	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification
2258	UV	1B-03	1-271X/B03	W MG-6	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification
2259	UV	1B-03	1-271X1/B03	W MG-6	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification
2260	UV	1B-03	1-271X2/B03	W MG-6	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2261	UV	1B-03	1-271X3/B03	W MG-6	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification
2262	UV	1B-03	1-271X4/B03	W MG-6	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification
2263	UV	1B-03	1-272/B03	ITE-27D	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification
2264	UV	1B-03	1-272X/B03	W MG-6	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification
2265	UV	1B-03	1-272X1/B03	W MG-6	1B-03	1B-03	ELEM 304	SS	Relay GERS or Specific Qualification
2266	UV	1B-03	1-272X2/B03	W MG-6	1B-03	1B-03	ELEM 304	SS	Relay GERS or Specific Qualification
2267	UV	1B-03	1-272X3/B03	W MG-6	1B-03	1B-03	ELEM 304	SS	Relay GERS or Specific Qualification
2268	UV	1B-03	1-272X4/B03	W MG-6	1B-03	1B-03	ELEM 304	SS	Relay GERS or Specific Qualification
2269	UV	1B-03	1-273/B03	ITE-27D	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification
2270	UV	1B-03	1-273X/B03	W MG-6	1B-03	1B-03	ELEM 303	SS	Relay GERS or Specific Qualification
2271	UV	1B-04	1-271/B04	ITE-27D	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification
2272	UV	1B-04	1-271X/B04	W MG-6	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification
2273	UV	1B-04	1-271X1/B04	W MG-6	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification
2274	UV	1B-04	1-271X2/B04	W MG-6	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification
2275	UV	1B-04	1-271X3/B04	W MG-6	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification
2276	UV	1B-04	1-271X4/B04	W MG-6	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification
2277	UV	1B-04	1-272/B04	ITE-27D	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2278	UV	1B-04	1-272X/B04	W MG-6	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification
2279	UV	1B-04	1-272X1/B04	W MG-6	1B-04	1B-04	ELEM 306	SS	Relay GERS or Specific Qualification
2280	UV	1B-04	1-272X2/B04	W MG-6	1B-04	1B-04	ELEM 306	SS	Relay GERS or Specific Qualification
2281	UV	1B-04	1-272X3/B04	W MG-6	1B-04	1B-04	ELEM 306	SS	Relay GERS or Specific Qualification
2282	UV	1B-04	1-272X4/B04	W MG-6	1B-04	1B-04	ELEM 306	SS	Relay GERS or Specific Qualification
2283	UV	1B-04	1-273/B04	ITE-27D	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification
2284	UV	1B-04	1-273X/B04	W MG-6	1B-04	1B-04	ELEM 305	SS	Relay GERS or Specific Qualification
2285	UV	2A-05	2-271/A05	ITE-27D	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2286	UV	2A-05	2-271X1/A05	W MG-6	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2287	UV	2A-05	2-271X2/A05	W MG-6	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2288	UV	2A-05	2-272/A05	ITE-27D	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2289	UV	2A-05	2-272X1/A05	W MG-6	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2290	UV	2A-05	2-272X2/A05	W MG-6	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2291	UV	2A-05	2-273/A05	ITE-27D	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2292	UV	2A-05	2-274/A05	ITE-27D	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2293	UV	2A-05	2-275/A05	ITE-27D	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2294	UV	2A-05	2TDRA/A05	AGASTAT 7014	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2295	UV	2A-05	2TDRB/A05	AGASTAT 7014	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2296	UV	2A-05	2TDRC/A05	AGASTAT 7014	2A-05	2A-05	ELEM 213	SS	Relay GERS or Specific Qualification
2297	UV	2A-06	2-271/A06	ITE-27D	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2298	UV	2A-06	2-271X1/A06	W MG-6	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2299	UV	2A-06	2-271X2/A06	W MG-6	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2300	UV	2A-06	2-272/A06	ITE-27D	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2301	UV	2A-06	2-272X1/A06	W MG-6	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2302	UV	2A-06	2-272X2/A06	W MG-6	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2303	UV	2A-06	2-273/A06	ITE-27D	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2304	UV	2A-06	2-274/A06	ITE-27D	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2305	UV	2A-06	2-275/A06	ITE-27D	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2306	UV	2A-06	2TDRA/A06	AGASTAT 7014	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2307	UV	2A-06	2TDRB/A06	AGASTAT 7014	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2308	UV	2A-06	2TDRC/A06	AGASTAT 7014	2A-06	2A-06	ELEM 218	SS	Relay GERS or Specific Qualification
2309	UV	2B-03	2-271/B03	ITE-27D	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification
2310	UV	2B-03	2-271X/B03	W MG-6	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification
2311	UV	2B-03	2-271X1/B03	W MG-6	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2312	UV	2B-03	2-271X2/B03	W MG-6	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification
2313	UV	2B-03	2-271X3/B03	W MG-6	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification
2314	UV	2B-03	2-271X4/B03	W MG-6	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification
2315	UV	2B-03	2-272/B03	ITE-27D	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification
2316	UV	2B-03	2-272X/B03	W MG-6	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification
2317	UV	2B-03	2-272X1/B03	W MG-6	2B-03	2B-03	ELEM 310	SS	Relay GERS or Specific Qualification
2318	UV	2B-03	2-272X2/B03	W MG-6	2B-03	2B-03	ELEM 310	SS	Relay GERS or Specific Qualification
2319	UV	2B-03	2-272X3/B03	W MG-6	2B-03	2B-03	ELEM 310	SS	Relay GERS or Specific Qualification
2320	UV	2B-03	2-272X4/B03	W MG-6	2B-03	2B-03	ELEM 310	SS	Relay GERS or Specific Qualification
2321	UV	2B-03	2-273/B03	ITE-27D	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification
2322	UV	2B-03	2-273X/B03	W MG-6	2B-03	2B-03	ELEM 309	SS	Relay GERS or Specific Qualification
2323	UV	2B-04	2-271/B04	ITE-27D	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification
2324	UV	2B-04	2-271X/B04	W MG-6	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification
2325	UV	2B-04	2-271X1/B04	W MG-6	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification
2326	UV	2B-04	2-271X2/B04	W MG-6	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification
2327	UV	2B-04	2-271X3/B04	W MG-6	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification
2328	UV	2B-04	2-271X4/B04	W MG-6	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2329	UV	2B-04	2-272/B04	ITE-27D	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification
2330	UV	2B-04	2-272X/B04	W MG-6	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification
2331	UV	2B-04	2-272X1/B04	W MG-6	2B-04	2B-04	ELEM 312	SS	Relay GERS or Specific Qualification
2332	UV	2B-04	2-272X2/B04	W MG-6	2B-04	2B-04	ELEM 312	SS	Relay GERS or Specific Qualification
2333	UV	2B-04	2-272X3/B04	W MG-6	2B-04	2B-04	ELEM 312	SS	Relay GERS or Specific Qualification
2334	UV	2B-04	2-272X4/B04	W MG-6	2B-04	2B-04	ELEM 312	SS	Relay GERS or Specific Qualification
2335	UV	2B-04	2-273/B04	ITE-27D	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification
2336	UV	2B-04	2-273X/B04	W MG-6	2B-04	2B-04	ELEM 311	SS	Relay GERS or Specific Qualification
2337	VNBI	W-85-M	2B42-3213C	CONTACTOR	2B-32	2B32-13C	ELEM 1655	CA13	Circuit/Relay Malfunction Acceptable
2338	VNBI	W-86-M	2B42-426J	CONTACTOR	2B-42	2B42-6J	ELEM 1658	CA13	Circuit/Relay Malfunction Acceptable
2339	VNCC	1W-1A1	X/1B52-15A	W Type M	1B-03	1B52-15A	ELEM 358	SWGR	Relays directly control Switchgear
2340	VNCC	1W-1A1-M	74/1B52-15A	W BF22S	C-01-1(2)C-04	C-01	ELEM 358	CA4	Circuit/Relay Malfunction Acceptable
2341	VNCC	1W-1B1	X/1B52-15B	W Type M	1B-03	1B52-15B	ELEM 359	SWGR	Relays directly control Switchgear
2342	VNCC	1W-1B1-M	74/1B52-15B	W BF22S	C-01-1(2)C-04	C-01	ELEM 359	CA4	Circuit/Relay Malfunction Acceptable
2343	VNCC	1W-1C1	X/1B52-18A	W Type M	1B-04	1B52-18A	ELEM 359	SWGR	Relays directly control Switchgear
2344	VNCC	1W-1C1-M	74/1B52-18A	W BF22S	C-01-1(2)C-04	C-01	ELEM 359	CA4	Circuit/Relay Malfunction Acceptable
2345	VNCC	1W-1D1	X/1B52-18B	W Type M	1B-04	1B52-18B	ELEM 358	SWGR	Relays directly control Switchgear



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2346	VNCC	1W-1D1-M	74/1852-18B	W BF22S	C-01-1(2)C-04	C-01	ELEM 358	CA4	Circuit/Relay Malfunction Acceptable
2347	VNCC	2W-1A1	X/2B52-39A	W Type M	2B-03	2B52-39A	ELEM 388	SWGR	Relays directly control Switchgear
2348	VNCC	2W-1A1-M	74/2B52-39A	W BF22S	C-01-1(2)C-04	C-01	ELEM 388	CA4	Circuit/Relay Malfunction Acceptable
2349	VNCC	2W-1B1	X/2B52-39B	W Type M	2B-03	2B52-39B	ELEM 389	SWGR	Relays directly control Switchgear
2350	VNCC	2W-1B1-M	74/2B52-39B	W BF22S	C-01-1(2)C-04	C-01	ELEM 389	CA4	Circuit/Relay Malfunction Acceptable
2351	VNCC	2W-1C1	X/2B52-26A	W Type M	2B-04	2B52-26A	ELEM 389	SWGR	Relays directly control Switchgear
2352	VNCC	2W-1C1-M	74/2B52-26A	W BF22S	C-01-1(2)C-04	C-01	ELEM 389	CA4	Circuit/Relay Malfunction Acceptable
2353	VNCC	2W-1D1	X/2B52-26B	W Type M	2B-04	2B52-26B	ELEM 388	SWGR	Relays directly control Switchgear
2354	VNCC	2W-1D1-M	74/2B52-26B	W BF22S	C-01-1(2)C-04	C-01	ELEM 388	CA4	Circuit/Relay Malfunction Acceptable
2355	VNDG	VNDG-4883A-S	3X/VNDG-4883	W BF62F	C-32	C-32	ELEM 841	CA17	Circuit/Relay Malfunction Acceptable
2356	VNDG	VNDG-4883A-S	62/VNDG-4883	AGASTAT 2412AD	C-32	C-32	ELEM 841	SS	Relay GERS or Specific Qualification
2357	VNDG	VNDG-4884A-S	3X/VNDG-4884	W BF62F	C-36	C-36	ELEM 841	CA17	Circuit/Relay Malfunction Acceptable
2358	VNDG	VNDG-4884A-S	62/VNDG-4884	AGASTAT 2412AD	C-36	C-36	ELEM 841	SS	Relay GERS or Specific Qualification
2359	VNDG	W-12A-M	1B42-329H	CONTACTOR	1B-32	1B32-9H	ELEM 596	SS	Relay GERS or Specific Qualification
2360	VNDG	W-12A-M	TS-4135	JONCTL A19AAF-12C	TS-4135	G01 RM	BECH M-143	CA17	Circuit/Relay Malfunction Acceptable
2361	VNDG	W-12A-M	TS-4136	JONCTL A19AAF-12C	TS-4136	G01 RM	BECH M-143	CA17	Circuit/Relay Malfunction Acceptable
2362	VNDG	W-12B-M	2B42-329H	CONTACTOR	2B-32	2B32-9H	ELEM 597	SS	Relay GERS or Specific Qualification



RELAY EVALUATION REPORT

TABLE B-1
 ASSOCIATED RELAY LIST

	SYSTEM	R-SSEL COMPONENT	RELAY ID	RELAY MAKE/MODEL	RELAY CABINET ID	LOCATION	DRAWING	SCREENING CODE (w/ note #)	SCREENING
2363	VNDG	W-12B-M	TS-4137	JONCTL A19AAF-12C	TS-4137	G01 RM	BECH M-143	CA17	Circuit/Relay Malfunction Acceptable
2364	VNDG	W-12B-M	TS-4138	JONCTL A19AAF-12C	TS-4138	G01 RM	BECH M-143	CA17	Circuit/Relay Malfunction Acceptable
2365	VNDG	W-12C-M	1B42-429M	CONTACTOR	1B-42	1B42-9M	ELEM 596	SS	Relay GERS or Specific Qualification
2366	VNDG	W-12C-M	TS-4139	JONCTL A19AAF-12C	TS-4139	G02 RM	BECH M-143	CA17	Circuit/Relay Malfunction Acceptable
2367	VNDG	W-12C-M	TS-4140	JONCTL A19AAF-12C	TS-4140	G02 RM	BECH M-143	CA17	Circuit/Relay Malfunction Acceptable
2368	VNDG	W-12D-M	2B42-429M	CONTACTOR	2B-42	2B42-9M	ELEM 597	SS	Relay GERS or Specific Qualification
2369	VNDG	W-12D-M	TS-4141	JONCTL A19AAF-12C	TS-4141	G02 RM	BECH M-143	CA17	Circuit/Relay Malfunction Acceptable
2370	VNDG	W-12D-M	TS-4142	JONCTL A19AAF-12C	TS-4142	G02 RM	BECH M-143	CA17	Circuit/Relay Malfunction Acceptable



RELAY EVALUATION REPORT

TABLE B-2
 FUNCTIONAL SCREENING NOTES

Table B-2; Associated Relay List Functional Screening Notes

Note #	Functional Screening Basis Discussion
1	The normal, failed and desired positions are "OPEN." Since seal-in is not incorporated in this circuitry, the only way to change the state of the valve is with the mechanical control switch.
2	The normal, failed and desired positions are "CLOSED." Since seal-in is not incorporated in this circuitry, the only way to change the state of the valve is with the mechanical control switch.
3	The device has only a non-control function. Therefore, its malfunction would not affect the position of the valve.
4	Alarm relay without any control functions
5	Relay is not connected in a seal-in configuration. Therefore, its chatter can only temporarily open the valve (milliseconds) - if it opens the valve at all.
6	Normal, failed and desired positions are "OPEN." Since seal-in is incorporated in the control circuitry for this valve, contactor 42/C should be seismically evaluated, while 42/O is chatter acceptable.
7	Normal, failed and desired positions are "CLOSED." Since seal-in is incorporated in the control circuitry for this valve, contactor 42/O should be seismically evaluated, while 42/C is chatter acceptable.
8	Normal, failed and desired states are "OFF" for the pump, and "TRIPPED" for the switchgear breaker. Therefore, the tripping circuitry is chatter acceptable, while the closing circuitry requires seismic screening.
9	Normal, failed and desired states are "OPEN." Therefore, devices in the "CLOSING" circuitry have to be evaluated for seismic adequacy, while devices in the "OPENING" circuitry are chatter acceptable.
10	Normal, failed and desired states are "CLOSED." Therefore, devices in the "OPENING" circuitry have to be evaluated for seismic adequacy, while devices in the "CLOSING" circuitry are chatter acceptable.
11	The solenoid valve is controlled with a mechanical switch or a combination of relays. Since a seal-in function is not incorporated in the control circuitry, chatter would cause, in the worst case, only a temporary change of the valve's state (milliseconds).
12	The solenoid valve is controlled with a timing relay, switchgear breaker, and a mechanical switch. Since a seal-in function is not incorporated in the control circuitry, chatter would cause, in the worst case, only a temporary change of the valve's state (milliseconds).
13	Relays have the control function, but the desired state of the equipment is stated to be "NO EFFECT," meaning that the position of that equipment is not critical to the safe shutdown process.
14	The failed and desired states for the switchgear breaker are "TRIPPED." Therefore, the tripping circuitry is chatter acceptable, while the closing circuitry should be seismically evaluated.



RELAY EVALUATION REPORT

TABLE B-2
 FUNCTIONAL SCREENING NOTES

Note #	Functional Screening Basis Discussion
15	The desired position of valves 1(2)MS-2019 and 1(2)MS-2020 is open. Although relays 1(2)62A and 1(2)62B are in the opening circuits of these valves, their function is anticipatory and non-safety related. Since parallel safety related paths exist in the opening circuits, relays 1(2)62A and 1(2)62B are not relied upon to open the valves, and chatter in these relays will not prevent the valves from opening.
16	The Westinghouse MG-6 relays have normally open and normally closed contact pairs in the breaker control circuits. The seismic capacity of the Westinghouse MG-6 normally de-energized, normally closed contact pair is 3g, and of the normally energized, normally open contact pair is 10g. The seismic screening applies only to the normally open contact pair with a capacity of 10g. The de-energized normally closed contact pair is screened as chatter acceptable. See Appendix E of this report for an explanation of the Westinghouse MG-6 de-energized, normally closed contact pair chatter acceptability.
17	Calculation N-88-034, "EDG Room Ventilation Test Evaluation" determined that the temperature rise in the diesel generator room, with no exhaust fans running, is .33 °F/min. The design basis ambient temperature for PBNP is 85 °F. The first diesel exhaust fan starts at a room temperature of 105 °F. Therefore, the fans are not required to operate until approximately 45 minutes after EDG start. Since the fan coolers are neither required to operate nor required to remain off during the period of strong motion, chatter of the temperature switches in the fan cooler control circuits is acceptable.
18	The 74XA3 and 74XB3 contacts can chatter closed and cause isolation of containment ventilation, which would have no adverse impact on the ability to perform a safe shutdown of either Unit.
19	Testing relays in the Reactor Protection System perform no control functions, so they are chatter acceptable.
20	Westinghouse MG-6 relays FSX and ESTX have de-energized, normally open contact pairs in the closing and lockout circuitry for the emergency diesel generator output breakers. Since no de-energized, normally closed contact pairs are being evaluated for these relays, a seismic capacity of 10g may be used.
21	Service Air compressor K3B is required to remain in the OFF position during the safety injection load sequencing on the emergency diesel generator. Although relay 2CR has a contact pair in the trip circuitry, an alternate path through relay 3CR is relied upon to perform the tripping function. Chatter of the 2CR contact pair will neither cause a compressor start nor prevent compressor tripping, provided relay 3CR performs its required function and does not chatter.
22	The relay is mounted in a control panel which is mounted on the emergency diesel generator or the air compressor. The relay is not chatter acceptable and is judged to be seismically adequate based on it functioning properly while vibrating during normal equipment operation.
23	The solenoid valve is controlled with a timing relay, a differential pressure switch, and the position switch for one of two motor operated valves. Since a seal-in function is not incorporated in the control circuitry, chatter would cause, in the worst case, only a temporary change of the valve's state (milliseconds).



RELAY EVALUATION REPORT

TABLE B 2
FUNCTIONAL SCREENING NOTES

Note #	Functional Screening Basis Discussion
24	The seismic capacity for the 1(2) PIC-639 is based on GERS package GERS-PS.5. The GERS checklist requires that the setpoint differentials should exceed the standard system operating values by at least 10%. ICP 6.15 documents the 1(2) PIC-639 setpoints.



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

The Essential Relay List (ERL) on the following pages provides a listing of the relays "essential" for the operation of the PBNP safe shutdown equipment. The list is sorted by "Relay ID". This list provides the results of the seismic capacity screening for the essential relays. The information in the table was initially recorded by the relay analyst on the Relay Identification / Functional Screening Worksheet and then transferred into a database. The relay identification number and the relay make and model were obtained from the electrical control circuit drawings. The "subsystem" field provides the equipment identification number for the safe shutdown component for which the relay functionality review is being performed. The "location" field provides the location of the relay as indicated on the corresponding electrical schematic drawing. The "relay cabinet id" field provides the equipment identification number corresponding to the component that was verified during the seismic walkdowns. The "screening code" field is the code used by the relay analyst to indicate the results of the functional screening. Some screening codes are followed by a number, which corresponds to the note in Appendix B, Table B-2. For the essential relays, the screening code will be either "SS#" or "SWGR", which are:

SS# seismic screening required - followed by a note # when required

SWGR switchgear "rule of the box" applies

The "low rugged relay check" field indicates which relays were checked against the list of low ruggedness relays found in Appendix E of EPRI NP 7148 [6.7]. The "LRR" entry indicates that the relay is not one of the low ruggedness relays. The "No" entry indicates that the relay is a low ruggedness relay. The "N/A" entry indicates that a low rugged relay check was not required. This was the case for essential relays mounted on vibrating equipment.



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

The "seismic capacity screening basis" field indicates which seismic capacity vs. demand screening level was used. The different screening levels are explained in Section 4 of the report. The "relay GERS seismic capacity" field provides the seismic capacity of the relay device and the relay device operating state that was used for the seismic capacity vs. demand check. The "Status" field provides final outcome of the seismic capacity vs. demand check; "yes" indicates the relay device has sufficient seismic capacity and "no" indicates the relay is an "outlier" either for being a low ruggedness relay or for not passing the seismic capacity vs. demand check.



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BAS' S	RELAY GERS SEISMIC CAPACITY	STATUS
1	1-1/N-31B-XA	W BF66F	RP	1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
2	1-1/N-31B-XB	W BF66F	RP	1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
3	1-1/N-32B-XA	W BF66F	RP	1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
4	1-1/N-32B-XB	W BF66F	RP	1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
5	1-1/N-33A-XA	W BF66F	RP	1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
6	1-1/N-33B-XB	W BF66F	RP	1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
7	1-1/N-35A-XA	W BF66F	RP	1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
8	1-1/N-35A-XB	W BF66F	RP	1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
9	1-1/N-36A-XA	W BF66F	RP	1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
10	1-1/N-36A-XB	W BF66F	RP	1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
11	1-1/N-38A-XA	W BF66F	RP	1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
12	1-1/N-38B-XB	W BF66F	RP	1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
13	1-1/N-39A-XA	W Nbfd66S	RP	1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
14	1-1/N-39A-XB	W Nbfd66S	RP	1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
15	1-1/N-39B-XA	W Nbfd66S	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
16	1-1/N-39B-XB	W Nbfd66S	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Mbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
17	1-1/N-41K-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
18	1-1/N-41K-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
19	1-1/N-42K-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
20	1-1/N-42K-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
21	1-1/N-43K-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
22	1-1/N-43K-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
23	1-1/N-44K-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
24	1-1/N-44K-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
25	1-1/N-47A-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
26	1-1/N-47B-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
27	1-2019X	W BFD66S	MS	1MS-2019-M	C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	8.00 (Westinghouse BFD) Non-operate, normally closed 8.00 Modified Relay GERS	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
28	1-2020X	W BFD66S	MS	1MS-2020-M	C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
29	1-271/A05	ITE-27D	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27) Non-operate, normally open 15.00) ANSI C37.98	Yes
30	1-271/A06	ITE-27D	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27) Non-operate, normally open 15.00) ANSI C37.98	Yes
31	1-271/B03	ITE-27D	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27) Non-operate, normally open 15.00) ANSI C37.98	Yes
32	1-271/B04	ITE-27D	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27) Non-operate, normally open 15.00) ANSI C37.98	Yes
33	1-271X/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
34	1-271X/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
35	1-271X1/A05	W MG-6	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
36	1-271X1/A06	W MG-6	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
37	1-271X1/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
38	1-271X1/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
39	1-271X2/A05	W MG-6	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
40	1-271X2/A06	W MG-6	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
41	1-271X2/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
42	1-271X2/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
43	1-271X3/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
44	1-271X3/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
45	1-271X4/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
46	1-271X4/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
47	1-272/A05	ITE-27D	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
48	1-272/A06	ITE-27D	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
49	1-272/B03	ITE-27D	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
50	1-272/B04	ITE-27D	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
51	1-272X/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
52	1-272X/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
53	1-272X1/A05	W MG-6	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
54	1-272X1/A06	W MG-6	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
55	1-272X1/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
56	1-272X1/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
57	1-272X2/A05	W MG-6	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
58	1-272X2/A06	W MG-6	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
59	1-272X2/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
60	1-272X2/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
61	1-272X3/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
62	1-272X3/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
63	1-272X4/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
64	1-272X4/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
65	1-273/A01-XA	W Nbfd66S	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
66	1-273/A01-XB	W Nbfd66S	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
67	1-273/A02-XA	W Nbfd66S	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
68	1-273/A02-XB	W Nbfd66S	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
69	1-273/A05	ITE-27D	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
70	1-273/A06	ITE-27D	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
71	1-273/B03	ITE-27D	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
72	1-273/B04	ITE-27D	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
73	1-273X/B03	W MG-6	UV	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
74	1-273X/B04	W MG-6	UV	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
75	1-274/A01-XA	W Nbfd66S	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
76	1-274/A01-XB	W Nbfd66S	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
77	1-274/A02-XA	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
78	1-274/A02-XB	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
79	1-274/A05	ITE-27D	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
80	1-274/A06	ITE-27D	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
81	1-275/A05	ITE-27D	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
82	1-275/A06	ITE-27D	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
83	1-33AC-SL-XA	W Nbfd66S	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
84	1-33AC-SL-XB	W Nbfd66S	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
85	1-33AC-SR-XA	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
86	1-33AC-SR-XB	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
87	1-62/4044A	AGASTAT 7014 PC	MS	1MS-2019-M	C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Agastat E7014, 7014, 2414) Non-operate, normally closed 10.00 ANSI C37.98	Yes
88	1-62/4044B	AGASTAT 7014 PC	MS	1MS-2020-M	C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Agastat E7014, 7014, 2414) Non-operate, normally closed 10.00 ANSI C37.98	Yes
89	1-62/P2A	AGASTAT 2412PC	480V	1B52-13A	1B-03	1B52-13A	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 12.50 (Agastat E7012, 7012, 2412) Non-operate, normally open 12.50 ANSI C37.98	Yes
90	1-62/P2B	AGASTAT 2412PC	480V	1B52-13B	1B-03	1B52-13B	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 12.50 (Agastat E7012, 7012, 2412) Non-operate, normally open 12.50 ANSI C37.98	Yes
91	1-62/P2C	AGASTAT 2412PC	480V	1B52-20A	1B-04	1B52-20A	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 12.50 (Agastat E7012, 7012, 2412) Non-operate, normally open 12.50 ANSI C37.98	Yes
92	1-63/AST3-XA	W Nbfd66S	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
93	1-63/AST3-XB	W Nbfd66S	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
94	1-63/AST4-XA	W Nbfd66S	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
95	1-63/AST4-XB	W Nbfd66S	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
96	1-63/AST5-XA	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
97	1-63/AST5-XB	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
98	1-71A/BAT	W Bfd44S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
99	1-71B/BAT	W Bfd44S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
100	1-86/A05	ELECTROSWITCH SERIES 24 CATALOG 7807D	4160V	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Electroswitch LOR) Non-operate, normally open 10.00 ANSI C37.98	Yes
101	1-86/A06	W WL	4160V	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse WL (DC)) Non-operate, normally open 10.00 Modified Relay GERS	Yes
102	1-86/B03	W WL	480V	1B-03	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse WL (DC)) Non-operate, normally open 10.00 Modified Relay GERS	Yes
103	1-86/B04	W WL	480V	1B-04	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse WL (DC)) Non-operate, normally open 10.00 Modified Relay GERS	Yes
104	1-86X/A05	W SG (DE,NO)	4160V	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (SG (DC voltage)) Non-operate, normally open 9.00 Modified Relay GERS	Yes
105	1-86X/A06	W SG (DE,NO)	4160V	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (SG (DC voltage)) Non-operate, normally open 9.00 Modified Relay GERS	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
106	1-86X/B03	W Nbfd65nr	480V	1B-03	1B-03	1B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
107	1-86X/B04	W Nbfd65nr	480V	1B-04	1B-04	1B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
108	1-87A/A05	W CA-16	4160V	1A-05	1A-05	1A-05	SS	LRR	Unknown capacity	No
109	1-87A/A06	W CA-16	4160V	1A-06	1A-06	1A-06	SS	LRR	Unknown capacity	No
110	1-87B/A05	W CA-16	4160V	1A-05	1A-05	1A-05	SS	LRR	Unknown capacity	No
111	1-87B/A06	W CA-16	4160V	1A-06	1A-06	1A-06	SS	LRR	Unknown capacity	No
112	1-87C/A05	W CA-16	4160V	1A-05	1A-05	1A-05	SS	LRR	Unknown capacity	No
113	1-87C/A06	W CA-16	4160V	1A-06	1A-06	1A-06	SS	LRR	Unknown capacity	No
114	1A52-06-XA	W Nbfd66s	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
115	1A52-06-XB	W Nbfd66s	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
116	1A52-12-XA	W Nbfd66s	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
117	1A52-12-XB	W Nbfd66s	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
118	1A52-59		SI	1P-15A-M	1A-05	1A52-59	SWGR	LRR	Switchgear Rule-of-the-Box	Yes
119	1A52-65		SI	1P-15B-M	1A-06	1A52-65	SWGR	LRR	Switchgear Rule-of-the-Box	Yes
120	1AFW-12X	W Bfd22s	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
121	1AFW-22X	W Bfd22s	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
122	1B42-3210F	CONTACTOR	SW	1SW-2907-M	1B-32	1B32-10F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.50 (Main1) Non-operate, normally open 4.50 Main Contactors	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
123	1B42-3210J	CONTACTOR	SW	SW-2870-M	1B-32	1B32-10J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
124	1B42-3210M	CONTACTOR	SW	SW-2891-M	1B-32	1B32-10M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
125	1B42-3211J	CONTACTOR	SW	SW-2816-M	1B-32	1B32-11J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
126	1B42-3212H	CONTACTOR	125VDC	D-109	1B42-3212H	1B42-3212H	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
127	1B42-3213C	CONTACTOR	CV	1CV-112B-M	1B-32	1B32-13C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
128	1B42-3213L	CONTACTOR	480V	1B52-3213L	1B-32	1B-32	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Operate, normally closed 4.50) Main Contactors	Yes
129	1B42-321F	CONTACTOR	SI	1SI-852A-M	1B-32	1B32-1F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
130	1B42-321J	CONTACTOR	SI	1SI-866A-M	1B-32	1B32-1J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
131	1B42-321M	CONTACTOR	SI	1SI-860A-M	1B-32	1B32-1M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
132	1B42-322C	CONTACTOR	SI	1SI-896A-M	1B-32	1B32-2C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
133	1B42-322F	CONTACTOR	SI	1SI-878D-M	1B-32	1B32-2F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
134	1B42-322J	CONTACTOR	SI	1SI-878A-M	1B-32	1B32-2J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
135	1B42-322M	CONTACTOR	SI	1SI-860C-M	1B-32	1B32-2M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
136	1B42-323C	CONTACTOR	SI	1SI-851A-M	1B-32	1B32-3C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
137	1B42-323M	CONTACTOR	SI	1SI-871A-M	1B-32	1B32-3M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
138	1B42-324C	CONTACTOR	SI	1SI-825A-M	1B-32	1B32-4C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
139	1B42-325F	CONTACTOR	SI	1SI-826C-M	1B-32	1B32-5F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
140	1B42-326C	CONTACTOR	CC	1CC-754A-M	1B-32	1B32-6C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
141	1B42-326F	CONTACTOR	CC	1CC-759A-M	1B-32	1B32-6F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
142	1B42-326J	CONTACTOR	CC	1CC-754B-M	1B-32	1B32-6J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
143	1B42-326M	CONTACTOR	CC	1CC-759B-M	1B-32	1B32-6M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
144	1B42-327M	CONTACTOR	CC	1CC-815-M	1B-32	1B32-7M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
145	1B42-328C	CONTACTOR	AF	AF-4009-M	1B-32	1B32-8C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
146	1B42-328F	CONTACTOR	AF	AF-4023-M	1B-32	1B32-8F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
147	1B42-329H	CONTACTOR	VNDG	W-12A-M	1B-32	1B32-9H	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
148	1B42-391	CONTACTOR	125VDC	D-07	1B42-391	1B39-1	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
149	1B42-4210C	CONTACTOR	SW	1SW-290B-M	1B-42	1B42-10C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
150	1B42-4210F	CONTACTOR	SW	1SW-2880-M	1B-42	1B42-10F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
151	1B42-4210M	CONTACTOR	FO	FO-3931-M	1B-42	1B42-10M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
152	1B42-421F	CONTACTOR	SI	1SI-852B-M	1B-42	1B42-1F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
153	1B42-421J	CONTACTOR	SI	1SI-866B-M	1B-42	1B42-1J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
154	1B42-421M	CONTACTOR	SI	1SI-860B-M	1B-42	1B42-1M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
155	1B42-422C	CONTACTOR	SI	1SI-896B-M	1B-42	1B42-2C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
156	1B42-422F	CONTACTOR	SI	1SI-878C-M	1B-42	1B42-2F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
157	1B42-422J	CONTACTOR	SI	1SI-878B-M	1B-42	1B42-2J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
158	1B42-422M	CONTACTOR	SI	1SI-860D-M	1B-42	1B42-2M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
159	1B42-423C	CONTACTOR	SI	1SI-851B-M	1B-42	1B42-3C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
160	1B42-423M	CONTACTOR	SI	1SI-871B-M	1B-42	1B42-3M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
161	1B42-424C	CONTACTOR	SI	1SI-825B-M	1B-42	1B42-4C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
162	1B42-425J	CONTACTOR	SI	1SI-826B-M	1B-42	1B42-5J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
163	1B42-426C	CONTACTOR	CC	1CC-719-M	1B-42	1B42-6C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
164	1B42-428C	CONTACTOR	AF	AF-4021-M	1B-42	1B42-8C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
165	1B42-428F	CONTACTOR	AF	1AF-4006-M	1B-42	1B42-8F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
166	1B42-429M	CONTACTOR	VNDG	W-12C-M	1B-42	1B42-9M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
167	1B42-491	CONTACTOR	125VDC	D-09	1B42-491	1B49-1	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
168	1B42-494	CONTACTOR	125VDC	D-10B	1B42-494	1B49-4	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
169	1B42/S-2019	CONTACTOR	MS	1MS-2019-M	1SMS-2019	1S-2019	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
170	1B42/S-2020	CONTACTOR	MS	1MS-2020-M	1SMS-2020	1S-2020	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
171	1CI-10X	W BFD48S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
172	1CI-11X	W BFD48S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
173	1CI-12X	W BFD48S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
174	1CI-20X	W BFD48S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
175	1CI-21X	W BFD48S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
176	1CI-22X	W BFD48S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
177	1CI-A	W MG-6	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
178	1CI-B	W MG-6	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
179	1CIR-A	W BFD22S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
180	1CIR-B	W BFD22S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
181	1CP-A	W NBFD65NR	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
182	1CP-A-X	W NBFD65NR	ESF		C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
183	1CP-B	W NBFD65NR	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
184	1CP-B-X	W NBFD65NR	ESF		C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
185	1CS-10X	W BFD64S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
186	1CS-20X	W BFD64S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
187	1CS-A	W MG-6	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
188	1CS-B	W MG-6	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
189	1F-10X	W BFD33S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
190	1F-20X	W BFD33S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
191	1F-30X	W BFD33S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
192	1F-40X	W BFD33S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
193	1FA-1	W MG-6	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
194	1FA-2	W MG-6	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
195	1FB-1	W MG-6	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
196	1FB-2	W MG-6	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
197	1FC-411-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
198	1FC-411-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
199	1FC-412-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
200	1FC-412-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
201	1FC-413-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
202	1FC-413-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
203	1FC-414-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
204	1FC-414-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
205	1FC-415-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
206	1FC-415-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
207	1FC-416-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.95	Yes
208	1FC-416-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
209	1FC-464A-XA	W BF44F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
210	1FC-464A-XB	W BF44F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
211	1FC-464B-XA	W BF44F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
212	1FC-464B-XB	W BF44F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
213	1FC-465A-XA	W BF44F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
214	1FC-465A-XB	W BF44F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
215	1FC-465B-XA	W BF44F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
216	1FC-465B-XB	W BF44F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
217	1FC-466C-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
218	1FC-466C-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
219	1FC-467B-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
220	1FC-467B-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
221	1FC-474A-XA	W BF44F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
222	1FC-474A-XB	W BF44F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
223	1FC-474B-XA	W BF44F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
224	1FC-474B-XB	W BF44F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
225	1FC-475A-XA	W BF44F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
226	1FC-475A-XB	W BF44F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
227	1FC-475B-XA	W BF44F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
228	1FC-475B-XB	W BF44F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
229	1FC-476C-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
230	1FC-476C-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
231	1FC-477B-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
232	1FC-477B-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
233	1IRB-1A	W NBFD66S	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
234	1IRB-1B	W NBFD66S	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
235	1IRB-2A	W NBFD66S	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
236	1IRB-2B	W NBFD66S	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
237	1LC-102C-XA	W BF42F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
238	1LC-102C-XB	W BF42F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
239	1LC-106C-XA	W BF42F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
240	1LC-106C-XB	W BF42F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
241	1LC-112B-X	W BF24F	CV	1CV-112B-M	1C-158/166/167	1C-158	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
242	1LC-141B-X	W BF24F	CV	1CV-112B-M	1C-158/166/167	1C-158	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
243	1LC-171C-XA	W BF42F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
244	1LC-171C-XB	W BF42F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
245	1LC-172C-XA	W BF42F	ESF		1C-158-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
246	1LC-172C-XB	W BF42F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
247	1LC-189C-XA	W BF42F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
248	1LC-189C-XB	W BF42F	ESF		1C-158/106/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
249	1LC-190C-XA	W BF42F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
250	1LC-190C-XB	W BF42F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
251	1LC-426A-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
252	1LC-426A-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
253	1LC-426B-XA	W BF46F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
254	1LC-426B-XB	W BF46F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
255	1LC-427A-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
256	1LC-427A-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
257	1LC-427C-XA	W BF46F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
258	1LC-427C-XB	W BF46F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
259	1LC-428A-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
260	1LC-428A-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
261	1LC-428E-XA	W BF46F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
262	1LC-428E-XB	W BF46F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
263	1LC-461A-XA	W BF44F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
264	1LC-461A-XB	W BF44F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
265	1LC-461B-XA	W BF57F	AF	AF-4023-M	1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
266	1LC-461B-XA	W BF57F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse 2F) Non-operate, normally closed 4.00 ANSI C37.98	Yes
267	1LC-461B-XB	W BF57F	AF	AF-4021-M	1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
268	1LC-461B-XB	W BF57F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
269	1LC-461B-YA	W BF57F	AF	AF-4023-M	1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
270	1LC-461B-YB	W BF57F	AF	AF-4021-M	1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
271	1LC-462A-XA	W BF57F	AF	AF-4023-M	1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
272	1LC-462A-XA	W BF57F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
273	1LC-462A-XB	W BF57F	AF	AF-4021-M	1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
274	1LC-462A-XB	W BF57F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
275	1LC-462A-YA	W BF57F	AF	AF-4023-M	1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
276	1LC-462A-YB	W BF57F	AF	AF-4021-M	1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
277	1LC-462B-XA	W BF55F	ESF		1C-166-167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
278	1LC-462B-XB	W BF55F	ESF		1C-166/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
279	1LC-462C-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
280	1LC-462C-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
281	1LC-463C-XA	W BF57F	AF	AF-4023-M	1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
282	1LC-463C-XA	W BF57F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
283	1LC-463C-XB	W BF57F	AF	AF-4021-M	1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
284	1LC-463C-XB	W BF57F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
285	1LC-463C-YA	W BF57F	AF	AF-4023-M	1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
286	1LC-463C-YB	W BF57F	AF	AF-4021-M	1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
287	1LC-463D-XA	W BF55F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
288	1LC-463D-XB	W BF55F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
289	1LC-463E-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
290	1LC-463E-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
291	1LC-471A-XA	W BF44F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
292	1LC-471A-XB	W BF44F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
293	1LC-471B-XA	W BF57F	AF	AF-4023-M	1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
294	1LC-471B-XA	W BF57F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
295	1LC-471B-XB	W BF57F	AF	AF-4021-M	1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
296	1LC-471B-XB	W BF57F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
297	1LC-471B-YA	W BF57F	AF	AF-4023-M	1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
298	1LC-471B-YB	W BF57F	AF	AF-4021-M	1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
299	1LC-472A-XA	W BF57F	AF	AF-4023-M	1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
300	1LC-472A-XA	W BF57F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
301	1LC-472A-XB	W BF57F	AF	AF-4021-M	1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
302	1LC-472A-XB	W BF57F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
303	1LC-472A-YA	W BF57F	AF	AF-4023-M	1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
304	1LC-472A-YB	W BF57F	AF	AF-4021-M	1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
305	1LC-472B-XA	W BF55F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
306	1LC-472B-XB	W BF55F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
307	1LC-472C-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
308	1LC-472C-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
309	1LC-473C-XA	W BF57F	AF	AF-4023-M	1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
310	1LC-473C-XA	W BF57F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
311	1LC-473C-XB	W BF57F	AF	AF-4021-M	1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
312	1LC-473C-XB	W BF57F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
313	1LC-473C-YA	W BF57F	AF	AF-4023-M	1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
314	1LC-473C-YB	W BF57F	AF	AF-4021-M	1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
315	1LC-473D-XA	W BF55F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
316	1LC-473D-XB	W BF55F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
317	1LC-473E-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
318	1LC-473E-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
319	1LCAA	W BFD44S	AF	AF-4023-M	C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
320	1LCAB	W BFD44S	AF	AF-4021-M	C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
321	1LCBA	W BFD44S	AF	AF-4023-M	C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
322	1LCBB	W BFD44S	AF	AF-4021-M	C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
323	1MS-A1	W BFD33S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
324	1MS-A2	W BFD33S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
325	1MS-B1	W BFD33S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
326	1MS-B2	W BFD33S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
327	1NC-31D-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
328	1NC-31D-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
329	1NC-32D-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
330	1NC-32D-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
331	1NC-35D-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
332	1NC-35D-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
333	1NC-35F-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
334	1NC-35F-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
335	1NC-36D-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
336	1NC-36D-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
337	1NC-36F-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
338	1NC-36F-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
339	1NC-41K-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
340	1NC-41K-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
341	1NC-41M-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
342	1NC-41M-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
343	1NC-41N-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
344	1NC-41N-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
345	1NC-41P-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
346	1NC-41P-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
347	1NC-41R-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
348	1NC-41R-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
349	1NC-41S-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
350	1NC-41S-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
351	1NC-42K-XA	W BF66F	RP		1C-151-155	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
352	1NC-42K-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
353	1NC-42M-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
354	1NC-42M-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
355	1NC-42N-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
356	1NC-42N-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
357	1NC-42P-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
358	1NC-42P-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
359	1NC-42R-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
360	1NC-42R-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
361	1NC-42S-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
362	1NC-42S-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
363	1NC-43K-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
364	1NC-43K-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
365	1NC-43M-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
366	1NC-43M-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
367	1NC-43N-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
368	1NC-43N-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
369	1NC-43P-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
370	1NC-43P-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
371	1NC-43R-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
372	1NC-43R-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
373	1NC-43S-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
374	1NC-43S-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
375	1NC-44K-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
376	1NC-44K-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
377	1NC-44M-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
378	1NC-44M-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
379	1NC-44N-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
380	1NC-44N-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
381	1NC-44P-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
382	1NC-44P-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
383	1NC-44R-XA	W CF66F	RF		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
384	1NC-44R-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
385	1NC-44S-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
386	1NC-44S-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
387	1P07-1A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
388	1P07-1B	W Nbfd84S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
389	1P07-2A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
390	1P07-2B	W Nbfd84S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
391	1P07-3A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
392	1P07-3B	W Nbfd84S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
393	1P08-1A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
394	1P08-1B	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
395	1P08-2A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
396	1P08-2B	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
397	1P09-1A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
398	1P09-1B	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
399	1P09-2A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
400	1P09-2B	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
401	1P10-1A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
402	1P10-1B	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
403	1P10-2A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
404	1P10-2B	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
405	1P32A-XA	W Bf62F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse Bf) Non-operate, normally closed 4.00 ANSI C37.98	Yes
406	1P32A-XB	W Bf62F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse Bf) Non-operate, normally closed 4.00 ANSI C37.98	Yes
407	1P32B-XA	W Bf62F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse Bf) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
408	1P32B-XB	W BF62F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
409	1P32C-XA	W BF62F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
410	1P32C-XB	W BF62F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
411	1P32D-XA	W BF62F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
412	1P32D-XB	W BF62F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
413	1P32E-XA	W BF62F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
414	1P32E-XB	W BF62F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
415	1P32F-XA	W BF62F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
416	1P32F-XB	W BF62F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
417	1PC-428B-XA	W BF53F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
418	1PC-428B-XB	W BF53F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
419	1PC-429A-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
420	1PC-429A-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
421	1PC-429C-XA	W BF46F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
422	1PC-429C-XB	W BF46F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
423	1PC-429E-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
424	1PC-429E-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
425	1PC-430A-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
426	1PC-430A-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
427	1PC-430E-XA	W BF46F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
428	1PC-430E-XB	W BF46F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
429	1PC-430F-XA	W BF66F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
430	1PC-430F-XB	W BF66F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
431	1PC-430H-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
432	1PC-430H-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
433	1PC-431A-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
434	1PC-431A-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
435	1PC-431G-XA	W BF46F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
436	1PC-431G-XB	W BF46F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
437	1PC-431I-XA	W BF66F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
438	1PC-431I-XB	W BF66F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
439	1PC-431J-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
440	1PC-431J-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
441	1PC-449A-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
442	1PC-449A-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
443	1PC-468A-XA	W BF46F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
444	1PC-468A-XB	W BF46F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
445	1PC-469A-XA	W BF48F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
446	1PC-469A-XB	W BF48F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
447	1PC-478A-XA	W BF46F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
448	1PC-478A-XB	W BF46F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
449	1PC-479A-XA	W BF48F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
450	1PC-479A-XB	W BF48F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
451	1PC-482A-XA	W BF48F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
452	1PC-482A-XB	W BF48F	ESF		1C-158/166/167	1C-188	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
453	1PC-483A-XA	W BF48F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
454	1PC-483A-XB	W BF48F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
455	1PC-484A-XA	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
456	1PC-484A-XB	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
457	1PC-485A-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
458	1PC-485A-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
459	1PC-486A-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
460	1PC-486A-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
461	1PC-628-XA	W BF22F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
462	1PC-629-XB	W BF22F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
463	1PC-639-X1	W BFD24S	CC	1P-11A-M	1C-158/165/167	1C-158	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
464	1PC-639-X2	W BFD11S	CC	1P-11B-M	C-01-1(2)C-04	1C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
465	1PC-945A-XA	W BF46F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
466	1PC-945A-XB	W BF46F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
467	1PC-945B-XA	W BF44F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
468	1PC-945B-XB	W BF44F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
469	1PC-946A-XA	W BF46F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
470	1PC-946A-XB	W BF46F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
471	1PC-946B-XA	W BF44F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
472	1PC-946B-XB	W BF44F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
473	1PC-947A-XA	W BF46F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
474	1PC-947A-XB	W BF46F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
475	1PC-947B-XA	W BF55F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
476	1PC-947B-XB	W BF55F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
477	1PC-948A-XA	W BF48F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
478	1PC-948A-XB	W BF48F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
479	1PC-948B-XA	W BF55F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
480	1PC-948B-XB	W BF55F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
481	1PC-949A-XA	W BF48F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
482	1PC-949A-XB	W BF48F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
483	1PC-949B-XA	W BF55F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
484	1PC-949B-XB	W BF55F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
485	1PC-950A-XA	W BF48F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
486	1PC-950A-XB	W BF48F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
487	1PC-950B-XA	W BF55F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
488	1PC-950B-XB	W BF55F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
489	1PIC-639	BARTON Model 288A	CC	1P-11A-M	1PIC-639	1PIC-639	SS24	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (Barton Models 288 & 289) Operate, normally open 3.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
490	1PRB-1A	W Nbfd69S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
491	1PRB-1B	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
492	1PRB-2A	W Nbfd66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
493	1PRB-2B	W Nbfd66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
494	1PY-4044-LLA	FOXBORO NO152CK - N-2AO-L2C-R	MS	1MS-2019-M	1C-170-173	1C-171	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
495	1PY-4044-LLB	FOXBORO NO152CK - N-2AO-L2C-R	MS	1MS-2020-M	1C-170-173	1C-171	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
496	1RC-1A	W Nbfd42S	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
497	1RC-1B	W Nbfd42S	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
498	1RC-2A	W Nbfd42S	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
499	1RC-2B	W Nbfd42S	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
500	1RC-3A	W Nbfd42S	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
501	1RC-3B	W Nbfd42S	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE {w/ note #}	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
502	1RC-4A	W Nbfd42S	RP	1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
503	1RC-4B	W Nbfd42S	RP	1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
504	1RCP-A-XA	W Nbfd66S	RP	1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
505	1RCP-A-XB	W Nbfd66S	RP	1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
506	1RCP-B-XA	W Nbfd66S	RP	1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
507	1RCP-B-XB	W Nbfd66S	RP	1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
508	1RT-10A	W Nbfd31S	RP	1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
509	1RT-10B	W Nbfd31S	RP	1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
510	1RT-11A	W Nbfd31S	RP	1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
511	1RT-11B	W Nbfd31S	RP	1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
512	1RT-12A	W Nbfd31S	RP	1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
513	1RT-12B	W Nbfd31S	RP	1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
514	1RT-1A	W Nbfd31S	RP	1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
515	1RT-1B	W Nbfd31S	RP	1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
516	1RT-2A	W Nbfd31s	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
517	1RT-2B	W Nbfd31s	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
518	1RT-3A	W Nbfd31s	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
519	1RT-3B	W Nbfd31s	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
520	1RT-4A	W Nbfd31s	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
521	1RT-4B	W Nbfd31s	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
522	1RT-5A	W Nbfd31s	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
523	1RT-5B	W Nbfd31s	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
524	1RT-6A	W Nbfd31s	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
525	1RT-6B	W Nbfd31s	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
526	1RT-7A	W Nbfd31s	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
527	1RT-7B	W Nbfd31s	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
528	1RT-8A	W Nbfd31s	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
529	1RT-8B	W Nbfd31s	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
530	1RT-9A	W Nbfd31S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00) ANSI C37.98	Yes
531	1RT-9B	W Nbfd31S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00) ANSI C37.98	Yes
532	1SI-10X	W Bfd84S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
533	1SI-10X1	ASEA RXMA1	125VDC	D-07	2C-20	2C-20	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (ASEA RXMA1) Operate, normally closed 10.00) ANSI C37.98	Yes
534	1SI-11X	W Bfd84S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
535	1SI-11X-AXA	W Nbfd66S	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00) ANSI C37.98	Yes
536	1SI-11X-AXB	W Nbfd66S	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00) ANSI C37.98	Yes
537	1SI-12X	W Bfd84S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
538	1SI-13X	W Bfd84S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
539	1SI-14X	W Bfd84S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
540	1SI-20X	W Bfd84S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
541	1SI-20X1	ASEA RXMA1	125VDC	D-08	2C-20	2C-20	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (ASEA RXMA1) Operate, normally closed 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
542	1SI-21X	W BFD84S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
543	1SI-21X-BXA	W NBFD66S	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
544	1SI-21X-BXB	W NBFD66S	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
545	1SI-22X	W BFD84S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
546	1SI-23X	W BFD84S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
547	1SI-24X	W BFD84S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
548	1SIA-A	W MG-6	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
549	1SIA-B	W MG-6	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
550	1SIB-A	W BFD75S	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
551	1SIB-B	W BFD75S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
552	1SIM-A	W MG-6	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
553	1SIM-B	W MG-6	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
554	1SIR-A	W Nbfd65NR	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
555	1SIR-B	W Nbfd65NR	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
556	1SRB-1A	W Nbfd66S	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
557	1SRB-1B	W Nbfd66S	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
558	1SRB-2A	W Nbfd66S	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
559	1SRB-2B	W Nbfd66S	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
560	1SW-A	W Bfd22S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
561	1SW-AX	W Bfd42S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
562	1SW-B	W Bfd22S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
563	1SW-BX	W Bfd42S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
564	1TC-401D-XA	W Bf66F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse Bf) Non-operate, normally closed 4.00 ANSI C37.98	Yes
565	1TC-401D-XB	W Bf66F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse Bf) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
566	1TC-402D-XA	W BF66F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
567	1TC-402D-XB	W BF66F	ESF		1C-158/156/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
568	1TC-403D-XA	W BF66F	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
569	1TC-403D-XB	W BF66F	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
570	1TC-404D-XA	W BF66F	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
571	1TC-404D-XB	W BF66F	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
572	1TC-405A-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
573	1TC-405A-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
574	1TC-405C-XA	W BF66F	RP		1C-151-155	1C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
575	1TC-405C-XB	W BF66F	RP		1C-161-165	1C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
576	1TC-406A-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
577	1TC-406A-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
578	1TC-406C-XA	W BF66F	RP		1C-151-155	1C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
579	1TC-406C-XB	W BF66F	RP		1C-161-165	1C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
580	1TC-407A-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
581	1TC-407A-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
582	1TC-407C-XA	W BF66F	RP		1C-151-155	1C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
583	1TC-407C-XB	W BF66F	RP		1C-161-165	1C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
584	1TC-408A-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
585	1TC-408A-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
586	1TC-408C-XA	W BF66F	RP		1C-151-155	1C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
587	1TC-408C-XB	W BF66F	RP		1C-161-165	1C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
588	1TDR-10	AGASTAT 2412PD	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50 ANSI C37.98	Yes
589	1TDR-11	AGASTAT 2412PD	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50 ANSI C37.98	Yes
590	1TDR-12	AGASTAT 2412PE	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50 ANSI C37.98	Yes
591	1TDR-13	AGASTAT 2412PD	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
592	1TDR-14	AGASTAT 2412PD	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
593	1TDR-15	AGASTAT 2412PE	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
594	1TDR-16	AGASTAT 2412PE	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
595	1TDR-17	AGASTAT 2412PE	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
596	1TDR-18	AGASTAT 2412PD	ESF		1C-156-157	1C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
597	1TDR-19	AGASTAT 2412PE	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
598	1TDR-20	AGASTAT 2412PD	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
599	1TDR-21	AGASTAT 2412PD	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
600	1TDR-22	AGASTAT 2412PE	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
601	1TDR-23	AGASTAT 2412PD	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
602	1TDR-24	AGASTAT 2412PD	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
603	1TDR-25	AGASTAT 2412PE	ESF		1C-158/166/167	1C-165	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
604	1TDR-26	AGASTAT 2412PE	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
605	1TDR-27	AGASTAT 2412PE	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
606	1TDR-28	AGASTAT 2412PD	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
607	1TDR-29	AGASTAT 2412PE	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
608	1TDRA/A05	AGASTAT 7014	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
609	1TDRA/A06	AGASTAT 7014	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
610	1TDRB/A05	AGASTAT 7014	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
611	1TDRB/A06	AGASTAT 7014	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
612	1TDRC/A05	AGASTAT 7014	UV	1A-05	1A-05	1A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
613	1TDRC/A06	AGASTAT 7014	UV	1A-06	1A-06	1A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
614	1V-10X	W BFD24S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
615	1V-20X	W BFD24S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
616	1VA	W MG-6	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00) ANSI C37.98	Yes
617	1VB	W MG-6	ESF		1C-158/166/167	1C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00) ANSI C37.98	Yes
618	1XAT1	W BFD11S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
619	1XAT2	W BFD11S	ESF		1C-156-157	1C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
620	1XBT1	W BFD11S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
621	1XBT2	W BFD11S	ESF		1C-158/166/167	1C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
622	2-1/N-31B-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00) ANSI C37.98	Yes
623	2-1/N-31B-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00) ANSI C37.98	Yes
624	2-1/N-32B-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00) ANSI C37.98	Yes
625	2-1/N-32B-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
626	2-1/N-33A-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
627	2-1/N-33B-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
628	2-1/N-35A-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
629	2-1/N-35A-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
630	2-1/N-36A-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
631	2-1/N-36A-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
632	2-1/N-38A-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
633	2-1/N-38B-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
634	2-1/N-39A-XA	W Nbfd66S	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
635	2-1/N-39A-XB	W Nbfd66S	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
636	2-1/N-39B-XA	W Nbfd66S	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
637	2-1/N-39B-XB	W Nbfd66S	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
638	2-1/N-41K-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
639	2-1/N-41K-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
640	2-1/N-42K-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
641	2-1/N-42K-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
642	2-1/N-43K-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
643	2-1/N-43K-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
644	2-1/N-44K-XA	W BF66F	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
645	2-1/N-44K-XB	W BF66F	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
646	2-1/N-47A-XA	W BF66F	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
647	2-1/N-47B-XB	W BF66F	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
648	2-2019X	W BFD66S	MS	2MS-2019-M	C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
649	2-2020X	W BFD66S	MS	2MS-2020-M	C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
650	2-271/A05	ITE-27D	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
651	2-271/A06	ITE-27D	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
652	2-271/B03	ITE-27D	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
653	2-271/B04	ITE-27D	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
654	2-271X/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
655	2-271X/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
656	2-271X1/A05	W MG-6	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
657	2-271X1/A06	W MG-6	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
658	2-271X1/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
659	2-271X1/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
660	2-271X2/A05	W MG-6	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
661	2-271X2/A06	W MG-6	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
662	2-271X2/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
663	2-271X2/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
664	2-271X3/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
665	2-271X3/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
666	2-271X4/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
667	2-271X4/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
668	2-272/A05	ITE-27D	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
669	2-272/A06	ITE-27D	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
670	2-272/B03	ITE-27D	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
671	2-272/B04	ITE-27D	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
672	2-272X/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
673	2-272X/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
674	2-272X1/A05	W MG-6	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
675	2-272X1/A06	W MG-6	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
676	2-272X1/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
677	2-272X1/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
678	2-272X2/A05	W MG-6	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse M3-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
679	2-272X2/A06	W MG-6	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
680	2-272X2/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
681	2-272X2/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
682	2-272X3/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
683	2-272X3/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
684	2-272X4/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
685	2-272X4/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
686	2-273/A01-XA	W Nbfd66S	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
687	2-273/A01-XC	W Nbfd66S	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
688	2-273/A02-XA	W Nbfd66S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
689	2-273/A02-XB	W Nbfd66S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
690	2-273/A05	ITE-27D	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
691	2-273/A06	ITE-27D	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
692	2-273/B03	ITE-27D	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
693	2-273/B04	ITE-27D	UV	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
694	2-273X/B03	W MG-6	UV	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
695	2-273X/B04	W MG-6	UV	2B-04	2B-04	2B-04	SS	LRF	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
696	2-274/A01-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
697	2-274/A01-XB	W Nbfd66S	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
698	2-274/A02-XA	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
699	2-274/A02-XB	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
700	2-274/A05	ITE-27D	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
701	2-274/A06	ITE-27D	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
702	2-275/A05	ITE-27D	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
703	2-275/A06	ITE-27D	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 15.00 (ITE 27 Non-operate, normally open 15.00) ANSI C37.98	Yes
704	2-33AC-SL-XA	W Nbfd66S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
705	2-33AC-SL-XB	W Nbfd66S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
706	2-33AC-SR-XA	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
707	2-33AC-SR-XB	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
708	2-62/4044A	AGASTAT 7014 PC	MS	2MS-2019-M	C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Agastat E7014, 7014, 2414 Non-operate, normally closed	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
									10.00 ANSI C37.98		
709	2-62/4044B	AGASTAT 7014PC	MS	2MS-2020-M	C-01-112 C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally closed 10.00) ANSI C37.98	Yes
710	2-62/P2A	AGASTAT 2412PC	480V	2B52-37A	2B-03	2B52-37A	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally open 12.50) ANSI C37.98	Yes
711	2-62/P2B	AGASTAT 2412PC	480V	2B52-37B	2B-03	2B52-37B	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally open 12.50) ANSI C37.98	Yes
712	2-63/AST3-XA	W Nbfd66S	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
713	2-63/AST3-XB	W Nbfd66S	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
714	2-63/AST4-XA	W Nbfd66S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
715	2-63/AST4-XB	W Nbfd66S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
716	2-63/AST5-XA	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
717	2-63/AST5-XB	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
718	2-71A/BAT	W Bfd44S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
719	2-71B/BAT	W Bfd44S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
720	2-86/A05	W WL	4160V	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse WL (DC) Non-operate, normally open 10.00) Modified Relay GERS	Yes
721	2-86/A06	W WL	4160V	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse WL (DC) Non-operate, normally open 10.00) Modified Relay GERS	Yes
722	2-86/B03	W WL	480V	2B-03	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse WL (DC) Non-operate, normally open 10.00) Modified Relay GERS	Yes
723	2-86/B04	W WL	480V	2B-04	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse WL (DC) Non-operate, normally open 10.00) Modified Relay GERS	Yes
724	2-86X/A05	W SG (DE NO)	4160V	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (SG (DC voltage) Non-operate, normally open 9.00) Modified Relay GERS	Yes
725	2-86X/A06	W SG (DE NO)	4160V	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (SG (DC voltage) Non-operate, normally open 9.00) Modified Relay GERS	Yes
726	2-86X/B03	W NBDF65NR	480V	2B-03	2B-03	2B-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
727	2-86X/B04	W NBDF65NR	480V	2B-04	2B-04	2B-04	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
728	2-87A/A05	W CA-16	4160V	2A-05	2A-05	2A-05	SS	LRR		Unknown capacity	No
729	2-87A/A06	W CA-16	4160V	2A-06	2A-06	2A-06	SS	LRR		Unknown capacity	No
730	2-87B/A05	W CA-16	4160V	2A-05	2A-05	2A-05	SS	LRR		Unknown capacity	No
731	2-87B/A06	W CA-16	4160V	2A-06	2A-06	2A-06	SS	LRR		Unknown capacity	No
732	2-87C/A05	W CA-16	4160V	2A-05	2A-05	2A-05	SS	LRR		Unknown capacity	No
733	2-87C/A06	W CA-16	4160V	2A-06	2A-06	2A-06	SS	LRR		Unknown capacity	No
734	27-13213L	W BF22F	480V	1B52-3213L	1B-32	1B-32	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
735	27-24212M	W BF22F	480V	2B52-4212M	2B-42	2B-42	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
736	2A52-06-XA	W Nbfd66S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
737	2A52-06-XB	W Nbfd66S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
738	2A52-12-XA	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
739	2A52-12-XB	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
740	2A52-68		SI	2P-15B-M	2A-06	2A52-68	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
741	2A52-74		SI	2P-15A-M	2A-05	2A52-74	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
742	2AFW-12X	W Bfd22S	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
743	2AFW-22X	W Bfd22S	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
744	2B42-3210F	CONTACTOR	SW	2SW-2907-M	2B-32	2B32-10F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1) Non-operate, normally open 4.50 Main Contactors	Yes
745	2B42-3210J	CONTACTOR	CV	2CV-112B-M	2B-32	2B32-10J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1) Non-operate, normally open 4.50 Main Contactors	Yes
746	2B42-3210M	CONTACTOR	FO	FO-3930-M	2B-32	2B32-10M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1) Non-operate, normally open 4.50 Main Contactors	Yes
747	2B42-321F	CONTACTOR	SI	2SI-852A-M	2B-32	2B32-1F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1) Non-operate, normally open 4.50 Main Contactors	Yes
748	2B42-321J	CONTACTOR	SI	2SI-866A-M	2B-32	2B32-1J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1) Non-operate, normally open 4.50 Main Contactors	Yes
749	2B42-321M	CONTACTOR	SI	2SI-860A-M	2B-32	2B32-1M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1) Non-operate, normally open 4.50 Main Contactors	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
750	2B42-322C	CONTACTOR	SI	2SI-896A-M	2B-32	2B32-2C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
751	2B42-322F	CONTACTOR	SI	2SI-878D-M	2B-32	2B32-2F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
752	2B42-322J	CONTACTOR	SI	2SI-878A-M	2B-32	2B32-2J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
753	2B42-322M	CONTACTOR	SI	2SI-860C-M	2B-32	2B32-2M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
754	2B42-323C	CONTACTOR	SI	2SI-851A-M	2B-32	2B32-3C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
755	2B42-323M	CONTACTOR	SI	2SI-871A-M	2B-32	2B32-3M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
756	2B42-324C	CONTACTOR	SI	2SI-825A-M	2B-32	2B32-4C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
757	2B42-325F	CONTACTOR	SI	2SI-826C-M	2B-32	2B32-5F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
758	2B42-326C	CONTACTOR	CC	2CC-754A-M	2B-32	2B32-6C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
759	2B42-326F	CONTACTOR	CC	2CC-759A-M	2B-32	2B32-6F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
760	2B42-326J	CONTACTOR	CC	2CC-754B-M	2B-32	2B32-6J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
761	2B42-326M	CONTACTOR	CC	2CC-759B-M	2B-32	2B32-6M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
762	2B42-327M	CONTACTOR	CC	2CC-815-M	2B-32	2B32-7M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
763	2B42-328C	CONTACTOR	AF	AF-4022-M	2B-32	2B32-8C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
764	2B42-329H	CONTACTOR	VNDG	W-12B-M	2B-32	2B32-9H	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
765	2B42-391	CONTACTOR	125VDC	D-09	2B42-391	2B39-1	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
766	2B42-394	CONTACTOR	125VDC	D-107	2B42-394	2B39-4	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
767	2B42-4210C	CONTACTOR	SW	2SW-2908-M	2B-42	2B42-10C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
768	2B42-4210F	CONTACTOR	SW	SW-2817-M	2B-42	2B42-10F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
769	2B42-4210J	CONTACTOR	SW	SW-2869-M	2B-42	2B42-10J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
770	2B42-4210M	CONTACTOR	SW	SW-2890-M	2B-42	2B42-10M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
771	2B42-4212B	CONTACTOR	125VDC	D-109	2B42-4212B	2B42-4212B	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
772	2B42-4212G	CONTACTOR	SW	2SW-2880-M	2B-42	2B42-12G	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
773	2B42-4212M	CONTACTOR	480V	2B52-4212M	2B-42	2B42-12M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Operate, normally closed 4.50) Main Contactors	Yes
774	2B42-421F	CONTACTOR	SI	2SI-852B-M	2B-42	2B42-1F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
775	2B42-421J	CONTACTOR	SI	2SI-866B-M	2B-42	2B42-1J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
776	2B42-421M	CONTACTOR	SI	2SI-860B-M	2B-42	2B42-1M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
777	2B42-422C	CONTACTOR	SI	2SI-896B-M	2B-42	2B42-2C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
778	2B42-422F	CONTACTOR	SI	2SI-878C-M	2B-42	2B42-2F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
779	2B42-422J	CONTACTOR	SI	2SI-878B-M	2B-42	2B42-2J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
780	2B42-422M	CONTACTOR	SI	2SI-860D-M	2B-42	2B42-2M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
781	2B42-423C	CONTACTOR	SI	2SI-851B-M	2B-42	2B42-3C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
782	2B42-423M	CONTACTOR	SI	2SI-871B-M	2B-42	2B42-3M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
783	2B42-424C	CONTACTOR	SI	2SI-825B-M	2B-42	2B42-4C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
784	2B42-425J	CONTACTOR	SI	2SI-826B-M	2B-42	2B42-5J	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
785	2B42-426C	CONTACTOR	CC	2CC-719-M	2B-42	2B42-6C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
786	2B42-427M	CONTACTOR	AF	2AF-4006-M	2B-42	2B42-7M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
787	2B42-426C	CONTACTOR	AF	AF-4016-M	2B-42	2B42-8C	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
788	2B42-428F	CONTACTOR	AF	AF-4020-M	2B-42	2B42-8F	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
789	2B42-429M	CONTACTOR	VNDG	W-12D-M	2B-42	2B42-9M	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
790	2B42-491	CONTACTOR	125VDC	D-08	2B42-491	2B49-1	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
791	2B42/S-2019	CONTACTOR	MS	2MS-2019-M	2SMS-2019	2S-2019	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
792	2B42/S-2020	CONTACTOR	MS	2MS-2020-M	2SMS-2020	2S-2020	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.50 (Main1 Non-operate, normally open 4.50) Main Contactors	Yes
793	2CI-10X	W BFD48S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
794	2CI-11X	W BFD48S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
795	2CI-12X	W BFD48S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
796	2CI-20X	W BFD48S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
797	2CI-21X	W BFD48S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
798	2CI-22X	W BFD48S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
799	2CI-A	W MG-6	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
800	2CI-B	W MG-6	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
801	2CIR-A	W BFD22S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
802	2CIR-B	W BFD22S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
803	2CP-A	W Nbfd65NR	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
804	2CP-A-X	W Nbfd65NR	ESF		C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
805	2CP-B	W Nbfd65NR	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
806	2CP-B-X	W Nbfd65NR	ESF		C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
807	2CS-10X	W Bfd64S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
808	2CS-20X	W Bfd64S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
809	2CS-A	W MG-6	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
810	2CS-B	W MG-6	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
811	2F-10X	W Bfd33S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
812	2F-20X	W Bfd33S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
813	2F-30X	W Bfd33S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
814	2F-40X	W Bfd33S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
B15	2FA-1	W MG-6	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
B16	2FA-2	W MG-6	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
B17	2FB-1	W MG-6	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
B18	2FB-2	W MG-6	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
B19	2FC-411-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
B20	2FC-411-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
B21	2FC-412-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
B22	2FC-412-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
B23	2FC-413-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
B24	2FC-413-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
B25	2FC-414-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
B26	2FC-414-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
B27	2FC-415-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
B28	2FC-415-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
829	2FC-416-XA	W BF66F	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
830	2FC-416-XB	W BF66F	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
831	2FC-464A-XA	W BF44F	ESF		2C-158-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
832	2FC-464A-XB	W BF44F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
833	2FC-464B-XA	W BF44F	ESF		2C-158-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
834	2FC-464B-XB	W BF44F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
835	2FC-465A-XA	W BF44F	ESF		2C-158-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
836	2FC-465A-XB	W BF44F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
837	2FC-465B-XA	W BF44F	ESF		2C-158-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
838	2FC-465B-XB	W BF44F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
839	2FC-466C-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
840	2FC-466C-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
841	2FC-467B-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
842	2FC-467B-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
843	2FC-474A-XA	W BF44F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
844	2FC-474A-XB	W BF44F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
845	2FC-474B-XA	W BF44F	ESF		2C-156-158	2C-158	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
846	2FC-474B-XB	W BF44F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
847	2FC-475A-XA	W BF44F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
848	2FC-475A-XB	W BF44F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
849	2FC-475B-XA	W BF44F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
850	2FC-475B-XB	W BF44F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
851	2FC-476C-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
852	2FC-476C-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
853	2FC-477B-XA	W BF66F	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
854	2FC-477B-XB	W BF66F	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
855	2IRB-1A	W Nbfd66S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
856	2IRB-1B	W Nbfd66S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
857	2IRB-2A	W Nbfd66S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
858	2IRB-2B	W Nbfd66S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
859	2LC-102C-XA	W BF42F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
860	2LC-102C-XB	W BF42F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
861	2LC-106C-XA	W BF42F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
862	2LC-106C-XB	W BF42F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
863	2LC-112B-X	W BF24F	CV	2CV-112B-M	2C-156-158	2C-158	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
864	2LC-141B-X	W BF24F	CV	2CV-112B-M	2C-156-158	2C-158	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
865	2LC-171C-XA	W BF42F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
866	2LC-171C-XB	W BF42F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
867	2LC-172C-XA	W BF42F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
868	2LC-172C-XB	W BF42F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
869	2LC-189C-XA	W BF42F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
870	2LC-189C-XB	W BF42F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
871	2LC-190C-XA	W BF42F	ESF		2C-156-15B	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
872	2LC-190C-XB	W BF42F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
873	2LC-426A-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
874	2LC-426A-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
875	2LC-426B-XA	W BF46F	ESF		2C-156-15B	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
876	2LC-426B-XB	W BF46F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
877	2LC-427A-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
878	2LC-427A-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
879	2LC-427C-XA	W BF46F	ESF		2C-156-15B	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
880	2LC-427C-XB	W BF46F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
881	2LC-428A-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
882	2LC-428A-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
883	2LC-428E-XA	W BF46F	ESF		2C-156-15B	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
884	2LC-428E-XB	W BF46F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
885	2LC-461A-XA	W BF44F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
886	2LC-461A-XB	W BF44F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
887	2LC-461B-XA	W BF57F	AF	AF-4022-M	2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
888	2LC-461B-XA	W BF57F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
889	2LC-461B-XB	W BF57F	AF	AF-4020-M	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
890	2LC-461B-XB	W BF57F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
891	2LC-461B-YA	W BF57F	AF	AF-4022-M	2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
892	2LC-461B-YB	W BF57F	AF	AF-4020-M	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
893	2LC-462A-XA	W BF57F	AF	AF-4022-M	2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
894	2LC-462A-XA	W BF57F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
895	2LC-462A-XB	W BF57F	AF	AF-4020-M	2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
896	2LC-462A-XB	W BF57F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
897	2LC-462A-YA	W BF57F	AF	AF-4022-M	2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
898	2LC-462A-YB	W BF57F	AF	AF-4020-M	2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
899	2LC-462B-XA	W BF55F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
900	2LC-462B-XB	W BF55F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
901	2LC-462C-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
902	2LC-462C-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
903	2LC-463C-XA	W BF57F	AF	AF-4022-M	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
904	2LC-463C-XA	W BF57F	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
905	2LC-463C-XB	W BF57F	AF	AF-4020-M	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
906	2LC-463C-XB	W BF57F	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
907	2LC-463C-YA	W BF57F	AF	AF-4022-M	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
908	2LC-463C-YB	W BF57F	AF	AF-4020-M	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
909	2LC-463D-XA	W BF55F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
910	2LC-463D-XB	W BF55F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
911	2LC-463E-XA	W BF66F	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes
912	2LC-463E-XB	W BF66F	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.9B	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
913	2LC-471A-XA	W BF44F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
914	2LC-471A-XB	W BF44F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
915	2LC-471B-XA	W BF57F	AF	AF-4022-M	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
916	2LC-471B-XA	W BF57F	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
917	2LC-471B-XB	W BF57F	AF	AF-4020-M	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
918	2LC-471B-XB	W BF57F	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
919	2LC-471B-YA	W BF57F	AF	AF-4022-M	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
920	2LC-471B-YB	W BF57F	AF	AF-4020-M	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
921	2LC-472A-XA	W BF57F	AF	AF-4022-M	2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
922	2LC-472A-XA	W BF57F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
923	2LC-472A-XB	W BF57F	AF	AF-4020-M	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
924	2LC-472A-XB	W BF57F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
925	2LC-472A-YA	W BF57F	AF	AF-4022-M	2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes
926	2LC-472A-YB	W BF57F	AF	AF-4020-M	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed [4.00] ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
927	2LC-472B-XA	W BF55F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
928	2LC-472B-XB	W BF55F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
929	2LC-472C-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
930	2LC-472C-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
931	2LC-473C-XA	W BF57F	AF	AF-4022-M	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
932	2LC-473C-XA	W BF57F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
933	2LC-473C-XB	W BF57F	AF	AF-4020-M	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
934	2LC-473C-XB	W BF57F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
935	2LC-473C-YA	W BF57F	AF	AF-4022-M	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
936	2LC-473C-YB	W BF57F	AF	AF-4020-M	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
937	2LC-473D-XA	W BF55F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
938	2LC-473D-XB	W BF55F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
939	2LC-473E-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
940	2LC-473E-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
941	2LCAA	W BFD44S	AF	AF-4022-M	C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
942	2LCAB	W BFD44S	AF	AF-4020-M	C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
943	2LCBA	W BFD44S	AF	AF-4022-M	C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
944	2LCBB	W BFD44S	AF	AF-4020-M	C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
945	2MS-A1	W BFD33S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
946	2MS-A2	W BFD33S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
947	2MS-B1	W BFD33S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
948	2MS-B2	W BFD33S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
949	2NC-31D-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
950	2NC-31D-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
951	2NC-32D-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
952	2NC-32D-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
953	2NC-35D-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
954	2NC-35D-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
955	2NC-35F-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
956	2NC-35F-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
957	2NC-36D-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
958	2NC-36D-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
959	2NC-36F-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
960	2NC-36F-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
961	2NC-41K-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
962	2NC-41K-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
963	2NC-41M-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
964	2NC-41M-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
965	2NC-41N-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
966	2NC-41N-XB	W BF66F	RP	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
967	2NC-41P-XA	W BF57F	RP	2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
968	2NC-41P-XB	W BF66F	RP	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
969	2NC-41R-XA	W BF66F	RP	2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
970	2NC-41R-XB	W BF66F	RP	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
971	2NC-41S-XA	W BF66F	RP	2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
972	2NC-41S-XB	W BF66F	RP	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
973	2NC-42K-XA	W BF66F	RP	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
974	2NC-42K-XB	W BF66F	RP	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
975	2NC-42M-XA	W BF66F	RP	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
976	2NC-42M-XB	W BF66F	RP	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
977	2NC-42N-XA	W BF66F	RP	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
978	2NC-42N-XB	W BF66F	RP	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
979	2NC-42P-XA	W BF66F	RP	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
980	2NC-42P-XB	W BF66F	RP	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
981	2NC-42R-XA	W BF66F	RP	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
982	2NC-42R-XB	W BF66F	RP	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
983	2NC-42S-XA	W BF66F	RP	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
984	2NC-42S-XB	W BF66F	RP	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
985	2NC-43K-XA	W BF66F	RP	2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
986	2NC-43K-XB	W BF66F	RP	2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
987	2NC-43M-XA	W BF66F	RP	2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
988	2NC-43M-XB	W BF66F	RP	2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
989	2NC-43N-XA	W BF66F	RP	2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
990	2NC-43N-XB	W BF66F	RP	2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
991	2NC-43P-XA	W BF66F	RP	2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
992	2NC-43P-XB	W BF66F	RP	2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
993	2NC-43R-XA	W BF66F	RP	2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
994	2NC-43R-XB	W BF66F	RP	2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
995	2NC-43S-XA	W BF66F	RP	2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
996	2NC-43S-XB	W BF66F	RP	2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
997	2NC-44K-XA	W BF66F	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
998	2NC-44K-XB	W BF66F	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
999	2NC-44M-XA	W BF66F	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1000	2NC-44M-XB	W BF66F	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1001	2NC-44N-XA	W BF66F	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1002	2NC-44N-XB	W BF66F	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1003	2NC-44P-XA	W BF66F	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1004	2NC-44P-XB	W BF66F	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1005	2NC-44R-XA	W BF66F	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1006	2NC-44R-XB	W BF66F	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1007	2NC-44S-XA	W BF66F	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1008	2NC-44S-XB	W BF66F	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1009	2P07-1A	W Nbfd84S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1010	2P07-1B	W Nbfd84D	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse N3FD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1011	2P07-2A	W Nbfd84S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1012	2P07-2B	W Nbfd84D	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1013	2P07-3A	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1014	2P07-3B	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1015	2P08-1A	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1016	2P08-1B	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1017	2P08-2A	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1018	2P08-2B	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1019	2P09-1A	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1020	2P09-1B	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1021	2P09-2A	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GE'S SEISMIC CAPACITY	STATUS
1022	2P09-2B	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1023	2P10-1A	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1024	2P10-1B	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1025	2P10-2A	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1026	2P10-2B	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1027	2P32A-XA	W BF62F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1028	2P32A-XB	W BF62F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1029	2P32B-XA	W BF62F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1030	2P32B-XB	W BF62F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1031	2P32C-XA	W BF62F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1032	2P32C-XB	W BF62F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1033	2P32D-XA	W BF62F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1034	2P32D-XB	W BF62F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1035	2P32E-XA	W BF62F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1036	2P32E-XB	W BF62F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1037	2P32F-XA	W BF62F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1038	2P32F-XB	W BF62F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1039	2PC-428B-XA	W BF53F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1040	2PC-428B-XB	W BF53F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1041	2PC-429A-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1042	2PC-429A-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1043	2PC-429C-XA	W BF46F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1044	2PC-429C-XB	W BF46F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1045	2PC-429E-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1046	2PC-429E-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1047	2PC-430A-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1048	2PC-430A-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1049	2PC-430E-XA	W BF46F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1050	2PC-430E-XB	W BF46F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1051	2PC-430F-XA	W BF66F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1052	2PC-430F-XB	W BF66F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1053	2PC-430H-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1054	2PC-430H-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1055	2PC-431A-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1056	2PC-431A-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1057	2PC-431G-XA	W BF46F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1058	2PC-431G-XB	W BF46F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1059	2PC-431I-XA	W BF66F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1060	2PC-431I-XB	W BF66F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1061	2PC-431J-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1062	2PC-431J-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1063	2PC-449A-XA	W BF66F	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1064	2PC-449A-XB	W BF66F	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1065	2PC-468A-XA	W BF46F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1066	2PC-468A-XB	W BF46F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1067	2PC-469A-XA	W BF48F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1068	2PC-469A-XB	W BF48F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1069	2PC-478A-XA	W BF46F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1070	2PC-478A-XB	W BF46F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1071	2PC-479A-XA	W BF48F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1072	2PC-479A-XB	W BF48F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1073	2PC-482A-XA	W BF48F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1074	2PC-482A-XB	W BF48F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1075	2PC-483A-XA	W BF48F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1076	2PC-483A-XB	W BF48F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1077	2PC-484A-XA	W NBF66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBF66) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1078	2PC-484A-XB	W Nbfd86S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
1079	2PC-485A-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1080	2PC-485A-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1081	2PC-486A-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1082	2PC-486A-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1083	2PC-628-XA	W BF22F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1084	2PC-629-XB	W BF22F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1085	2PC-639-X1	W BFD24S	CC	2P-11A-M	2C-156-158	2C-158	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1086	2PC-639-X2	W BFD11S	CC	2P-11B-M	C-01-1(2)C-04	2C-03	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1087	2PC-945A-XA	W BF46F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1088	2PC-945A-XB	W BF46F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1089	2PC-945B-XA	W BF44F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1090	2PC-945B-XB	W BF44F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1091	2PC-946A-XA	W BF46F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1092	2PC-946A-XB	W BF46F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1093	2PC-946B-XA	W BF44F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1094	2PC-946B-XB	W BF44F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1095	2PC-947A-XA	W BF48F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1096	2PC-947A-XB	W BF48F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1097	2PC-947B-XA	W BF55F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1098	2PC-947B-XB	W BF55F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1099	2PC-948A-XA	W BF48F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1100	2PC-948A-XB	W BF48F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1101	2PC-948B-XA	W BF55F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1102	2PC-948B-XB	W BF55F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1103	2PC-949A-XA	W BF48F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1104	2PC-949A-XB	W BF48F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
1105	2PC-949B-XA	W BF55F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1106	2PC-949B-XB	W BF55F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1107	2PC-950A-XA	W BF48F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1108	2PC-950A-XB	W BF48F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1109	2PC-950B-XA	W BF55F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1110	2PC-950B-XB	W BF55F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1111	2PIC-639	BARTON Model 288A	CC	2P-11A-M	2PIC-639	2PIC-639	SS24	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (Barton Models 288 & 289) Operate, normally open 3.00 ANSI C37.98	Yes
1112	2PRB-1A	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1113	2PRB-1B	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1114	2PRB-2A	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1115	2PRB-2B	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1116	2PY-4044-LLA	FOXBORO NO152CK - N-2A0-L2C-R	MS	2MS-2019-M	2C-170-173	2C-171	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1117	2PY-4044-LLB	FOXBORO NO152CK - N-2A0-L2C-R	MS	2MS- 2020-M	2C-170-173	2C-171	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
1118	2RC-1A	W NBFD42S	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1119	2RC-1B	W NBFD42S	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1120	2RC-2A	W NBFD42S	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1121	2RC-2B	W NBFD42S	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1122	2RC-3A	W NBFD42S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1123	2RC-3B	W NBFD42S	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1124	2RC-4A	W NBFD42S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1125	2RC-4B	W NBFD42S	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1126	2RCP-A-XA	W NBFD66S	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1127	2RCP-A-XB	W NBFD66S	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1128	2RCP-B-XA	W NBFD66S	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1129	2RCP-B-XB	W NBFD66S	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1130	2RT-10A	W NBFD31S	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1131	2RT-10B	W NBFD31S	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1132	2RT-11A	W NBFD31S	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1133	2RT-11B	W NBFD31S	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1134	2RT-12A	W NBFD31S	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1135	2RT-12B	W NBFD31S	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1136	2RT-1A	W NBFD31S	RP	2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.93	Yes
1137	2RT-1B	W NBFD31S	RP	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1138	2RT-2A	W NBFD31S	RP	2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1139	2RT-2B	W NBFD31S	RP	2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1140	2RT-3A	W NBFD31S	RP	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1141	2RT-3B	W NBFD31S	RP	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1142	2RT-4A	W NBFD31S	RP	2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1143	2RT-4B	W NBFD31S	RP	2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1144	2RT-5A	W Nbfd31S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1145	2RT-5B	W Nbfd31S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1146	2RT-6A	W Nbfd31S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1147	2RT-6B	W Nbfd31S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1148	2RT-7A	W Nbfd31S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1149	2RT-7B	W Nbfd31S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1150	2RT-8A	W Nbfd31S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1151	2RT-8B	W Nbfd31S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1152	2RT-9A	W Nbfd31S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1153	2RT-9B	W Nbfd31S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.9B	Yes
1154	2SI-10X	W Bfd84S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1155	2SI-10X1	ASEA RXMA1	125VDC	D-07	2C-20	2C-20	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (ASEA RXMA1) Operate, normally closed 10.00 ANSI C37.9B	Yes
1156	2SI-11X	W Bfd84S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1157	2SI-11X-AXA	W Nbfd66S	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1158	2SI-11X-AXB	W Nbfd66S	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1159	2SI-12X	W Bfd84S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1160	2SI-13X	W Bfd84S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1161	2SI-14X	W Bfd84S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1162	2SI-20X	W Bfd84S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FPS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1163	2SI-20X1	ASEA RXMA1	125VDC	D-08	2C-20	2C-20	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (ASEA RXMA1) Operate, normally closed 10.00 ANSI C37.98	Yes
1164	2SI-21X	W Bfd84S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1165	2SI-21X-BXA	W Nbfd66S	RP		2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1166	2SI-21X-BXB	W Nbfd66S	RP		2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1167	2SI-22X	W Bfd84S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd) Non-operate, normally closed 9.00 Modified Relay GERS	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1168	2SI-23X	W BFD84S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1169	2SI-24X	W BFD84S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1170	2SIA-A	W MG-6	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1171	2SIA-B	W MG-6	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1172	2SIB-A	W BFD75S	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1173	2SIB-B	W BFD75S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1174	2SIM-A	W MG-6	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1175	2SIM-B	W MG-6	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1176	2SIR-A	W NBFD65NR	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1177	2SIR-B	W NBFD65NR	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1178	2SRB-1A	W NBFD66S	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes
1179	2SRB-1B	W NBFD66S	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD Non-operate, normally closed 5.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1180	2SRB-2A	W Nbfd66S	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
1181	2SRB-2B	W Nbfd66S	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse Nbfd Non-operate, normally closed 5.00) ANSI C37.98	Yes
1182	2SW-A	W Bfd22S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1183	2SW-AX	W Bfd42S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1184	2SW-B	W Bfd22S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1185	2SW-BX	W Bfd42S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse Bfd Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1186	2TC-401D-XA	W Bf66F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse Bf Non-operate, normally closed 4.00) ANSI C37.98	Yes
1187	2TC-401D-XB	W Bf66F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse Bf Non-operate, normally closed 4.00) ANSI C37.98	Yes
1188	2TC-402D-XA	W Bf66F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse Bf Non-operate, normally closed 4.00) ANSI C37.98	Yes
1189	2TC-402D-XB	W Bf66F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse Bf Non-operate, normally closed 4.00) ANSI C37.98	Yes
1190	2TC-403D-XA	W Bf66F	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse Bf Non-operate, normally closed 4.00) ANSI C37.98	Yes
1191	2TC-403D-XB	W Bf66F	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse Bf Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1192	2TC-404D-XA	W BF66F	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1193	2TC-404D-XB	W BF66F	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1194	2TC-405A-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1195	2TC-405A-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1196	2TC-405C-XA	W BF66F	RP		2C-151-155	2C-151	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1197	2TC-405C-XB	W BF66F	RP		2C-161-165	2C-161	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1198	2TC-406A-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1199	2TC-406A-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1200	2TC-406C-XA	W BF66F	RP		2C-151-155	2C-152	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1201	2TC-406C-XB	W BF66F	RP		2C-161-165	2C-162	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1202	2TC-407A-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1203	2TC-407A-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1204	2TC-407C-XA	W BF66F	RP		2C-151-155	2C-153	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes
1205	2TC-407C-XB	W BF66F	RP		2C-161-165	2C-163	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF) Non-operate, normally closed 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW R/JGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1206	2TC-40BA-XA	W BF66F	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1207	2TC-40BA-XB	W BF66F	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1208	2TC-40BC-XA	W BF66F	RP	2C-151-155	2C-154	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1209	2TC-40BC-XB	W BF66F	RP	2C-161-165	2C-164	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1210	2TDR-10	AGASTAT 2412PD	ESF	2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50) ANSI C37.98	Yes
1211	2TDR-11	AGASTAT 2412PD	ESF	2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50) ANSI C37.98	Yes
1212	2TDR-12	AGASTAT 2412PE	ESF	2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50) ANSI C37.98	Yes
1213	2TDR-13	AGASTAT 2412PD	ESF	2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50) ANSI C37.98	Yes
1214	2TDR-14	AGASTAT 2412PD	ESF	2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50) ANSI C37.98	Yes
1215	2TDR-15	AGASTAT 2412PE	ESF	2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50) ANSI C37.98	Yes
1216	2TDR-16	AGASTAT 2412PE	ESF	2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50) ANSI C37.98	Yes
1217	2TDR-17	AGASTAT 2412PE	ESF	2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally closed 12.50) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
									12.50 ANSI C37.98	
1218	2TDR-18 AGASTAT 2412PD	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1219	2TDR-19 AGASTAT 2412PE	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1220	2TDR-20 AGASTAT 2412PD	ESF		2C-166-137	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1221	2TDR-21 AGASTAT 2412PD	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1222	2TDR-22 AGASTAT 2412PE	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1223	2TDR-23 AGASTAT 2412PD	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1224	2TDR-24 AGASTAT 2412PD	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1225	2TDR-25 AGASTAT 2412PE	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1226	2TDR-26 AGASTAT 2412PE	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1227	2TDR-27 AGASTAT 2412PE	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1228	2TDR-28	AGASTAT 2412PD	ESF		2C-156-158	2C-156	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1229	2TDR-29	AGASTAT 2412PE	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally closed 12.50) ANSI C37.98	Yes
1230	2TDRA/A05	AGASTAT 7014	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
1231	2TDRA/A06	AGASTAT 7014	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
1232	2TDRB/A05	AGASTAT 7014	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
1233	2TDRB/A06	AGASTAT 7014	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
1234	2TDRC/A05	AGASTAT 7014	UV	2A-05	2A-05	2A-05	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
1235	2TDRC/A06	AGASTAT 7014	UV	2A-06	2A-06	2A-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally open 10.00) ANSI C37.98	Yes
1236	2V-10X	W BFD24S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate normally closed 9.00) Modified Relay GERS	Yes
1237	2V-20X	W BFD24S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1238	2VA	W MG-6	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1239	2VB	W MG-6	ESF		2C-166-167	2C-166	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1240	2XAT1	W BFD11S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1241	2XAT2	W BFD11S	ESF		2C-156-158	2C-157	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1242	2XBT1	W BFD11S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1243	2XBT2	W BFD11S	ESF		2C-166-167	2C-167	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1244	33X/1-V870A	W BF82F	SI	1SI-871A-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1245	33X/1-V870B	W BF82F	SI	1SI-871B-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1246	33X/1-V897A	W BFD62S	SI	1SI-851A-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1247	33X/1-V897B	W BFD62S	SI	1SI-851A-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1248	33X/2-V870A	W BF82F	SI	2SI-871A-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes
1249	33X/2-V870B	W BF82F	SI	2SI-871B-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Westinghouse BF Non-operate, normally closed 4.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
1250	33X/2-V897A	W BFD62S	SI	2SI-851A-M	C-01-1121C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1251	33X/2-V897B	W BFD62S	SI	2SI-851A-M	C-01-1121C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1252	3CR	PB KRP11D	480V	2B52-29C	K-3B	C-54	SS	N/A	Relays mounted on vibrating equipment		Yes
1253	4020X	W NBFD65NR	AF	AF-4020-M	C-01-1121C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1254	4021X	W NBFD65NR	AF	AF-4021-M	C-01-1121C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1255	4022X	W NBFD65NR	AF	AF-4022-M	C-01-1121C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1256	4023X	W NBFD65NR	AF	AF-4023-M	C-01-1121C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	5.00 (Westinghouse NBFD) Non-operate, normally closed 5.00 ANSI C37.98	Yes
1257	40T/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1258	40T/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1259	40V/G01	W AV	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1260	40V/G02	W AV	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1261	42X-13212H	ASEA RXMA1	125VDC	D-109	2C-20	2C-20	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (ASEA RXMA1) Operate, normally closed 10.00 ANSI C37.98	Yes
1262	42X-1491	ASEA RXMA1	125VDC	D-09	2C-20	2C-20	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (ASEA RXMA1) Operate, normally closed 10.00 ANSI C37.98	Yes
1263	42X-2091	ASEA RXMA1	125VDC	D-09	2C-20	2C-20	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (ASEA RXMA1) Operate, normally closed 10.00 ANSI C37.98	Yes
1264	42X-24212B	ASEA RXMA1	125VDC	D-109	2C-20	2C-20	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (ASEA RXMA1) Operate, normally closed 10.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1265	42Y-13212H	SQD 8501 HO-33	125VDC	D-109	1B-32	1B32-12H	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
1266	42Y-1391	SQD 8501 HO-33	125VDC	D-07	1B42-391	1B42-391	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
1267	42Y-1491	SQD 8501 HO-33	125VDC	D-09	1B42-491	1B42-491	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
1268	42Y-1494	SQD 8501 HO-33	125VDC	D-108	1B42-494	1B42-494	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
1269	42Y-2391	SQD 8501 HO-33	125VDC	D-09	2B42-391	2B42-391	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
1270	42Y-2394	SQD 8501 HO-33	125VDC	D-107	2B42-394	2B42-394	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
1271	42Y-24212B	SQD 8501 HO-33	125VDC	D-109	2B-42	2B42-12B	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
1272	42Y-2491	SQD 8501 HO-33	125VDC	D-08	2B42-491	2B42-491	SS	LRR	Level 4: Current Standards/Licensing Criteria	Yes
1273	50G/1A52-58	W ITH	4160V	1A52-58	1A-05	1A52-58	SS	No	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (Westinghouse ITH Non-operate, normally open 3.00) ANSI C37.98	No
1274	50G/1A52-59	W ITH	SI	1P-15A-M	1A-05	1A52-59	SS	No	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (Westinghouse ITH Non-operate, normally open 3.00) ANSI C37.98	No
1275	50G/1A52-64	W ITH	4160V	1A52-64	1A-06	1A52-64	SS	No	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (Westinghouse ITH Non-operate, normally open 3.00) ANSI C37.98	No
1276	50G/1A52-65	W ITH	SI	1P-15B-M	1A-06	1A52-65	SS	No	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (Westinghouse ITH Non-operate, normally open 3.00) ANSI C37.98	No
1277	50G/2A52-68	W ITH	SI	2P-15B-M	2A-06	2A52-68	SS	No	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (Westinghouse ITH Non-operate, normally open 3.00) ANSI C37.98	No
1278	50G/2A52-69	W ITH	4160V	2A52-69	2A-06	2A52-69	SS	No	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (Westinghouse ITH Non-operate, normally open 3.00) ANSI C37.98	No



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1279	50G/2A52-74	W ITH	SI	2P-15A-M	2A-05	2A52-74	SS	No	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (Westinghouse ITH Non-operate, normally open 3.00) ANSI C37.98	No
1280	50G/2A52-75	W ITH	4160V	2A52-75	2A-05	2A52-75	SS	No	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (Westinghouse ITH Non-operate, normally open 3.00) ANSI C37.98	No
1281	51/1A52-60	W CO-5	DG	1A52-60	1A-05	1A52-60	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1282	51/1A52-66	W CO-5	DG	1A52-66	1A-06	1A52-66	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1283	51/2A52-67	W CO-5	DG	2A52-67	2A-06	2A52-67	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1284	51/2A52-73	W CO-5	DG	2A52-73	2A-05	2A52-73	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1285	51/50A/1A52-58	W CO	4160V	1A52-58	1A-05	1A52-58	SS	LRR	Unknown capacity	No
1286	51/50A/1A52-59	W COM 5	SI	1P-15A-M	1A-05	1A52-59	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102) Non-operate, normally open 3.00) ANSI C37.98	Yes
1287	51/50A/1A52-64	W CO	4160V	1A52-64	1A-06	1A52-64	SS	LRR	Unknown capacity	No
1288	51/50A/1A52-65	W COM 5	SI	1P-15B-M	1A-06	1A52-65	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102) Non-operate, normally open 3.00) ANSI C37.98	Yes
1289	51/50A/2A52-68	W COM 5	SI	2P-15B-M	2A-06	2A52-68	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102) Non-operate, normally open 3.00) ANSI C37.98	Yes
1290	51/50A/2A52-69	W CO	4160V	2A52-69	2A-06	2A52-69	SS	LRR	Unknown capacity	No
1291	51/50A/2A52-74	W COM 5	SI	2P-15A-M	2A-05	2A52-74	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102) Non-operate, normally open 3.00) ANSI C37.98	Yes
1292	51/50A/2A52-75	W CO	4160V	2A52-75	2A-05	2A52-75	SS	LRR	Unknown capacity	No



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1293	51/50B/1A52-58	W CO	4160V	1A52-58	1A-05	1A52-58	SS	LRR		Unknown capacity	No
1294	51/50B/1A52-59	W COM 5	SI	1P-15A-M	1A-05	1A52-59	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102)) Non-operate, normally open 3.00 ANSI C37.98	Yes
1295	51/50B/1A52-64	W CO	4160V	1A52-64	1A-06	1A52-64	SS	LRR		Unknown capacity	No
1296	51/50B/1A52-65	W COM 5	SI	1P-15B-M	1A-06	1A52-65	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102)) Non-operate, normally open 3.00 ANSI C37.98	Yes
1297	51/50B/2A52-68	W COM 5	SI	2P-15B-M	2A-06	2A52-68	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102)) Non-operate, normally open 3.00 ANSI C37.98	Yes
1298	51/50B/2A52-69	W CO	4160V	2A52-69	2A-06	2A52-69	SS	LRR		Unknown capacity	No
1299	51/50B/2A52-74	W COM 5	SI	2P-15A-M	2A-05	2A52-74	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102)) Non-operate, normally open 3.00 ANSI C37.98	Yes
1300	51/50B/2A52-75	W CO	4160V	2A52-75	2A-05	2A52-75	SS	LRR		Unknown capacity	No
1301	51/50C/1A52-58	W CO	4160V	1A52-58	1A-05	1A52-58	SS	LRR		Unknown capacity	No
1302	51/50C/1A52-59	W COM 5	SI	1P-15A-M	1A-05	1A52-59	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102)) Non-operate, normally open 3.00 ANSI C37.98	Yes
1303	51/50C/1A52-64	W CO	4160V	1A52-64	1A-06	1A52-64	SS	LRR		Unknown capacity	No
1304	51/50C/1A52-65	W COM 5	SI	1P-15B-M	1A-06	1A52-65	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102)) Non-operate, normally open 3.00 ANSI C37.98	Yes
1305	51/50C/2A52-68	W COM 5	SI	2P-15B-M	2A-06	2A52-68	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102)) Non-operate, normally open 3.00 ANSI C37.98	Yes
1306	51/50C/2A52-69	W CO	4160V	2A52-69	2A-06	2A52-69	SS	LRR		Unknown capacity	No



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1307	51/50C/2A52-74	W COM 5	SI	2P-15A-M	2A-05	2A52-74	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	3.00 (COM-5 (Style # 289B355A11, WEST I.L. 41-102) Non-operate, normally open 3.00) ANSI C37.98	Yes
1308	51/50C/2A52-75	W CO	4160V	2A52-75	2A-05	2A52-75	SS	LRR		Unknown capacity	No
1309	51C/G01	W CO-5	DG	G-01	C-34	C-34	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1310	51C/G02	W CO-5	DG	G-02	C-35	C-35	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1311	52V/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1312	52V/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1313	51A/G01	W CO-5	DG	G-01	C-34	C-34	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1314	51A/G02	W CO-5	DG	G-02	C-35	C-35	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1315	51B/G01	W CO-5	DG	G-01	C-34	C-34	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1316	51B/G02	W CO-5	DG	G-02	C-35	C-35	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	6.00 (CO-5 (WEST I.L. 41-102) Non-operate, normally open 6.00) ANSI C37.98	Yes
1317	62/4042	AGASTAT 7014PC	AF	P-38A-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally closed 10.00) ANSI C37.98	Yes
1318	62/4043	AGASTAT 7014PC	AF	P-38B-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Agastat E7014, 7014, 2414 Non-operate, normally closed 10.00) ANSI C37.98	Yes
1319	62/VNDG-4883	AGASTAT 2412AD	VNDG	VNDG-4883A-S	C-32	C-32	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally open 12.50) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1320	62/VNDG-4884	AGASTAT 2412AD	VNDG	VNDG-4884A-S	C-36	C-36	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally open 12.50 ANSI C37.98	Yes
1321	67P1/G01	W CW	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1322	67P1/G02	W CW	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1323	67P3/G01	W CW	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1324	67P3/G02	W CW	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1325	67RP/G01	W CW	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1326	67RP/G02	W CW	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1327	86/1A52-58	W MG-6	4160V	1A52-58	1A-05	1A52-58	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
1328	86/1A52-60	W MG-6	DG	1A52-60	1A-05	1A52-60	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
1329	86/1A52-64	W MG-6	4160V	1A52-64	1A-06	1A52-64	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
1330	86/1A52-66	W MG-6	DG	1A52-66	1A-06	1A52-66	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
1331	86/1B52-10A	W MG-6	CC	1P-11A-M	1B-03	1B52-10A	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
1332	86/1B52-12B	W MG-6	480V	1B52-12B	1B-03	1B52-12B	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
1333	86/1B52-13B	W MG-6	480V	1B52-13B	1B-03	1B52-13B	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
1334	86/1B52-20A	W MG-6	480V	1B52-20A	1B-04	1B52-20A	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
1335	86/1B52-21B	W MG-6	480V	1B52-21B	1B-04	1B52-21B	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes
1336	86/1B52-23B	W MG-6	CC	1P-11B-M	1B-04	1B52-23B	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC)) Non-operate, normally open 10.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
1337	86/2A52-67	W MG-6	DG	2A52-67	2A-06	2A52-67	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1338	86/2A52-69	W MG-6	4180V	2A52-69	2A-06	2A52-69	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1339	86/2A52-73	W MG-6	DG	2A52-73	2A-05	2A52-73	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1340	86/2A52-75	W MG-6	4180V	2A52-75	2A-05	2A52-75	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1341	86/2B52-28A	W MG-6	480V	2B52-28A	2B-04	2B52-28A	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1342	86/2B52-28B	W MG-6	CC	2P-11B-M	2B-04	2B52-28B	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1343	86/2B52-29B	W MG-6	480V	2B52-29B	2B-04	2B52-29B	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1344	86/2B52-34A	W MG-6	CC	2P-11A-M	2B-03	2B52-34A	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1345	86/2B52-36B	W MG-6	480V	2B52-36B	2B-03	2B52-36B	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1346	86/2B52-37A	W MG-6	480V	2B52-37A	2B-03	2B52-37A	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1347	86/2B52-37B	W MG-6	480V	2B52-37B	2B-03	2B52-37B	SS16	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1348	86/A52-59	W MG-6	SI	1P-15A-M	1A-05	1A52-59	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1349	86/A52-65	W MG-6	SI	1P-15B-M	1A-06	1A52-65	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1350	86/A52-68	W MG-6	SI	2P-15B-M	2A-06	2A52-68	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
1351	86/A52-74	W MG-6	SI	2P-15A-M	2A-05	2A52-74	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 [DC]) Non-operate, normally open 10.00) ANSI C37.98	Yes
1352	AC CONT./G01	SQ D FAL	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1353	AC CONT./G02	SQ D FAL	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1354	AIR COMP./G01		DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment		Yes
1355	AIR COMP./G02		DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment		Yes
1356	ALARM CONT./G01	SQ D FAL	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1357	ALARM CONT./G02	SQ D FAL	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1358	ALCP/G01	VC 38530082-01	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1359	ALCP/G02	VC 38530082-01	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1360	AP1/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment		Yes
1361	AP1/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment		Yes
1362	AP2/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment		Yes
1363	AP2/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment		Yes
1364	CB FT/G01	SQ D FAL	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment		Yes
1365	CB FT/G02	SQ D FAL	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment		Yes
1366	COPS/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment		Yes
1367	COPS/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment		Yes
1368	CPM/G01	SQ D FAL	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment		Yes
1369	CPM/G02	SQ D FAL	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment		Yes
1370	CPMC/G01	CH MODEL 6	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment		Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
1371	CPMC/G02	CH MODEL 6	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes	
1372	CPS/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes	
1373	CPS/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes	
1374	DC CONTROL/G01	SQ D FAL	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1375	DC CONTROL/G02	SQ D FAL	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1376	DCCP/G01	VC 36530082-01	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1377	DCCP/G02	VC 36530082-01	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1378	ECR/G01	AGASTAT 2412	DG	G-01	C-34	C-34	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally open 12.50 ANSI C37.98	Yes
1379	ECR/G02	AGASTAT 2412	DG	G-02	C-35	C-35	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally open 12.50 ANSI C37.98	Yes
1380	ECRA/G01	SQ D TYPE FSD022	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1381	ECRA/G02	SQ D TYPE FSD022	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1382	ESR1/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1383	ESR1/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1384	ESR2/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1385	ESR2/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1386	ESTD/G01	AGASTAT 2422	DG	G-01	C-34	C-34	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Agastat E7022, 7022, 2422) Transition, normally open 4.00 ANSI C37.98	Yes
1397	ESTD/G02	AGASTAT 2422	DG	G-02	C-35	C-35	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	4.00 (Agastat E7022, 7022, 2422) Transition, normally open 4.00 ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1388	ESTR/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1389	ESTR/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1390	ESTX/G01	W MG-6	DG	G-01	C-34	C-34	SS20	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1391	ESTX/G02	W MG-6	DG	G-02	C-35	C-35	SS20	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1392	ETS/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1393	ETS/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1394	EXC/G01	SQ D FAL	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1395	EXC/G02	SQ D FAL	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1396	FFC/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1397	FFC/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1398	FFV/G01	VC 36530082-01	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1399	FFV/G02	VC 36530082-01	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1400	FPD/G01	SQ D TYPE EQ	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1401	FPD/G02	SQ D TYPE EQ	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1402	FPR/G01	VC 12-8336	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1403	FPR/G02	VC 12-8336	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1404	FSR1/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1405	FSR1/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1406	FSR2/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1407	FSR2/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1408	FSX/G01	W MG-6	DG	G-01	C-34	C-34	SS20	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1409	FSX/G02	W MG-6	DG	G-02	C-35	SS20	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	10.00 (Westinghouse MG-6 (DC) Non-operate, normally open 10.00) ANSI C37.98	Yes
1410	FTC1/G01	CH MODEL 6	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1411	FTC1/G02	CH MODEL 6	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1412	FTC2/G01	CH MODEL 6	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1413	FTC2/G02	CH MODEL 6	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1414	FTH/G01	VC 36530082-01	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1415	FTH/G02	VC 36530082-01	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1416	FTL/G01	VC 36530082-01	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1417	FTL/G02	VC 36530082-01	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1418	FTS1/G01	MAGNETROL	DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1419	FTS1/G02	MAGNETROL	DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1420	FTSL/G01	MAGNETROL	DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1421	FTSL/G02	MAGNETROL	DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1422	FTSN/G01	MAGNETROL	DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1423	FTSN/G02	MAGNETROL	DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1424	FTT/G01	W BF42F	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1425	FTT/G02	W BF42F	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1426	GCS L/G01		DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1427	GCS L/G02		DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1428	GCS R/G01		DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
1429	GCS R/G02		DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes	
1430	GOV. SOL/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes	
1431	GOV. SOL/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes	
1432	GP/G01	VC 36530082-01	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1433	GP/G02	VC 36530082-01	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1434	GPA/G01	W BFD225	DG	G-01	C-34	C-34	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1435	GPA/G02	W BFD225	DG	G-02	C-35	C-35	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1436	GS/G01	VC 36530082-01	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1437	GS/G02	VC 36530082-01	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1438	H5/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes	
1439	H5/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes	
1440	IHC/G01	CH 9560ED139	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes	
1441	IHC/G02	CH 9560ED139	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes	
1442	LFP1/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes	
1443	LFP1/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes	
1444	LFP2/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes	
1445	LFP2/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes	
1446	LOL/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes	



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1447	LC/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1448	LOTS/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1449	LOTS/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1450	LS/3930AX	W BFD44S	FO	FO-3930-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * A.np Factor 9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1451	LS/3931AX	W BFD44S	FO	FO-3931-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1452	LS/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1453	LS/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1454	LWD/G01	AGASTAT 2412	DG	G-01	C-34	C-34	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 12.50 (Agastat E7012, 7012, 2412) Non-operate, normally open 12.50 ANSI C37.98	Yes
1455	LWD/G02	AGASTAT 2412	DG	G-02	C-35	C-35	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 12.50 (Agastat E7012, 7012, 2412) Non-operate, normally open 12.50 ANSI C37.98	Yes
1456	LWS/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1457	LWS/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1458	MB1/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1459	MB1/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1460	MB2/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1461	MB2/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1462	MB3/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1463	MB3/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1464	MB4/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment		Yes
1465	MB4/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment		Yes
1466	MBX1/G01	VC 36530082-01	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1467	MBX1/G02	VC 36530082-01	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1468	MBX2/G01	VC 36530082-01	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1469	MBX2/G02	VC 36530082-01	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1470	MFP1/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment		Yes
1471	MFP1/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment		Yes
1472	MFP2/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment		Yes
1473	MFP2/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment		Yes
1474	MSR1/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1475	MSR1/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1476	MSR2/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1477	MSR2/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1478	MVST1/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment		Yes
1479	MVST1/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment		Yes
1480	MVST2/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment		Yes
1481	MVST2/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment		Yes
1482	NFLD/G01	DELTA CONTROLS	DG	G-01	G-01	C-64A	SS	N/A	Relays mounted on vibrating equipment		Yes
1483	NFLD/G02	DELTA CONTROLS	DG	G-02	G-02	C-65A	SS	N/A	Relays mounted on vibrating equipment		Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1484	NFLDA/G01	DELTA CONTROLS	DG	G-01	G-01	C-64A	SS	N/A	Relays mounted on vibrating equipment	Yes
1485	NFLDA/G02	DELTA CONTROLS	DG	G-02	G-02	C-65A	SS	N/A	Relays mounted on vibrating equipment	Yes
1486	OC/G01	DELTA CONTROLS	DG	G-01	G-01	C-64A	SS	N/A	Relays mounted on vibrating equipment	Yes
1487	OC/G02	DELTA CONTROLS	DG	G-02	G-02	C-65A	SS	N/A	Relays mounted on vibrating equipment	Yes
1488	OL CPM/G01	DELTA CONTROLS	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1489	OL CPM/G02	DELTA CONTROLS	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1490	OL SPM/G01	THERMAL OL	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1491	OL SPM/G02	THERMAL OL	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1492	OL1/G01	THERMAL OL	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1493	OL1/G02	THERMAL OL	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1494	OL2/G01	THERMAL OL	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1495	OL2/G02	THERMAL OL	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1496	OLIH/G01	THERMAL OL	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment	Yes
1497	OLIH/G02	THERMAL OL	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment	Yes
1498	OT/G01	DELTA CONTROLS	DG	G-01	G-01	C-64A	SS	N/A	Relays mounted on vibrating equipment	Yes
1499	OT/G02	DELTA CONTROLS	DG	G-02	G-02	C-65A	SS	N/A	Relays mounted on vibrating equipment	Yes
1500	OTR/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1501	OTR/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1502	OTS/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1503	OTS/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1504	P38A-1X	W BFD31S	AF	AF-4023-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1505	P38A-2X	W BFD31S	AF	AF-4022-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1506	P38A-3X	W BFD66S	AF	P-38A-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1507	P38B-1X	W BFD31S	AF	AF-4021-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1508	P38B-2X	W BFD31S	AF	AF-4020-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1509	P38B-3X	W BFD66S	AF	P-38B-M	C-01-1(2)C-04	C-01	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	9.00 (Westinghouse BFD) Non-operate, normally closed 9.00) Modified Relay GERS	Yes
1510	PFD1/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1511	PFD1/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1512	PFD2/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1513	PFD2/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1514	PFDA1/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1515	PFDA1/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1516	PFDA2/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1517	PFDA2/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1518	PY-4042-LL FOXBORO NO152CK - N-2AO-L2C-R	AF	P-38A-M	1C-170-173	1C-171	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
1519	PY-4043-LL FOXBORO NO152CK - N-2AO-L2C-R	AF	P-38B-M	2C-170-173	2C-173	SS	LRR	Level 4: Current Standards/Licensing Criteria		Yes
1520	RP/G01 DELTA CONTROLS	DG	G-01	G-01	C-64A	SS	N/A	Relays mounted on vibrating equipment		Yes
1521	RP/G02 DELTA CONTROLS	DG	G-02	G-02	C-65A	SS	N/A	Relays mounted on vibrating equipment		Yes
1522	RWS/G01	DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment		Yes
1523	RWS/G02	DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment		Yes
1524	SCR/G01 SQ D TYPE EQ	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment		Yes
1525	SCR/G02 SQ D TYPE EQ	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment		Yes
1526	SFA/G01 DELTA CONTROLS	DG	G-01	G-01	C-64A	SS	N/A	Relays mounted on vibrating equipment		Yes
1527	SFA/G02 DELTA CONTROLS	DG	G-02	G-02	C-65A	SS	N/A	Relays mounted on vibrating equipment		Yes
1528	SFB1/G01 AGASTAT 7012	DG	G-01	C-34	C-34	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally open 12.50) ANSI C37.98	Yes
1529	SFB1/G02 AGASTAT 7012	DG	G-02	C-35	C-35	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally open 12.50) ANSI C37.98	Yes
1530	SFB2/G01 AGASTAT 7012	DG	G-01	C-34	C-34	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412 Non-operate, normally open 12.50) ANSI C37.98	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS	
1531	SFB2/G02	AGASTAT 7012	DG	G-02	C-35	C-35	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor	12.50 (Agastat E7012, 7012, 2412) Non-operate, normally open 12.50 ANSI C37.98	Yes
1532	SFD1/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1533	SFD1/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1534	SFD2/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1535	SFD2/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1536	SPMC/G01	CH TYPE M	DG	G-01	G-01	C-64	SS	N/A	Relays mounted on vibrating equipment		Yes
1537	SPMC/G02	CH TYPE M	DG	G-02	G-02	C-65	SS	N/A	Relays mounted on vibrating equipment		Yes
1538	SSP1/G01	EMD	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1539	SSP1/G02	EMD	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1540	SSP2/G01	EMD	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1541	SSP2/G02	EMD	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1542	START1/G01	SQ D FAL	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1543	START1/G02	SQ D FAL	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1544	START2/G01	SQ D FAL	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1545	START2/G02	SQ D FAL	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1546	STCP1/G01	VC 38530082-01	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1547	STCP1/G02	VC 38530082-01	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1548	STCP2/G01	VC 36530082-01	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1549	STCP2/G02	VC 36530082-01	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1550	STL01/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1551	STL01/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1552	STL02/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1553	STL02/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1554	STR1/G01	VC 36530082-01	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1555	STR1/G02	VC 36530082-01	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1556	STR2/G01	VC 12-8336	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1557	STR2/G02	VC 12-8336	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1558	TB/G01	TEMP SW	DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1559	TB/G02	TEMP SW	DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1560	TOS/G01		DG	G-01	G-01	G-01	SS	N/A	Relays mounted on vibrating equipment	Yes
1561	TOS/G02		DG	G-02	G-02	G-02	SS	N/A	Relays mounted on vibrating equipment	Yes
1562	TR	W BFD44S	480V	1B52-22A	N-06	N-06	SS	LRR	Level 2: GERS/TRS v. Conservative FRS * Amp Factor 9.00 (Westinghouse BFD) Non-operate, normally closed 9.00 Modified Relay GERS	Yes
1563	VSD1/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1564	VSD1/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1565	VSD2/G01	SQ D TYPE EQ	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1566	VSD2/G02	SQ D TYPE EQ	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1567	VSR1/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1568	VSR1/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1569	VSR2/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR	Unknown capacity	No
1570	VSR2/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR	Unknown capacity	No
1571	X/1A52-58	W Life Line Contactor	4160V	1A52-58	1A-05	1A52-58	SWGR	LRR	Switchgear Rule-of-the-Box	Yes
1572	X/1A52-60	W Life Line Contactor	DG	1A52-60	1A-05	1A52-60	SWGR	LRR	Switchgear Rule-of-the-Box	Yes
1573	X/1A52-61	W Life Line Contactor	4160V	1A52-61	1A-05	1A52-61	SWGR	LRR	Switchgear Rule-of-the-Box	Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1574	X/1A52-64	W Life Line Contactor	4160V	1A52-64	1A-06	1A52-64	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1575	X/1A52-66	W Life Line Contactor	DG	1A52-66	1A-06	1A52-66	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1576	X/1B52-10A	W Type M	CC	1P-11A-M	1B-03	1B52-10A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1577	X/1B52-11B	W Type M	480V	1B52-11B	1B-03	1B52-11B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1578	X/1B52-12A	W Type M	480V	1B52-12A	1B-03	1B52-12A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1579	X/1B52-12C	W Type M	AF	P-3BA-M	1B-03	1B52-12C	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1580	X/1B52-13A	W Type M	480V	1B52-13A	1B-03	1B52-13A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1581	X/1B52-13B	W Type M	480V	1B52-13B	1B-03	1B52-13B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1582	X/1B52-13C	W Type M	480V	1B52-13C	1B-03	1B52-13C	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1583	X/1B52-14A	W Type M	480V	1B52-14A	1B-03	1B52-14A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1584	X/1B52-14B	W Type M	480V	1B52-14B	1B-03	1B52-14B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1585	X/1B52-15A	W Type M	VNCC	1W-1A1	1B-03	1B52-15A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1586	X/1B52-15B	W Type M	VNCC	1W-1B1	1B-03	1B52-15B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1587	X/1B52-16B	W Type M	480V	1B52-16B	1B-03	1B52-16B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1588	X/1B52-17B	W Type M	480V	1B52-17B	1B-04	1B52-17B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1589	X/1B52-18A	W Type M	VNCC	1W-1C1	1B-04	1B52-18A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1590	X/1B52-18B	W Type M	VNCC	1W-1D1	1B-04	1B52-18B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1591	X/1B52-19A	W Type M	480V	1B52-19A	1B-04	1B52-19A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1592	X/1B52-20A	W Type M	480V	1B52-20A	1B-04	1B52-20A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1593	X/1B52-21A	W Type M	480V	1B52-21A	1B-04	1B52-21A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1594	X/1B52-23A	W Type M	480V	1B52-23A	1B-04	1B52-23A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1595	X/1B52-23B	W Type M	CC	1P-11B-M	1B-04	1B52-23B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1596	X/1B52-23C	W Type M	480V	1B52-23C	1B-04	1B52-23C	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1597	X/1B52-24C	W Type M	480V	1B52-24C	1B-04	1B52-24C	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1598	X/2A52-67	W Life Line Contactor	DG	2A52-67	2A-06	2A52-67	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1599	X/2A52-69	W Life Line Contactor	4160V	2A52-69	2A-06	2A52-69	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1600	X/2A52-72	W Life Line Contactor	4160V	2A52-72	2A-06	2A52-72	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1601	X/2A52-73	W Life Line Contactor	DG	2A52-73	2A-05	2A52-73	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1602	X/2A52-75	W Life Line Contactor	4160V	2A52-75	2A-05	2A52-75	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1603	X/2B52-25B	W Type M	480V	2B52-25B	2B-04	2B52-25B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1604	X/2B52-26A	W Type M	VNCC	2W-1C1	2B-04	2B52-26A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1605	X/2B52-26B	W Type M	VNCC	2W-1D1	2B-04	2B52-26B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1606	X/2B52-27A	W Type M	480V	2B52-27A	2B-04	2B52-27A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1607	X/2B52-28A	W Type M	480V	2B52-28A	2B-04	2B52-28A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1608	X/2B52-28B	W Type M	CC	2P-11B-M	2B-04	2B52-28B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1609	X/2B52-29A	W Type M	480V	2B52-29A	2B-04	2B52-29A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1610	X/2B52-31A	W Type M	480V	2B52-31A	2B-04	2B52-31A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1611	X/2B52-31B	W Type M	480V	2B52-31B	2B-04	2B52-31B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1612	X/2B52-31C	W Type M	AF	P-38B-M	2B-04	2B52-31C	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1613	X/2B52-32C	W Type M	480V	2B52-32C	2B-04	2B52-32C	SWGR	LRR	Switchgear Rule-of-the-Box		Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1614	X/2B52-33C	W Type M	480V	2B52-33C	2B-03	2B52-33C	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1615	X/2B52-34A	W Type M	CC	2P-11A-M	2B-03	2B52-34A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1616	X/2B52-35C	W Type M	480V	2B52-35C	2B-03	2B52-35C	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1617	X/2B52-36A	W Type M	480V	2B52-36A	2B-03	2B52-36A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1618	X/2B52-36C	W Type M	480V	2B52-36C	2B-03	2B52-36C	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1619	X/2B52-37A	W Type M	480V	2B52-37A	2B-03	2B52-37A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1620	X/2B52-37B	W Type M	480V	2B52-37B	2B-03	2B52-37B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1621	X/2B52-38A	W Type M	480V	2B52-38A	2B-03	2B52-38A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1622	X/2B52-38B	W Type M	480V	2B52-38B	2B-03	2B52-38B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1623	X/2B52-39A	W Type M	VNCC	2W-1A1	2B-03	2B52-39A	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1624	X/2B52-39B	W Type M	VNCC	2W-1B1	2B-03	2B52-39B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1625	X/2B52-40B	W Type M	480V	2B52-40B	2B-03	2B52-40B	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1626	Y/1A52-58	W Life Line Contactor	4160V	1A52-58	1A-05	1A52-58	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1627	Y/1A52-60	W Life Line Contactor	DG	1A52-60	1A-05	1A52-60	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1628	Y/1A52-61	W Life Line Contactor	4160V	1A52-61	1A-05	1A52-61	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1629	Y/1A52-64	W Life Line Contactor	4160V	1A52-64	1A-06	1A52-64	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1630	Y/1A52-66	W Life Line Contactor	DG	1A52-66	1A-06	1A52-66	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1631	Y/2A52-67	W Life Line Contactor	DG	2A52-67	2A-06	2A52-67	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1632	Y/2A52-69	W Life Line Contactor	4160V	2A52-69	2A-06	2A52-69	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1633	Y/2A52-72	W Life Line Contactor	4160V	2A52-72	2A-06	2A52-72	SWGR	LRR	Switchgear Rule-of-the-Box		Yes



RELAY EVALUATION REPORT

ESSENTIAL RELAY LIST

	RELAY ID	RELAY MAKE	SYSTEM	SUB-SYSTEM	RELAY CABINET ID	LOCATION	SCREENING CODE (w/ note #)	LOW RUGGED RELAY CHECK	RELAY CAPACITY SCREENING BASIS	RELAY GERS SEISMIC CAPACITY	STATUS
1634	Y/2A52-73	W Life Line Contactor	DG	2A52-73	2A-05	2A52-73	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1635	Y/2A52-75	W Life Line Contactor	4160V	2A52-75	2A-05	2A52-75	SWGR	LRR	Switchgear Rule-of-the-Box		Yes
1636	ZSR1/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1637	ZSR1/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No
1638	ZSR2/G01	SQ D TYPE PO	DG	G-01	C-34	C-34	SS	LRR		Unknown capacity	No
1639	ZSR2/G02	SQ D TYPE PO	DG	G-02	C-35	C-35	SS	LRR		Unknown capacity	No



RELAY EVALUATION REPORT

EVALUATION DISCUSSIONS

The following is the index of the specific evaluation discussions provided in Appendix F

- F.1 THE PBNP SAFE SHUTDOWN EARTHQUAKE EVENT AND EXPECTED PLANT RESPONSE
- F.2 WESTINGHOUSE MG-6 CHATTER ACCEPTABILITY IN SWITCHGEAR
- F.3 EVALUATION OF THE WESTINGHOUSE ITH SEISMIC CAPACITY
- F.4 EMERGENCY DIESEL LOADING DUE TO THE INADVERTENT START OF NON-ESSENTIAL ELECTRICAL LOADS
- F.5 WESTINGHOUSE MG-6 CHATTER ACCEPTABILITY IN ENGINEERED SAFEGUARDS SYSTEMS



F.1 THE PBNP SAFE SHUTDOWN EARTHQUAKE EVENT AND EXPECTED PLANT RESPONSE

As stated in Section II.3.1.2 of the GIP, offsite power may or may not be available for up to 72 hours following the earthquake.

The initial strong motion associated with the PBNP SSE event is expected to last for 30 seconds. The following electrical power system response is expected to occur. The response is described using the equipment from Unit 1, however, the Unit 2 equipment is expected to respond in kind. The sequence shows that either offsite or emergency power will be maintained to the 4160 VAC safety-related buses, 1A-05 and 1A-06.

The SSE is expected to result in a unit trip. If a unit turbine generator trip occurs, the non safety-related buses, 1A-01 and 1A-02, are transferred by a fast bus transfer scheme (using stored energy breakers) to the unit's station low voltage auxiliary transformer (1X-04) [6.20, Section 8.2.2]. The power supply breakers, 1A52-01 and 1A52-17, to 1A-01 and 1A-02 respectively, open. The 1A-01/1A-03 tie breaker, 1A52-37, and 1A-02/1A-04 tie breaker, 1A52-55, will shut if the following conditions are met. Control power for the breakers is from the 125 VDC distribution subsystem.

1. No Unit 2 train A or train B SI signal.
2. For the 1A-01/1A-03 bus tie (1A52-37) - the 1A-03/2A-03 bus tie breaker 1A52-40 is open or the 2A-01/2A-03 bus tie breaker 2A52-44 is open.
3. For the 1A-02/1A-04 bus tie (1A52-55) - the 1A-04/2A-04 bus tie breaker 1A52-52 is open or the 2A-02/2A-04 bus tie breaker 2A52-48 is open.
4. Bus synchronizing relays detect the buses in synchronism.
5. The associated bus lock out devices are not tripped.

This prohibitive scheme prevents overloading the 1X-04 transformer and prevents any unit supply bus from automatically assuming total associated load of both units and assures a dedicated normal engineered safeguards power supply to a unit experiencing a safety injection. The scheme also ensures that power is maintained to the 1A-05 and 1A-06 buses without introducing a fault which may be present on the non safety-related 4160 VAC buses. The components associated with the fast bus transfer scheme are not safety-related and therefore, are not included on the SSEL. The safety-related buses are protected by their associated degraded voltage, under-voltage and phase differential relays.



RELAY EVALUATION REPORT

EVALUATION DISCUSSIONS

In the event that voltage on 1A-05 or 1A-06 is degraded or lost, the associated degraded voltage relays (273/A05, 274/A05, 275/A05, 273/A06, 274/A06, 275/A06), using two out of three logic, will disconnect the buses from their normal (offsite) power supply to prevent the operation of connected loads at damaging (low) voltages.

When the voltage is lost on the 4160 VAC safety-related buses, the associated under-voltage relays (271/A05, 272/A05, 271/A06, 272/A06) will disconnect the buses from their normal (offsite) power supply. In addition, the relays will provide a signal to start the emergency diesel generators and transfer the buses to this emergency power supply.

With the occurrence of under-voltage on 4160 VAC bus 1A-05, the automatic sequence is as follows:

1. Trip bus 1A-05 supply breaker 1A52-57 to isolate bus 1A-05 from bus 1A-03.
2. All feeder breakers on 480 VAC bus 1B-03, except for the component cooling water pump motor, auxiliary feedwater pump motor, feeder breaker to 1B-39 and the safeguards motor control center 1B-32, are tripped by under-voltage. The tie breakers to buses 1B-01 and 1B-04 are tripped by under-voltage also.
3. Start the emergency diesel generators G-01 and G-02, the normal and alternate emergency power supplies.
4. After the EDGs come up to speed and voltage, close the emergency diesel generator output breaker 1A52-60. The alternate EDG (G-02) will run unloaded until stopped manually if power to 1A-06 is still available.
5. If the motor-driven auxiliary feedwater pump or the component cooling water pump had been operating prior to the loss of voltage, they would be automatically restarted upon return of bus voltage. If either had not been running, it would be subject to its automatic starting logic.
6. After automatic loading, manually start any auxiliary equipment as required for safe plant operation. If there is a requirement for engineered safety features operation coincident with under-voltage, step 4, above, is automatically followed by the sequential starting of engineered safety features equipment. This loading sequence for



RELAY EVALUATION REPORT

EVALUATION DISCUSSIONS

emergency diesel generator G-01 is as follows, continuing from step 4.* The time lapse for Step 3 to Step 4 is 10 seconds. This is the maximum allowed by design per the FSAR.

Time Lapse after Step 4*

- | | |
|---|---------|
| a. Start Safety Injection Pump 1P-15A | 0 sec. |
| b. Start Residual Heat Removal Pump 1P-10A | 5 sec. |
| c. Start Auxiliary Feedwater Pump P-38A | 10 sec. |
| d. Start Service Water Pump P-32A | 15 sec. |
| e. Start Service Water Pump P-32B | 20 sec. |
| f. Start Service Water Pump P-32F | 25 sec. |
| g. Start Containment Ventilation Fan 1W-1A1 | 30 sec. |

* Relative time to initiation of the breaker closing signal following loss of voltage and a requirement for engineering safety features. Starting of containment spray pumps, if initiated automatically by high containment pressure, is accomplished with any of the above steps following the starting of the residual heat removal pump.

The emergency diesel generator automatic loading sequence, including engine starting, will be accomplished in approximately 60 seconds. Safeguards motor control centers are energized and injection valves are opened at the same time that the 480 VAC power is restored to bus 1B-03.

The automatic sequences for bus 2A-05 and for buses 1A-06 and 2A-06, associated with emergency generator G-02 are similar to that described for bus 1A-05.



F.2 WESTINGHOUSE MG-6 CHATTER ACCEPTABILITY IN SWITCHGEAR

The Westinghouse MG-6 Relay is used as a lockout relay for the 4160 VAC and 480 VAC switchgear breakers. The MG-6 relay has a de-energized normally closed contact pair in the circuit breaker closing circuit and a de-energized normally open contact pair in the circuit breaker tripping circuit. The seismic capacity of the de-energized normally closed contact pair is 3.0g [6.12]. The seismic capacity of the normally open contact pair is 10.0g [6.12]. As a result of the low seismic capacity of the normally closed contact pair, this chatter acceptability evaluation is developed. The chatter is only considered to occur during the period of the earthquake strong motion [Section 3.2.3], after which the relay is considered to function normally.

The normally closed contact pair in the breaker closing circuit functions to prevent the closure of the breaker prior to resetting the relay, in the event of a lockout signal. The lockout signal energizes the MG-6 relay, opening the normally closed contact pair in the breaker closing circuit. The MG-6 relay also has a normally opened contact pair which shuts, maintaining the MG-6 relay energized until it is reset.

Relay chatter of the de-energized normally closed contact pair in the breaker closing circuit only affects the breaker's function if a breaker closing signal is received while the relay is chattering. If this occurs, the relay chatter could prevent the breaker from closing. A breaker will fit into one of the following three categories for determining chatter acceptability of the MG-6 lockout relay.

1. The breaker is normally closed and remains closed upon the receipt of a bus under-voltage signal. The component cooling water pump (1P-11A) breaker, 1B52-10A, is an example.

For breakers that are closed and remain closed, a closing signal is never generated. Therefore, the MG-6 de-energized normally closed contact pair chatter is acceptable.

2. The breaker is normally closed and is tripped open upon the receipt of a bus under-voltage signal. The breaker is required to remain open because its electrical load was not considered in the diesel generator loading analysis [6-21]. The electric fire pump (P-35A) breaker, 1B52-10B, is an example.

For breakers that do not receive an automatic close signal, there is no urgency for the load to be re-energized. If the operator manually closes the breaker during the period of potential relay chatter, the breaker may not close due to the chatter of the MG-6 normally closed contact pair. The



RELAY EVALUATION REPORT

EVALUATION DISCUSSIONS

operator will maintain the control switch in the closed position until indication is received that the breaker is closed. Therefore, relay chatter in this situation will only temporarily delay closing of the affected breaker, and will not adversely affect the ability to safely shutdown the plant.

3. The breaker is normally open and required to close upon the receipt of an automatic actuation signal. The auxiliary feed pump (P-38A) breaker, 1B52-12C, is an example.

Based on a review of the FSAR Chapter 14 accident analysis [6-20], three accidents requiring engineered safeguards system actuation are considered possible following an earthquake; 1) Loss of External Electrical Load, 2) Loss of Normal Feedwater and 3) Loss of All AC Power to Auxiliaries. In each case, the engineered safeguards system actuation is not expected until after the 30 second period of earthquake strong motion is over. Therefore relay chatter is considered acceptable during the period of the earthquake strong motion.



F.3 EVALUATION OF THE WESTINGHOUSE ITH RELAY SEISMIC CAPACITY

The Westinghouse ITH Relay is used as a ground instantaneous current relay (50G ITH) for the 4160 VAC switchgear breakers for equipment on the safe shutdown equipment list [West 499B466 Sh 201, Rev 9]. The Westinghouse ITH relay has a de-energized normally open contact pair in the circuit breaker over-current protection circuit. The contact pair is in the direct control path of the lockout relay 86 of the breaker trip circuit. The contact pair also has an associated seal-in relay (ICS) such that once the ITH relay actuates, the ICS relay and contact pair maintains power to the lockout relay 86 in the breaker trip circuit. Once the lockout relay is energized, it must be manually reset prior to shutting the associated circuit breaker. The function of the Westinghouse ITH relay in the breaker control circuit is such that relay chatter is not acceptable. The relay can not be evaluated using the "Switchgear Rule-of-the-Box" because it directly controls a switchgear lockout device [6.7]. Therefore the relay must have a relay specific seismic capacity screening.

The Westinghouse ITH relay is listed as a low ruggedness relay [6.7, Appendix E]. A review of the reference material for the low ruggedness determination, [6.17] indicates that the relay is on the low ruggedness list because it is susceptible to chatter resulting from mechanical shock. Subsequent to the relay being placed on the low ruggedness list, it was tested as part of the SQUG Relay GERS test program. The relay seismic fragility data indicates that the relay seismic capacity is 3.0g for the de-energized normally open contact pair configuration and 10.0g for the energized normally open or normally closed contact pair configuration [6.13]. The available information indicates that the relay has some capacity in the natural frequency ranges required to be checked by for USI A-46 (i.e., 4-16 Hz, and ZPA), however, it is susceptible to chatter due to high frequency accelerations (i.e., mechanical shock).

Based on the available information, the relay is considered a low ruggedness relay. For USI A-46, however, the relay is not automatically targeted for replacement. Its capacity is being evaluated based on the information in EPRI NP-7147 Volume 2: Addendum 1.



F.4 EMERGENCY DIESEL LOADING DUE TO THE INADVERTENT START OF
NON-ESSENTIAL ELECTRICAL LOADS

The Emergency Diesel Generator loading is analyzed for the maximum loading conditions during a safety injection actuation in response to a LOCA [WE Calculation N-91-016, Ref. 6-21]. The analysis considers the different electrical loading during each of the two response phases, the injection phase and the recirculation phase.

For the USI A-46 postulated seismic event, the potential exists for the loss of off-site power and emergency diesel generator operation, coincident with a safety injection actuation. To ensure that the emergency diesel generators will not be loaded in excess of that analyzed for in the diesel generator loading analysis, a relay review of the 4160 VAC (A-05 and A-06) and the 480 VAC (B-03 and B-04) buses' under-voltage and lockout relays was performed. Non-essential loads are stripped from the bus in three situations; 1) bus under-voltage, 2) safety injection actuation, and 3) bus under-voltage coincident with safety injection actuation. In addition to the loads being stripped, the loads are also locked out and require operator action to reset the lockout prior to re-energizing the load. Table B.3-1 provides a listing of the breakers for the non-essential electrical loads on the 480 VAC and 4160 VAC buses that were screened via the under-voltage and lockout relay review.

MCC loads did not have a relay review based on the size of the electrical load. The K-2 A&B Instrument Air Compressors are exceptions because they are 100 Hp loads which would significantly affect diesel loading.

For the breakers listed in Table F.4-1, the X & Y coils (for the 4160 VAC breakers) and the X coil (for the 480 VAC breakers) were identified in the opening and closing circuits of the breaker. The X & Y coils are mounted in each breaker cubicle for the associated breaker and are considered seismically adequate based on the "switchgear rule-of-the-box".



RELAY EVALUATION REPORT

EVALUATION DISCUSSIONS

**TABLE F.4-1 NON-ESSENTIAL ELECTRICAL LOADS SCREENED
 VIA UNDER-VOLTAGE AND LOCKOUT RELAY REVIEW**

	BUS	BREAKER NUMBER	BREAKER DESCRIPTION	ELEMENTARY	UV TRIP	UV LOCKOUT	SI TRIP/LOCKOUT	UV/SI COINCIDENT TRIP
1	1B-03	1B52-10B	P-35A Fire Pump	SH 371	X		X	
2	1B-03	1B52-12B	PP14 Pzr Htr Backup Group C	SH 324		X	X	
3	1B-03	1B52-14C	MCC 1B-31 Primary Auxiliary Building	SH 357	X		X	
4	1B-03	1B52-15C	Tie to Bus 1B-01	SH 353	X		X	
5	1B-03	1B52-16C	Tie to Bus 1B-04	SH 354	X		X	
6	1B-04	1B52-18C	Tie to Bus 1B-02	SH 353	X		X	
7	1B-04	1B52-21B	PP13 Pzr Htr Backup Group D	SH 324A		X	X	
8	1B-04	1B52-21C	MCC B43 Primary Auxiliary Building Common Loads	SH 357	X		X	
9	1B-04	1B52-22C	PP12 Pzr Htr Control Group E	SH 323	X		X	
10	2B-03	2B52-33C	Multi-Amp Feeder	SH 371	X		X	
11	2B-03	2B52-36B	PP19 Pzr Htr Backup Group C	SH 340A		X	X	
12	2B-03	2B52-37C	MCC B-33 Primary Auxiliary Building Common Loads	SH 387	X		X	
13	2B-03	2B52-38C	MCC 2B-31 Primary Auxiliary Building	SH 387	X		X	
14	2B-03	2B52-39C	Tie to Bus 2B-01	SH 383	X		X	
15	2B-03	2B52-40C	Tie to Bus 2B-04	SH 384	X		X	
16	2B-04	2B52-26C	Tie to Bus 2B-02	SH 383	X		X	
17	2B-04	2B52-28C	MCC B-21 South Service Building	SH 387	X		X	
18	2B-04	2B52-29B	PP18 Pzr Htr Backup Group D	SH 340		X	X	
19	2B-04	2B52-30B	Turbine Building Crane Z-14	SH 393	X		X	
20	2B-04	2B52-30C	PP17 Pzr Htr Control Group E	SH 339	X		X	
21	1A-05	1A52-57	Tie to Bus 1A-03	SH 265	X		X	
22	1A-06 (old)	1A52-63	Tie to Bus 1A-04	SH 265	X		X	
23	2A-05	2A52-76	Tie to Bus 2A-03	SH 295	X		X	
24	2A-06 (old)	2A52-70	Tie to Bus 2A-04	SH 295	X		X	



F.5 WESTINGHOUSE MG-6 CHATTER ACCEPTABILITY IN ENGINEERED SAFEGUARDS SYSTEMS

The MG-6 relays in the Engineered Safeguards System are normally de-energized. The relays have both normally open and normally closed contact pairs. All of the normally closed contact pairs were found to be associated with annunciators and solenoid valves and therefore chatter acceptable. All of the MG-6 relays in the Engineered Safeguards System are considered to have a GERS capacity of 10 g based on the non-operate normally open contact pair.



F.6 SEISMIC CAPACITY OF THE WESTINGHOUSE CO-5 RELAY

The Westinghouse CO-5 relay is used in the applications listed in Table F.6-1 in the Emergency Diesel Generator and 4160 VAC breaker control circuits.

TABLE F.6-1

WESTINGHOUSE CO-5 OVER-CURRENT PROTECTION RELAYS

	RELAY ID	SYSTEM/ COMPONENT	RELAY CABINET ID
1	51/1A52-60	DG/ 1A52-60	1A-05
2	51/1A52-66	DG/ 1A52-66	1A-06
3	51/1A52-67	DG/ 1A52-67	2A-06
4	51/1A52-73	DG/ 1A52-73	2A-05
5	51A/G01	DG/ G-01	C-34
6	51A/G02	DG/ G-02	C-35
7	51B/G01	DG/ G-01	C-34
8	51B/G02	DG/ G-02	C-35
9	51C/G01	DG/ G-01	C-34
10	51C/G02	DG/ G-02	C-35

The CO-5 relay consists of a CO and an ICS unit. The CO unit is the only one required to be seismically screened for the relay functionality review. The capacity of the W CO-5 relay of 6 g's is used based on the capacity of the CO unit in the W COM-5 relay tested as part of test group 7 in EPRI NP-7147 Volume 2: Addendum 1 [6.13]. A comparison of the W COM-5, Style # 289B355A, documented in Westinghouse Instruction Leaflet (I.L.) 41-102 and the W CO-5, Style # 1875238 documented in W I.L. 41-101 was made. The units are identical and therefore are considered to have the same seismic capacity.