

NUREG/CR-5604  
EGG-2508  
Vol. 3

---

---

# Assessment of ISLOCA Risk— Methodology and Application to a Babcock and Wilcox Nuclear Power Plant

Appendices I–M

---

---

Prepared by  
W. J. Galyean, D. I. Gertman

Idaho National Engineering Laboratory  
EG&G Idaho, Inc.

Prepared for  
U.S. Nuclear Regulatory Commission

9205270071 920430  
PDR NUREG  
CR-5604 R PDR

#### AVAILABILITY NOTICE

##### Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 2120 L Street, NW., Lower Level, Washington, DC 20555
2. The Superintendent of Documents, U.S. Government Printing Office, P.O. Box 37082, Washington, DC 20013-7082
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC bulletins, circulars, information notices, inspection and investigation notices; licensee event reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, international agreement reports, grant publications, and NRC booklets and brochures. Also available are regulatory guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG-series reports and technical reports prepared by other Federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions. *Federal Register* notices, Federal and State legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports, and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Office of Administration, Distribution and Mail Services Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Norfolk Avenue, Bethesda, Maryland, for use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

#### DISCLAIMER NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

NUREG/CR-5604  
EGG-2608  
Vol. 3  
RG, 1S, 9L

---

---

# Assessment of ISLOCA Risk- Methodology and Application to a Babcock and Wilcox Nuclear Power Plant

Appendices I-M

---

---

Manuscript Completed: March 1992  
Date Published: April 1992

Prepared by  
W. J. Galycan, D. I. Gertman

Idaho National Engineering Laboratory  
Managed by the U.S. Department of Energy

EG&G Idaho, Inc.  
Idaho Falls, ID 83415

Prepared for  
Division of Safety Issue Resolution  
Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555  
NRC FIN B5699  
Under DOE Contract No. DE-AC07-76ID01570

## ABSTRACT

This document presents information essential to understanding the risk associated with inter-system loss-of-coolant accidents (ISLOCAs). The methodology developed and presented in this document provides a state-of-the-art method for identifying and evaluating plant-specific hardware designs, human performance issues, and accident consequence factors relevant to the prediction of the ISLOCA risk. This ISLOCA methodology was developed and then applied to a Babcock and Wilcox (B&W) nuclear power plant. The results from this application are described in detail. For this particular B&W reference plant, the assessment indicated that the probability of a severe ISLOCA is approximately  $2.2E - 06$ /reactor-year.

# CONTENTS

## Volume 1

ABSTRACT .....	iii
EXECUTIVE SUMMARY .....	xi
ACKNOWLEDGMENTS .....	xv
ACRONYMS .....	xvii
1. INTRODUCTION .....	1
2. APPROACH .....	3
2.1 Assess Potential Fo. ISLOCA .....	3
2.2 Gather Detailed Plant-Specific Information .....	4
2.3 Develop Event Trees .....	4
2.4 Estimate Rupture Potential .....	4
2.5 Perform Human Reliability Analysis .....	5
2.6 Quantify Event Trees .....	9
2.7 Consequences .....	9
2.8 Sensitivity Studies .....	10
3. DESCRIPTION OF THE B&W REFERENCE PLANT INTERFACING SYSTEMS .....	11
3.1 Interfacing Systems .....	11
3.2 Possible ISLOCA Sequences .....	11
3.2.1 LPI Sequences .....	11
3.2.2 DHR Sequences .....	11
3.2.3 HPI Sequences .....	14
4. B&W REFERENCE PLANT RESULTS .....	15
4.1 Component and System Rupture Probabilities .....	16
4.1.1 Pressure Fragility Calculations .....	17
4.1.2 Estimating Local System Pressures .....	20
4.1.3 HPI-Sequences Rupture Probability .....	20
4.1.4 DHR/LPI Sequences Rupture Probability .....	21

4.2	Human Reliability Analysis .....	22
4.2.1	Introduction and Overview .....	22
4.2.2	Detailed Breakdown of Human Error Actions .....	28
4.2.3	Decision-Based Errors .....	28
4.2.4	Human Factors Influence on the Risk Associated with ISLOCA .....	28
4.3	Reference B&W Plant Event Trees .....	28
4.3.1	Makeup and Purification System Interface Event Tree—MU&P .....	30
4.3.2	High-Pressure Injection System Interface Event Tree—HPI .....	33
4.3.3	DHR Letdown (Shutdown) Interface Event Tree—DHR-SD .....	33
4.3.4	DHR Letdown (Startup) Interface Event Tree—DHR-SU .....	34
4.3.5	Low-Pressure Injection System Interface Event Tree—LPI .....	36
4.3.6	Auxiliary Building Environmental Analysis .....	38
4.3.7	ISLOCA Sequence Timing and Operator Actions .....	44
4.4	ISLOCA CDF Estimation .....	46
4.5	Risk Assessment .....	47
4.6	Sensitivity Study Results .....	49
4.6.1	Pipe Rupture Pressure Uncertainty .....	49
4.6.2	HRA Method Sensitivity .....	51
5.	OBSERVATIONS .....	57
5.1	B&W Reference Plant-Specific Observations .....	57
5.2	Generalized Observations .....	58
6.	REFERENCES .....	60

## Volume 2

Appendix A—Historical Experience Related to ISLOCA Events .....	A-1
Appendix B—Component Failure Rates .....	B-1
Appendix C—Reference B&W Plant System Descriptions .....	C-1
Appendix D—Reference B&W Plant ISLOCA Event Trees .....	D-1
Appendix E—Human Reliability Analysis for the B&W ISLOCA Probabilistic Risk Assessment .....	E-1
Appendix F—Thermal Hydraulic Calculations .....	F-1
Appendix G—Bounding Core Uncovery Time Calculations .....	G-1
Appendix H—System Rupture Probability Calculations Using EVENTRE .....	H-1

## Volume 3

Appendix I—Consequence Calculations .....	I-1
Appendix J—External Events Analysis of ISLOCA Sequences .....	J-1
Appendix K—Review of Pressure Fragility Calculations .....	K-1
Appendix L—Uncertainty Analysis .....	L-1
Appendix M—Steam Propagation Analysis for the B&W Plant Auxiliary Building .....	M-1

## LIST OF FIGURES

ES-1.	Approach for plant-specific evaluation of ISLOCA .....	xii
1.	Approach for plant-specific evaluation of ISLOCA .....	3
2.	HRA event tree for HDA2-MU (operators fail to diagnose ISLOCA) .....	7
3.	Schematic diagram of the reference B&W plant HPI system .....	12
4.	Schematic diagram of the reference B&W plant DHR/LPI system .....	13
5.	Pressure drop through DHR system as a function of RCS pressure .....	21
6.	DHR system pressure response to DHR-SD ISLOCA .....	22
7.	Probability density function of the HEP of prematurely entering DHR cooling .....	23
8.	DHR/LPI system rupture probability as a function of RCS pressure .....	24
9.	Schematic of the MU&P system interface .....	31
10.	Reference B&W plant MU&P system interface event tree .....	32
11.	Schematic diagram of the HPI interface .....	34
12.	HPI ISLOCA sequence event tree .....	35
13.	Schematic diagram of the DHR letdown interface (shutdown) .....	36
14.	DHR letdown system (shutdown) ISLOCA sequence event tree .....	37
15.	Schematic diagram of the DHR letdown interface (startup) .....	38
16.	DHR letdown (startup) ISLOCA sequence event tree .....	39
17.	Schematic diagram of the LPI interface .....	40
18.	LPI ISLOCA sequence event tree .....	41
19.	Sequence contribution to total ISLOCA CDF .....	48

## LIST OF TABLES

ES-1.	Plant-damage state frequencies from ISLOCA sequences for a B&W reference plant (frequency per reactor-year) .....	xii
1.	List of ISLOCA interface sequences .....	14
2.	Pressure fragilities of HPI components .....	18
3.	Pressure fragilities of DHR/LPI components .....	18



4.	Predicted failure probabilities for DHR/LPI components .....	25
5.	LPI scenario involving quarterly stroke test for 2A, MU&P flow .....	26
6.	HPI scenario involving quarterly stroke test, no MU&P flow .....	26
7.	Shutdown scenario involving premature opening of DH11 and DH12 .....	27
8.	Startup scenario involving DHR system .....	27
9.	LPI system ISLOCA scenario .....	27
10.	Latent errors .....	29
11.	Distribution of errors from supporting analyses .....	29
12.	Decision-based errors (either task or subtask values) .....	29
13.	Summary of ISLOCA times to core uncoverly based on exhaustion of water inventory (from Appendix G) .....	45
14.	Summary of ISLOCA times to core uncoverly based on time to fail all ECCS by flooding (from Appendix M) .....	45
15.	Plant-damage state frequencies from ISLOCA sequences for a B&W reference plant (frequency per reactor-year) .....	47
16.	MACCS consequence results for a range of possible DFs (Oconee source term, scaled to the B&W reference-plant power, and the Surry site) .....	48
17.	ISLOCA risk for the B&W reference plant (Oconee source term, scaled to reference-plant power, and the Surry site) .....	49
18.	DHR system rupture probabilities (weighted by the HEP of prematurely opening DH-11/12) as a function of RCS pressure (pipe failure pressure log-std-dev = 0.36) .....	50
19.	DHR system rupture probabilities (weighted to the HEP of prematurely opening DH-11/12) as a function of RCS pressure (pipe failure pressure log-std-dev = 0.1) .....	51
20.	Sensitivity of pipe rupture pressure uncertainty on DHR-SD sequence CDF (per reactor-year). Base case, log-std-dev = 0.36; sensitivity case, log-std-dev = 0.1 .....	52
21.	Relative weighing of HEP as a function of RCS pressure, base case. Regression used for estimating pressure dependent HEPs .....	53
22.	Relative weighing of HEP as a function of RCS pressure, sensitivity case. Regression used for estimating pressure dependent HEPs. (Sensitivity Case #1) .....	53
23.	DHR system rupture probabilities (weighted by the HEP of prematurely opening DH-11/12) as a function of RCS pressure. Sensitivity case for relative weight of $1.0E-04$ at RCS pressure of 2,200 psig .....	54

24.	Relative weighing of HEP as a function of RCS pressure, sensitivity case. Regression used for estimating pressure dependent HEPs (Sensitivity Case #2) .....	54
25.	DHR system rupture probabilities (weighted by the HEP of prematurely opening DH-11/12) as a function of RCS pressure. Assumes a linear probability distribution of the HEP, probability weight at 400 psig = 1.0; at 1,000 psig = 0.0 (Sensitivity Case #2) .....	55
26.	Sensitivity of pressure dependent HEP on DHR-SD sequence CDF (per reactor-year). Base case: HEP relative weight at 2,200 psig, $1.0E-03$ . Sensitivity cases: HEP relative weight at 2,200 psig, $1.0E-04$ (Sensitivity Case #1); probability = 0 at 1,000 psig (Sensitivity Case #2) .....	55
27.	Sensitivity of both CDF (per reactor-year) and risk to optimizing PSFs .....	56

**Appendix I**  
**Consequence Calculations**

**K. R. Jones**  
**D. L. Knudson**

## CONTENTS

I.1. Discussion . . . . .	I-3
I.2. Detailed Input Description . . . . .	I-8
I.3. Results . . . . .	I-21
I.4. References . . . . .	I-27

## FIGURES

I-1. Early Fatality Consequences for B&W plant ISLOCA normalized to a nationwide-average site. . . . .	I-23
I-2. Latent Cancer Fatality Consequences for B&W plant ISLOCA normalized to a nationwide-average site. . . . .	I-24
I-3. Population Dose Consequences for B&W plant ISLOCA, normalized to a nationwide-average site. . . . .	I-25
I-4. Total Cost Consequences for B&W Plant ISLOCA, normalized to a nationwide-average site. . . . .	I-26

## TABLES

I-1. Site population factors and wind rose weighted SPFs . . . . .	I-4
I-2. Scrubbing decontamination factor for the containment by-pass sequence with overlying water. . . . .	I-6
I-3. MACCS results for ISLOCA analysis for a range of decontamination factors. . . . .	I-21
I-4. ISLOCA results using NUREG/CR-4551 composite DF weighing factors for a V sequence with overlying water. . . . .	I-22

## APPENDIX I CONSEQUENCE CALCULATIONS

### I.1 Discussion

The purpose of this appendix is to provide an estimate of the radiological consequences associated with an Interfacing System Loss-of-Coolant Accident. These hypothetical accidents have been postulated to occur in light water reactor (LWR).

The MELCOR Accident Consequence Code System (MACCS) was selected for radiological consequence modeling. The construction of a complete MACCS model for the specific plant under study was not considered desirable. This is because of the generic nature of the ISLOCA analysis. It was determined that plant specific source terms and accident sequences could be normalized to a nation-wide average site using an existing MACCS model.<sup>1-1</sup> This model is also adequate for determining the effectiveness of potential accident management strategies (i.e., modifications in accident sequences and decontamination factors) through sensitivity calculations.

The readily-available MACCS models were limited to those used in NUREG-1150 (second draft). The model selection is of importance because predicted consequences are model dependent. The selection objective was to find a model that would represent a nation-wide average for all U.S. plants. It was assumed that the radiological consequences were primarily dependent on population density when implementing this model selection objective.

Site population factors (SPFs) were developed by the NRC to provide a method for comparing populations surrounding nuclear plant sites.<sup>1-2</sup> The factors are intended to be dimensionless measures of total risk within specified radial distances from a given reactor site. Because correlations between population distribution and wind direction may significantly influence risk at some sites, a wind rose weighted formulation of the SPF (or WRSPF) was also developed.

The SPFs and WRSPFs were calculated for 91 U.S. reactor sites at radii of 5, 10, 20, and 30 mi<sup>1-2</sup> using 1970 census data. The average values of SPF and WRSPF were then determined for the 91 sites. The difference between the

average values and the values for the five NUREG-1150 (second draft) sites were then determined. These differences are shown below in Table I-1. The differences represent the deviation of the NUREG sites from average values for U.S. plants. The smallest deviation is associated with the NUREG site that is closest to average risk conditions.

The Surry 1 site is closest to average risk conditions with respect to WRSPF data at radii greater than 5 miles. Within a 5-mile radius, differences between NUREG sites are insignificant with the exception of the Zion 1 site. Since the WRSPF is a better measure of consequence risk and the Surry 1 site is closest to average for this measure, it was decided that the Surry 1 MACCS model would be adequate for use in the ISLOCA program. The most recent version of the draft NUREG-1150 MACCS 1.5.11 input decks for Surry were utilized. These files differ in some places from those used in the pre-decisional second draft of NUREG-1150. The pre-decisional draft utilized version 1.5.5 of MACCS. These changes reflect additions to support code improvements and input error corrections. The second draft NUREG-1150 input files for Surry were obtained from Sandia National Laboratories.

Table I-1. Site population factors and wind rose weighted SPFs

Site Name	SPF5*	SPF10*	SPF20*	SPF30*
Grand Gulf 1	0.064631	0.069299	0.091110	0.110164
Peach Bottom 2	0.055659	0.042620	0.006532	0.021141
Sequoyah 1	0.002281	0.003744	0.053928	0.012281
Surry 1	0.065422	0.012330	0.016468	0.007101
Zion 1	0.636709	0.617710	0.471118	0.423291

$$SPF_{xx}^* = ABS ( (SPF_{xx})_{avg \text{ of } 91} - (SPF_{xx})_{named \text{ site}} )$$

Site Name	WRSPF5*	WRSPF10*	WRSPF20*	WRSPF30*
Grand Gulf 1	0.056091	0.072459	0.097906	0.115450
Peach Bottom 2	0.053448	0.052079	0.015018	0.022470
Sequoyah 1	0.032236	0.004121	0.127492	0.080040
Surry 1	0.054780	0.002804	0.001998	0.012580
Zion 1	0.809106	0.745092	0.566652	0.517020

$$WRSPF_{xx}^* = ABS ( (WRSPF_{xx})_{avg \text{ of } 91} - (WRSPF_{xx})_{named \text{ site}} )$$

A source term and accident sequence for the plant were needed for incorporation into the Surry MACCS model. Published data for an ISLOCA at the reference B&W plant are not available. An ISLOCA was analyzed in a probabilistic risk assessment (PRA) for the B&W plant Oconee 3;<sup>1-3</sup> and this information employed because

- a.) Oconee 3 is also a B&W plant and,
- b.) both units have a similar thermal power (2772 Mwt and 2568 Mwt, for the reference plant and Oconee, respectively).

It was then possible to scale the Oconee 3 ISLOCA source term to the B&W reference plant. This scaling was accomplished by using the associated ISLOCA accident sequence modified by the ratio of the thermal powers. This scaling should not significantly misrepresent the reference B&W plant ISLOCA source term. On this basis the appropriate modifications of the Oconee 3 PRA data were incorporated into the Surry 1 MACCS model for ISLOCA consequence analysis of the reference B&W plant.

Radionuclide release during the B&W reference plant's ISLOCA sequences can occur through a submerged breach in a flooded ECCS pump room. A scrubbing decontamination factor (DF) will reduce the actual release from the auxiliary building. Credit was not taken for radionuclide removal by this scrubbing mechanism in the ISLOCA sequences in the Oconee source terms. The scrubbing decontamination factor thus needs to be included in the reference plant's consequence analysis. A great deal of uncertainty is associated with the selection of the appropriate decontamination factor to model this effect.<sup>1-4</sup> Table C-20 of NUREG/CR-4551, Volume 1, provides a summary of expert opinion for the scrubbing DF for the containment bypass sequence (ISLOCA) when the release occurs in a potentially flooded area. These decontamination factors are presented as distributions for each reviewer and the composite distribution is reproduced as follows:

Table I-2. Scrubbing decontamination factor for the containment bypass sequence with overlying water

<u>DF Level</u>	<u>Composite Weighing Factor</u>
100	0.13
12	0.26
5	0.38
2	0.43

These DF values pertain to the V Sequence analysis for Surry. However, for the purpose of this analysis, it is assumed that they are generically applicable to a V Sequence for a typical LWR.

To evaluate the effect of decontamination factors on the consequence measures, ten MACCS cases were run using a range of decontamination factors from 1 to infinity. The Dfs were applied uniformly to all the radionuclide groups except the noble gases. This calculation is scoping in nature and as such does not take into account any changes in the emergency response scenario, time of release, duration of release, or accident alarm times for each source term. The source term timing data were obtained from release category 2 of the Oconee 3 PRA, which assumes a 3.5-hour release duration beginning 1.5 hours following accident initiation and a 30-minute delay after accident initiation before general emergency conditions are reached. In accordance with the second draft NUREG-1150 analysis, 99.5% of the population within the affected zone is assumed to follow the Surry site evacuation model, which assumes a 1.8 m/s radial evacuation speed beginning 2.0 hours following the declaration of general emergency conditions, with 0.05% of the population maintaining normal activity within the 10-mile evacuation zone.

A PC version of the MELCOR Accident Consequence Code System Version 1.5.11 (MACCS 1.5.11) was used for this analysis.<sup>1-5</sup> The computer code is comprised of a single FORTRAN77 program that consists of three basic modules, ATMOS, EARLY, and CHRONC, which are exercised in sequence. This program has been developed for the purpose of evaluating the severe accident consequences at commercial LWR power plants. MACCS 1.5 incorporates several improvements over earlier modeling capabilities available in CRAC2 for the treatment of variable and/or long-term releases, deposition modeling, dosimetry, emergency



response, long-term mitigative actions, radiological health effects, and economic impacts.

## 1.2 Detailed Input Description

Of the six input files required by MACCS, only the ATMOS input file was modified from the Draft NUREG-1150 MACCS 1.5.11 Surry Model. These changes include case-specific input representing the ISLOCA source terms for a range of decontamination factors. A detailed description of the ATMOS input file follows:

Variable Name - **ATNAM1**  
 Purpose - Identifier for specific ATMOS case (Case Specific).

CASE 1: 20RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-001'

CASE 2: RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-002'

CASE 3: RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-003'

CASE 4: RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-004'

CASE 5: RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-005'

CASE 6: RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-006'

CASE 7: RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-007'

CASE 8: RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-008'

CASE 9: RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-009'

CASE 10: RIATNAM1001 'IN1A.INP, SURRY, USING B&W PLANT SOURCE TERMS CASE-010'

Variable Name - **NUMRAD**  
 Purpose - Number of radial spatial elements defined in the model.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

GENUMRAD001 26

Variable Name - **SPAEND**  
 Purpose - Distance in meters to the end of the spatial interval.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

\* SURRY  
 \*

GESPAEND001	.16	.52	1.21	1.61	2.13
GESPAEND002	3.22	4.02	4.83	5.63	8.05
GESPAEND003	11.27	16.09	20.92	25.75	32.19
GESPAEND004	40.23	48.28	64.37	80.47	112.65
GESPAEND005	160.93	241.14	321.87	563.27	804.67
GESPAEND006	1609.34				

Variable Name - CWASH1  
 Purpose - Linear term of the washout factor.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

WDCWASH1001 9.5E-5 (JON HELTON AFTER JONES, 1986)

Variable Name - CWASH2  
 Purpose - The exponential term for the washout factor.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

WDCWASH2001 0.8 (JON HELTON AFTER JONES, 1986)

Variable Name - DNPSGRP  
 Purpose - The number of particle size groups that are used for dry deposition.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

DNPSGRP001 1

Variable Name - VDEPOS  
 Purpose - The representative dry deposition velocities associated with each of the particle size groups.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

DDVDEPOS001 0.01

Variable Name - CYSIGA  
 Purpose - The linear term in the expression for sigma-y for 6 stability classes.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

\* STABILITY CLASS: A B C D E F  
 \*  
 DPCYSIGA001 0.3658 0.2751 0.2089 0.1474 0.1046 0.0722

Variable Name - CYSIGB  
 Purpose - The exponential term of the expression for sigma-y, 6 stability classes.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

\* STABILITY CLASS: A B C D E F  
 \*  
 DPCYSIGB001 .9031 .9031 .9031 .9031 .9031 .9031

Variable Name - CZSIGA  
 Purpose - The linear term of the expression for sigma-z, 6 stability classes.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

\* STABILITY CLASS: A B C D E F  
 \*  
 DPCZSIGA001 2.5E-4 1.9E-3 .2 .3 .4 .2

Variable Name - CZSIGB

Purpose - The exponential term of the expression for sigma-z, 6 stability classes.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

* STABILITY CLASS;	A	B	C	D	E	F
* DPCZSIGB001	2.125	1.6021	.8543	.6532	.6021	.6020

Variable Name - YSCALE  
 Purpose - The linear scaling factor for the sigma-y function.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

DPYSCALE001 1.

Variable Name - ZSCALE  
 Purpose - The linear scaling factor for the sigma-z function.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

DPZSCALE001 1.27

Variable Name - TIMBAS  
 Purpose - The time base for the expansion factor (seconds).  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

PMTIMBAS001 600. (10 MINUTES)

Variable Name - BRKPNT  
 Purpose - The break point in the formula used for calculating the plume meander expansion factor.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

PMBRKPNT001 3600. (1 HOUR)

Variable Name - XPFAC1  
 Purpose - Exponential expansion factor number 1.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

PMXPFAC1001 0.2

Variable Name - XPFAC2  
 Purpose - Exponential expansion factor number 2.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

PMXPFAC2001 0.25

Variable Name - SCLCRW  
 Purpose - Scaling factor for the critical wind speed for entrainment of a buoyant plume.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

PRSCLCRW001 1.

Variable Name - SCLADP  
 Purpose - Scaling factor for the a-d stability plume rise formula.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

PRCLADP001 1.

Variable Name - SCLEFP  
Purpose - Scaling factor for the e-f stability plume rise formula.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

PRSCLEFP001 1.

Variable Name - BUILDW  
Purpose - Width of the reactor building in meters.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

WEBUILDW001 40. \* SURRY

Variable Name - BUILDH  
Purpose - Height of the reactor building in meters.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

WEBUILDH001 50. \* SURRY

Variable Name - ENDAT1  
Purpose - Flag to indicate that this is the last program in the series to be run.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

OCENDAT1001 .FALSE. (SET THIS VALUE TO .TRUE. TO SKIP EARLY AND CHRONC)

Variable Name - IDEBUG  
Purpose - Debug output flag (0 - no debug).  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

OCIDDEBUG001 0

Variable Name - METCOD  
Purpose - Meteorological sampling option code.  
metcod = 1, user specified day and hour in the year,  
2, weather category bin sampling,  
3, 120 hours of weather specified on the atmos user input file,  
4, constant met,  
5, stratified random samples for each day of the year.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M1METCOD001 2

Variable Name - LIMSPA  
Purpose - Last Spacial Interval for Measured Weather  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M2LIMSPA001 25

Variable Name - BNDMXH  
Purpose - Boundary weather mixing layer height.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M2BNDKXH001 1000. (METERS)

Variable Name - IBDSTB  
Purpose - Boundary weather stability class index.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M2IBDSTB001 4 (D-STABILITY)

Variable Name - BNDRAIN  
Purpose - Boundary weather rain rate.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M2BNDRAIN001 5. (MM/HR)

Variable Name - BNDWIND  
Purpose - Boundary weather wind speed.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M2BNDWIND001 4. (M/S)

Variable Name - NSMPLS  
Purpose - Number of samples per bin.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M4NSMPLS001 4 (THIS NUMBER SHOULD BE SET TO 4 FOR RISK ASSESSMENT)

Variable Name - NRRINT  
Purpose - Number of rain distance intervals for binning.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M4NRRINT001 6

Variable Name - RNDSTS  
Purpose - Endpoints of the rain distance intervals (kilometers)  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M4RNDSTS001 3.22 5.63 11.27 20.92 40.23 80.47

Variable Name - RNRATE  
Purpose - Number of rain intensity breakpoints.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M4NRINTN001 3

Variable Name - RNRATE  
Purpose - Rain intensity breakpoints for weather binning  
(millimeters per hour).  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M4RNRATE001 2. 4. 6.

Variable Name - IRSEED  
Purpose - Initial seed for random number generator.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

M4IRSEED001 79

Variable Name - NUMISO  
Purpose - Number of nuclides defined in the model.  
Source - Oconee Unit 3 PRA, NSAC/60.  
ISNUMISO001 54

Variable Name - MAXGRP  
Purpose - Number of nuclide groups defined in the model.  
Source - Oconee Unit 3 PRA, NSAC/60.

ISMAXGRP001 7

Variable Name - WETDEP  
Purpose - Logical flag for each of the nuclide groups that indicate whether they are subject to wet deposition.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

Variable Name - DRYDEP  
Purpose - Logical flag for each of the nuclide groups that indicate whether they are subject to dry deposition.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

\* WETDEP DRYDEP  
\*

ISDEPFLA001	.FALSE.	.FALSE.
ISDEPFLA002	.TRUE.	.TRUE.
ISDEPFLA003	.TRUE.	.TRUE.
ISDEPFLA004	.TRUE.	.TRUE.
ISDEPFLA005	.TRUE.	.TRUE.
ISDEPFLA006	.TRUE.	.TRUE.
ISDEPFLA007	.TRUE.	.TRUE.

Variable Name - NUCNAM  
Purpose - Identifying name associated with each on the nuclides.  
Source - Oconee Unit 3 PRA, NSAC/60.

Variable Name - PARENT  
Purpose - Name of parent nuclide if any.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

Variable Name - IGROUP  
Purpose - Chemical group to which nuclide is assigned.  
Source - Oconee Unit 3 PRA, NSAC/60.

Variable Name - HAFLIF  
Purpose - Half-life of the isotope in seconds.  
Source - NUREG-1150 MACCS 1.5.11 Surry Model.

* NUCNAM	PARENT	IGROUP	HAFLIF(S)	
ISOTPGRP001	CO-58	NONE	6	6.160E+06
ISOTPGRP002	CO-60	NONE	6	1.660E+08
ISOTPGRP003	KR-85	NONE	1	3.386E+08
ISOTPGRP004	KR-85M	NONE	1	1.613E+04

ISOTPGRP005	KR-87	NONE	1	4.560E+03
ISOTPGRP006	KR-88	NONE	1	1.008E+04
ISOTPGRP007	RB-86	NONE	3	1.611E+06
ISOTPGRP008	SR-89	NONE	5	4.493E+06
ISOTPGRP009	SR-90	NONE	5	8.865E+08
ISOTPGRP010	SR-91	NONE	5	3.413E+04
ISOTPGRP011	Y-90	SR-90	7	2.307E+05
ISOTPGRP012	Y-91	SR-91	7	5.080E+06
ISOTPGRP013	NB-95	ZR-95	7	3.033E+06
ISOTPGRP014	ZR-95	NONE	7	5.659E+06
ISOTPGRP015	ZR-97	NONE	7	6.048E+04
ISOTPGRP016	MO-99	NONE	6	2.377E+05
ISOTPGRP017	TC-99M	MO-99	6	2.167E+04
ISOTPGRP018	RIJ-103	NONE	6	3.421E+06
ISOTPGRP019	RU-105	NONE	6	1.598E+04
ISOTPGRP020	RU-106	NONE	5	3.188E+07
ISOTPGRP021	RH-105	RU-105	5	1.278E+05
ISOTPGRP022	SB-127	NONE	4	3.283E+05
ISOTPGRP023	SB-129	NONE	4	1.562E+04
ISOTPGRP024	TE-127	SB-127	4	3.366E+04
ISOTPGRP025	TE-127M	NONE	4	9.418E+06
ISOTPGRP026	TE-129	SB-129	4	4.200E+03
ISOTPGRP027	TE-129M	NONE	4	2.886E+06
ISOTPGRP028	TE-131M	NONE	4	1.080E+05
ISOTPGRP029	TE-132	NONE	4	2.808E+05
ISOTPGRP030	I-131	TE-131M	2	6.947E+05
ISOTPGRP031	I-132	TE-132	2	8.226E+03
ISOTPGRP032	I-133	NL	2	7.488E+04
ISOTPGRP033	I-134	NONE	2	3.156E+03
ISOTPGRP034	I-135	NONE	2	2.371E+04
ISOTPGRP035	XE-133	I-133	1	4.571E+05
ISOTPGRP036	XE-135	I-135	1	3.301E+04
ISOTPGRP037	CS-134	NONE	3	6.501E+07
ISOTPGRP038	CS-136	NONE	3	1.123E+06
ISOTPGRP039	CS-137	NONE	3	9.495E+08
ISOTPGRP040	BA-140	NONE	5	1.105E+06
ISOTPGRP041	LA-140	BA-140	7	1.448E+05
ISOTPGRP042	CE-141	NONE	7	2.811E+06
ISOTPGRP043	CE-143	NONE	7	1.188E+05
ISOTPGRP044	CE-144	NONE	7	2.457E+07
ISOTPGRP045	PR-143	CE-143	7	1.173E+06
ISOTPGRP046	ND-147	NONE	7	9.495E+05
ISOTPGRP047	PU-238	CM-242	7	2.809E+09
ISOTPGRP048	PU-239	NP-239	7	7.700E+11
ISOTPGRP049	PU-240	CM-244	7	2.133E+11
ISOTPGRP050	PU-241	NONE	7	4.608E+08
ISOTPGRP051	NP-239	NONE	7	2.030E+05
ISOTPGRP052	AM-241	PU-241	7	1.366E+10
ISOTPGRP053	CM-242	NONE	7	1.408E+07
ISOTPGRP054	CM-244	NONE	7	5.712E+08

Variable Name - ATNAM2  
Purpose - Descriptive text identifying the source term. This text is used to identify specific source terms in the output.



Case 1:  
RDATNAM2001 'B&W PLANT SOURCE TERM AS SCALED FROM OCONEE PRA DF=1.0'

Case 2:  
RDATNAM2001 'B&W PLANT SOURCE TERM AS SCALED FROM OCONEE PRA DF=2.0'

Case 3:  
RDATNAM2001 'B&W PLANT SOURCE TERM AS SCALED FROM OCONEE PRA DF=5.0'

Case 4:  
RDATNAM2001 'B&W PLANT SOURCE TERM AS SCALED FROM OCONEE PRA DF=10.'

Case 5:  
RDATNAM2001 'B&W PLANT SOURCE TERM AS SCALED FROM OCONEE PRA DF=20.'

Case 6:  
RDATNAM2001 'B&W PLANT SOURCE TERM AS SCALED FROM OCONEE PRA DF=50.'

Case 7:  
RDATNAM2001 'B&W PLANT SOURCE TERM AS SCALED FROM OCONEE PRA DF=100.'

Case 8:  
RDATNAM2001 'B&W PLANT SOURCE TERM SCALED FROM OCONEE PRA DF=1000.'

Case 9:  
RDATNAM2001 'B&W PLANT SOURCE TERM SCALED FROM OCONEE PRA DF=10000.'

Case 10:  
RDATNAM2001 'B&W PLANT SOURCE TERM AS SCALED FROM OCONEE PRA DF=inf'

Variable Name - OALARM  
Purpose - Time after accident initiation when the accident reaches general emergency conditions (as defined in NURFG-0654), or when plant personnel can reliably predict that general emergency conditions will be attained  
Source - Oconee Unit 3 PRA, NSAC/60.

RDOALARM001 1800.0

Variable Name - NUMREL  
Purpose - Number of plume segments that are released.  
Source - Oconee Unit 3 PRA, NSAC/60.

RNUMREL001 1

Variable Name - MAXRIS  
Purpose - Selection of risk dominant plume.  
Source - Single plume release.

RDMAXRIS001 1

Variable Name - REFTIM  
Purpose - Reference time for dispersion and radioactive decay.  
Source - A value of 0.0 is assumed for this analysis. This results in the trailing edge of the plume's release period being

used as the representative time point for the dispersion, dry deposition and radioactive decay models, resulting in a conservative calculation.

RDREFTIM001 0.0

Variable Name - PLHEAT  
 Purpose - Heat content of plume release (w).  
 Source - Oconee Unit 3 PRA, NSAC/60.

RDPLHEAT001 9.66E+06

Variable Name - PLHITE  
 Purpose - Height of plume segments at release (m).  
 Source - Oconee Unit 3 PRA, NSAC/60.

RDPLHITE001 0.0

Variable Name - PLUDUR  
 Purpose - Duration of plume segments (s).  
 Source - Oconee Unit 3 PRA, NSAC/60.

RDPLUDUR001 12600.0

Variable Name - PDELAY  
 Purpose - Time of release for each plume segment (s).  
 Source - Oconee Unit 3 PRA, NSAC/60.

RDPDELAY001 5400.0

Variable Name - PSDIST  
 Purpose - Particle size distribution for each nuclide group.  
 Source - NUREG-1150 MACCS 1.5.11 Surry Model.

RDPSDIST001 1.0  
 RDPSDIST002 1.0  
 RDPSDIST003 1.0  
 RDPSDIST004 1.0  
 RDPSDIST005 1.0  
 RDPSDIST006 1.0  
 RDPSDIST007 1.0

Variable Name - CORINV  
 Purpose - Defines the total core inventory for each nuclide, NUCNAM  
 Source - Oconee Unit 3 PRA, NSAC/60.  
 OCONEE 3 CORE INVENTORY FROM A LOR2 CALCULATION  
 B&W PWR, 177 FUEL ASSEMBLIES, 2568 Mwt, 421 EFPD BURNUP

*	NUCNAM	CORINV (CI)
*		
RDCORINV001	CO-58	8.00E+05
RDCORINV002	CO-60	3.00E+05
RDCORINV003	KR-85	5.45E+05
RDCORINV004	KR-85M	1.80E+07
RDCORINV005	KR-87	3.33E+07

RDCORINV006	XR-88	4.72E+07
RDCORINV007	RB-86	9.99E+04
RDCORINV008	SR-89	6.51E+07
RDCORINV009	SR-90	4.43E+06
RDCORINV010	SR-91	8.14E+07
RDCORINV011	Y-90	4.57E+06
RDCORINV012	Y-91	8.44E+07
RDCORINV013	NB-95	1.16E+08
RDCORINV014	ZR-95	1.16E+08
RDCORINV015	ZR-97	1.17E+08
RDCORINV016	MO-99	1.29E+08
RDCORINV017	TC-99M	1.11E+08
RDCORINV018	RU-103	1.11E+08
RDCORINV019	RU-105	7.72E+07
RDCORINV020	RU-106	3.26E+07
RDCORINV021	RH-105	7.06E+07
RDCORINV022	SB-127	6.28E+06
RDCORINV023	SB-129	2.24E+07
RDCORINV024	TE-127	6.28E+06
RDCORINV025	TE-127M	9.11E+05
RDCORINV026	TE-129	2.09E+07
RDCORINV027	TE-129M	5.67E+06
RDCORINV028	TE-131M	1.02E+07
RDCORINV029	TE-132	9.95E+07
RDCORINV030	I-131	6.92E+07
RDCORINV031	I-132	1.01E+08
RDCORINV032	I-133	1.42E+08
RDCORINV033	I-134	1.55E+08
RDCORINV034	I-135	1.33E+08
RDCORINV035	XE-133	1.43E+08
RDCORINV036	XE-135	5.72E+07
RDCORINV037	CS-134	1.26E+07
RDCORINV038	CS-136	4.57E+06
RDCORINV039	CS-137	6.16E+06
RDCORINV040	BA-140	1.24E+08
RDCORINV041	LA-140	1.26E+08
RDCORINV042	CE-141	1.16E+08
RDCORINV043	CE-143	1.07E+08
RDCORINV044	CE-144	7.69E+07
RDCORINV045	PR-143	1.05E+08
RDCORINV046	ND-147	4.57E+07
RDCORINV047	PU-238	1.92E+05
RDCORINV048	PU-239	3.92E+04
RDCORINV049	PU-240	3.00E+04
RDCORINV050	PU-241	7.54E+06
RDCORINV051	NP-239	1.66E+09
RDCORINV052	AM-241	6.21E+03
RDCORINV053	CM-242	1.96E+06
RDCORINV054	CM-244	1.15E+05

Variable Name - SCLCRW  
Purpose - Scaling factor to adjust the core inventory.  
Source - SCLCRW includes a conversion from curies to becquerels and the ratio of reference plant's thermal power (2772 mwt) to the thermal power of Oconee 3 (2568 Mwt). SCLCR is then:

SCLCRW = 2772 Mwth / 2568 Mwth \* 3.7E10 bq/ci  
SCLCRW = 3.99E+10

RDCORSCA001 3.99E+10

Variable Name - RELFAC  
Purpose - Release fractions for isotope groups in release (Case Dependant).  
Sources - The release fractions for Case 1 are based upon the Oconee Unit 3 PRA values for Release Category 2 which includes Interfacing LOCA events. The remaining nine cases represent application of uniform decontamination factors to the non-Noble gas release fractions of Case 1.

Case 1:

\* ISOTOPE GROUPS:

\* XE/KR I CS TE SR RU LA

\* DF=1.0

RDRELFRC001 1.0 3.1E-01 3.2E-01 3.0E-01 5.6E-02 2.7E-02 4.1E-03

Case 2:

\* DF=2.0

RDRELFRC001 1.0 1.5E-01 1.6E-01 1.5E-01 1.8E-02 1.3E-02 2.1E-03

Case 3:

\* DF=5.0

RDRELFRC001 1.0 6.2E-02 6.4E-02 6.0E-02 7.2E-03 5.4E-03 8.2E-04

Case 4:

\* DF=10.

RDRELFRC001 1.0 3.1E-02 3.2E-02 3.0E-02 3.6E-03 2.7E-03 4.1E-04

Case 5:

\* DF=12.

RDRELFRC001 1.0 2.6E-02 2.7E-02 2.5E-02 3.0E-03 2.2E-03 3.4E-04

Case 6:

\* DF=50.

RDRELFRC001 1.0 6.2E-03 6.4E-03 6.0E-03 7.2E-04 5.4E-04 8.2E-05

Case 7:

\* DF=100.

RDRELFRC001 1.0 3.1E-03 3.2E-03 3.0E-03 3.6E-04 2.7E-04 4.1E-05

Case 8:

\* DF=1000.

RDRELFRC001 1.0 3.1E-04 3.2E-04 3.0E-04 3.6E-05 2.7E-05 4.1E-06

Case 9:

\* DF=10000.

RDRELFRC001 1.0 3.1E-05 3.2E-05 3.0E-05 3.6E-06 2.7E-06 4.1E-07

Case 9:

\* DF= infinite

RDRELFRC001 1.0 0.0E+00 0.0E+00 0.0E+00 0.0E+00 0.0E+00 0.0E+00

### Additional Input Files

The ATMOS module requires a site meteorological data file. The NUREG-1150 MACCS 1.5.11 Surry Model site meteorological data file was utilized.

The EARLY and CHRONC modules each require their own input files as well as two auxiliary data files, a site data file and a dose conversion file. The EARLY and CHRONC input files were obtained from the NUREG-1150 MACCS 1.5.11 Surry Model and did not require modification for this analysis. The dose conversion file "MACCS DOSE CONVERSION FILE: MOD SER #32, 6-JUL-89, 15:59:19 SANDIA NATIONAL LABORATORIES, J. JOHNSON" was utilized. This is the most recent dosimetry file provided by Sandia National Laboratory for MACCS 1.5. The site data file used was also from the NUREG-1150 MACCS 1.5.11 Surry Model.

### 1.3 Results

The mean values obtained for four measures of accident consequence are summarized in Table I-3 for each of the ten cases run. These include the total number of early fatalities, the total number of latent cancer fatalities within a 50 and a 1000 mile radius of the calculational grid, the total population dose within 50 miles in sieverts, and the total economic cost in dollars. These results are also presented in Figures I-1 through I-4.

An effort has been made to estimate the effect of overlying water at the location of the break in scrubbing the release and reducing the radiological consequences. The NUREG/CR-4551 composite DF weighing factors described earlier were applied to the MACCS results to obtain the consequence measures presented in Table I-4.

Table I-3. MACCS results for ISLOCA analysis for a range of decontamination factors

DF	Total Number Early Fatalities	Total Number of Latent Cancer Fatalities		Total Population Dose (Sv.) 50 Mi.	Total Economic Cost (\$)
		1000 Mi.	50 Mi.		
1.00	3.58E-02	4.47E+03	5.25E+02	2.79E+04	1.11E+10
2.00	2.45E-03	2.84E+03	3.50E+02	1.98E+04	5.11E+09
5.00	2.97E-04	1.46E+03	2.23E+02	1.32E+04	2.29E+09
10.00	5.80E-05	8.92E+02	1.62E+02	9.73E+03	1.28E+09
12.00	3.49E-05	7.83E+02	1.52E+02	9.11E+03	1.09E+09
50.00	2.03E-06	2.56E+02	7.55E+01	4.52E+03	2.38E+08
100.00	1.21E-06	1.43E+02	4.89E+01	2.91E+03	1.27E+08
1000.00	7.88E-07	2.24E+01	1.16E+01	6.70E+02	5.23E+06
10000.00	7.65E-07	5.38E+00	3.32E+00	1.75E+02	4.80E+04
-INFINITE-	7.63E-07	3.05E+00	1.97E+00	9.59E+01	2.69E+03

Table I-4. ISLOCA results using NUREG/CR-4551 composite DF weighing factors for a V sequence with overlying water

---

Total Number of Early Fatalities . . . . .	6.86E-04
Total Number of Latent Cancer Fatalities	
1000 Miles . . . . .	1.43E+03
50 Miles . . . . .	1.11E+02
Total 50 Mile Population Dose (Sv.) . . . . .	1.23E+04
Total Economic Cost (\$) . . . . .	2.35E+09

---

The total economic costs are calculated by the CHRONC module of MACCS and as a result the economic costs associated with different EARLY cohorts are not determined by the code. MACCS somewhat arbitrarily uses the results from the last EARLY cohort run as a basis for calculating the evacuation and relocation costs in CHRONC. This is contrary to what the user might assume, that the overall EARLY results combined using the emergency response scenario weighing fractions would be used as a basis for calculating the evacuation and relocation costs in CHRONC. This distinction is not pointed out by the users manual for MACCS 1.5. For the cases run, these costs are relatively small in comparison to the total economic costs and do not impact the results reported in Table I-3.






Figure I-1. Early Fatality Consequences for B&W plant ISLOCA normalized to a nationwide-average site.




Figure I-2. Latent Cancer Fatality Consequences for B&W plant ISLOCA normalized to a nationwide-average site.




Figure 1-3. Population Dose Consequences for B&W plant ISLOCA, normalized to a nationwide-average site.




Figure I-4. Total Cost Consequences for B&W Plant ISLOCA, normalized to a nationwide average site.

#### 1.4 References

- 1-1. D. I. Chanin, *MELCOR Accident Consequence Code System, MACCS Version 1.5 User's Manual*, Draft NUREG/CR-4691, 21 September 1988.
- 1-2. D.C. Aldrich et al., *Technical Guidance for Siting Criteria Development*, NUREG/CR-2239, SAND81-1549, 1982.
- 1-3. Nuclear Safety Analysis Center (Electric Power Research Institute) and Duke Power Company, *Oconee PRA: A Probabilistic Risk Assessment of Oconee Unit 3*, NSAC-60, June 1984.
- 1-4. Sandia National Laboratories, *Evaluation of Severe Accident Risks and the Potential For Risk Reduction: Surry Power Station, Unit 1*, Draft NUREG/CR-4551, SAND86-1309, Volume 1, July 1989.
- 1-5. K. R. Jones and C. A. Dobbe, *Documentation of the INEL PC Version of MACCS 1.5.11*, 3 November 1989.

**Appendix J**  
**External Events Analysis of ISLOCA Sequences**

**J. A. Schroeder**

## CONTENTS

J.1. Introduction . . . . .	J-4
J.1.1. Screening Analysis . . . . .	J-4
J.1.2. Bounding Analysis . . . . .	J-4
J.2. Interfacing Systems . . . . .	J-5
J.2.1. HPI System Interface . . . . .	J-5
J.2.2. DHR System Interface . . . . .	J-5
J.2.3. LPI System Interface . . . . .	J-6
J.3. Screening of External Events . . . . .	J-6
J.3.1. Aircraft Impact . . . . .	J-7
J.3.2. Avalanche . . . . .	J-7
J.3.3. External Flood . . . . .	J-7
J.3.4. Fire . . . . .	J-8
J.3.5. Forest Fire . . . . .	J-8
J.3.6. Hail . . . . .	J-8
J.3.7. Ice Cover . . . . .	J-8
J.3.8. Ice Storms . . . . .	J-9
J.3.9. Industrial Facility Accident . . . . .	J-9
J.3.10. Internal Flood . . . . .	J-9
J.3.11. Landslide . . . . .	J-9
J.3.13. Low lake/River level . . . . .	J-10
J.3.14. Lightning . . . . .	J-10
J.3.15. Meteorite . . . . .	J-10
J.3.16. Missiles . . . . .	J-10
J.3.17. Pipeline Accidents . . . . .	J-11
J.3.18. Seismic . . . . .	J-11
J.3.19. Transportation Accidents . . . . .	J-11
J.3.20. Tornado . . . . .	J-12
J.3.21. Volcanic Activity . . . . .	J-12
J.3.22. Wind . . . . .	J-12
J.4. Bounding Analysis . . . . .	J-12
J.4.1. Analysis of Fire Events . . . . .	J-12
J.4.2. Analysis of Internal Flooding . . . . .	J-15
J.4.3. Analysis of Seismic Events . . . . .	J-17
J.5. B&W Results . . . . .	J-21
J.6. References . . . . .	J-22

## FIGURES

Figure J-1. HPI interface event tree for fire induced ISLOCA event. . . . .	J-14
Figure J-2. HPI interface event tree for flood induced ISLOCA events. . . . .	J-16
Figure J-3. Seismic hazard curve for the B&W study plant. . . . .	J-18
Figure J-4. HPI interface event tree for seismic induced ISLOCA events. . . . .	J-20

## TABLES

Table J-1. Median Hazard Curve Values . . . . .	J-18
---	------



## APPENDIX J EXTERNAL EVENTS ANALYSIS OF ISLOCA SEQUENCES

### J.1. Introduction

This appendix describes the ISLOCA analysis of the external events at the B&W reference plant. These external events were examined with respect to their potential to cause an inter-system loss-of-coolant accident. The analysis was completed in two phases, a screening analysis and a bounding analysis. (Because of the low risk calculated in the bounding analysis, a detailed analysis was not required.)

#### J.1.1. Screening Analysis

A systematic screening of the external events was made to eliminate events that are not likely to be a threat to the plant. The external events were screened from further consideration when the median frequency was qualitatively predicted to be low. Section J.3 contains the details of this screening.

A coordinated evaluation of all nonnegligible external events was also made to minimize data gathering efforts. For example, it was determined that the design basis for seismic Class I structures was controlled by tornado loads rather than wind loads.

#### J.1.2. Bounding Analysis

A bounding analysis was performed for the external events after the negligible events were eliminated in the screening analysis. This analysis utilized generic data to generate an upper bound on the ISLOCA core damage frequency resulting from external events. The surviving events for which bounding analyses were performed are fire, flood, and seismic events.

## J.2. Interfacing Systems

### J.2.1. HPI System Interface

The HPI system consists of two pump trains, each of which branch into two injection legs. Each injection leg then discharges into one of the four RCS cold legs. The pressure isolation boundary is maintained by two check valves that are welded together, a normally closed MOV and, the HPI pump discharge check valve HP-23 (or HP-22). Because the HPI pressure isolation check valves (PIV's HP-57/59, HP-56/58, HP48/50, and HP-49/51) are welded together, leak testing cannot be performed on the individual check valves. Therefore, these valves were treated as a single check valve for analytical purposes. Since the MOVs (HP-2A, B, C, and D) are maintained with their control and motive power circuits always energized, they are considered susceptible to external events causing spurious operation.

### J.2.2. DHR System Interface

The DHR System could be over-pressurized if the DHR letdown line remains open while the RCS is being heated and pressurized, or if the isolation valves are opened after operating temperature and pressure are reached. There are two ways RCS water can enter the DHR system via the letdown line:

1. Through the normal letdown MOV's DH-11 and DH-12 and,
2. Through the MOV-bypass valves DH-21 and DH-23, which are local-manually operated valves.

DH-11 and DH-12 are interlocked to automatically close when the RCS pressure is above 300 psig. However, the interlocks are normally disabled (per plant tech specs) to prevent inadvertent operation. Normal plant procedure is to maintain DH-11 and DH-12 in a disabled state by removing their control power (the valve position indicators remain functional with control power removed) and racking out their motive power supply breakers. The only time valve control power is energized and motive power is returned to the motors is when the valves are to be operated.

Given that the power supply breakers to DH-11 and 12 are normally racked out, and that DH-21 and DH-23 are manual valves, there are no credible external event induced failure modes that could affect the DHR system interface. Therefore an external event induced ISLOCA challenge at the DHR interface is not considered further.

### J.2.3. LPI System Interface

This interface is formed by two check valves (CF-30 and DH-76) in series. These two check valves form the pressure isolation boundary between the RCS and the LPI systems. The system consists of two redundant trains, with each injection line being shared with one core flood tank.

If CF-30 and DH-76 fail, RCS water will back-leak into the LPI system and over-pressurize it. LPI over-pressurization at full RCS operating temperature and pressure will result in certain rupture. The DHR heat exchanger is the most likely failure location. If CF-30 and CF-28 fail the RCS will back-leak into the Core Flood Tank. However, because these potential scenarios only include the failure of check valves (assumed not to be susceptible to external event induced failures), they are not further discussed here.

### J.3. Screening of External Events

A review of information on the site region and plant design was made to identify all external events to be considered. The data in the B&W Final Safety Analysis Report (FSAR), Fire Hazards Analysis Report (FHAR), and other sources were reviewed for the purpose of minimizing the possibility of omitting significant external events while narrowing the scope of the analysis to only those events that are credible.

The following sections describe the screening analysis performed to eliminate insignificant external events from consideration as ISLOCA initiators.

### J.3.1. Aircraft Impact

The closest airport serving commercial airlines is located 38 miles west of the B&W site. The nearest airport with a paved runway is located east-southeast, 13 miles from the site. The two nearest VHF Omni-Directional Radio Range Airways are designated V232 and V-45 and are located seven miles from the site.<sup>J-1</sup>

There are no low-level flight patterns or airport facilities in the proximity of the station site. The existence of the restricted air space in the area of the site reduces the amount of low-level aircraft operations that could be expected.<sup>J-1</sup>

### J.3.2. Avalanche

There are no mountains in the area of the B&W site, therefore an avalanche is not possible.

### J.3.3. External Flood

The station structures are over 3,000 feet from the lake's shoreline. All station grade floors are at elevation 585 feet Internal Great Lakes Datum (I.G.L.D.) and the station is designed for normal power generation at water levels from 562 feet (I.G.L.D.) up to this elevation. In addition, a breakwater dike is installed along the north and east side of the station to protect it against flooding due to waves and wave run-up during a probable maximum meteorological event.

The maximum wave run-up on this breakwall will be 6.6 feet above the probable maximum static water level of 583.7 feet (I.G.L.D.). This will give a maximum water run-up level on the breakwall of 590.3 feet (I.G.L.D.). As a result, no large unbroken waves should reach the station's buildings and none should top the wave protection dike.

The intake structure is designed to accept the wave action directly. The cooling tower is located outside the diked area and could be subjected to wave action. This wave action might require the cooling tower to be taken out

of service. In this event, the station can be brought to a safe and orderly shutdown condition and maintained in this condition because all other systems are fully protected.

If for any possible reason the main discharge pipe in the sewer system fails to handle the estimated probable maximum runoff effluent into the river, the runoff water will build up in the sewer system and on the ground around the station.

Because all structures are protected against water buildup and flooding up to 585.0 feet (I.G.L.D.), there will be no threat to the structure from this probable maximum buildup runoff water.<sup>J-1</sup>

#### J.3.4. Fire

A bounding analysis was performed for this event.

#### J.3.5. Forest Fire

There are no forests in the immediate area of the B&W site, therefore forest fires are not a concern.

#### J.3.6. Hail

Tornado generated missiles govern this event.

#### J.3.7. Ice Cover

The adjoining lake is subject to extensive ice formations. However, the depth of the intake structure precludes blockage of intake flow from normal ice formations. The shore area of the station's site is subject to ice pileup from northeast wind-driven lake ice. The rockfill barrier beyond the intake structure and the rockfill around the structure itself provides protection from ice chunks that could be forced to and along the bottom surface by this piling action. If ice pileup should extend to the lake bottom in the area of the intake structure, it is extremely unlikely that all intake ports could be covered completely and the conservative design of the intake areas provides

### J.3.13. Low lake/River level

All cooling water requirements for the B&W plant are taken from the surrounding lake. The cooling water is supplied to the station's intake canal. This canal is fully closed and is connected to the lake via a submerged 96 inch conduit. This conduit extends approximately 3,300 feet into the lake. The water flow into the conduit is through an intake crib. The intake crib is at an elevation of 561.85 feet. The intake canal will be completely cutoff from the lake if the water level falls below this elevation. However, there is sufficient water impounded in the Class I portion of the intake structure forebay to provide sufficient cooling water to provide for an orderly shutdown and to maintain the plant in a safe condition for at least 30 days if the intake canal is isolated from the lake.<sup>J-1</sup>

### J.3.14. Lightning

Lightning is not a concern. The valves and associated control centers and relays are located well within the auxiliary building or the containment structure and are adequately shielded from the threat of a lightning strike.

### J.3.15. Meteorite

The probability of a meteorite impacting a nuclear power plant is negligible.<sup>J-2</sup>

### J.3.16. Missiles

The station was designed so that the Seismic Class I structures would withstand tornado effects. These effects include credible missiles generated by a tornado. An exception to the Class I structures is the Borated Water Storage Tank.<sup>J-1</sup>

A National Guard training center is located 4.5 miles southeast of the site. The training center is immediately adjacent to the east of the industrial park. This training installation is used extensively by the National Guard. The training includes small arms firing and limited firing of 40 mm anti-aircraft ordnance.<sup>J-1</sup>

All Seismic Class I structures are designed and are capable of withstanding an end-on impact of internally generated missiles. All walls and slabs of the B&W reference plant have more than double the thickness required to prevent missile penetrations. This design aspect of the facility prevents spalling of the concrete and generation of secondary missiles.<sup>J-1</sup>

#### J.3.17. Pipeline Accidents

There are no oil or gas pipelines within five miles of the B&W site.<sup>J-1</sup>

#### J.3.18. Seismic

The maximum probable operating basis earthquake (OBE) is 0.08g; the maximum possible safe shutdown earthquake (SSE) is 0.15g.<sup>J-1</sup>

A bounding analysis was performed for this event.

#### J.3.19. Transportation Accidents

Transportation accidents on the adjoining state highway could involve trucks carrying flammables or explosives. The arrangement of the entrance roadways, rail line, and site topography adjacent to this highway is such that it precludes a vehicle from accidentally traveling for any distance onto the site from the highway. A fire or explosion resulting from a truck accident will have no effect on the safety of the station. This is because the distance of the station structures from the highway is 2,600 feet.

The drainage of this portion of the site is away from the site area containing the station structures. The elevation of this area of the site is 6 to 14 feet above the natural site elevation. This topography feature of the site precludes the spread of burning flammables to the station buildings.

No credible highway transportation accident could adversely affect the safety of the station.<sup>J-1</sup>

### J.3.20. Tornado

Tornadoes are common in the state in which the B&W reference plant is located. The probability of a tornado striking a point within the one-degree square in which the site is located is  $6.3E-4$  (per year). The associated recurrence interval is once in approximately 1,590 years.<sup>J-1</sup>

The station was designed so that the Seismic Class I structures would withstand tornado effects. These effects include credible missiles generated by a tornado. The BWST is an exception to this generalization.<sup>J-1</sup>

### J.3.21. Volcanic Activity

Volcanic activity is not possible at the site. There are no active volcanos in the area of the B&W site.

### J.3.22. Wind

The design basis for seismic Class I structures was controlled by tornado loads rather than wind loads.<sup>J-1</sup>

## J.4. Bounding Analysis

An analysis of the external events that contribute to the plant's risk is included in this section. The events that survived the screening analysis are fire, internal flood, and seismic events.

### J.4.1. Analysis of Fire Events

The search for ISLOCA challenges that might result from a fire event is based on two assumptions. First, fires will not affect the structural integrity of the RCS pressure boundary. Second, fires will not cause the operators to mistakenly open a valve that might contribute to an ISLOCA event. The only failure mechanism where fire is postulated to cause an ISLOCA event is by fire induced failures within valve motor control centers, control circuitry, or cabling.



The ISLOCA event trees from Appendix D were used to identify which valves should be included in the bounding analysis. In the makeup and purification event tree, MOV HP-2A could be affected by fire induced failures. Additional non-fire related failures would also be required before an ISLOCA could occur. In the high-pressure injection system ISLOCA event tree, MOVs HP-2B, C, or D could also be affected by fire. Additional non-fire related failures would also have to occur in this case. In the two DHR letdown trees, only DK-11 and DL-12 could be affected, however, the valve motor power supply breakers are racked out, making inadvertent operation of the valves incredible. Finally, the LPI event tree was examined and found to contain no valves that would be affected by a fire.

For the analysis that follows, the makeup and purification interface is used as the model to represent all four of the high-pressure injection interfaces. For a failure of any one of the boundary MOVs (HP-2A, B, C, D) to lead to an ISLOCA challenge, the corresponding pressure isolation check valves would have to fail along with either the HPI/BWST vent line or the pump discharge check valve. Because the failure mechanism for the A-line check valves is failure-to-close on demand (rather than a time based leakage failure) it represents the bounding case for the four lines. Therefore it was used in the present analysis. An event tree modeling the failures associated with a fire induced ISLOCA is shown in Figure J-1. The events shown in Figure J-1 are explained in the following sections.

**IE-F.** This event represents the occurrence of a fire in room 236 (where both HP-2A and its control circuit are located). Previous studies, which used License Event Report (LER) data from the Nuclear Regulatory Commission (NRC), indicate that the overall frequency of fires for nuclear power plants is approximately 0.16 per reactor year on a plant-wide basis<sup>J-3, J-4</sup>. This number was divided by the total number of rooms in the plant (approximately 300) to obtain a per-room frequency of  $5.3E-4$  per reactor year.

**HM1.** This event represents the probability that a fire in room 236 will cause HP-2A to open. A bounding probability of 0.10 is used. A more detailed analysis would require knowledge of fire size and location. It would also require detailed modeling of the controls and cabling, all of which would likely reduce the probability of the valve opening.




Figure J-1. HPI interface event tree for fire induced ISLOCA events.

**HC1.** The probability that check valves HP-57 and HP-59 (treated as a single valve because they are welded together) fail to close when demanded (i.e. when HP-2A opens and makeup flow is diverted) is assumed to be  $1E-3$ . This event was taken from Appendix D. Makeup and purification flow normally keeps these valves open.

**HV1.** This event is modeled the same as for the internal events analysis. Specifically, the possibility that the recirculation line from the HPI pump discharge to the BWST being left open after completion of the pump test is estimated at  $1.3E-3$ .

**HC2.** The probability that check valve HP-23 fails to close on demand is estimate at  $1.0E-3$ , and was taken from Appendix D. This is a demand failure probability because this valve is normally free and not seated unless HP2-A opens.

The above probabilities were used in the event tree shown in Figure J-1. The quantification of this event tree results in an ISLOCA frequency of failure of HP-2A of  $1.2E-10$ /reactor year. Because HP-2B, C, and D, were assumed to provide identical, independent contributions, the total frequency for ISLOCA challenges at the high-pressure injection system interface is then four times this number, or  $4.9E-10$ .

#### J.4.2. Analysis of Internal Flooding

The B&W plant has four rooms where flooding could result in possible damage to the HPI isolation valves and associated equipment. Each room was looked at in detail to identify the possible sources of flooding.

An internal flood can contribute to an ISLOCA event at the high-pressure injection system interface by causing motor operated valves HP-2A, B, C, or D to open. For one of these events to lead to an ISLOCA the corresponding injection check valves would have to fail, and either the pump discharge check valve or the HPI/BWST vent line would have to be left open. The event tree is shown in Figure J-2 for the failures required when HP-2A is affected by internal flood. The events shown in Figure J-2 are explained in the following sections. As for the fire analysis, the flood analysis models only the HP-2A line to estimate the ISLOCA risk from all four injection legs.

IE-IF. Internal flood in room 209 or 236. Room 209 is a corridor located inside the Auxiliary building next to the BWST heater at elevation 565 feet. HP-2C and HP-2D are located in this room with the Motor Control Center for these two valves. A 6-in., 30 psia process steam line to the Borated Water Storage Tank heat exchanger and a 3-in. condensate line from the heat exchanger run through this room. Jet impingement and steam flooding could affect operation of essential MCCs and other equipment. Two inch and smaller piping for the Reactor Coolant Pump (RCP) seal supply water system are also present. The failure of this line could result in jet impingement forces affecting essential equipment.

Room 236, No. 2 mechanical penetration room, is located inside the Auxiliary building adjacent to the containment structure at elevation 565 feet. HP-2A and HP-2B are located in this room along with the Motor Control Center (MCC), transfer switch cabinet, and electrical trays for these valves. A continuous blowout area of 15 ft<sup>2</sup> is provided to prevent a buildup of flood waters. Two 6-in. steam supply lines to the AFW pump turbines in the room could cause steam flooding and jet impingement and possible damage to the MCC and other equipment.




Figure J-2. HPI interface event tree for flood induced ISLOCA events.

Quantification of pipe rupture in these rooms is based on a random pipe break frequency of  $5.0E-11/\text{hr-ft}$ .<sup>J-5</sup> Assuming 100 feet of pipe in each room gives:

$$\text{frequency} = (5.0E-11/\text{hr-ft})(100\text{ft})(8760\text{hr/ry}) = 4.4E-5/\text{ry}$$

**HM1.** The probability that an internal flood in room 236 causes HP-2A to open is estimated at 0.10. This event is described in more detail in the fire analysis.

**HC1.** The probability that check valves HP-57 and HP-59 (treated as a single valve because they are welded together) fail to close when demanded (i.e. when HP-2A opens and makeup flow is diverted) is assumed to be  $1E-3$ . This event was taken from Appendix D. Makeup and purification flow normally keeps these valves open.

**HV1.** This event is modeled the same as for the internal events analysis. Specifically, the possibility that the recirculation line from the HPI pump discharge to the BWST being left open after completion of the pump test is estimated at  $1.3E-3$ .

**HC2.** The probability that check valve HP-23 fails to close on demand is estimate at  $1.0E-3$ , and was taken from Appendix D. This is a demand failure

probability because this valve is normally free and not seated unless HP2-A opens.

The above probabilities were used in the event tree shown in Figure J-2. The quantification of the event tree results in a frequency of  $1.0E-11/Rx-yr$ . This frequency is for ISLOCA challenges resulting from failure of HP-2A. Because HP-2B, C, and D, are assumed to provide identical, independent contributions, the total frequency for ISLOCA challenges at the high-pressure injection system interface is then four times this number, or  $4.0E-11/Rx-yr$ .

#### J.4.3. Analysis of Seismic Events

The seismicity of the site is evaluated on the basis of the Seismic-Risk Map of the United States. This map shows that the site is located within Zone 1. The minimum distance from the site to a Zone 2 boundary is 40 miles and to a Zone 3 boundary, 75 miles.

Zone 1 is described as follows: "Minor damage; distant earthquakes may cause damage to structures with fundamental periods greater than 1.0 seconds; corresponds to intensities V and VI of the MM Scale (Modified Mercalli Intensity Scale of 1931)."

The failure scenario most likely to result in a seismic induced ISLOCA begins with the failure of the open relay in one of the interfacing system MOVs due to relay chatter. The normally-open relay contacts are postulated to close during a seismic event allowing power to be applied to the valve motor and opening the valve.

#### Seismicity and Hazard Curves

The hazard curves used in this analysis were taken from a US NRC sponsored study. This study was performed by the Lawrence Livermore National Laboratory. The curves were taken from the Eastern U.S. Seismic Hazard Characterization Program<sup>J-6</sup>. The use of the LLNL seismic curves in the external event analysis does not imply that other hazard curves are invalid or not appropriate for ISLOCA analysis. Table J-1 contains the numeric values obtained from the hazard curve shown in Figure J-3.




Figure J-3. Seismic hazard curve for the B&W study plant.

Table J-1. Median Hazard Curve Values

PGA Bin (g)	Bin Freq per year	Conditional Probability of Relay Chatter
.10	3.7E-3	0.025
.20	7.4E-4	0.041
.30	1.6E-4	0.14
.40	6.0E-5	0.35
.50	2.0E-5	0.62
.60	9.2E-6	0.82
.70	5.1E-6	0.93
.80	2.3E-6	0.97
.90	1.4E-6	0.99
1.0	8.2E-7	1.00
Total	4.7E-3	

### Relay Fragility Data

The seismic fragility estimate for the relays in the valve motor control centers were developed using generic relay data<sup>1-7</sup> together with cabinet amplification and structural response spectra for the B&W reference plant.

Fragilities were estimated for four types of relays. As a bounding estimate the least rugged of the four types is used in the present analysis. Specifically, the values for socket-type auxiliary relays normally de-energized are given below.

Median	0.42
Beta (R)	0.33
Beta (U)	0.30
HCLPF (g)	0.15

Failure mode: relay chatter in excess of two milliseconds

The probability that the relay failure frequency ( $p_r$ ) exceeds  $p_{r'}$  for an acceleration  $A''$  given the best estimate of the median ground acceleration capacity  $A$  is given by:

$$P(p_r \geq p_{r'} | A'') = \Phi \left[ \frac{\ln(A''/A)}{\beta_U} \right]$$

where:

$\phi$  = standard Gaussian cumulative function  
 $\beta_U$  = uncertainty concerning the ground motion capacity  
 $p_r$  = failure frequency based on the underlying random variable associated with ground acceleration  $A$   
 $p_{r'}$  = given failure frequency value (0.5 in this case)  
 $A''$  = given ground acceleration value.

A seismic event can contribute to an ISLOCA at the HPI interface by causing any of the normally closed MOVs (HP-2A, B, C, or D) to fail open by inducing chatter in the normally-open relay. For an ISLOCA to occur, the corresponding injection check valve would have to fail, and either the pump discharge check valve or the HPI/BWST vent line would have to be left open. The event tree used to model the failures at the HPI interface is shown in Figure J-4.

All four MOV's are treated in an identical fashion, and the total frequency is the sum of the four contributors. The events shown in Figure J-4 are discussed below.

IE-S. Seismic frequency of occurrence obtained by differentiation of the hazard curve shown in Figure J-3. Table J-1 contains the individual




Figure J-4. HPI interface event tree for seismic induced ISLOCA events.

frequencies for each PGA interval. Value on the event tree represents the frequency of an earthquake of any magnitude.

**HM1.** Probability that HP-2A opens as a result of a seismic event. The probability of this event for each PGA interval is shown in Table J-1. The value shown on the event tree is an average, weighted over all seismic bins.

**HC1.** The probability that check valves HP-57 and HP-59 (treated as a single valve because they are welded together) fail to close when demanded (i.e. when HP-2A opens and makeup flow is diverted) is assumed to be  $1E-3$ . This event was taken from Appendix D. Makeup and purification flow normally keeps these valves open.

**HV1.** This event is modeled the same as for the internal events analysis. Specifically, the possibility that the recirculation line from the HPI pump discharge to the BWST being left open after completion of the pump test is estimated at  $1.3E-3$ .

**HC2.** The probability that check valve HP-23 fails to close on demand is estimate at  $1.0E-3$ , and was taken from Appendix D. This is a demand failure probability because this valve is normally free and not seated unless HP2-A opens.

Evaluating sequences 4 and 5 of the event tree shown in Figure J-4 at each PGA shown in Table J-1, and summing over all PGA values results in a



frequency of  $4.5E-10/Rx-yr$ . The total frequency for a seismic induced ISLOCA at the HPI interface is four times this number, or  $1.8E-9/Rx-yr$ .

### J.5. T&W Results

An ISLOCA challenge resulting from external events depends on the probability that MOV failure resulting from the event will, combined with other failures, cause the pressurization of low-pressure rated systems. The screening analysis from Section J.3 excluded from further consideration all external events not likely to be a threat to plant systems. The events retained after screening included fire, internal flood, and seismic. The bounding analysis from Section J.4 then determined the frequency of ISLOCA challenges from each external event.

A fire can contribute to an ISLOCA event at the high pressure injection interface by causing motor operated valves HP-2A, B, C, or D to open. For a failure of one of these events to lead to an ISLOCA challenge, (i.e., pressurization of low-pressure rated piping) the corresponding pressure isolation check valves would have to fail, and either the pump discharge check valve would have to fail. The total fire-induced ISLOCA frequency for the high pressure injection system interface was calculated to be  $4.9E-10/ry$ .

An internal flood can contribute to an ISLOCA event at the high pressure injection system interface by causing motor operated valves HP-2A, B, C, or D to open. The logic used for this calculation was identical to that used in the fire analysis. Only the interpretation of some basic events changed. The resulting ISLOCA frequency is  $4.0E-11$ .

The affect of a seismic event on the ISLOCA challenge frequency was also calculated. The high pressure injection system interface was considered vulnerable to MOV opening as a result of relay chatter. The seismic-induced ISLOCA frequency was calculated to be  $1.8E-9$ .

The overall frequency of an ISLOCA due to external events was obtained by summing the failure frequencies for each event that survived the screening analysis. An upper bound estimate of the total external events initiated ISLOCA frequency is  $2.3E-09$ .

## J.6. References

- J-1. B&W Nuclear Power Station *Updated Safety Analysis Report*.
- J-2. K. A. Solomon et al., *Estimate of the Hazards to a Nuclear Reactor From the Random Impact of Meteorites*, UCLA-ENG-7426, March 1974.
- J-3. M. P. Bohn and J. A. Lambright, *Recommended Procedures for Simplified External Event Risk Analyses*, NUREG/CR-4846, Sandia National Laboratories, Albuquerque, NM, February 1988.
- J-4. M. P. Bohn et al., *NUREG-1150 External Event Risk Analysis Surry Power Station*, NUREG/CR-4550, Rev.1, Vol.3, Part 3, Sandia National Laboratories, Albuquerque, NM, November 1989.
- J-5. S. A. Eide et al., *Generic Component Failure Data Base for Light Water and Liquid Sodium Reactor PRA's*, EGG-SSRE-8875, February 1990.
- J-6. D. L. Bernreuter et al., *Seismic Hazard Characterization of 69 Nuclear Plant Sites East of the Rocky Mountains*, NUREG/CR-5250 Vol.1-8, January 1989.
- J-7. K. K. Bandyopadhyay et al., *Seismic Fragility of Nuclear Power Plant Components (Phase II), Switchgear, I&C Panels (NSSS) and Relays*, NUREG/CR-4659, February 1990.

Appendix K  
Review of Pressure Fragility Calculations

APPENDIX K  
REVIEW OF PRESSURE FRAGILITY CALCULATIONS

As part of the ISLOCA program, a subcontract was negotiated between EG&G Idaho, Inc. and ABB Impell. This subcontract was for the development of the fluid system component pressure fragilities for the reference B&W plant that was used as the model for this study. This work, which is documented in a separate report (D. A. Wesley et al., *Pressure-Dependent Fragilities for Piping Components*, NUREG/CR-5603), was used to calculate the probability of an overpressure ruptures in secondary systems. At the request of Dr. John O'Brien (U.S. NRC/RES), an independent review of the pressure fragility calculation, methodology and results, was performed. This review was conducted by Dr. Everett C. Rodabaugh. The product of that review is contained in this appendix, specifically two letters dated February 2, 1989 and February 17, 1990.

Appendix L  
Uncertainty Analysis

## CONTENTS

L.1	Introduction . . . . .	L-3
L.2	Results . . . . .	L-4
L.3	References . . . . .	L-5

## TABLES

Table L-1.	Uncertainty estimates for the Reference B&W plant PDS frequency (per Rx-yr) . . . . .	L-6
Table L-2.	Uncertainty results for event tree end-states (sequences). . . . .	L-7

## APPENDIX L UNCERTAINTY ANALYSIS

### L.1 Introduction

An uncertainty analysis was performed in order to provide a more complete understanding of the risk attributable to ISLOCAs for the reference B&W plant. This analysis required two calculational steps. The first involved estimating the uncertainty associated with the individual event probabilities. In the second effort, cutsets (Boolean equations) were developed using IRRAS<sup>L-1</sup> for the event trees end-states. IRRAS was used for the uncertainty analysis rather than ETA-II<sup>L-2</sup> because ETA-II does not possess the capability for doing uncertainty analyses. However, ETA-II is much simpler and easier to use when performing point estimate quantification. As a result, the ETA-II software was used for the bulk of the quantification. After the end-state equations were loaded into IRRAS, the individual event uncertainties were then propagated through the logic equations using IRRAS' Latin Hypercube simulation feature. Both failure and success events are included in the logic equations. Because ETA-II generates end-state equations in terms of failure events only, once the equations were loaded into IRRAS the successes were added manually. Two sets of Latin Hypercube simulations were run. The first was performed at the event tree end-state level; the second at the PDS level.

## L.2 Results

Table L-1 presents the uncertainty analysis results generated on the PDS calculations. These calculations were performed on a group level whereby all end-state equations classified with the same PDS were quantified collectively. Table L-2 displays the results of the uncertainty calculations performed on the individual end-state equations.



### L.3 References

- L-1. K. D. Russell et al., *Integrated Reliability and Risk Analysis System (IRRAS) Version 2.5, Volume 1 - Reference Manual*, NUREG/CR-5300, February 1991.
- L-2. Science Applications International Corporation, *ETA-II User's Manual*, November 1987.

Table L-1. Uncertainty estimates for the Reference B&W plant PDS frequency (per Rx-yr)

PDS Name	Mean Median	MinCut Stand. Dev.	5th Perc. 95th Perc.	Minimum Maximum	Seed Size
LK-NCD	1.477E-003 8.941E-004	1.461E-003 2.289E-003	2.823E-004 4.339E-003	7.529E-005 7.618E-002	54321 10000
LOCA-IC	8.214E-008 6.624E-009	2.340E-008 8.440E-007	5.908E-010 1.681E-007	1.104E-011 4.263E-005	54321 10000
OK-OP	1.108E-002 9.348E-003	1.106E-002 7.785E-003	3.966E-003 2.385E-002	1.071E-003 2.994E-001	54321 10000
REL-LG	2.332E-006 4.470E-007	1.294E-006 1.492E-005	4.497E-008 7.031E-006	5.322E-009 6.425E-004	54321 10000
REL-MIT	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000

Table L-2. Uncertainty results for event tree end-states (sequences).

Seq. No.	Event Tree Name Sequence Name	Mean Median	MinCut Stand. Dev.	5th Perc. 95th Perc.	Minimum Maximum	Seed Size
1	HPMU HPMU-03	3.949E-003	3.958E-003	4.907E-004	3.788E-005	54321
		2.458E-003	4.915E-003	1.224E-002	9.111E-002	10000
2	HPMU HPMU-04	3.185E-005	3.191E-005	2.782E-006	3.506E-007	54321
		1.759E-005	4.818E-005	1.046E-004	9.975E-004	10000
3	HPMU HPMU-06	3.185E-005	3.191E-005	2.782E-006	3.506E-007	54321
		1.759E-005	4.818E-005	1.046E-004	9.975E-004	10000
4	HPMU HPMU-07	1.023E-007	3.993E-008	6.136E-010	3.714E-012	54321
		1.534E-008	5.043E-007	3.836E-007	2.223E-005	10000
5	HPMU HPMU-08	6.844E-007	2.795E-007	1.861E-009	1.417E-011	54321
		6.769E-008	4.564E-006	2.427E-006	2.544E-004	10000
6	HPMU HPMU-09	9.400E-006	3.634E-006	5.558E-008	+0.000E+000	54321
		1.394E-006	4.989E-005	3.485E-005	2.733E-003	10000
7	HPMU HPMU-10	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	54321
		+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	10000
8	HPMU HPMU-11	1.906E-008	7.284E-009	7.477E-011	8.477E-013	54321
		2.241E-009	1.615E-007	6.575E-008	1.349E-005	10000
9	HPMU HPMU-12	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	54321
		+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	10000
10	HPMU HPMU-13	5.518E-008	2.198E-008	3.325E-011	1.358E-013	54321
		2.169E-009	5.099E-007	1.492E-007	2.333E-005	10000
11	HPMU HPMU-14	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	54321
		+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	10000
12	HPMU HPMU-15	2.967E-008	1.028E-008	4.420E-011	2.375E-013	54321
		1.867E-009	3.177E-007	8.840E-008	2.286E-005	10000
13	HPMU HPMU-17	5.152E-003	5.152E-003	1.415E-003	3.223E-004	54321
		4.155E-003	3.775E-003	1.223E-002	5.671E-002	10000
14	HPMU HPMU-18	4.143E-005	4.154E-005	7.499E-006	1.216E-006	54321
		2.999E-005	4.070E-005	1.124E-004	8.911E-004	10000
15	HPMU HPMU-19	4.478E-006	4.518E-006	3.179E-007	+0.000E+000	54321
		2.217E-006	7.476E-006	1.521E-005	1.622E-004	10000
16	HPMU HPMU-20	6.679E-007	6.751E-007	2.834E-008	1.526E-009	54321
		2.703E-007	1.420E-006	2.440E-006	4.241E-005	10000

Table L-2. (continued)

Seq. No.	Event Tree Name Sequence Name	Mean Median	MinCut Stand. Dev.	5th Perc. 95th Perc.	Minimum Maximum	Seed Size
17	HPMU HPMU-21	5.198E-010 9.579E-011	5.137E-010 2.319E-009	4.492E-012 1.959E-009	+0.000E+000 9.106E-008	54321 10000
18	HPMU HPMU-22	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
19	HPMU HPMU-23	1.068E-012 1.554E-013	1.029E-012 5.759E-012	6.661E-015 3.757E-012	+0.000E+000 2.634E-010	54321 10000
20	HPMU HPMU-24	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
21	HPMU HPMU-25	3.474E-012 1.518E-013	3.107E-012 4.935E-011	2.664E-015 8.193E-012	+0.000E+000 3.004E-009	54321 10000
22	HPMU HPMU-26	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
23	HPMU HPMU-27	1.596E-012 1.287E-013	1.454E-012 1.967E-011	3.552E-015 5.015E-012	+0.000E+000 1.574E-009	54321 10000
24	HPMU HPMU-28	1.288E-010 1.617E-011	5.198E-011 6.304E-010	5.440E-013 4.722E-010	6.217E-015 2.259E-008	54321 10000
25	HPMU HPMU-29	8.893E-010 7.060E-011	3.639E-010 6.716E-009	1.613E-012 2.850E-009	2.264E-014 4.352E-007	54321 10000
26	HPMU HPMU-30	1.256E-008 1.467E-009	4.731E-009 7.598E-008	5.034E-011 4.464E-008	+0.000E+000 3.426E-006	54321 10000
27	HPMU HPMU-31	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
28	HPMU HPMU-32	2.442E-011 2.348E-012	9.481E-012 1.608E-010	6.261E-014 8.098E-011	4.440E-016 1.016E-008	54321 10000
29	HPMU HPMU-33	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
30	HPMU HPMU-34	8.429E-011 2.315E-012	2.861E-011 1.134E-009	3.241E-014 1.744E-010	+0.000E+000 7.096E-008	54321 10000
31	HPMU HPMU-35	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
32	HPMU HPMU-36	4.195E-011 1.965E-012	1.339E-011 6.258E-010	3.819E-014 1.034E-010	4.440E-016 3.635E-008	54321 10000

Table L-2. (continued)

Seq. No.	Event Tree Name Sequence Name	Mean Median	MinCut Stand. Dev.	5th Perc. 95th Perc.	Minimum Maximum	Seed Size
33	HPMU	8.834E-004	8.800E-004	3.308E-005	1.585E-006	54321
	HPMU-37	3.304E-004	2.306E-003	3.305E-003	1.274E-001	10000
34	HPI	1.515E-003	1.520E-003	5.703E-005	2.434E-006	54321
	HPI-03	5.709E-004	3.501E-003	5.710E-003	1.074E-001	10000
35	HPI	1.511E-008	1.522E-008	2.176E-010	5.278E-012	54321
	HPI-04	3.495E-009	4.959E-008	5.954E-008	1.295E-006	10000
36	HPI	1.021E-007	1.065E-007	6.166E-010	1.090E-011	54321
	HPI-05	1.517E-008	4.637E-007	3.749E-007	1.723E-005	10000
37	HPI	1.398E-006	1.387E-006	1.863E-008	+0.000E+000	54321
	HPI-06	3.241E-007	5.043E-006	5.240E-006	2.473E-004	10000
38	HPI	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	54321
	HPI-07	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	10000
39	HPI	2.719E-009	2.780E-009	2.653E-011	+0.000E+000	54321
	HPI-08	5.124E-010	1.003E-008	1.104E-008	3.241E-007	10000
40	HPI	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	54321
	HPI-09	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	10000
41	HPI	7.681E-009	8.390E-009	1.055E-011	7.460E-014	54321
	HPI-10	5.140E-010	5.520E-008	2.424E-008	2.924E-006	10000
42	HPI	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	54321
	HPI-11	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	10000
43	HPI	1.916E-009	1.960E-009	4.937E-012	5.195E-014	54321
	HPI-12	1.810E-010	1.678E-008	6.499E-009	1.364E-006	10000
44	HPI	1.693E-006	1.721E-006	3.978E-008	+0.000E+000	54321
	HPI-13	5.185E-007	4.585E-006	6.364E-006	1.290E-004	10000
45	HPI	2.521E-007	2.573E-007	3.859E-009	1.748E-010	54321
	HPI-14	6.267E-008	8.440E-007	9.585E-007	3.590E-005	10000
46	HPI	2.373E-010	1.960E-010	7.793E-013	+0.000E+000	54321
	HPI-15	2.159E-011	4.791E-009	6.854E-010	4.659E-007	10000
47	HPI	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	54321
	HPI-16	+0.000E+000	+0.000E+000	+0.000E+000	+0.000E+000	10000
48	HPI	3.775E-013	3.930E-013	1.332E-015	+0.000E+000	54321
	HPI-17	3.597E-014	2.961E-012	1.279E-012	2.303E-010	10000

Table L-2. (continued)

Seq. No.	Event Tree Name Sequence Name	Mean Median	MinCut Stand. Dev.	5th Perc. 95th Perc.	Minimum Maximum	Seed Size
49	HPI HPI-18	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
50	HPI HPI-19	1.214E-012 3.463E-014	1.185E-012 2.835E-011	+0.000E+000 2.744E-012	+0.000E+000 2.730E-009	54321 10000
51	HPI HPI-20	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
52	HPI HPI-21	2.970E-013 1.199E-014	2.771E-013 5.808E-012	+0.000E+000 6.781E-013	+0.000E+000 5.546E-010	54321 10000
53	HPI HPI-22	1.939E-011 3.657E-012	1.981E-011 7.358E-011	1.878E-013 7.812E-011	3.996E-015 2.362E-009	54321 10000
54	HPI HPI-23	1.353E-010 1.594E-011	1.387E-010 7.667E-010	5.342E-013 4.812E-010	9.325E-015 3.553E-008	54321 10000
55	HPI HPI-24	1.754E-009 3.350E-010	1.805E-009 6.226E-009	1.650E-011 7.190E-009	+0.000E+000 1.936E-007	54321 10000
56	HPI HPI-25	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
57	HPI HPI-26	3.417E-012 5.382E-013	3.618E-012 1.451E-011	2.398E-014 1.356E-011	+0.000E+000 6.242E-010	54321 10000
58	HPI HPI-27	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
59	HPI HPI-28	9.287E-012 5.475E-013	1.092E-011 6.738E-011	9.325E-015 2.974E-011	+0.000E+000 3.136E-009	54321 10000
60	HPI HPI-29	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
61	HPI HPI-30	2.345E-012 1.878E-013	2.552E-012 1.884E-011	3.996E-015 7.776E-012	+0.000E+000 1.107E-009	54321 10000
62	DHR-SD DHR-D-02	3.670E-004 1.259E-004	3.623E-004 1.037E-003	8.506E-006 1.414E-003	+0.000E+000 5.751E-002	54321 10000
63	DHR-SD DHR-D-03	2.219E-004 7.703E-005	2.230E-004 5.398E-004	6.828E-006 8.617E-004	1.561E-007 1.435E-002	54321 10000
64	DHR-SD DHR-D-04	7.354E-005 2.234E-005	7.352E-005 2.212E-004	1.664E-006 2.893E-004	+0.000E+000 9.089E-003	54321 10000

Table L-2. (continued)

Seq. No.	Event Tree Name Sequence Name	Mean Median	MinCut Stand. Dev.	5th Perc. 95th Perc.	Minimum Maximum	Seed Size
65	DHR-SD DHR-D-05	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
66	DHR-SD DHR-D-06	5.676E-007 1.097E-007	5.929E-007 2.305E-006	5.351E-005 2.140E-006	1.602E-010 9.578E-005	54321 10000
67	DHR-SD DHR-D-07	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
68	DHR-SD DHR-D-08	4.051E-007 3.519E-008	4.473E-007 2.380E-006	8.517E-010 1.358E-006	7.970E-012 8.067E-005	54321 10000
69	DHR-SD DHR-D-09	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
70	DHR-SD DHR-D-10	1.582E-008 1.598E-009	1.491E-008 1.209E-007	4.931E-011 5.012E-008	4.167E-013 7.124E-006	54321 10000
71	DHR-SU DHR-S-02	1.986E-004 1.254E-004	1.987E-004 2.417E-004	2.583E-005 6.081E-004	3.076E-006 4.704E-003	54321 10000
72	DHR-SU DHR-S-03	5.930E-007 2.335E-007	5.902E-007 1.438E-006	2.422E-008 2.160E-006	1.514E-009 5.834E-005	54321 10000
73	DHR-SU DHR-S-04	7.758E-009 2.666E-009	7.774E-009 2.205E-008	2.353E-010 2.960E-008	1.135E-011 1.079E-006	54321 10000
74	DHR-SU DHR-S-05	6.472E-011 5.513E-012	5.980E-011 5.384E-010	1.481E-013 1.990E-010	9.992E-016 2.857E-008	54321 10000
75	DHR-SU DHR-S-06	5.839E-007 2.332E-007	5.920E-007 1.282E-006	2.452E-008 2.067E-006	9.867E-010 3.399E-005	54321 10000
76	DHR-SU DHR-S-07	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
77	DHR-SU DHR-S-08	6.687E-009 2.316E-009	6.915E-009 1.565E-008	2.088E-010 2.603E-008	+0.000E+000 4.014E-007	54321 10000
78	DHR-SU DHR-S-09	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
79	DHR-SU DHR-S-10	4.475E-010 9.187E-011	4.225E-010 1.954E-009	4.245E-012 1.779E-009	+0.000E+000 8.986E-008	54321 10000
80	DHR-SU DHR-S-11	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000

Table L-2. (continued)

Seq. No.	Event Tree Name Sequence Name	Mean Median	MinCut Stand. Dev.	5th Perc. 95th Perc.	Minimum Maximum	Seed Size
81	DHR-SU DHR-S-12	4.150E-009 1.301E-009	4.050E-009 1.184E-008	1.139E-010 1.609E-008	7.794E-012 4.534E-007	54321 10000
82	DHR-SU DHR-S-13	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
83	DHR-SU DHR-S-14	6.436E-013 4.185E-014	7.790E-013 4.085E-012	8.881E-016 2.130E-012	+0.000E+000 1.865E-010	54321 10000
84	DHR-SU DHR-S-15	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
85	DHR-SU DHR-S-16	2.184E-010 6.301E-011	2.181E-010 6.971E-010	3.365E-012 8.407E-010	+0.000E+000 2.553E-008	54321 10000
86	DHR-SU DHR-S-17	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
87	DHR-SU DHR-S-18	2.765E-011 5.512E-012	2.779E-011 1.475E-010	2.041E-013 1.105E-010	+0.000E+000 1.163E-008	54321 10000
88	DHR-SU DHR-S-19	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
89	DHR-SU DHR-S-20	2.448E-010 7.208E-011	2.459E-010 7.609E-010	4.098E-012 9.421E-010	+0.000E+000 2.591E-008	54321 10000
90	DHR-SU DHR-S-21	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
91	DHR-SU DHR-S-22	5.303E-014 2.997E-015	5.995E-014 4.984E-013	1.110E-016 1.648E-013	+0.000E+000 3.343E-011	54321 10000
92	DHR-SU DHR-S-24	2.870E-007 3.707E-008	2.584E-007 2.385E-006	1.438E-009 9.468E-007	2.135E-011 1.709E-004	54321 10000
93	DHR-SU DHR-S-25	7.588E-010 6.596E-011	7.701E-010 5.404E-009	1.809E-012 2.403E-009	1.720E-014 3.162E-007	54321 10000
94	DHR-SU DHR-S-26	6.860E-012 4.944E-013	7.153E-012 5.252E-011	1.199E-014 2.196E-011	1.110E-016 2.427E-009	54321 10000
95	DHR-SU DHR-S-27	7.923E-014 1.554E-015	7.771E-014 1.335E-012	+0.000E+000 1.543E-013	+0.000E+000 1.065E-010	54321 10000
96	DHR-SU DHR-S-28	7.385E-010 6.610E-011	7.720E-010 5.211E-009	1.876E-012 2.515E-009	2.276E-014 2.756E-007	54321 10000



Table L-2. (continued)

Seq. No.	Event Tree Name Sequence Name	Mean Median	MinCut Stand. Dev.	5th Perc. 95th Perc.	Minimum Maximum	Seed Size
97	DHR-SU DHR-S-29	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
98	DHR-SU DHR-S-30	5.924E-012 3.307E-013	5.007E-012 1.227E-010	6.439E-015 1.566E-011	+0.000E+000 1.153E-008	54321 10000
99	DHR-SU DHR-S-31	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
100	DHR-SU DHR-S-32	1.409E-013 4.329E-015	8.137E-014 6.354E-012	1.110E-016 2.357E-013	+0.000E+000 6.319E-010	54321 10000
101	DHR-SU DHR-S-33	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
102	DHR-SU DHR-S-34	3.701E-012 1.251E-013	2.078E-012 1.361E-010	2.331E-015 6.202E-012	+0.000E+000 1.270E-008	54321 10000
103	DHR-SU DHR-S-35	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
104	DHR-SU DHR-S-36	6.547E-016 +0.000E+000	6.661E-016 1.788E-014	+0.000E+000 1.221E-015	+0.000E+000 1.661E-012	54321 10000
105	DHR-SU DHR-S-37	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
106	DHR-SU DHR-S-38	1.106E-013 6.661E-016	+0.000E+000 1.021E-012	+0.000E+000 3.338E-013	+0.000E+000 6.249E-011	54321 10000
107	DHR-SU DHR-S-39	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
108	DHR-SU DHR-S-40	3.124E-015 +0.000E+000	+0.000E+000 1.470E-013	+0.000E+000 4.551E-015	+0.000E+000 1.462E-011	54321 10000
109	DHR-SU DHR-S-41	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
110	DHR-SU DHR-S-42	6.518E-013 4.507E-014	7.799E-013 5.737E-012	9.992E-016 2.029E-012	+0.000E+000 3.978E-010	54321 10000
111	DHR-SU DHR-S-43	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
112	DHR-SU DHR-S-44	5.523E-017 +0.000E+000	1.110E-016 7.184E-016	+0.000E+000 1.110E-016	+0.000E+000 3.452E-014	54321 10000

Table L-2. (continued)

Seq. No.	Event Tree Name Sequence Name	Mean Median	MinCut Stand. Dev.	5th Perc. 95th Perc.	Minimum Maximum	Seed Size
113	LPI LPI-03	6.567E-006 1.464E-007	1.055E-006 8.042E-005	1.386E-009 1.477E-005	+0.000E+000 5.164E-003	54321 10000
114	LPI LPI-04	5.789E-007 7.612E-009	8.881E-008 1.516E-005	4.685E-011 9.399E-007	+0.000E+000 1.422E-003	54321 10000
115	LPI LPI-05	7.530E-008 8.597E-010	1.555E-008 1.019E-006	5.038E-012 1.312E-007	3.552E-015 5.790E-005	54321 10000
116	LPI LPI-06	1.483E-010 6.661E-014	1.043E-011 1.103E-008	2.220E-016 3.049E-011	+0.000E+000 1.100E-006	54321 10000
117	LPI LPI-07	6.057E-011 8.340E-013	1.043E-011 8.005E-010	6.217E-015 1.092E-010	+0.000E+000 5.235E-008	54321 10000
118	LPI LPI-08	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
119	LPI LPI-09	6.350E-006 1.336E-007	9.756E-007 8.447E-005	1.097E-009 1.348E-005	+0.000E+000 5.180E-003	54321 10000
120	LPI LPI-10	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
121	LPI LPI-11	9.167E-007 1.469E-008	1.694E-007 1.057E-005	1.106E-010 1.913E-006	+0.000E+000 6.557E-004	54321 10000
122	LPI LPI-12	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
123	LPI LPI-13	5.896E-008 6.124E-010	1.156E-008 7.564E-007	3.667E-012 9.655E-008	3.552E-015 4.225E-005	54321 10000
124	LPI LPI-14	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	+0.000E+000 +0.000E+000	54321 10000
125	LPI LPI-15	3.596E-008 1.921E-010	4.062E-009 1.140E-006	1.182E-012 3.441E-008	1.332E-015 1.042E-004	54321 10000

Appendix M

Steam Propagation Analysis for the  
B&W Plant Auxiliary Building

J. A. Schroeder

## CONTENTS

M.1	Analysis Objective . . . . .	6
M.2	Summary of Results . . . . .	6
M.3	Method of Calculation . . . . .	10
M.4	Modeling Data . . . . .	12
M.4.1	RELAP5 Modeling Data . . . . .	12
M.4.1.1	Break Sequence 1 . . . . .	12
M.4.1.2	Break Sequence 2 . . . . .	13
M.4.1.3	Break Sequence 3 . . . . .	13
M.4.1.4	Break Sequence 4 . . . . .	13
M.4.1.5	Break Sequence 5 . . . . .	13
M.4.2	CONTAIN Modeling Data . . . . .	14
M.4.2.1	Compartment Gas Volume Data . . . . .	14
M.4.2.2	Compartment Sump and Drainage Data . . . . .	16
M.4.2.3	Compartment Condensing Surface Data . . . . .	18
M.4.2.4	Flow Path Data . . . . .	19
M.4.2.5	Spray Data . . . . .	23
M.4.3	Material Properties . . . . .	23
M.5	Results . . . . .	24
M.5.1	Break Sequence 1 . . . . .	24
M.5.2	Break Sequence 2 . . . . .	25
M.5.3	Break Sequence 3 . . . . .	26
M.5.4	Break Sequence 4 . . . . .	26
M.5.5	Break Sequence 5 . . . . .	27
M.6	Findings . . . . .	29
M.7	References . . . . .	32

## FIGURES

M-1.	RELAP5/MOD3 Nodalization for the simplified reactor coolant system model. . . . .	33
M-2.	Simplified piping diagram showing the break location for break sequence 1. . . . .	34
M-3.	RELAP5/MOD3 Piping model for break sequence 1. . . . .	35
M-4.	Simplified piping diagram showing the break locations for break sequence 2. . . . .	36
M-5.	RELAP5/MOD3 piping model for break sequence 2. . . . .	37
M-6.	Simplified piping diagram showing break location for break sequence 3. . . . .	38
M-7.	Simplified piping diagram showing break location for break sequence 4. . . . .	39
M-8.	RELAP5/MOD3 piping model for break sequence 3. . . . .	40
M-9.	RELAP5/MOD3 piping model for break sequence 4. . . . .	41
M-10.	Simplified piping diagram showing the break location for break sequence 5. . . . .	42
M-11.	RELAP5/MOD3 piping model for break sequence 5. . . . .	43

M-12. CONTAIN nodalization diagram for the B&W Plant Auxiliary building . . . . .	44
M-13. Reactor coolant system pressure for break sequence 1. . . . .	45
M-14. Reactor coolant system temperature for break sequence 1. . . . .	46
M-15. Mass flow rates to auxiliary building room 236 resulting from break sequence 1. . . . .	47
M-16. Break enthalpy for steam released to auxiliary building room 236. . . . .	48
M-17. Auxiliary building temperatures resulting from a decay heat removal system piping rupture in Room 236 (break sequence 1). The discharge limiting flow area is 0.6013 ft <sup>2</sup> . . . . .	49
M-18. Auxiliary building pool depths resulting from a decay heat removal system piping rupture in Room 236 (break sequence 1). The discharge limiting flow area is 0.6012 ft <sup>2</sup> . . . . .	50
M-19. Reactor coolant system pressure for break sequence 2. . . . .	51
M-20. Reactor coolant system temperature for break sequence 2. . . . .	52
M-21. Auxiliary building break flow for sequence 2. . . . .	53
M-22. Auxiliary building break enthalpy for break sequence 2. . . . .	54
M-23. Auxiliary building temperatures resulting from a decay heat removal system heat exchanger rupture in Room 113 (break sequence 2). The discharge limiting flow area totals 0.0443 ft <sup>2</sup> . . . . .	55
M-24. Auxiliary building pool depths resulting from a rupture in the decay heat removal system heat exchangers in Room 113 (break sequence 2). The discharge limiting flow area is 0.0443 ft <sup>2</sup> . . . . .	56
M-25. Reactor coolant system pressure for break sequence 3. . . . .	57
M-26. Reactor coolant system temperature during break sequence 3. . . . .	58
M-27. Auxiliary building break flow during break sequence 3. . . . .	59
M-28. Auxiliary building break enthalpy during break sequence 3. . . . .	60
M-29. Auxiliary building temperatures resulting from an LPI pump suction piping rupture in Rooms 105 and 113 (break sequence 3). The discharge limiting flow area totals 0.0443 ft <sup>2</sup> . . . . .	61
M-30. Auxiliary building pool depths resulting from an LPI pump suction piping rupture in Rooms 105 and 113 (break sequence 3). The discharge limiting flow area totals 0.0443 ft <sup>2</sup> . . . . .	62
M-31. Reactor coolant system pressure during break sequence 4. . . . .	63
M-32. Reactor coolant system temperature during break sequence 4. . . . .	64
M-33. Mass flow rates to auxiliary building room 113 resulting from break sequence 4. . . . .	65
M-34. Enthalpy of break flow to auxiliary building room 113 resulting from break sequence 4. . . . .	66
M-35. Auxiliary building temperatures resulting from a heat exchanger rupture in room 113 (break sequence 4). The discharge limiting flow area is 0.3821 ft <sup>2</sup> . . . . .	67
M-36. Auxiliary building pool depths resulting from a heat exchanger rupture in room 113 (break sequence 4). The discharge limiting flow area is 0.3821 ft <sup>2</sup> . . . . .	68
M-37. Reactor coolant system pressure plotted against transient time for break sequence 5. . . . .	69
M-38. Reactor coolant system temperature plotted against transient time for break sequence 5. . . . .	70
M-39. Auxiliary building break flows plotted as a function of time for break sequence 5. . . . .	71
M-40. Auxiliary building break enthalpies for break sequence 5. . . . .	72
M-41. Auxiliary building temperatures resulting from an HPI pump suction line rupture (break sequence 5). The discharge limiting flow area is 0.02463 ft <sup>2</sup> . . . . .	73

M-42.	Auxiliary building pool depths resulting from an HPI pump suction line rupture (break sequence 5). The discharge limiting flow area is 0.02463 ft <sup>2</sup> .	74
M-43.	B&W CSAU SBLOCA nominal case primary and secondary pressures plotted against transient time.	75
M-44.	B&W CSAU study SBLOCA nominal case primary loop temperature plotted against transient time.	76
M-45.	B&W CSAU study SBLOCA nominal case break mass flow rate plotted against transient time.	77
M-46.	B&W CSAU SBLOCA nominal case break enthalpy plotted against transient time.	78
M-47.	B&W CSAU study SBLOCA nominal case break void fraction plotted against transient time.	79
M-48.	Reactor coolant system pressure for break sequence 5 compared to the B&W CSAU SBLOCA predictions.	80
M-49.	Simplified reactor coolant system model temperature predictions compared to the B&W CSAU SBLOCA predictions.	81
M-50.	Simplified model break discharge mass flow rate predictions compared to B&W CSAU SBLOCA predictions.	82
M-51.	Simplified RCS model break discharge enthalpy predictions compared to B&W CSAU SBLOCA predictions.	83
M-52.	Auxiliary building temperatures for break sequence 5 that result when using a break discharge from the Oconee SBLOCA study.	84
M-53.	Auxiliary building pool depths resulting from the break discharge from the Oconee SBLOCA study.	85
M-54.	Auxiliary building temperatures for break sequence 5 that result when using a break discharge from the Oconee SBLOCA study. In this case the discharge was adjusted to reflect a dry blowdown after 8 minutes.	86
M-55.	Auxiliary building pool depths resulting from the break discharge from the Oconee SBLOCA study. In this case the break discharge was adjusted to reflect dry steam in the blowdown after 8 minutes.	87
M-56.	Auxiliary building temperatures for break sequence 5, using the Oconee SBLOCA discharge adjusted to a break quality of 1.0 after 8 minutes. This case includes 100,000 lb of metal mass in each compartment.	88
M-57.	Auxiliary building pool depths resulting from the B&W CSAU SBLOCA break discharge adjusted for a steam quality of 1.0. Each compartment includes 100,000 lb of metal mass.	89

#### TABLES

Table M-1.	Summary of plant volumes used in the HELB analysis.	16
Table M-2.	Sprinkler and drain capacities for rooms that drain to the ECCS sump in room 105.	18
Table M-3.	Summary of CONTAIN flow path and flow junction data.	24

## LISTINGS

LISTING 1 - RELAP5 Input for BS-1 . . . . .	90
LISTING 2 - RELAP5 Input for BS-2 . . . . .	99
LISTING 3 - RELAP5 Input for BS-3 . . . . .	111
LISTING 4 - RELAP5 Input for BS-4 . . . . .	123
LISTING 5 - RELAP5 Input for BS-5 . . . . .	132
LISTING 6 - CONTAIN Input for BS-1 . . . . .	141
LISTING 7 - CONTAIN Input for BS-2 . . . . .	154
LISTING 8 - CONTAIN Input for BS-3 . . . . .	198
LISTING 9 - CONTAIN Input for BS-4 . . . . .	217
LISTING 10 - CONTAIN Input for BS-5 . . . . .	232
LISTING 11 - CONTAIN Input for BS-5a . . . . .	253
LISTING 12 - CONTAIN Input for BS-5b . . . . .	261
LISTING 13 - CONTAIN Input for BS-5c . . . . .	269
LISTING 14 - CONTAIN Input for BS-5d . . . . .	278
LISTING 15 - CONTAIN Input for BS-5e . . . . .	287
LISTING 16 - CONTAIN Input for BS-5f . . . . .	296

APPENDIX M  
STEAM PROPAGATION CALCULATIONS  
FOR THE  
B&W PLANT AUXILIARY BUILDING

M.1 Analysis Objective

The objective of this calculation is to determine the environmental conditions in the B&W reference plant's auxiliary building during an interfacing system loss-of-coolant accident (ISLOCA). The parameters of interest are the pressure, temperature, relative humidity, and water level in affected emergency core cooling system (ECCS) equipment rooms. This data will be used, in a separate analysis, to determine the extent to which equipment in compartments adjacent to the break compartment fails from high temperature or submergence, and to determine the extent to which operator recovery actions will be limited by the steam and water that propagates through the auxiliary building.

M.2 Summary of Results

Five break sequences and three sensitivity cases were evaluated using a combination of RELAP5 and CONTAIN models (References 1 and 2). The five sequences involved breaks in different locations within the decay heat removal/low pressure injection (DHR/LPI) system and the high pressure injection (HPI) system, each sequence is described below.

- 1) The plant is operating at rated power and normal operating temperature and pressure. Isolation of the DHR letdown line fails, causing pressurization of the DHR system, which results in rupture of a 12-inch line and discharge into auxiliary building room 236.
- 2) The plant is operating at rated power and normal operating temperature and pressure. Isolation of the DHR letdown line fails, causing pressurization of the DHR system, which results in simultaneous rupture in both decay heat removal heat exchangers and discharge to room 113. The limiting flow area is in the 2.5-inch bypass lines around valves DH-1517 and DH-1518.
- 3) The plant is operating at rated power and normal operating temperature and pressure. Isolation of the DHR letdown line fails, causing pressurization of the DHR system, which results in simultaneous rupture in the low-pressure decay heat removal pump suction piping, resulting in discharge to both rooms 105 and 113.



The limiting flow area is in the 2.5-inch bypass lines around valves DH-1517 and DH-1518.

- 4) The plant is operating at rated power and normal operating temperature and pressure. The check valve isolation on the injection side of the LPI system fails, resulting in a rupture at the 1-2 decay heat cooler with discharge into room 113.
- 5) The plant is operating at rated power and normal operating temperature and pressure. The high pressure injection (HPI) discharge isolation check valves fail, resulting in a rupture in the suction piping to HPI pump 1-2 and discharge into room 115.

In order to evaluate the effects simple models and code uncertainties might have on the results, three sensitivity studies were performed for the last sequence. These sensitivity studies are further described on page M-9. The first sensitivity used a break discharge table from a best estimate Oconee small break loss-of-coolant accident (SBLOCA) analysis<sup>a</sup>. The second also used the Oconee discharge table, but the discharge steam quality was forced to 1.0. The third added metal masses to each compartment until a noticeable variation in the results was obtained.

Simplified RELAP5 models of the B&W reference plant were used as the bases for calculating the break flow rates and the enthalpies for each of the break sequences. The large break calculations (sequences 1 and 4) were generally representative with respect to break mass flow rates. These calculations may have resulted in a faster primary system cooldown than would be expected from more detailed calculations. If this is true the result is that the enthalpies are slightly lower than what a best estimate calculation would predict. The small breaks (sequences 2, 3, and 5) were more difficult to represent with simple models and clearly over-predicted the RCS pressures. The simple primary system RELAP5 models fail to account for the secondary system behavior and operator actions. The result is that the RCS pressure predictions are much higher than calculated in a recent best estimate study of a B&W plant's response to SBLOCAs.<sup>a</sup> The resulting enthalpy of the discharge

---

a. The results of the Oconee SBLOCA study will eventually be published. This work was sponsored by the USNRC and a draft report, *Code Scaling, Applicability, and Uncertainty Study of RELAP5/MOD3 Applied to a B&W SBLOCA Scenario*, has been distributed for review under EG&G letter number MGO-73-91, dated November 25, 1991. The break discharge data used in this report was obtained directly from the report authors, and does not all appear in the aforementioned draft report.

and mass flow rates, being dependent on system pressure, are likewise too high for most of the transient. These inaccuracies in the small break calculations were shown to have negligible impact on the calculated auxiliary building parameters.

The CONTAIN code predicted no significant pressurization (less than one psig) of the auxiliary building as a result of any of the break sequences evaluated. This lack of pressurization is a result of the large flow areas available along flow paths between the break area and the outside atmosphere. A more detailed modeling of the balance-of-plant in the CONTAIN model would produce higher pressure predictions. The detailed modeling effort was judged as unworthy because the increased modeling effort would not have a significant effect on the calculated room temperatures. The room temperature is the critical equipment qualification parameter that would be affected by pressure.

CONTAIN predicted temperatures of 212°F or less in the ECCS equipment rooms for prolonged portions of the ISLOCA for all of the break sequences addressed here. Given that the pressure calculation is reasonably certain, uncertainty in the temperature calculation is driven by the uncertainty in the break discharge enthalpy. If the break discharge enthalpy is less than 1150 Btu/lb the thermodynamics of the blowdown require the discharge temperature to be equal to the saturation temperature for the compartment pressure. If the break discharge enthalpy is higher than 1150 Btu/lb (assuming approximately atmospheric pressure in the auxiliary building), superheat can appear in the blowdown compartment. The results obtained in this analysis all indicate the discharge enthalpy is less than 1150 Btu/lb, however, this value is approached quite closely.

The relative humidity predictions were similar in each sequence. All the auxiliary building rooms that were evaluated experienced periods of 100% relative humidity.

The rate of flooding varied considerably between the sequences. In the sequences with large breaks (sequences 1 and 4), flooding propagated from one compartment to the next. The flood propagated through pipe chases and over flood walls. The result was flooding of ECCS equipment in rooms initially isolated from the break location. In these sequences flooding led to ECCS

equipment submergence in 20-30 minutes. The flood propagation was the result of the dispersal of the unflashed portion of the break discharge. Sump pump operation is insignificant in these sequences.

In the sequences with small breaks (sequences 2, 3, and 5), flooding was minimal. The primary reason is that the discharge from the break was small and much of the discharge flashed to steam. The steam was then carried throughout the building. The steam was released to the atmosphere through blowouts or was condensed well away from the break location. Additionally, the sump pumps, had they been included in the model, would have further slowed pool growth and delayed the threat to ECCS equipment operation. The flooding is primarily the result of firewater discharging from the sprinkler systems and its draining into the ECCS compartment.

The three sensitivity studies were performed to estimate the effect of using relatively simple models and of uncertainties in the codes. Specifically, the following issues were examined in the sensitivity studies:

- 1) The sensitivity of the auxiliary building results to refined reactor coolant system discharge data was determined by making additional CONTAIN runs using break discharge data from the aforementioned Oconee SBLOCA study.
- 2) The sensitivity of the auxiliary building results to high enthalpy (dry) steam in the break discharge was determined by making additional CONTAIN runs with the break discharge data from the aforementioned Oconee SBLOCA study adjusted to a quality of 1.0.
- 3) The sensitivity of the auxiliary building results to neglecting compartment metal masses was determined by making additional CONTAIN runs with large metal masses added to the model.

The first sensitivity study showed that the rate of flooding was significantly different when the break discharge data from the Oconee best-estimate SBLOCA study were used. For the small break ISLOCA evaluated, the flooding rate remained small even with the Oconee data. The flooding rate was driven by the firewater release and not break discharge. As a result, an improvement in the small break primary system RELAP5 model would not produce significantly different auxiliary building environmental conditions.

The second sensitivity study showed that the auxiliary building temperature response is relatively insensitive to variations in the discharge enthalpy. This is true as long as the blowdown remained a wet two-phase mixture with the discharge enthalpy below 1150 Btu/lb. The auxiliary building temperatures did not exceed 212°F in these cases. However, when the blowdown mixture dried (steam quality of 1.0), the temperatures in the auxiliary building approached 276°F. This sensitivity study was based on the Oconee SBLOCA discharge results. It is postulated that the break discharge may approach dryout very near the onset of core damage.

The last sensitivity showed that including metal masses of up to 100,000 lb per compartment had a negligible impact on compartment temperatures and flooding.

### M.3 Method of Calculation

The calculation of auxiliary building pressures, temperatures, and water levels depends on the steam flow rate into the building, the steam energy, the volume of the auxiliary building, the flow paths through the building, and the rate of heat removal by condensation of steam on structural materials and equipment, and fire sprays. The steam flow rate and energy into the building was calculated with the simple RELAP5 models of the RCS. The resulting steam source data were used as boundary conditions. The boundary conditions were then applied to the CONTAIN calculations to predict the auxiliary building's response to the ISLOCA's break discharge.

The RELAP5 models treated the RCS as five volumes; cold leg, lower plenum, core, upper plenum, and hot leg. The decay heat was modeled with a best estimate Oconee core model normalized to the B&W reference plant operating power level. ECCS injection was included using pressure dependent flow tables. The pressure losses between the RCS and the break location were estimated by including detailed models of the piping run. The purpose of this approach was to obtain a first order approximation of RCS behavior on the premise that the auxiliary building response to the ISLOCA is not strongly dependent on the RCS behavior.

The CONTAIN computer code was used to calculate the time response of the auxiliary building parameters. The CONTAIN software is a containment modeling code that has adequate steam condensing heat transfer models for the scenarios of interest. The software also provides adequate engineered system models that allow modeling of fire sprays, compartment sumps, and drainage paths among compartments. The approach used in this calculation was to construct detailed CONTAIN models of compartments with ECCS equipment that might be affected by the ISLOCA. These compartments were auxiliary building rooms 105, 113, 115, and 236. The rest of the auxiliary building (sometimes referred to as balance-of-plant) was then treated as a boundary condition for the detailed portion of the model.

CONTAIN required, as input, the gas volume of each compartment, the area and flow loss characteristics of flow paths between each compartment, and a description of heat transfer surfaces within each compartment. CONTAIN also required a description of drainage paths among compartments. The code tracked the pool depths in each compartment. These pools resulted from both condensation of steam and drainage of fire sprays or condensate from adjacent rooms. This flood propagation is an important aspect of the larger break sequences, because the high break discharge flow rate will quickly fill the compartment sumps. This phenomena will allow flooding of the lower or adjacent compartments to occur. Only one compartment in this analysis (room 236) has fire sprays. Since the fire sprays can be expected to trip early in the break sequence, aggravating the flooding problem, they were included in the model.

The compartment sump pumps, the fan coolers, and pump heat were excluded from the model. The sump pumps were excluded because they do not have adequate capacity to remove the break discharge and condensate. Also, extended periods of firewater discharge can exceed the capacity of the sumps. In the small break sequences where the combined accumulation of water from these sources was close to the sump pump capacity, the impact of sump pump operation was evaluated qualitatively. The pump heat was neglected because it would be removed by the fan coolers, and the fan coolers were not modeled because a large fraction of the cooler's capacity would be used to remove pump heat.

## M.4 Modeling Data

The modeling data required for this analysis consisted of both RELAP5 and CONTAIN input data. The RELAP5 data described the RCS and attached interfacing system piping between the RCS and the break location. The CONTAIN modeling data described the auxiliary building. The RELAP5 data describing the RCS was taken from Reference 3. This simplified RCS model was combined with piping models described in Reference 4 for each break sequence. The CONTAIN data was extracted from the B&W reference plant HELB analysis (References 5 and 6).

### M.4.1 RELAP5 Modeling Data

The RELAP5 RCS model for each sequence combines the RCS volumes shown in Figure M-1 with the detailed piping models shown in Figures M-3, M-5, M-8, M-9 and M-11. The fluid volume data for the RCS portion of the model included the reactor vessel volume, the loop volume, and the pressurizer volume. The fluid available for injection consisted of the CFT and BWST volumes. A simple control model kept track of the water injected into the RCS through the injection flow table. When the contents of the BWST were completely injected, the transient was considered over, as core damage could result thereafter. The total water inventory available for discharge into the auxiliary building is summarized as follows:

Loop Volume (one loop)	= 3,025 ft <sup>3</sup>
Pressurizer volume	= 1,542 ft <sup>3</sup>
Vessel volume	= 3,797 ft <sup>3</sup>
CFT volume (combined)	= 2,080 ft <sup>3</sup>
BWST volume	= 64,550 ft <sup>3</sup>

The following describes the specific break sequence RCS models.

**M.4.1.1 Break Sequence 1.** Break Sequence 1 (BS-1) is a rupture in the decay heat removal system piping between DH-11 and the piping separation to valves DH-1518 and DH-1517. The break is located in auxiliary building room

236 and does not disable LPI. A simplified drawing showing the flow path between the RCS and the break is shown in Figure M-2. Figure M-3 shows the piping model combined with the RCS model in Figure M-1. This information was used to obtain the RELAP5 model for calculation of the room 236 source term. A input listing of the RELAP5 model is provided by Listing 1.

**M.4.1.2 Break Sequence 2.** Break Sequence 2 (BS-2) is a rupture in decay heat coolers 1-2 and 1-1. The breaks are located in room 113 and are assumed to fail LPI. A simplified drawing of the flow path between the RCS and the break is shown in Figure M-4. Figure M-5 shows the piping model combined with the RCS model. All dead legs, and flow paths associated only with system relief valves have been eliminated from the model to improve computational efficiency. Piping downstream of the 2.5 inch diameter choke plane in the DH-1517 and DH-1518 bypass piping has been included in the model, although, on review of the results, it could have been eliminated. The RELAP5 listing for the combined model is provided in Listing 2.

**M.4.1.3 Break Sequence 3.** Break Sequence 3 (BS-3) is a rupture in the suction lines to the DHR pumps 1-2 and 1-1. The breaks are located in rooms 105 and 113 as shown in Figure M-6. Since the break occurs on the path between the BWST and the LPI pumps, the LPI system is assumed to fail. The RELAP5 piping model combined with the RCS model in Figure M-1 is shown in Figure M-8. The combined RELAP5 listing is provided in Listing 3.

**M.4.1.4 Break Sequence 4.** Break Sequence 4 (BS-4) is a rupture in DHR cooler 1-2. The break is located in room 113 and is assumed to disable one train of LPI. This sequence involves backflow from the RCS through the decay heat cooler discharge piping as shown in Figure M-7. The piping nodalization for this sequence is shown in Figure M-9. The RELAP5 input listing is provided in Listing 4.

**M.4.1.5 Break Sequence 5.** Break Sequence 5 (BS-5) is a rupture in the HPI pump 1-2 suction piping. The break is located in room 115 and is assumed to disable only one train of HPI. This sequence involves backflow from the

RCS through the HPI 1-2 discharge piping as shown in Figure M-10. The nodalization diagram for the piping portion of the model is shown in Figure M-10. The RELAP5 listing is provided in Listing 5.

#### M.4.2 CONTAIN Modeling Data

The CONTAIN model used in this analysis consists of five volumes representing the auxiliary building and a sixth volume representing the environment. Figure M-12 shows the CONTAIN nodalization diagram for the model. Auxiliary building rooms 105, 113, 115, and 236 are modeled as separate compartments while the rest of the auxiliary building (including turbine building and containment annulus) is treated as a single compartment. Each compartment includes a sump volume. This volume is determined by the maximum height a pool forming on the floor could reach before a flow path to another compartment is found. The nodalization diagram shows the vapor flow paths connecting each compartment. Each flow path represents an opening such as a pipe chase or doorway. For simplicity, the CONTAIN model includes only one junction between each volume. The multiple flowpaths shown in Figure M-12 were combined to form junctions. Each of the auxiliary building rooms modeled, with the exception of the balance-of-plant, include heat structures representing the concrete in walls, floor, and ceiling. The metal mass in each compartment is neglected. The influence of the compartment's metal mass was investigated through separate sensitivity calculations.

Water aerosol data was not developed because impingement of the break discharge on surfaces within each break compartment is expected to remove most suspended moisture from the atmosphere at the release point.

**M.4.2.1 Compartment Gas Volume Data.** The essential volume information includes the floor elevation in each room, the distance from floor to ceiling, the total floor area, and the total free volume. The volume of a given compartment is not always the product of the floor area and compartment height. Sometimes the HELB analysis (Reference 5) from which the following data were extracted included a reduction factor to eliminate from the gas volume that volume occupied by piping and equipment. Where Reference 5 applied reduction factors, they are included in the following data.



Room 105.

Floor elevation	= 545 ft	= 166. m	(Ref 7)
Ceiling height	= 18 ft	= 5.49 m	(Ref 5, pg. 54)
Total floor area	= 3180 ft <sup>2</sup>	= 295. m <sup>2</sup>	(Ref 5, pg. 54)
Free volume	= 40068 ft <sup>3</sup>	= 1134 m <sup>3</sup>	(Ref 5, pg. 54)

Room 113.

Floor elevation	= 545 ft	= 166. m	(Ref 7)
Ceiling Height	= 18 ft	= 5.49 m	(Ref 5, pg. 57)
Total floor area	= 930 ft <sup>2</sup>	= 86.4 m <sup>2</sup>	(Ref 5, pg. 57)
Free volume	= 13400 ft <sup>3</sup>	= 379. m <sup>3</sup>	(Ref 5, pg. 57)

Room 115.

Floor elevation	= 545 ft	= 166. m	(Ref 7)
Ceiling Height	= 18 ft	= 5.49 m	(Ref 5, pg. 61)
Total floor area	= 1150 ft <sup>2</sup>	= 107. m <sup>2</sup>	(Ref 5, pg. 61)
Free volume	= 18600 ft <sup>3</sup>	= 526. m <sup>3</sup>	(Ref 5, pg. 61)

Room 236.

Floor elevation	= 565 ft	= 172. m	(Ref 7)
Ceiling Height	= 18 ft	= 5.49 m	(Ref 5, pg. 82)
Total floor area	= 990 ft <sup>2</sup>	= 92.0 m <sup>2</sup>	(Ref 5, pg. 82)
Free volume	= 8910 ft <sup>3</sup>	= 252. m <sup>3</sup>	(Ref 5, pg. 82)

Balance-of-Plant. The volume of the auxiliary building can be broken down as shown in Table M-1 (Reference 6). Table M-1 does not include the entire auxiliary building. It includes only the rooms affected by a HELB in room 235 as determined in Reference 5. These are the appropriate volumes for the five break sequences considered in this analysis. The total floor area is not readily available so

Table M-1. Summary of plant volumes used in the HELB analysis.

Room	Volume (ft <sup>3</sup> )	Volume (m <sup>3</sup> )
225	3,100	88
208	23,300	659
236	20,000	566
Containment Annulus	465,000	13,160
303	35,100	993
Turbine building	5,810,000	164,400
314	22,900	648
501	28,000	792
427	19,500	552
100	13,600	348
105	40,100	1,134
113	13,400	379
500	40,800	1,155
115	18,600	526
515	36,100	1,022
237	6,610	187
238	8,930	253
Sum =>	6,592,000	186,555

Floor elevation = 545 ft = 166. m (Ref 7)  
 Ceiling Height = 127.2 ft = 38.8 m  
 Free volume = 6.59E6 ft<sup>3</sup> = 1.87E5 m<sup>3</sup>  
 Total floor area = Volume/height  
 Total floor area = 51800 ft<sup>2</sup> = 4814. m<sup>2</sup>

**M.4.2.2 Compartment Sump and Drainage Data.** The CONTAIN lower cell model includes the floor concrete mass and pool description. Water sprayed or condensed into each compartment will collect on the compartment floor and drain to collection sumps. Each sump is equipped with level-actuated pumps. If the condensation rate is small, water will not collect on the floor surface until the pumps fail and the sump is filled. Because the condensation rate is initially unknown, the calculation was run without condensate removal. In this case the sump area included in the model is the floor area of the compartment. Note that firespray and condensate from the rest of the auxiliary building is not included in the calculation. This is a modeling

weakness that could be significant in the small break sequences since many rooms in the auxiliary building drain to the ECCS sump in room 105. This is of particular concern for the rooms containing sprinkler systems that could be triggered by the presence of steam. To show the size of the neglected water source, Table M-2 summarizes the sprinkler discharge capacities and floor drainage capacities available in rooms in the auxiliary building, that drain to ECCS sump 1-1 (located in room 105).

Room 105. If water overflows the sump in this compartment, drainage into room 100 is possible. Room 105 is separated from room 100 by fire doors that are not water tight and will not stand up to pressure differentials greater than 1 psid. The maximum water depth these doors can support is about 5.7 feet. The ECCS sump 1-1 is located in this room and has a total sump discharge capacity of 183 gpm. This sump also collects water from a large number of rooms not included in the model.

Floor surface area= 3180. ft<sup>2</sup> = 295. m<sup>2</sup> (Ref 5, pg. 54)  
Floor thickness = 2.00 ft = .610 m (Ref 5, pg. E2)  
Maximum pool depth= 0.50 ft = .15 m (Ref 7)  
Concrete mass = (295 m<sup>2</sup>)(.610 m)(240 kg/m<sup>3</sup>) = 43,188. kg

Room 113. This room includes the ECCS sump 1-3 with discharge capacity of 183 gpm.

Floor surface area= 930. ft<sup>2</sup> = 86.4 m<sup>2</sup> (Ref 5, pg. E3)  
Floor thickness = 3.00 ft = .914 m (Ref 5, pg. E3)  
Maximum pool depth= 10.0 ft = 3.05 m (Ref 7)  
Concrete mass = (86.4 m<sup>2</sup>)(.914 m)(240 kg/m<sup>3</sup>) = 18,953. kg

Room 115. This room includes ECCS sump 1-2 which has a discharge capacity of 150 gpm.

Floor surface area= 1150. ft<sup>2</sup> = 107. m<sup>2</sup> (Ref 5, pg. E4)  
Floor thickness = 3.00 ft = .914 m (Ref 5, pg. E4)  
Maximum pool depth= 10.0 ft = 3.05 m (Ref 7)  
Concrete mass = (107 m<sup>2</sup>)(.914 m)(240 kg/m<sup>3</sup>) = 23,472. kg

Table M-2. Sprinkler and drain capacities for rooms that drain to the ECCS sump in room 105.

Room Number	Sprinkler Capacity (gpm)	Drain Capacity (gpm)
208/202	594	364
303	594	364
501	900	364
207/209	240	364
304	348	546
405	60	182

Room 236. The floor thickness is two feet. Half of this floor mass is assigned to the ceiling of the compartment below. This room has a floor drain capable of discharging 182 gpm to the Miscellaneous Waste Drain Tank. This drain is normally isolated by a spring loaded wafer check valve that opens when the water depth reaches 1 inch. Since it would be difficult to accurately split the flow between the Miscellaneous Waste Drain Tank and the pipe chase to room 115 below, the pipe chase is assumed to drain all fire spray, condensate, and break discharge into room 115.

Floor surface area = 990. ft<sup>2</sup> = 91.9 m<sup>2</sup> (Ref 5, pg. 82)

Floor thickness = 1.00 ft = .305 m (Ref 5, pg. E4)

Maximum pool depth = 0.08 ft = .025 m

Concrete mass = (91.9 m<sup>2</sup>)(.305 m)(240 kg/m<sup>3</sup>) = 6,727. kg

**M.4.2.3 Compartment Condensing Surface Data.** The heat sinks available for steam condensing in each compartment were taken from the Reference 5. The reference plant data did not include metal mass. In the following data the floor was not included as a heat sink because CONTAIN divides each compartment into an upper and lower cell volume. The upper cell volume includes the compartment gas volume and heat structures affecting the gas volume. The lower cell includes the sump volume, and any debris or heat structures that would affect heat transfer into the sump water volume. For this reason the wall, ceiling, and equipment heat sinks (if any) are described in this section, and the sump parameters in the preceding section.

Room 105.

Wall surface area	= 3213. ft <sup>2</sup> = 298. m <sup>2</sup>	(Ref 5, pg. E2)
Wall thickness	= 2.30 ft = .701 m	(Ref 5, pg. E2)
Ceiling area	= 3180. ft <sup>2</sup> = 295. m <sup>2</sup>	(Ref 5, pg. E2)
Ceiling thickness	= 3.00 ft = .914 m	(Ref 5, pg. E2)

Room 113.

Wall surface area	= 2736. ft <sup>2</sup> = 254. m <sup>2</sup>	(Ref 5, pg. E3)
Wall thickness	= 2.60 ft = .792 m	(Ref 5, pg. E3)
Ceiling area	= 930. ft <sup>2</sup> = 86.4 m <sup>2</sup>	(Ref 5, pg. E3)
Ceiling thickness	= 2.00 ft = .610 m	(Ref 5, pg. E3)

Room 115.

Wall surface area	= 2592. ft <sup>2</sup> = 241. m <sup>2</sup>	(Ref 5, pg. E4)
Wall thickness	= 2.00 ft = .610 m	(Ref 5, pg. E4)
Ceiling area	= 1150. ft <sup>2</sup> = 107. m <sup>2</sup>	(Ref 5, pg. E4)
Ceiling thickness	= 2.00 ft = .610 m	(Ref 5, pg. E4)

Room 236. Reference 5 did not include heat structure data sheets for room 236. The heat structure data for this compartment is based on a RELAP4 input deck used in the HELB analysis (Reference 6). Therefore the breakdown between wall, ceiling, and floor surface areas is not known. The entire surface described in Reference 6 is assumed to be wall surface.

Wall surface area	= 4840 ft <sup>2</sup> = 450. m <sup>2</sup>	(Ref 6)
Wall thickness	= 0.50 ft = .152 m	(Ref 6)

**M.4.2.4 Flow Path Data.** The compartments in the auxiliary building are connected by a variety of doorways, pipe tunnels, and ventilation paths. The pipe chases are always open in the compartments of interest, while the doors, if closed, have a relatively low pressure capacity. Blowout panels are also present in some compartments. The input required to describe a flow path

consists of the path area, the ratio of area to flow length, the turbulent flow coefficient, and optionally, the elevation of each end of the flow junction. A further simplification used in the following is to include only one path between any two compartments. In the following each flow path is described, then the flow paths are combined, and the combined flow path is referred to as a flow junction. All of the modeling parameters are readily available in Reference 5 except the flow coefficient. The flow coefficient value will be 1.0 in the model, flow areas, A/L, and elevations are representative of the plant geometry. Detailed evaluation of specific flow paths resulted in flow coefficients from .7 to .9. Because of the difficulty of modeling the effect of partial flow path blockage (as occurs in pipe chases) more detailed flow coefficient calculations were not performed.

Path 1. The double doors (82"x84") connecting room 105 to room 100. These doors are normally closed but will fail at a differential pressure of 1.0 psid. These doors provide a horizontal connection between 100 and 105 at floor level (el. 545 ft). The thickness of the wall (L) at this level is 2 feet.

Flow area	= 48.0 ft <sup>2</sup>	= 4.46 m <sup>2</sup>	(Ref 5, pg. 52)
Elevation	= 548.5 ft	= 167. m	(Ref 7)
A/L	= 24.0 ft	= 7.32 m	

Path 2. Path 2 is a pipe chase that connects room 105 to room 208. This pipe chase provides a vertical connection with the BOP at elevation 565 ft. Reference 5 indicates that the pipe chase opening is 8' x 8', but that it is assumed to be 40% blocked by the piping that runs through the opening. The Ceiling is 3 feet thick

Flow area	= 38.0 ft <sup>2</sup>	= 3.53 m <sup>2</sup>	(Ref 5, pg. 55)
Elevation	= 565. ft	= 172. m	(Ref 7)
A/L	= 38/3 ft	= 3.86 m	

Path 3. Path 3 is the pipe chase connecting room 105 to room 225. This pipe chase provides a vertical connection at elevation 565 ft. Reference 5 indicates that the pipe chase opening is 4' x 4', but that it is assumed to be 40% blocked by the piping that runs through the opening. The ceiling is 3 feet thick.

Flow area	= 9.60 ft <sup>2</sup>	= .892 m <sup>2</sup>	(Ref 5, pg. 55)
Elevation	= 565. ft	= 172. m	(Ref 7)
A/L	= 9.6/3 ft	= .975 m	

Path 4. The open door and pipe chase connecting room 105 to room 113 is path 4. The pipe chase is 16' x 12' and 40% blocked by piping. The door is 7x3 ft. The total area is then 136 ft<sup>2</sup>. The wall is 2 feet thick, the center of the door is at elevation 545 + 10 + 7/2 = 558 feet.

Flow area	= 136. ft <sup>2</sup>	= 12.6 m <sup>2</sup>	(Ref 5, pg. 55)
Elevation	= 558. ft	= 170. m	(Ref 7)
A/L	= 136/2 ft	= 20.7 m	

Path 5. The pipe chase connecting room 113 to room 225 is path 5. This pipe chase provides a 4' x 4' vertical connection to room 225. As with the other chases, the opening is assumed to be 40 % blocked. The ceiling is 2 feet thick (p. E-3 of Ref. 5).

Flow area	= 9.60 ft <sup>2</sup>	= .892 m <sup>2</sup>	(Ref 5, pg. 58)
Elevation	= 565 ft	= 172. m	(Ref 7)
A/L	= 9.6/2 ft	= 1.46 m	

Path 6. The 3' x 7' door connecting room 113 to room 115 is path 6. The elevation is 545 + 10 + 7/2 = 558 feet. The wall is two feet thick.

Flow area	= 21.0 ft <sup>2</sup>	= 1.95 m <sup>2</sup>	(Ref 5, pg. 58)
Elevation	= 558. ft	= 170. m	(Ref 7)
A/L	= 21/2 ft	= 3.2 m	

Path 7. Path 7 is the single closed door connecting room 115 to room 114. The door is 3' x 7' and has a blowout pressure of 1.7 psig. The doors provide a horizontal connection at level 558 ft (assumes a 10 foot flood wall).

Flow area	= 21.0 ft <sup>2</sup>	= 1.95 m <sup>2</sup>	(Ref 5, pg. 59)
Elevation	= 558. ft	= 170. m	(Ref 7)
A/L	= 10.5 ft	= 3.20 m	

Path 8. The 9' x 6' pipe chase that connects room 115 to room 236 is path 8. This pipe chase is about 40% blocked by piping.

Flow area	= 32.0 ft <sup>2</sup>	= 2.97 m <sup>2</sup>	(Ref 5, pg. 61)
Elevation	= 565. ft	= 172. m	(Ref 7)
A/L	= 32/2 ft	= 4.88 m	

Path 9. This flow path connects room 236 to the turbine building through blowout panels. The panels are normally closed but open when differential pressure reaches 0.5 psig. The blowouts are assumed to occur at floor level plus two feet. The wall is two feet thick.

Flow area	= 250. ft <sup>2</sup>	= 23.2 m <sup>2</sup>	(Ref 5, pg. 83)
Elevation	= 567. ft	= 173. m	(Ref 7)
A/L	= 250/2 ft	= 38.1 m	

Path 10. Flow path 10 is a 15 ft<sup>2</sup> blowout panel connecting room 236 to room 235. The blowout direction appears to be from room 235 to room 236. The panels open at a pressure of 1.0 psig. It is assumed the panels open to reverse flow at the same pressure.

Flow area	= 15.0 ft <sup>2</sup>	= 1.39 m <sup>2</sup>	(Ref 5, pg. 80)
Elevation	= 567. ft	= 173. m	(Ref 7)
A/L	= 15/2 ft	= 2.29 m	



Path 11. The closed door that connects room 236 to room 227 is flow path 11. This door is normally closed. The door will fail at a differential pressure of 1.7 psig away from the jam. This provides a horizontal connection at floor level (el. 565 ± 7/2 ft). The wall is assumed to be 2 feet thick.

Flow area	= 21.0 ft <sup>2</sup> = 1.95 m <sup>2</sup>	(Ref 5, pg. E2)
Elevation	= 568.5 ft = 173. m	
A/L	= 21/2 ft = 3.20 m	

Path 12. This flow path connects room 236 to the containment annulus. The wall is 2 feet thick.

Flow area	= 12.6 ft <sup>2</sup> = 1.17 m <sup>2</sup>	(Ref 5, pg. 83)
Elevation	= 567. ft = 173. m	
A/L	= 12.6/2 ft = 1.92 m	

Path 13. The pipe chase that connects room 236 to room 314 is flow path 13.

Flow area	= 15.0 ft <sup>2</sup> = 1.39 m <sup>2</sup>	(Ref 5, pg. 83)
Elevation	= 585. ft = 173. m	
A/L	= 15/2 ft = 2.29 m	

The above flow path data is summarized in Table M-3.

**M.4.2.5 Spray Data.** The firewater sprays in room 236 are included in the model. The sprays are activated by fusible links (at 212°F). The sprays provide 336 gpm of water from heads scattered around the room at different elevations. The droplet size is not known, and is assumed to be .001 meters. The spray fall height is 18 feet (5.49 m).

#### M.4.3 Material Properties

The material properties required for this analysis are those of steam, water and concrete. Material properties for steam, water, concrete and steel are built into the CONTAIN code. The material property data for the RELAP5 models was documented in References 3 and 4.

Table M-3. Summary of CONTAIN flow path and flow junction data.

Junction	Paths	Area (m <sup>2</sup> )	A/l (m)
1	1,2,3	8.88	14.6
2	4	12.6	20.7
3	5	.892	1.46
4	6	1.95	3.20
5	7	1.95	3.20
6	8	2.97	4.88
7	9,10,11,12,13	29.1	157.

## M.5 Results

### M.5.1 Break Sequence 1

The RELAP5 calculations provided the reactor coolant system response data shown in Figures M-13 through M-16. Figure M-13 shows the RCS pressure plotted against time. The pressure drops from normal operating pressure to about 100 psia in about 10 minutes. At 10 minutes, system pressure is determined by the pump characteristics and by head losses between the pump and the break. Because the flows are large (nearly runout flow for two LPI pumps) the RCS cools to about 100°F in the same time frame (see Figure M-14). The resulting break flows and enthalpies are shown in Figures M-15 and M-16. Break flows are initially very large, but as saturated conditions are reached in the RCS, break flow drops off. The break flows plotted in Figure M-15 are both the liquid and vapor flow rates. The increase in vapor flow rate shows the onset of saturation, while the decrease to zero shows the eventual subcooling of the system during refill. The total break flow is reduced during refill, but eventually returns to essentially the runout flow of the ECCS systems. The contents of the CFTs and BWST are injected in 48 minutes, at this time injection stops.

The auxiliary building response to this blowdown is shown in Figures M-17 and M-18. The temperature, shown in Figure 16, increases to a maximum of

about 212°F in a few minutes, and stays there until cooling of the RCS discharge causes temperature to drop. This occurs early in the transient. The pressure predictions (not shown) indicate an increase in auxiliary building pressure of less than 1 psig.

The last parameter of interest shown in figure M-18 is pool depth. During the first few minutes of the transient flooding is a minor problem. The flooding becomes serious as the RCS cools. Most of the water released in the break compartment is carried through the auxiliary building as steam. The condensation rate in most compartments is small. In room 236 (the break compartment) fire sprays, condensate, and that portion of the break discharge that does not flash to steam drains through the pipe chase in the floor to room 115 below. This results in a rapid filling of room 115. Room 115 is separated from room 113 by a 10-foot high flood wall, and is filled to the top of the flood wall in 20 minutes. Spillage from room 115 into room 113 begins and causes room 113 to be flooded to the top of the flood wall into room 105 by 30 minutes. Room 105 then starts to fill, and by 50 minutes into the transient, room 105 has filled sufficiently to burst the doorway into room 100.

#### M.5.2 Break Sequence 2

The predicted RCS response during this sequence is shown in Figures M-19 through 21. This sequence, like break sequence 1, was run for 1 hour of transient time. Unlike the previous transient, this sequence could continue for some time after the one hour cutoff (in the previous sequence the BWST would be exhausted in one hour). However, the auxiliary building results, shown in Figures M-23 and M-24, indicate the clear trend. Temperatures are going to reach 212°F very quickly and remain there until the RCS is cooled down. The cooling that begins at 20 minutes reflects the cooling of the RCS, and the establishment of natural circulation paths in the model.

The flooding that results from the break is shown in Figure M-23. Note that Room 115 shows the greatest fill rate. In this sequence, the primary contributor to flooding is the drainage of firespray water from room 236 above. The condensate is the next significant contributor, resulting in similar fill rates in the remaining compartments.

### M.5.3 Break Sequence 3

In this sequence the piping breaks in both rooms 105 and 113. The RCS conditions are shown in Figures M-25 through M-28. There is essentially no difference between the RCS performance for this sequence and for sequence 2 because the choke plane is in exactly the same place in both models. The auxiliary building response differs because the two breaks are in separate rooms instead of the same room as in sequence 2. The pressures in the auxiliary building are again limited to near atmospheric pressure.

The temperatures, shown in Figure M-29, in rooms 105 and 113 rise to 212°F in several minutes and remain there for about 20 minutes before starting to cool. The other rooms in the model reach a maximum temperature of 198°F. Since temperatures in room 236 never exceed 212°F, the sprinkler system does not trip.

The relative humidity remains high, having saturated steam in rooms 105 and 113 for twenty minutes, after that the relative humidity remains near 100% for a long period of time.

The flooding, shown in Figure M-30, is a slow process in this sequence. There is less than a foot of accumulated water in any compartment at the end of one hour. The maximum flooding occurs in room 113. Flooding in room 115 is less than in other cases because the sprinklers in room 236 do not activate. The maximum flooding rate in this sequence is close to the capacity of the sump pumps. For example, in room 105 at approximately 5 minutes into the transient, the total flooding rate is about 244 gpm. The sump discharge capacity is only 183 gpm. The result is that flooding in this compartment will occur much slower than shown in the figures.

### M.5.4 Break Sequence 4

The RELAP5 predictions of pressure, temperature, break flow and break enthalpy are shown in Figures M-31 through M-34. The pressures in the auxiliary building are again low.

The auxiliary building temperatures are shown in Figure M-35. Again, saturated steam conditions are predicted to appear immediately and to last for twenty minutes. At this time the discharge is predicted to cool, resulting in lowering temperatures in the auxiliary building. Fire sprays will release in room 236 and contribute to the cooling process. The relative humidity is 100%.

Flooding, as shown in Figure M-36, occurs at a high rate. No spillage from one compartment to another occurs in the first hour, but will likely occur soon thereafter.

#### M.5.5 Break Sequence 5

The RELAP5 predictions of pressure, temperature, and break flow and enthalpy are shown in Figures M-37 through M-40. This sequence offers the possibility for benchmark comparison with more detailed calculations because of the CSAU study of B&W plants. This sequence is nearly identical to the CSAU Nominal SBLOCA case.

Comparison of RCS pressure (Figure M-36) with CSAU predictions (Figure M-43) shows that the simplified model predicts pressures that are too high. This results because energy removal mechanisms are neglected. Steam generator heat removal would remove much additional energy not accounted for in the simplified model.

Comparison of RCS temperature (Figure M-38) with CSAU predictions (Figure M-44) shows that model predictions are too high early in the transient, and too low late in the transient. This is because steam generator heat removal removes energy early, while later, it provides a source of stored energy. Both phenomena are neglected by the simplified model.

For easy reference, comparisons of pressure, temperature, break discharge flow, and break enthalpy are shown in Figures M-48, M-49, M-50, and M-51.

CONTAIN runs were made using the break discharge data from both the simple primary coolant system RELAP5 calculation, and from the Oconee CSAU calculations. The CONTAIN temperature and pool depths for the simplified model source term are plotted in Figures M-41 and M-42. Figures M-52 and M-53 show the same parameters calculated by CONTAIN when the Oconee steam source is used. Note that despite the inaccuracies in the simplified RCS model results, the CONTAIN predictions have similar implications for the risk analysis these calculations support. Temperatures peak at 211°F and pool depths are only different by about 2 feet after 2 hours. Percentage wise, the difference in pool depths is significant, however, both calculations show that the time required to fail ECCS equipment from submergence is long compared to the time required for the operators to recover the plant (i.e., the additional time available before ECCS submergence will have no effect on the likelihood the operators will successfully recover the plant). This demonstrates the relative insensitivity of auxiliary building conditions to the source term for the small breaks.

The high void fractions shown in Figure M-47 might be a cause for some concern. If the steam void fraction reaches .994 (the Oconee model predicts .95 to .99 for much of the transient) the constant enthalpy expansion that is assumed by the CONTAIN code will cause auxiliary building temperature predictions much higher than the 211°F predicted for both the previous cases. To determine the potential impact of dry steam in the discharge an additional sensitivity case was run. This case used the Oconee best estimate break discharge data from the preceding sensitivity with the steam quality set to 1.0 during the high void fraction portion of the transient. The resulting temperatures and flooding predictions are shown in Figures M-54 and M-55. Note that the resulting temperatures reach a maximum of about 276°F.

This result has significant implications. While the blowdown predicted in the Oconee model is never completely dry, it is so close that code uncertainties do not justify concluding that the discharge cannot become dry. Additional calculations are not likely to resolve this issue, and test data have not been published in sufficient detail to decide this issue. Therefore there remains some uncertainty about the maximum temperatures that can appear in the auxiliary building.

Besides the dry discharge sensitivity, runs were made that incorporated 1000 lb, 10,000 lb, 100,000 lb, and 1,000,000 lb of metal mass into each compartment. The dry discharge sensitivity above was modified to include the metal mass. The results showed the metal mass had a minimal impact on calculated temperatures up to a metal mass of 100,000 lb. The results for the 100,000 lb run are shown in Figures M-56 and M-57.

## M.6 Findings

A number of generalizations can be made from the results described in the preceding section.

The break discharge calculated with simplified RELAP5 models of the reference plant RCS provided a rough estimate of the steam source in the auxiliary building. Benchmark comparisons and sensitivity calculations have shown that, for a small break, the auxiliary building conditions are not strongly dependent on the discharge. For a large break the break discharge will be more important, but the large break results are believed to be more accurate than the small break calculations. Therefore the existing break calculations are sufficient for the purposes of this analysis.

The pressurization of auxiliary building is limited to less than 1 psig. This result occurs because auxiliary building compartments are very well connected. The modeling parameters that affect the calculated pressure rise between compartments are flow area, discharge coefficient, and L/D. These parameters are all accurately known for the ECCS rooms, so any uncertainties in the flow model (and hence the pressure calculation) would depend on the number of flow junctions neglected in the balance-of-plant model. The largest pressure drop in the model should occur as the fluid passes from the break compartment to the adjacent compartments (assuming roughly equal flow areas connecting each compartment). At each successive flow junction the mass flow will be reduced by the mass condensed in passing through each compartment, and the effective area associated with the flow will increase as more and more parallel flow paths become available to the fluid. Therefore pressure drops at each junction will decrease with increasing distance from the break. This

leads to the conclusion that model refinements affecting the pressure calculation are unwarranted.

Temperatures in the auxiliary building do not exceed 212°F. There is one modeling uncertainty that could change this result. The modeling uncertainty is the quality of the steam mixture discharged into the auxiliary building. For all of the break sequences evaluated in this analysis, the break discharge is a two-phase mixture with steam quality no higher than roughly 0.9. The CONTAIN treatment of the break discharge is essentially that of an isenthalpic expansion from RCS pressure to compartment pressure. Given this characterization of the process, the resulting compartment temperatures will always be at, or very near, the saturation temperature for the calculated compartment pressure, unless the break quality exceeds about 0.93 (a void fraction of 0.994). When this occurs, the discharged fluid will have sufficient enthalpy (greater than 1150 Btu/lb) to drive the steam in the compartment atmosphere into superheat. The maximum temperature obtainable by this process is about 320°F and this occurs when the RCS discharge is dry saturated steam at about 500 psia. It must be emphasized that none of the simplified model predictions, or the best estimate Ocone predictions used in this analysis predict the existence of dry steam in the break discharge, however, THE OCONEE RESULTS SHOW PROLONGED PERIODS DURING WHICH THE DISCHARGE IS VERY NEARLY DRY. Given the uncertainty inherent in any RELAP5 calculation, it is hard to rule out the possibility that high quality steam will be discharged long enough to drive the steam in the break compartment into superheat.

The relative humidity in the ECCS rooms will be 100% for much of the transient in all the break sequences analyzed here.

The pool depth results described in the previous section can be summarized with two generalizations

- 1) For break sequences 1 and 4, flooding will occur in the break compartment and the adjacent compartments at a rate that will cover essential ECCS components within one hour.



- 2) For break sequences 2, 3, and 5, flooding will occur slowly and could be delayed by operation of the compartment sumps, requiring a period of many hours before essential ECCS components would be covered.

Of the different factors controlling pool formation, there are two factors that dominate. The first is the rate of discharge of unflashed fluid from the break, the second is the extent to which firewater and condensate from the rest of the auxiliary building finds its way into rooms 105, 113, and 115. For the large breaks, the principal contributor to the pool formation is the discharge that does not flash. For the break sequences 1 and 4, as the RCS cools down, this becomes essentially the run out flow of the surviving ECCS. In sequences 2, 3, and 5, the discharge of firesprays provides a greater flooding hazard than the accumulation of condensate or unflashed break discharge.

## M.7 References

1. K. E. Carlson et al., *RELAP5/MOD3 Code Manual Volume III: Developmental Assessment and Solution Methods*, NUREG/CR-5535, EGG-2596, Draft, (available from EG&G Idaho, Inc. P.O. Box 1625, Idaho Falls, ID 83415-2404), June 1990.
2. K. K. Murata et al., *User's Manual for CONTAIN 1.1: A Computer Code for Severe Nuclear Reactor Accident Containment Analysis*, NUREG/CR-5026, SAND87-2309, November 1989.
3. C. M. Kullberg, Calculation Notebook for Core Uncovery Time Estimates for the B&W Reference Nuclear Power Plant.
4. W. J. Galyean and D. I. Gertman, *Assessment of ISLOCA Risks—Methodology and Application to a Babcock and Wilcox Nuclear Power Plant*, NUREG/CR-5604, EGG-2608, Appendix F, April 1992.
5. The B&W Reference Plant's Energy Line Break Analysis.
6. The B&W Reference Plant's HELB Analysis, RELAP4 input, Job Number 1040-039-1662, EDS Calc NO. 1040-039-004, ADCONLA, BREAK.BW500.
7. The B&W Reference Plant's Drawing Number M-130, Rev. 4.




Figure M-1. RELAP5/MOD3 Nodalization for the simplified reactor coolant system model.




Figure M-2. Simplified piping diagram showing the break location for break sequence 1.




Figure M-3. RELAP5/MOD3 Piping model for break sequence 1.




Figure M-4. Simplified piping diagram showing the break locations for break sequence 2.




Figure M-5. RELAP5/MOD3 piping model for break sequence 2.




Figure M-6. Simplified piping diagram showing break location for break sequence 3.






Figure M-7. Simplified piping diagram showing break location for break sequence 4.




Figure M-8. RELAP5/MOD3 piping model for break sequence 3.




Figure M-9. RELAP5/MOD3 piping model for break sequence 4.






Figure M-11. RELAP5/MOD3 piping model for break sequence 5.




Figure M-12.  
building

CONTAIN nodalization diagram for the B&W Plant Auxiliary

# BS-1 Reactor Coolant System Pressure




Figure M-13. Reactor coolant system pressure for break sequence 1.

BS-1 Reactor Coolant System Temperature




Figure M-14. Reactor coolant system temperature for break sequence 1.



# ES-1 Auxiliary Building Break Flows



Figure M-15. Mass flow rates to auxiliary building room 236 resulting from break sequence 1.

# BS-1 Break Enthalpy




Figure M-16.

Break enthalpy for steam released to auxiliary building room 236.

# BS-1 Auxiliary Building Temperatures



Figure M-17. Auxiliary building temperatures resulting from a decay heat removal system piping rupture in Room 236 (break sequence 1). The discharge limiting flow area is 0.6013 ft<sup>2</sup>.

# BS-1 Auxiliary Building Pool Depths




Figure M-18. Auxiliary building pool depths resulting from a decay heat removal system piping rupture in Room 236 (break sequence 1). The discharge limiting flow area is 0.6012 ft<sup>2</sup>.

# BS-2 Reactor Coolant System Pressure




Figure M-19. Reactor coolant system pressure for break sequence 2.

# BS-2 Reactor Coolant System Temperature




Figure M-20. Reactor coolant system temperature for break sequence 2.

# BS-2 Auxiliary Building Break Flow



Figure M-21. Auxiliary building break flow for sequence 2.

# BS-2 Auxiliary Building Break Enthalpy




Figure M-22. Auxiliary building break enthalpy for break sequence 2.



# BS-2 Auxiliary Building Temperatures



Figure M-23. Auxiliary building temperatures resulting from a decay heat removal system heat exchanger rupture in Room 113 (break sequence 2). The discharge limiting flow area total is 0.0443 ft<sup>2</sup>.

# BS-2 Auxiliary Building Pool Depths




Figure M-24. Auxiliary building pool depths resulting from a rupture in the decay heat removal system heat exchangers in Room 113 (break sequence 2). The discharge limiting flow area is 0.0443 ft<sup>2</sup>.

# BS-3 Reactor Coolant System Pressure



Figure M-25. Reactor coolant system pressure for break sequence 3.

BS-3 Reactor Coolant System Temperature




Figure M-26. Reactor coolant system temperature during break sequence 3.

# BS-3 Auxiliary Building Break Flows




Figure M-27. Auxiliary building break flow during break sequence 3.

# BS-3 Auxiliary Building Break Enthalpy




Figure M-28. Auxiliary building break enthalpy during break sequence 3.

# BS-3 Auxiliary Building Temperatures



Figure M-29. Auxiliary building temperatures resulting from an LPI pump suction piping rupture in Rooms 105 and 113 (break sequence 3). The discharge limiting flow area totals 0.0443 ft<sup>2</sup>.

# BS-3 Auxiliary Building Pool Depth




Figure M-30. Auxiliary building pool depths resulting from an LPI pump suction piping rupture in Rooms 105 and 113 (break sequence 3). The discharge limiting flow area totals 0.0443 ft<sup>2</sup>.



# BS-4 Reactor Coolant System Pressure




Figure M-31. Reactor coolant system pressure during break sequence 4.

# BS-4 Reactor Coolant System Temperature



Figure M-32. Reactor coolant system temperature during break sequence 4.

# BS-4 Auxiliary Building Break Flows




Figure M-33. Mass flow rates to auxiliary building room 113 resulting from break sequence 4.

# BS-4 Auxiliary Building Break Enthalpy




Figure M-34. Enthalpy of break flow to auxiliary building room 113 resulting from break sequence 4.

# BS-4 Auxiliary Building Temperatures




Figure M-35. Auxiliary building temperatures resulting from a heat exchanger rupture in room 113 (break sequence 4). The discharge limiting flow area is 0.3821 ft<sup>2</sup>.

# BS-4 Auxiliary Building Pool Depths




Figure M-36. Auxiliary building pool depths resulting from a heat exchanger rupture in room 113 (break sequence 4). The discharge limiting flow area is 0.3821 ft<sup>2</sup>.

RCS Pressure for BS-5




Figure M-37. Reactor coolant system pressure plotted against transient time for break sequence 5

RCS Temperature for BS-5



Figure M-38. Reactor coolant system temperature plotted against transient time for break sequence 5.



# BS-5 Break Flow Rates




Figure M-39. Auxiliary building break flows plotted as a function of time for break sequence 5.

# BS-5 Break Enthalpy



Figure M-40. Auxiliary building break enthalpies for break sequence 5.

# BS-5 Auxiliary Building Temperatures




Figure M-41. Auxiliary building temperatures resulting from an HPI pump suction line rupture (break sequence 5). The discharge limiting flow area is 0.02463 ft<sup>2</sup>.

# BS-5 Auxiliary Building Pool Depths




Figure M-42. Auxiliary building pool depths resulting from an HPI pump suction line rupture (break sequence 5). The discharge limiting flow area is 0.02463 ft<sup>2</sup>.

# B&W CSAU Nominal Case




Figure M-43. B&W CSAU SBLOCA nominal case primary and secondary pressures plotted against transient time.

# B&W CSAU Nominal Case




Figure M-44. B&W CSAU study SBLOCA nominal case primary loop temperatures plotted against transient time.

# B&W CSAU Nominal Case




Figure M-45. B&W CSAU study SBLOCA nominal case break mass flow rate plotted against transient time.

B&W CSAU Nominal Case




Figure M-45. B&W CSAU SBLOCA nominal case break enthalpy plotted against transient time.



# B&W CSAU Nominal Case




Figure M-47. B&W CSAU study SBLOCA nominal case break void fraction plotted against transient time.

# BS-5 Reactor Coolant System Pressure




Figure M-48. Reactor coolant system pressure for break sequence 5 compared to the B&W CSAU SBLOCA predictions.

# BG-5 Reactor Coolant System Temperature




Figure M-49. Simplified reactor coolant system model temperature predictions compared to the B&W CSAU SBLOCA predictions.

# BS-5 Break Flow Rates

4 inch pipe rupture in room 115




Figure M-50. Simplified model break discharge mass flow rate predictions compared to B&W CSAU SBLOCA predictions.

# BS-5 Break Enthalpy




Figure M-51. Simplified RCS model beak discharge enthalpy predictions compared to B&W CSAU SBLOCA predictions.

# BS-5 Auxiliary Building Temperatures




Figure M-52. Auxiliary building temperatures for break sequence 5 that result when using a break discharge from the Oconee SBLOCA study.

# BS-5 Auxiliary Building Pool Depths



Figure M-53. Auxiliary building pool depths resulting from the break discharge from the Oconee SBLOCA study.

# BS-5 Auxiliary Building Temperatures





Figure M-54. Auxiliary building temperatures for break sequence 5 that result when using a break discharge from the Oconee SBLOCA study. In this case the discharge was adjusted to reflect a dry blowdown after 8 minutes.



# BS-5 Auxiliary Building Pool Depths



**Figure M-55.** Auxiliary building pool depths resulting from the break discharge from the Oconee SBLOCA study. In this case the break discharge was adjusted to reflect dry steam in the blowdown after 8 minutes.

# BS-5 Auxiliary Building Temperatures





Figure M-56. Auxiliary building temperatures for break sequence 5, using the Oconee SBLOCA discharge adjusted to a break quality of 1.0 after 8 minutes. This case includes 100,000 lb of metal mass in each compartment.

# BS-5 Auxiliary Building Pool Depths



**Figure M-57.** Auxiliary building pool depths resulting from the B&W CSAU SBLOCA break discharge adjusted for a steam quality of 1.0. Each compartment includes 100,000 lb of metal mass.

# LISTING 1 - RELAP5 Input for BS-1

```

= BBW Plant DHR LETDOWN INTERFACING LOCA - BS-1
*
*
100 new transnt
101 run
102 british british
* 104 none * No restart file
*
*
* alloc
105 1.0 2.0 10800.
*
110 air
115 1.0
*
*
* end min max opt minor major restart
201 1. 1.0e-4 0.0010 3 10000 10000 50000
202 15. 1.0e-4 0.0100 3 100 1000 5000
203 3000. 1.0e-4 0.1000 3 100 1000 5000
204 10000. 1.0e-4 1.0000 3 100 1000 5000
*
* ----- Minor Edits -----
*
301 p 020060000 * Pressure at break
302 tempf 020060000 * Temperature at break
303 tempg 020060000 * Temperature at break
304 mflowj 020050000 * Total break flow rate
* 305 mflowj 021000000 *
306 mflowj 022000000
307 cntrlvar 190 * Break vapor mass flow rate
308 cntrlvar 130 * Break vapor enthalpy
309 cntrlvar 200 * Break liquid mass flow rate
310 cntrlvar 180 * Break liquid enthalpy
*
311 cputime 0
312 tmass 0
314 p 512010000 * tp of vessel
315 mflowj 712000000 * chg
316 mflowj 711000000 * hpi
317 q 514010000 * mid plane energy
318 p 300010000 *
... p 301010000 *
* cntrlvar 110
... cntrlvar 120
*
* ----- Trips -----
*
* 501 trip card starts transient by opening motor operated valve
* 502 trip card keeps valve open for a long time
* Trip 502 exists only to meet code requirement for a closing trip.
* 503 opens the 1st relief valve PSV4849 on 320 psia
* 504 opens the 2nd relief valve FV5A on 75 psia
* 505 opens the 3rd relief valve PSV1550 on 450 psia
*
501 time 0 ge null 0 0.0 n * open boundary MOV
502 time 0 ge null 0 1.e6 n
* 503 p 30010000 ge null 0 320. n
506 time 0 ge null 0 0.0 n * open break at time 0.
*
598 time 0 lt null 0 1.e6 n
599 time 0 gt null 0 1.e6 n
*
* ----- Hydrodynamic Components -----

```

\* Time dependent volume for charging junction

8990000	vesin	tmdpvol	
8990101	12.00	0.	3000.
8990102	0.	0.	0.
8990103	0.	0.	10
8990200	03	0	
8990201	-1.0e99	2000.	70.
8990202	0.0	2000.	70.

\* CHARGING FLOW RATE  
\* PERFORMANCE CURVES NOT AVAILABLE  
\* APPROXIMATED TO 300 GPM AT 2200 PSIA  
\* AND 700 GPM AT 200 PSIA.

\* at power chg rate =  $300 * 62.4 * .00223 = 41.74$   
\* run out mass flow rate, mass flow rate =  $700 * 62.4 * .00223 = 97.4$  lbs/sec

7120000	chgflow	tmdpjun		* LOOP .hg FLOWRATE
7120101	899000000	300000000	.0500	
7120200	1	598	p	300010000
7120201	-1.00e+00	0.0	0.0	0.0
7120202	20.	97.4	0.0	0.0
7120203	200.	97.4	0.0	0.0
7120204	2200.	41.74	0.0	0.0

\* Time dependent volume for HPI and LPI junction

9000000	vesin	tmdpvol	
9000101	12.00	0.0	3000.
9000102	0.	0.	0.
9000103	0.	0.	10
9000200	03	0	
9000201	-1.0e99	2000.	70.
9000202	0.0	2000.	70.

\* Sum of Lpi and Hpi mass flow rates

7110000	ecflow	tmdpjun		* LOOP HPI FLOWRATE+PI flow rate
7110101	900000000	300000000		1.4
7110200	1	598	p	300010000
7110201	-1.00e+00	0.	0.0	0.0
7110202	0.	1469.	0.0	0.0
7110203	115.	1469.	0.0	0.0
7110204	155.	1186.	0.0	0.0
7110206	192.	492.	0.0	0.0
7110207	197.	214.	0.0	0.0
7110208	1614.	160.	0.0	0.0
* 7110209	1.4537e+3	113.2	0.0	0.0
* 7110210	1.5636e+3	84.8	0.0	0.0
* 7110211	1.6239e+3	56.8	0.0	0.0
* 7110212	1.6409e+3	28.8	0.0	0.0
* 7110213	1.6421e+3	.00e+00	0.0	0.0

\* Component 300:  
\* Cops cold leg junction connection

3000000	COLDLG	pipe	
3000001	1		
3000101	12.00	1	
3000301	0.0	1	
3000401	3024.	1	
3000601	0.0	1	
3000801	0.00015	2.42	1
3001001	00	1	
3001201	003	2260.	557. 0. 0. 0. 1

\* component 508:  
 \* the following data represent the downcomer and lower plenum  
 \*

```

5080000          lowplup          branch
5080001
5080101          0.0              12.000          1266.          0
5080102          0.0              0.0              0.0
5080103          0.00015          5.6655          00
5080200          003          2260. 557.
*crdno  from          to          area  f loss  r loss  cabs
5081101  300010000      508010000  12.0000  1.3180  1.3180  10100
5082101  508010000      514000000  32.8781  0.0      0.0      10100
*cardno.  f vel.  v vel.  i vel.
* 5081201  23.195696  23.195696  0.0          * 37994.087
* 5082201  23.195696  23.195696  0.0          * 37994.087
5081201  0. 0. 0.          * 37994.087
5082201  0. 0. 0.          * 37994.087
  
```

\* component 514:  
 \* the following data represent the core and upper plenum  
 \*

```

5140000          core          pipe
5140001          1
5140101          0.0
5140301          12.          1
5140401          1265.          1
5140601          90.0          1
5140701          12.          1
5140801          0.00015          0.040092          1
5141001          00          1
5141201  003          2194. 608. 0. 0. 0. 1
  
```

\* Core heat structure

```

15151000  12  9  2  1  0.
15151100  0
15151101  5  0.01542  1  0.01571  2  0.01792
15151201  2  5  3  6  4  8
15151301  .85  2  .93  1.4  1.4  5  0.8
15151400  0
15151401  2000. 6  760.7  710.8  650.9
15151501  0  0  0  0  0. 12
15151601  514010000  00000  1  0  4144.5  12
15151701  1  0.0778  0. 0. 1
15151702  1  0.0885  0. 0. 2
15151703  1  0.0877  0. 0. 3
15151704  1  0.0860  0. 0. 4
15151705  1  0.0847  0. 0. 5
15151706  1  0.0838  0. 0. 6
15151707  1  0.0840  0. 0. 7
15151708  1  0.0848  0. 0. 8
15151709  1  0.0862  0. 0. 9
15151710  1  0.0879  0. 0. 10
15151711  1  0.0859  0. 0. 11
15151712  1  0.0627  0. 0. 12
*          dia  ht lngf  ht lngr  g lngf  g lngr  glossf  glor. sr  boilf  strno  * 902000
15151801  0. 100. 100. 0. 0. 0. 0. 1. 12 * 902000
15151901  0.0415 100. 100. 0. 0. 0. 0. 1. 12 * 902000
  
```

\* thermal properties of uo2 - composition 2

```

*-----*
*crdno  mtrl type  th.con  ht.cap  material
20100200  tb1/fctn  1  1  * uo2
*-----*
  
```

\* thermal properties of uo2

\*-----\*

*crdno	temperature	th cond
* 20100201	188.6	1.284e-3
20100201	0.	1.284e-3
20100202	332.6	1.1235e-3
20100203	440.6	9.951e-4
20100204	500.0	9.2806e-4
20100205	650.0	7.4194e-4
20100206	800.0	7.4361e-4
20100207	950.0	6.7750e-4
20100208	1100.0	6.2278e-4
20100209	1250.0	5.7722e-4
20100210	1400.0	5.3889e-4
20100211	1500.0	5.0639e-4
20100212	1700.0	4.7889e-4
20100213	1850.0	4.5528e-4
20100214	2000.0	4.3556e-4
20100215	2100.0	4.1861e-4
20100216	2300.0	4.0472e-4
20100217	2450.0	3.9306e-4
20100218	2600.0	3.8389e-4
20100219	3100.0	3.6750e-4
20100220	3600.0	3.7028e-4
20100221	4100.0	3.9056e-4
20100222	4600.0	4.2722e-4
20100223	5100.0	4.8056e-4

*crdno	temperature	vol ht cap
* 20100251	32.0	34.45
20100251	0.	34.45
20100252	122.0	38.35
20100253	212.0	40.95
20100254	392.0	43.55
20100255	752.0	46.80
20100256	2012.0	51.35
20100257	2732.0	52.65
20100258	3092.0	56.55
20100259	3452.0	63.05
20100260	3812.0	72.80
20100261	4352.0	89.70
20100262	4532.0	94.25
20100263	4712.0	98.15
20100264	4892.0	100.10
20100265	5144.0	101.40
20100266	8000.0	101.40

\*\*\*\*\*  
 \* thermal properties of fuel gap - composition 3  
 \*\*\*\*\*

*crdno	matl type	th.con	ht.cap	material
20100300	tbl/fctn	1	1	* fuel gap

\*-----\*  
 \* thermal properties of fuel gap  
 \*-----\*

\*values of thermal conductivity were derived from matpro and a frapcon  
 \*computer run at constant power over the total burnup interval  
 \*

\*burnup = 0.00000 pressure = .12362e+04 gap width = .00213  
 \* he frac = .10000e+01 kr frac = 0. xe frac = 0.

*crdno	temperature	th. cond.
* 20100301	70.000	2.52892e-05
20100301	0.000	2.52892e-05
20100302	300.000	3.14014e-05
20100303	500.000	3.70561e-05
20100304	700.000	4.23747e-05
20100305	900.000	4.74311e-05
20100306	1100.000	5.22745e-05

20100307	1300.000	5.89395e-05
20100308	1500.000	6.14522e-05
20100309	1700.000	6.58324e-05
20100310	1900.000	7.00957e-05
20100311	2100.000	7.42548e-05
20100312	2300.000	7.83201e-05
20100313	2500.000	8.23004e-05
20100314	2700.000	8.62029e-05
20100315	2900.000	9.00341e-05
20100316	3100.000	9.37993e-05
20100317	3300.000	9.75033e-05
20100318	3500.000	1.01150e-04
20100319	3700.000	1.04744e-04
20100320	3900.000	1.08288e-04
20100321	4100.000	1.11764e-04
20100322	4300.000	1.15236e-04
20100323	4500.000	1.18646e-04
20100324	4700.000	1.22017e-04
20100325	4900.000	1.25349e-04
20100326	5100.000	1.28645e-04
20100327	5300.000	1.31907e-04

*crdno	temperature	vol ht cap
20100351	0.0	0.000075
20100352	5400.0	0.000075

\* thermal properties of cladding - composition 4

*crdno	matl type	th.con	ht.cap	material
20100400	tbl/fctn	1	1	* cladding

\* thermal properties of cladding

*crdno	temperature	th.cond
* 20100401	50.0	1.9267e-3
20100401	0.0	1.9267e-3
20100402	392.0	1.9267e-3
20100403	752.0	2.2478e-3
20100404	1112.0	2.7297e-3
20100405	1472.0	3.0579e-3
20100406	1832.0	3.5325e-3
20100407	2192.0	4.0142e-3
20100408	2552.0	4.8169e-3
20100409	2912.0	5.7803e-3
20100410	3272.0	7.0647e-3
20100411	3632.0	8.8311e-3
20100412	3992.0	1.0918e-2

*crdno	tr	vol ht cap
20100451	0	28.392
20100452	0.3	34.476
20100453	5.00	85.176
20100454	1787.5	34.370
20100455	3500.0	34.476

\* table number 1 - core power vs. time

\* this table represents a best-estimate of fission product decay heat using the ans standard plus a contribution from actinides.  
\* table is activated by trip 540. reference: work by c. b. davis

* card	type	trip	time factor	power(mw)
20200100	power	0	1.0	2772.

\* sec normalized power



```

20200101      -1.      .0      * start at one second
* 20200101      -1.      1.0
* 20200102      0.      1.0
* 20200103      .1      .8382
* 20200104      .2      .5720
* 20200105      .3      .3806
* 20200106      .4      .2792
* 20200107      .5      .2246
* 20200108      .6      .1904
* 20200109      .7      .1672
* 20200110      .8      .1503
* 20200111      .9      .1376
20200112      1.0      .1275
20200113      1.5      .1032
20200114      2.      .09884
20200115      3.      .09209
20200116      4.      .08690
20200117      5.      .08271
20200118      6.      .07922
20200119      8.      .07375
20200120     10.      .06967
20200121     15.      .06251
20200122     20.      .05751
20200123     30.      .05060
20200124     40.      .04591
20200125     50.      .04246
20200126     60.      .03977
20200127     80.      .03604
20200128    100.      .03357
20200129    120.      .03145
20200130    150.      .02997
20200131    200.      .02798
20200132    300.      .02565
20200133    400.      .02418
20200134    500.      .02307
20200135    600.      .02217
20200136    800.      .02073
20200137   1000.      .01959
20200138   1250.      .01844
20200139   1500.      .01749
20200140   2000.      .01600
20200141   2500.      .01489
20200142   3000.      .01401
20200143   3500.      .01331
20200144   4000.      .01274
20200145   5000.      .01185
20200146   6000.      .01118
20200147   7000.      .01067
20200148   8000.      .01025
20200149   9000.      .009895
20200150  10000.      .009596
20200151  15000.      .008553
20200152  20000.      .007902

```

```

* component 012:
* the following data represent the upper head and pressurizer

```

```

5120000      corein1      branch
5120001      1      0
5120101      0.0      12.000      2808.
5120102      0.0      90.0      12.00
5120103      0.00015      10.0      00
5120200      003      2194.      608.
5121101      514010000      51.000000      0.0      0.1979      0.1979      10100
5121201      5. 0. 0.      * 36815.350

```

```

*
9240000      upjun      sng'jun

```

9240101 512010000 301000000 12.00 0.1200 0.1200 00002  
9240201 0 0.0 0.0

\*

\* component 301:

\* 4 loops cold leg junction connection

\*

3010000		1h13		pipe	
3010001		1			
3010101	12.00				1
3010301	0.0			1	
3010401	3025.				1
3010601	0.0				1
3010801	0.00015	2.42			1
3011001	00				1
3011201	003	2194. 608. 0. 0. 0.		1	

\*

\* Single Junction (Component 205)

\*

2050000	inletjun	sngljun			
2050101	301010000	010000000	0.0	0.0	0.0 01100
2050201	1 0.0	0.0	0.0		

\*

\* Pipe (Component 10)

\*

0100000	"12-CCA-4"		pipe	
0100001	19			
0100101	0.6013	19		
0100301	4.0	19		
0100601	0.0			
0100801	1.5e-4	0.0	19	
0100901	0.0	0.0	1	
0100902	0.108	0.108	2	
0100903	0.108	0.108	3	
0100904	0.0	0.0	4	
0100905	0.216	0.216	5	
0100906	0.0	0.0	6	
0100907	0.0	0.0	9	
0100908	0.108	0.108	10	
0100909	0.0	0.0	11	
0100910	0.324	0.324	12	
0100911	0.0	0.0	13	
0100912	0.216	0.216	14	
0100913	0.0	0.0	15	
0100914	0.0	0.0	16	
0100915	0.216	0.216	17	
0100916	0.0	0.0	18	
0101001	00	19		
0101101	0100	18		
0101201	003	2194. 608. 0. 0. 0.	19	
0101301	0.0	0.0 0.0	18	

\*

\* Valve DH12 (Component 15)

\*

0150000	DH12		valve	
0150101	010010000	020000000	0.6013	1.0 1.0 00100
0150201	1 0.0	0.0	0.0	
0150300	mtrvly			
0150301	501	502	0.1 0.0	

\*

\* Pipe (Component 20)

\*

0200000	"12-GCB-7"		pipe	
0200001	6			
0200101	0.8185	6		
0200301	4.0	6		
0200601	0.0	6		
0200801	1.5e-4	0.0	6	
0200901	0.0	0.0	1	

```

0200902 1.216 1.216 2
0200903 0.0 0.0 3
0200904 0.216 0.216 4
0200905 1.0 1.0 5
0201001 00 6
0201101 01000 5
0201201 003 50. 100. 0. 0. 0. 6
0201301 0.0 0.0 0.0 5

```

\* Break for BS-1, located at end of 12 inch piping.

```

0220000 break valvw
0220101 020010000 902000000 0. 0. 0. 000'00
0220201 1 0. 0. 0.
0220300 trpvlv
0220301 506

```

\* Time-dependent volume downstream of the leak

```

9020000 vesout tmdpvol
9020101 18.40 0.0 3000.
9020102 0 0 0
9020103 0 0 10
9020200 03 0
9020201 0 0 15. 213.

```

\* ===== Control Variables =====

20500000 4095.

\* Sum of total eccs

```

*ctlvar name type factor init f c
20501100 "ecctot" sum 2.2046 0.0 1

```

```

*ctlvar a0 coeff variable name parameter no.
20501101 0.0 1.0 mflowj 711000000
20501102 1.0 1.0 fflowj 712000000

```

\*integrate eccs mass flow rate

```

**ctlvar name type factor init f c min max
20501200 "inteccs" integral 1.0 0.0 0.3 0.0 4.8e6

```

```

*ctlvar integrand name integrand no.
20501201 cntrlvar 110

```

\* Controller for break vapor enthalpy - output SI units, break conditions taken from donor volume.

\*  $h_g = u_g + p \cdot v_g$

```

20501300 "v-enth" sum 1. 0. 1
20501301 0. 1. ug 020060000
20501302 1. cntrlvar 140

```

```

20501400 "v-p*vg" mult 1. 0. 1
20501401 p 020060000
20501402 cntrlvar 150

```

```

20501500 "v-1/rho" div 1. 1. 1
20501501 rhog 020060000

```

\* Controller for break liquid enthalpy

\*  $h_f = u_f + p \cdot v_f$

```

20501600 "f-enth" sum 1. 0. 1

```

```

20501601 0.      1.      uf      020060000
20501602      1.      cntrlvar 170
*
20501700 "f-pv"  mult    1.      0.      1
20501701      p      020060000
20501702      cntrlvar 180
*
20501800 "1/rho" div    1.      1.      1
20501801      rhof   020060000
*
* Controller for break vapor mass flow rate
*
20501900 mflowg  mult    0.07604 0.      1
20501901      voidgj  022000000
20501902      rhogj   022000000
20501903      velgj   022000000
*
* Controller for break fluid mass flow rate
*
20502000 mflowf  mult    0.07604 0.      1
20502001      voidfj  022000000
20502002      rhofj   022000000
20502003      velfj   022000000
*
.End

```

## LISTING 2 - RELAP5 Input for BS-2

```

* B&W Plant DHP LETDOWN INTERFACING LOCA - BS-2
*
* File:
*
*   rlp002.mdl
*
* Description:
*
*   This RELAP5/MOD2 input deck is used to obtain the steam source term
*   resulting from an ISLOCA in the B&W Plant decay heat removal pump
*   discharge line. The break occurs in auxiliary building room 113.
*   This model was constructed from a long-term cooling deck written by
*   Craig Kullberg, a low-pressure injection system piping model written
*   by Everett Gruen, and an Oconee "generic" core decay heat model.
*
* Written by:
*
*   John Schroeder 6/91
*
100  new      transvt
101  run
102  british  british
* 104  none          * No restart
*
*
*   105  1.0      2.0      alloc
*           10800.
*
110  air
115  1.0
*
*   end      min      max      opt      minor      major      restart
201  .5      1.0e-4  0.0010  3      10000     10000     50000
202  100.    1.0e-4  0.0050  3      200       20000     10000
203  500.    1.0e-4  0.0100  3      1000      10000     10000
204  3600.   1.0e-4  0.1000  3      100       1000      5000
*
* ----- Minor Edits -----
*
301  p      120360000 * Pressure at break
302  tempf  120360000 * Temperature at break
303  tempg  120360000 * Temperature at break
304  mflowj 723000000 * Total break flow rate
* 305  mflowj 021000000 *
306  mflowj 724000000
307  cntrlvar 190      * Break vapor mass flow rate
308  cntrlvar 130      * Break vapor enthalpy
309  cntrlvar 200      * Break liquid mass flow rate
310  cntrlvar 160      * Break liquid enthalpy
*
311  cputime 0
312  tmass 0
314  p      512010000 * top of vessel
315  mflowj 712000000 * chg
316  mflowj 711000000 * hpi
317  q      514010000 * mid plane energy
318  p      300010000 *
319  p      301010000 *
* 320  cntrlvar 110
321  cntrlvar 120      * Integrated injection flow
*
* ===== Trips =====
*
* 501 trip card starts transient by opening motor operated valve
* 502 trip card keeps valve open for a long time

```

- \* Trip 502 exists only to meet code requirement for a closing trip.
- \* 503 opens the 1st relief valve PSV4849 on 320 psia
- \* 504 opens the 2nd relief valve FV5A on 75 psia
- \* 505 opens the 3rd relief valve PSV1550 on 450 psia

```

*
501   time   0       ge null 0  0.0  n   * open boundary MOV
502   time   0       ge null 0  1.e6  n
* 503   p     30010000 ge null 0  320.  n
* 506   time   0       ge null 0  0.0  n   * open break at time 0.
*
598   time   0       lt null 0  1.e6  n
599   time   0       gt null 0  1.e6  n

```

\*\*\*\*\* Hydrodynamic Components \*\*\*\*\*

\* Time dependent volume for charging junction

```

8990000 TDVCHG  tmdpvol
8990101 12.00  0.      3000.
8990102 0.      0.      0.
8990103 0.      0.      10
8990200 03      0
8990201 -1.0e99  2000.  70.
8990202 0.0     2000.  70.

```

- \* CHARGING FLOW RATE
- \* PERFORMANCE CURVES NOT AVAILABLE
- \* APPROXIMATED TO 300 GPM AT 2200 PSIA
- \* AND 700 GPM AT 200 PSIA.

```

* at power chg rate          = 300*62.4*.00223 = 41.74
* run out mass flow rate, mass flow rate = 700*62.4*.00223=97.4 lbs/sec

```

```

7120000 CHGFLOW  tmdpjun          * LOOP chg FLOWRATE
7120101 899000000 300000000 .0500
7120200 1          598          p          300010000
7120201 -1.00e+00 0.0          0.0          0.0
7120202 20.         97.4         0.0          0.0
7120203 200.        97.4         0.0          0.0
7120204 2200.       41.74        0.0          0.0

```

\* Time dependent volume for HPI and LPI junction

```

9000000 TDVLPI  tmdpvol
9000101 12.00  0 0      3000.
9000102 0.      0.      0.
9000103 0.      0.      10
9000200 03      0
9000201 -1.0e99  2000.  70.
9000202 0.0     2000.  70.

```

\* Sum of Lpi and Hpi mass flow rates

```

7110000 ECCSFLOW tmdpjun          * LOOP HPI FLOWRATE
7110101 900000000 300000000 1.4
7110200 1          598          p          300010000
7110201 -1.00e+00 0.          0.0          0.0
7110202 0.         214.         0.0          0.0
7110203 115.        214.         0.0          0.0
7110204 155.        214.         0.0          0.0
7110206 192.        214.         0.0          0.0
7110207 197.        214.         0.0          0.0
7110208 1614.       160.         0.0          0.0

```

- \* Component 300:
- \* 4 loops cold leg junction connection

```

*
3000000 COLDLG pipe
3000001 1
3000101 12.00 1
3000301 0.0 1
3000401 3024. 1
3000601 0.0 1
3000801 0.00015 2.42 1
3001001 00 1
3001201 003 2260. 557. 0. 0. 0. 1

```

```

* Component 508:
* the following data represent the downcomer and lower plenum

```

```

5080000 LDWRPLM branch
5080001 2 0
5080101 0.0 12.000 1265.
5080102 0.0 0.0 0.0
5080103 0.00015 5.6655 00
5080200 003 2260. 557.
* from to area f loss r loss vcahs
5081101 300010000 508010000 12.0000 1.3180 1.3180 10100
5082101 508010000 514000000 32.8781 0.0 0.0 10100
* f vel. v vel. l vel.
5081201 0. 0. 0. * 37994.087
5082201 0. 0. 0. * 37994.087

```

```

* Component 514:
* the following data represent the core and upper plenum

```

```

5140000 CORE pipe
5140001 1
5140101 0.0 1
5140301 12. 1
5140401 1265. 1
5140601 90.0 1
5140701 12. 1
5140801 0.00015 0.040092 1
5141001 00 1
5141201 003 2194. 608. 0. 0. 0. 1

```

```

* Component 512:
* the following data represent the upper head and pressurizer

```

```

5120000 UPPRPLM branch
5120001 1 0
5120101 0.0 12.000 2808.
5120102 0.0 90.0 12.00
5120103 0.00015 10.0 00
5120200 003 2194. 608.
5121101 514010000 512000000 0.0 0.1979 0.1979 10100
5121201 0. 0. 0. * 36815.350

```

```

9240000 VESSLOUT sngljun
9240101 512010000 301000000 12.00 0.1200 0.1200 00002
9240201 0 0. 0. 0. 0

```

```

* Component 301

```

```

3010000 HCTLEG pipe
3010001 1
3010101 12.00 1
3010301 0.0 1
3010401 3025. 1
3010601 0.0 1
3010801 0.00015 2.42 1
3011001 00 1

```

3011201 003 2194. 608. 0. 0. 0. 1

\*  
\* Single Junction -- decay heat removal pump suction line  
\*

2050000 DHRINLET sngljun  
2050101 301010000 010000000 0.0 0.0 0.0 01100  
2050201 1 0.0 0.0 0.0

\* Pipe  
\*

0100000 "12-CCA-4" pipe  
0100001 19  
0100101 0.6013 19  
0100301 4.0 19  
0100601 0.0 19  
0100801 1.5e-4 0.0 19  
0100901 0.0 0.0 1  
0100902 0.108 0.108 2  
0100903 0.108 0.108 3  
0100904 0.0 0.0 4  
0100905 0.216 0.216 5  
0100906 0.0 0.0 6  
0100907 0.0 0.0 9  
0100908 0.108 0.108 10  
0100909 0.0 0.0 11  
0100910 0.324 0.324 12  
0100911 0.0 0.0 13  
0100912 0.216 0.216 14  
0100913 0.0 0.0 15  
0100914 0.0 0.0 16  
0100915 0.216 0.216 17  
0100916 0.0 0.0 18  
0101001 00 19  
0101101 01000 18  
0101201 003 2194. 608. 0. 0. 0. 19  
0101301 0.0 0.0 0.0 18

\* Valve DH12  
\*

0150000 DH12 valve  
0150101 010010000 020000000 6013 1.0 1.0 00100  
0150201 1 0.0 0.0 0.0  
0150300 mtrvly  
0150301 501 502 0.1 0.0

\* Pipe -- suction line, 12 inch GCB-7  
\*

0200000 "12-GCB-7" pipe  
0200001 6  
0200101 0.8185 6  
0200301 4.0 6  
0200601 0.0 6  
0200801 1.5e-4 0.0 6  
0200901 0.0 0.0 1  
0200902 1.216 1.216 2  
0200903 0.0 0.0 3  
0200904 0.216 0.216 4  
0200905 1.0 1.0 5  
0201001 00 6  
0201101 01000 5  
0201201 003 50. 100. 0. 0. 0. 6  
0201301 0.0 0.0 0.0 5

\* Junction of suction line with train 1-2  
\*

0230000 inletjun sngljun  
0230101 020010r70 040000000 0.0 0.0 0.0 01100  
0230201 1 0.0 0.0 0.0



\*  
 \* Junction of suction line with train 1-1  
 \*

0240000 inletjun sngljun  
 0240101 020010000 440000000 0.0 0.0 0.0 01100  
 0240201 1 0.0 0.0 0.0

\*  
 \* Piping to train 1-2 pump suction -- includes 2 1/2 inch bypass line  
 \* around valve DH-1518.  
 \*

0400000 "2.5GCB-7" pipe  
 0400001 13  
 0400101 0.8185 1  
 0400102 0.03322 2  
 0400103 0.03322 7  
 0400104 0.81850 13  
 0400201 0.03322 3  
 0400202 0.02215 4  
 0400203 0.03322 12  
 0400301 4.0 13  
 0400601 0.0 13  
 0400801 1.5e-4 0.0 13  
 0400901 1.0 1.0 1  
 0400902 0.216 0.216 2  
 0400903 0.648 0.648 3  
 0400904 0.0 0.0 4  
 0400905 0.648 0.648 5  
 0400906 0.216 0.216 6  
 0400907 1.216 1.216 7  
 0400908 0.0 0.0 8  
 0400909 0.216 0.216 9  
 0400910 0.216 0.216 10  
 0400911 0.0 0.0 11  
 0400912 1.216 1.216 12  
 0401001 00 13  
 0401101 01000 3  
 0401102 00000 4  
 0401103 01000 6  
 0401104 00000 7  
 0401105 01000 12  
 0401201 003 50.100 0. 0. 0. 13  
 0401301 0.0 0.0 0.0 12

\*  
 \* Single Junction (Component 43)  
 \*

0430000 inletjun sngljun  
 0430101 040010000 120000000 0.0 0.0 0.0 01100  
 0430201 1 0.0 0.0 0.0

\*  
 \* pipe (Component 120) INCLUDES 18, 12, AND 10 INCH PIPE  
 \*

1200000 "12-GBC-8" pipe  
 1200001 36  
 1200101 1.6467 1  
 1200102 0.8150 12  
 1200103 0.5731 36  
 1200301 4.0 36  
 1200601 0.0 36  
 1200801 1.5e-4 0.0 36  
 1200901 0.316 0.316 1  
 1200902 0.0 0.0 2  
 1200903 0.216 0.216 3  
 1200904 0.0 0.0 6  
 1200905 0.216 0.216 7  
 1200906 0.0 0.0 9  
 1200907 0.216 0.216 10  
 1200908 0.0 0.0 11  
 1200909 3.0 3.0 12 \* P42-2 decay heat/LPI pump

```

1200910 0.216 0.216 13
1200911 1.0 1.0 14
1200912 0.0 0.0 15
1200913 0.0 0.0 19
1200914 0.216 0.216 20
1200915 0.0 0.0 21
1200916 0.0 0.0 22
1200917 0.216 0.216 23
1200918 0.0 0.0 24
1200919 0.216 0.216 25
1200920 0.216 0.216 26
1200921 0.0 0.0 29
1200922 0.216 0.216 32
1200923 0.0 0.0 34
1200924 0.216 0.216 35
1201001 00 36
1201101 01000 35
1201201 003 50. 100. 0. 0. 0. 36
1201301 0.0 0.0 0.0 35

```

\* Second parallel piping run begins here.

\* pipe (Component 440)

```

4400000 "2.5GCB-7" pipe
4400001 13
4400101 0.8185 1
4400102 0.03322 2
4400103 0.03322 7
4400104 0.81850 13
4400201 0.03322 3
4400202 0.02215 4
4400203 0.03322 12
4400301 4.0 13
4400601 0.0 13
4400801 1.5e-4 0.0 13
4400901 1.0 1.0 1
4400902 0.216 0.216 2
4400903 0.648 0.648 3
4400904 0.0 0.0 4
4400905 0.648 0.648 5
4400906 0.216 0.216 6
4400907 1.216 1.216 7
4400908 0.0 0.0 8
4400909 0.216 0.216 9
4400910 0.216 0.216 10
4400911 0.0 0.0 11
4400912 1.216 1.216 12
4401001 00 13
4401101 01000 6
4401102 00000 7
4401103 01000 12
1201 003 50. 100. 0. 0. 0. 13
4401301 0.0 0.0 0.0 12

```

\* Single Junction (Component 43)

```

4430000 inletjun sngljun
4430101 440010000 520000000 0.0 0.0 0.0 01100
4430201 1 0.0 0.0 0.0

```

\* Pipe INCLUDES 18, 12, AND 10 INCH PIPE

```

5200000 "12-GBC-8" pipe
5200001 36
5200101 1.8487 1
5200102 0.8150 12
5200103 0.5731 36

```

```

5200301 4.0 36
5200601 0.0 36
5200801 1.5e-4 0.0 36
5200901 0.316 0.316 1
5200902 0.0 0.0 2
5200903 0.216 0.216 3
5200904 0.0 0.0 6
5200905 0.216 0.216 7
5200906 0.0 0.0 9
5200907 0.216 0.216 10
5200908 0.0 0.0 11
5200909 3.0 3.0 12 * P42-1 decay heat/LPI pump
5200910 0.216 0.216 13
5200911 1.0 1.0 14
5200912 0.0 0.0 15
5200913 0.0 0.0 19
5200914 0.216 0.216 20
5200915 0.0 0.0 21
5200916 0.0 0.0 22
5200917 0.216 0.216 23
5200918 0.0 0.0 24
5200919 0.216 0.216 25
5200920 0.216 0.216 26
5200921 0.0 0.0 29
5200922 0.216 0.216 32
5200923 0.0 0.0 34
5200924 0.216 0.216 35
5201001 00 36
5201101 01000 35
5201201 003 50. 100. 0. 0. 0. 36
5201301 0.0 0.0 0.0 35

```

\* Break for BS-2, located at DHR cooler 1-2

```

7230000 BREAK-1 valve * fvcahs
7230101 120010000 902000000 0.5731 0. 0. 000100
7230201 1 0. 0. 0.
7230300 trpvlv
7230301 506

```

\* Break for BS-2, located at DHR cooler 1-1

```

7240000 BREAK-2 valve * fvcahs
7240101 520010000 902000000 0.5731 0. 0. 000100
7240201 1 0. 0. 0.
7240300 trpvlv
7240301 506

```

\* Time-dependent volume downstream of the leak

```

9020000 AUXBLDG tmdpvol
9020101 18.40 0. 3000.
9020102 0 0 0
9020103 0 0 10
9020200 03 0
9020201 0.0 15. 213.

```

\* ===== Heat Structures =====

\* Core heat structure

```

15151000 12 9 2 1 0.
15151100 0 1
15151101 5 0.01542 1 0.01571 2 0.01792
15151201 2 5 3 6 4 6
15151301 .85 2 .9 3 1.4 1.4 5 0.8
15151400 0
15151401 2000 6 760 7 710 6 650.9

```

15151501	0	0	0	0	0	0.	12
15151601	514010000	00000	1	0	4144.5	12	
15151701	1	0.0778	0.	0.	1		
15151702	1	0.0885	0.	0.	2		
15151703	1	0.0877	0.	0.	3		
15151704	1	0.0860	0.	0.	4		
15151705	1	0.0847	0.	0.	5		
15151706	1	0.0839	0.	0.	6		
15151707	1	0.0840	0.	0.	7		
15151708	1	0.0848	0.	0.	8		
15151709	1	0.0862	0.	0.	9		
15151710	1	0.0879	0.	0.	10		
15151711	1	0.0859	0.	0.	11		
15151712	1	0.0627	0.	0.	12		

\* dia htlngr htlngr glngr glossf glossr boilf strno \* 902000  
 15151801 0. 100. 100. 0. 0. 0. 0. 1. 12 \* 902000  
 15151901 0.0415 100. 100. 0. 0. 0. 0. 1. 12 \* 902000

\*\*\*\*\*  
 \* thermal properties of uo2 - composition 2  
 \*-----\*

mtrl type	th.con	ht.cap	material
20100200 tbl/ctn	1	1	* uo2

\*-----\*

\* thermal properties of uo2  
 \*-----\*

	temperature	th.cond
* 20100201	188.6	1.284e-3
20100201	0.	1.284e-3
20100202	332.6	1.1235e-3
20100203	440.6	9.951e-4
20100204	500.0	9.2806e-4
20100205	650.0	7.4194e-4
20100206	800.0	7.4361e-4
20100207	950.0	6.7750e-4
20100208	1100.0	6.2278e-4
20100209	1250.0	5.7722e-4
20100210	1400.0	5.3889e-4
20100211	1500.0	5.0639e-4
20100212	1700.0	4.7889e-4
20100213	1850.0	4.5528e-4
20100214	2000.0	4.3556e-4
20100215	2150.0	4.1861e-4
20100216	2300.0	4.0472e-4
20100217	2450.0	3.9306e-4
20100218	2600.0	3.8389e-4
20100219	3100.0	3.6750e-4
20100220	3600.0	3.7028e-4
20100221	4100.0	3.9056e-4
20100222	4600.0	4.2722e-4
20100223	5100.0	4.8056e-4

	temperature	vol ht cap
* 20100251	32.0	34.45
20100251	0.	34.45
20100252	122.0	38.35
20100253	212.0	40.95
20100254	392.0	43.55
20100255	752.0	46.80
20100256	2012.0	51.35
20100257	2732.0	52.65
20100258	3092.0	56.55
20100259	3452.0	63.05
20100260	3812.0	72.80
20100261	4352.0	89.70
20100262	4532.0	94.25

20100263	4712.0	98.15
20100264	4892.0	100.10
20100265	5144.0	101.40
20100266	8000.0	101.40

\* thermal properties of fuel gap - composition 3

* mtrl type	th.con	ht.cap	material
20100300 tbl/fctn	1	1	* fuel gap

\* thermal properties of fuel gap

\* values of thermal conductivity were derived from matpro and a fraccon

\* computer run at constant power over the total burnup interval

\* burnup = 0.00000 pressure = .12362e+04 gap width = .00213  
 \* he frac = .10000e+01 kr frac = 0. xe frac = 0.

* 20100301	temperature	th. cond.
20100301	70.000	2.52892e-05
20100301	0.000	2.52892e-05
20100302	300.000	3.14014e-05
20100303	500.000	3.70561e-05
20100304	700.000	4.23747e-05
20100305	900.000	4.74311e-05
20100306	1100.000	5.22745e-05
20100307	1300.000	5.69395e-05
20100308	1500.000	6.14522e-05
20100309	1700.000	6.58324e-05
20100310	1900.000	7.00957e-05
20100311	2100.000	7.42548e-05
20100312	2300.000	7.83201e-05
20100313	2500.000	8.23004e-05
20100314	2700.000	8.62029e-05
20100315	2900.000	9.00341e-05
20100316	3100.000	9.37993e-05
20100317	3300.000	9.75033e-05
20100318	3500.000	1.01150e-04
20100319	3700.000	1.04744e-04
20100320	3900.000	1.08288e-04
20100321	4100.000	1.11784e-04
20100322	4300.000	1.15236e-04
20100323	4500.000	1.18646e-04
20100324	4700.000	1.22017e-04
20100325	4900.000	1.25349e-04
20100326	5100.000	1.28645e-04
20100327	5300.000	1.31907e-04

* 20100351	temperature	vol ht cap
20100351	0.0	0.000075
20100352	5400.0	0.000075

\* thermal properties of cladding - composition 4

* crdno	mtrl type	th.con	ht.cap	material
20100400	tbl/fctn	1	1	* cladding

\* thermal properties of cladding

* 20100401	temperature	th.cond
20100401	50.0	1.9267e-3
20100401	0.0	1.9267e-3
20100402	392.0	1.9267e-3
20100403	752.0	2.2478e-3
20100404	1112.0	2.7297e-3
20100405	1472.0	3.0508e-3

20100406	1832.0	3.5325e-3
20100407	2182.0	4.0142e-3
20100408	2552.0	4.8169e-3
20100409	2912.0	5.7803e-3
20100410	3272.0	7.0647e-3
20100411	3632.0	8.8311e-3
20100412	3992.0	1.0918e-2

*	temperature	vol ht cap
20100451	0.0	28.392
20100452	1480.3	34.476
20100453	1675.0	85.176
20100454	1787.5	34.370
20100455	3500.0	34.476

\* table number 1 - core power vs. time

\* this table represents a best-estimate of fission product decay heat using the ans standard plus a contribution from actinides.  
\* reference: work by c. b. davis

\* Mode<sup>1</sup> modified to reflect the B&W Plant power level - John Schroeder

*	type	trip	factor	power(mw)
20200100	power	0	1.0	2772.

*	sec	normalized power
20200101	-1.	0. * start at one second

* 20200101	-1.	1.0
* 20200102	0.	1.0
* 20200103	.1	.6382
* 20200104	.2	.5720
* 20200105	.3	.3806
* 20200106	.4	.2792
* 20200107	.5	.2246
* 20200108	.6	.1904
* 20200109	.7	.1672
* 20200110	.8	.1503
* 20200111	.9	.1376
20200112	1.0	.1275
20200113	1.5	.1032
20200114	2.	.09884
20200115	3.	.09209
20200116	4.	.08690
20200117	5.	.08271
20200118	6.	.07922
20200119	8.	.07375
20200120	10.	.06967
20200121	15.	.06251
20200122	20.	.05751
20200123	30.	.05060
20200124	40.	.04591
20200125	50.	.04246
20200126	60.	.03977
20200127	80.	.03604
20200128	100.	.03357
20200129	125.	.03145
20200130	150.	.02997
20200131	200.	.02798
20200132	300.	.02565
20200133	400.	.02418
20200134	500.	.02307
20200135	600.	.02217
20200136	800.	.02073
20200137	1000.	.01959
20200138	1250.	.01844
20200139	1500.	.01749

```

20200140 2000 .01000
20200141 2500 .01489
20200142 3000 .01401
20200143 3500 .01331
20200144 4000 .01274
20200145 5000 .01185
20200146 6000 .01118
20200147 7000 .01067
20200148 8000 .01025
20200149 9000 .009895
20200150 10000 .009596
20200151 15000 .008553
20200152 20000 .007902

```

```

* ===== Control Variables =====

```

```

20500000 4095

```

```

* Sum of total eecs

```

```

* name type factor init f c
20501100 "ecctot" sum 2.2046 0.0 1

```

```

* a0 coeff name parameter nr
20501101 0.0 1.0 mflowj 711000000
20501102 1.0 1.0 mflowj 712000000

```

```

* Integrate eecs mass flow rate

```

```

* name type factor init f c min max
20501200 "inteeccs" integral 1.0 0.0 0 3 0.0 4.8e6

```

```

* name no.
20501201 cntrlvar 110

```

```

* Controller for break vapor enthalpy - output SI units, break conditions
taken from donor volume.

```

```

*  $h_g = u_g + p \cdot v_g$ 

```

```

20501300 "v-enth" sum 1. 0. 1
20501301 0. 1. ug 120360000
20501302 1. cntrlvar 140

```

```

20501400 "v-p*vg" mult 1. 0. 1
20501401 p 120360000
20501402 cntrlvar 150

```

```

20501500 "v-1/rho" div 1. 1. 1
20501501 rhog 120360000

```

```

* Controller for break liquid enthalpy

```

```

*  $h_f = u_f + p \cdot v_f$ 

```

```

20501600 "f-enth" sum 1. 0. 1
20501601 0. 1. uf 120360000
20501602 1. cntrlvar 170

```

```

20501700 "f-pv" mult 1. 0. 1
20501701 p 120360000
20501702 cntrlvar 180

```

```

20501800 "l/rho" div 1. 1. 1
20501801 rhof 120360000

```

```

* Controller for break vapor mass flow rate

```

```
20501900 mflowg mult 0.05324 0. 1
20501901 voidgj 723000000
20501902 rhogj 723000000
20501903 velgj 723000000
```

```
*
* Controller for break fluid mass flow rate
```

```
20502000 mflowf mult 0.05324 0. 1
20502001 voidfj 723000000
20502002 rhofj 723000000
20502003 velfj 723000000
```

```
*
end
```



### LISTING 3 - RELAP5 Input for BS-3

```

* B&W Plant DHR LETDOWN INTERFACING LDCA - BS-3
*
* File:
*
*   rlp003.mdl
*
* Description:
*
*   This RELAP5/MD03 input deck is used to obtain the steam source term
*   resulting from an ISLOCA in the B&W Plant decay heat removal pump
*   discharge line. The break occurs in auxilliary building room 113.
*   This model was constructed from a long-term cooling deck written by
*   Craig Kullberg, a low-pressure injection system piping model written
*   by Everet Gruen, and an Ocone "generic" core decay heat model.
*
* Written by:
*
*   John Schroeder 6/91
*
100  new      transnt
101  run
102  british  british
* 104  none          * No restart file
*
*           alloc
105  1.0      2.0      10800.
*
110  air
115  1.0
*
*           end      min      max      opt      minor      major      restart
201  1.        1.0e-4   0.0010  3        10000     100000    50000
202  15.       1.0e-4   0.0050  3        1000      10000     10000
203  500.      1.0e-4   0.0100  3        500       10000     10000
204  3500.     1.0e-4   0.1000  3        100       1000      5000
*
* ===== Minor Edits =====
*
301  p          080020000 * Pressure at break
302  tempf      080020000 * Temperature at break
303  tempg      080020000 * Temperature at break
304  mflowj     723000000 * Total break flow rate
* 305  mflowj     021000000 *
306  mflowj     724000000
307  cntrlvar   190      * Break vapor mass flow rate
308  cntrlvar   130      * Break vapor enthalpy
309  cntrlvar   200      * Break liquid mass flow rate
310  cntrlvar   160      * Break liquid enthalpy
*
311  cputime    0
312  tmass      0
314  p          5120.0000 * top of vessel
315  mflowj     712000000 * chg
316  mflowj     711000000 * hpi
317  q          514010000 * mid plane energy
318  p          300010000 *
319  p          301010000 *
* 320  cntrlvar  110
321  cntrlvar  120      * Integrated injection flow
*
* ===== Trips =====
*
* 501 trip card starts transient by opening motor operated valve
* 502 trip card keeps valve open for a long time

```

- \* Trip 502 exists only to meet code requirement for a closing p.
- \* 503 opens the 1st relief valve PSV4849 on 320 psia
- \* 504 opens the 2nd relief valve FV5A on 75 psia
- \* 505 opens the 3rd relief valve PSV1550 on 450 psia

```

*
501 time 0 ge null 0 0.0 n * open boundary MOV
502 time 0 ge null 0 1.e6 n
* 503 p 30010000 ca null 0 320. n
506 time 0 ge null 0 0.0 n * open break at time 0.
*
598 time 0 lt null 0 1.e6 n
599 time 0 gt null 0 1.e6 n

```

----- Hydrodynamic Components -----

\* Time dependent volume for charging junction

```

*
8990000 TDVCHG tmdpvol
8990101 12.00 0. 3000.
8990102 0. 0. 0.
8990103 0. 0. 10
8990200 03 0
8990201 -1.0e99 2000. 70.
8990202 0.0 2000. 70.

```

- \* CHARGING FLOW RATE
- \* PERFORMANCE CURVES NOT AVAILABLE
- \* APPROXIMATED TO 300 GPM AT 2200 PSIA
- \* AND 700 GPM AT 200 PSIA.

```

* at power chg rate = 300*62.4*.00223 = 41.74
* run out mass flow rate, mass flow rate = 700*62.4*.00223=97.4 lbs/sec

```

```

*
7120000 CHGFLOW tmdpjun * LOOP chg FLOWRATE
7120101 899000000 300000000 0500
7120200 1 598 p 300010000
7120201 -1.00e+00 0.0 0.0 0.0
7120202 20. 97.4 0.0 0.0
7120203 200. 97.4 0.0 0.0
7120204 2200. 41.74 0.0 0.0

```

\* Time dependent volume for HPI and LPI junction

```

*
9000000 TDVLPi tmdpvol
9000101 12.00 0.0 3000.
9000102 0. 0. 0.
9000103 0. 0. 10
9000200 03 0
9000201 -1.0e99 2000. 70.
9000202 0.0 2000. 70.

```

\* Sum of Lpi and Hpi mass flow rates

```

*
7110000 ECCSFLOW tmdpjun * 2 HPI FLOWRATE + 0 LPI flow rate
7110101 900000000 300000000 1.4
7110200 1 598 p 300010000
7110201 -1.00e+00 0. 0.0 0.0
7110202 0. 214. 0.0 0.0
7110203 115. 214. 0.0 0.0
7110204 155. 214. 0.0 0.0
7110206 182. 214. 0.0 0.0
7110207 197. 214. 0.0 0.0
7110208 1614. 160. 0.0 0.0

```

- \* Component 300:
- \* 4 loops cold leg junction connection

```

*
3000000 COLDLG pipe
3000001 1
3000101 12.00 1
3000301 0.0 1
3000401 3024. 1
3000601 0.0 1
3000801 0.00015 2.42 1
3001001 00 1
3001201 003 2260. 557. 0. 0. 0. 1

```

```

* Component 508:
* the following data represent the downcomer and lower plenum
*

```

```

5080000 LWRPLM branch
5080001 2 0
5080101 0.0 12.000 1266.
5080102 0.0 0.0 0.0
5080103 0.00015 5.6655 00
5080200 003 2260. 557.
* from to area f loss r loss vcahs
5081101 300010000 508010000 12.0000 1.3180 1.3180 10100
5082101 508010000 514000000 32.8781 0.0 0.0 10100
* f vel. v vel. l vel.
5081201 0. 0. 0. * 37994.087
5082201 0. 0. 0. * 37994.087

```

```

* Component 514:
* the following data represent the core and upper plenum
*

```

```

5140000 CORE pipe
5140001 1
5140101 0.0 1
5140301 12. 1
5140401 1265. 1
5140601 90.0 1
5140701 12. 1
5140801 0.00015 0.040092 1
5141001 00 1
5141201 003 2194. 608. 0. 0. 0. 1

```

```

* Component 512:
* the following data represent the upper head and pressurizer
*

```

```

5120000 UPRPLM branch
5120001 1 0
5120101 0.0 12.000 2808.
5120102 0.0 90.0 12.00
5120103 0.00015 10.0 00
5120200 003 2194. 608.
5121101 514010000 512000000 0.0 0.1979 0.1979 10100
5121201 0. 0. 0. * 36815.350

```

```

9240000 VESSLOUT sngl jun
9240101 512010000 301000000 12.00 0.1200 0.1200 00002
9240201 0 0. 0. 0.0

```

```

* Component 301
*

```

```

3010000 HOTLEG pipe
3010001 1
3010101 12.00 1
3010301 0.0 1
3010401 3025. 1
3010601 0.0 1
3010801 0.00015 2.42 1
3011001 00 1

```

3011201 003 2194. 608. 0. 0. 0. 1

\*  
\* Single Junction -- delay heat removal pump suction line  
\*

2050000 DHRINLET sngljun  
2050101 301010000 010000000 0.0 0.0 0.0 01100  
2050201 1 0.0 0.0 0.0

\* Pipe  
\*

0100000 "12-CCA-4" pipe  
0100001 19  
0100101 0.6013 19  
0100301 4.0 19  
0100601 0.0 19  
0100801 1.5e-4 0.0 19  
0100901 0.0 0.0 1  
0100902 0.108 0.108 2  
0100903 0.108 0.108 3  
0100904 0.0 0.0 4  
0100905 0.216 0.216 5  
0100906 0.0 0.0 6  
0100907 0.0 0.0 9  
0100908 0.108 0.108 10  
0100909 0.0 0.0 11  
0100910 0.324 0.324 12  
0100911 0.0 0.0 13  
0100912 0.216 0.216 14  
0100913 0.0 0.0 15  
0100914 0.0 0.0 16  
0100915 0.216 0.216 17  
0100916 0.0 0.0 18  
0101001 00 19  
0101101 01000 18  
0101201 003 2194. 608. 0. 0. 0. 19  
0101301 0.0 0.0 0.0 18

\* Valve DN12  
\*

0150000 DN12 valve  
0150101 010010000 020000000 0.6013 1.0 1.0 00100  
0150201 1 0.0 0.0 0.0  
0150300 mtrvly  
0150301 501 502 0.1 0.0

\* Pipe -- suction line, 12 inch GCB-7  
\*

0200000 "12-GCB-7" pipe  
0200001 6  
0200101 0.8185 6  
0200301 4.0 6  
0200601 0.0 6  
0200801 1.5e-4 0.0 6  
0200901 0.0 0.0 1  
0200902 1.216 1.216 2  
0200903 0.0 0.0 3  
0200904 0.216 0.216 4  
0200905 1.0 1.0 5  
0201001 00 6  
0201101 01000 5  
0201201 003 50.100. 0. 0. 0. 6  
0201301 0.0 0.0 0.0 5

\* Junction of suction line with train 1-2  
\*

0230000 inletjun sngljun  
0230101 020010000 040000000 0.0 0.0 0.0 01100  
0230201 1 0.0 0.0 0.0

\*  
 \*  
 \* Junction of suction line with train 1-1  
 \*  
 0240000 inletjun sngljun  
 0240101 020010000 440000000 0.0 0.0 0.0 01100  
 0240201 1 0.0 0.0 0.0  
 \*  
 \* Piping to train 1-2 pump suction -- includes 2 1/2 inch bypass line  
 \* around valve DH-1518.  
 \*

0400000 "2.5GCB-7" pipe  
 0400001 13  
 0400101 0.8185 1  
 0400102 0.03322 2  
 0400103 0.03322 7  
 0400104 0.81850 13  
 0400201 0.03322 3  
 0400202 0.02215 4  
 0400203 0.03322 12  
 0400301 4.0 13  
 0400601 0.0 13  
 0400801 1.5e-4 0.0 13  
 0400901 1.0 1.0 1  
 0400902 0.216 0.216 2  
 0400903 0.648 0.648 3  
 0400904 0.0 0.0 4  
 0400905 0.648 0.648 5  
 0400906 0.216 0.216 6  
 0400907 1.216 1.216 7  
 0400908 0.0 0.0 8  
 0400909 0.216 0.216 9  
 0400910 0.216 0.216 10  
 0400911 0.0 0.0 11  
 0400912 1.216 1.216 12  
 0401001 00 13  
 0401101 01000 3  
 0401102 00000 4  
 0401103 01000 6  
 0401104 00000 7  
 0401105 01000 12  
 0401201 003 50.100. 0. 0. 0. 13  
 0401301 0.0 0.0 0.0 12  
 \*

\* Single Junction (Component 41)  
 \*  
 0410000 inletjun sngljun  
 0410101 040010000 050000000 0.0 0.0 0.0 01100  
 0410201 1 0.0 0.0 0.0  
 \*

\* pipe (Component 50)  
 \*  
 0500000 "18-GCB-8" pipe  
 0500001 3  
 0500101 1.6467 3  
 0500301 4.0 3  
 0500601 0.0 3  
 0500801 1.5e-4 0.0 3  
 0500901 1.216 1.216 1  
 0500902 1.0 1.0 2  
 0501001 00 3  
 0501101 01000 2  
 0501201 003 50.100. 0. 0. 0. 3  
 0501301 0.0 0.0 0.0 2  
 \*

\* Single Junction (Component 51)  
 \*  
 0510000 inletjun sngljun

0510101 050010000 060000000 0.0 0.0 0.0 01100  
0510201 1 0.0 0.0 0.0

\*  
\* pipe (Component 60)  
\*

0600000 "18-HCB-1" pipe  
0600001 1  
0600101 1.6941 1  
0600301 4.0 1  
0600601 0.0 1  
0600801 1.5e-4 0.0 1  
0601001 00 1  
0601201 003 50. 100. 0. 0. 0. 1

\* Single Junction (Component 63)  
\*

0630000 inletjun sngljun  
0630101 060010000 080000000 0.0 0.0 0.0 01100  
0630201 1 0.0 0.0 0.0

\* pipe (Component 80)  
\*

0800000 "18-GCB-8" pipe  
0800001 2  
0800101 1.6467 2  
0800301 4.0 2  
0800601 0.0 2  
0800801 1.5e-4 0.0 2  
0800901 0.0 0.0 1  
0801001 00 2  
0801101 01000 1  
0801201 003 50. 100. 0. 0. 6. 2  
0801301 0.0 0.0 0.0 1

\* Second parallel piping run begins here  
\*

\* pipe (Component 440)  
\*

4400000 "2.5GCB-7" pipe  
4400001 13  
4400101 0.8185 1  
4400102 0.03322 2  
4400103 0.03322 7  
4400104 0.81850 13  
4400201 0.03322 3  
4400202 0.03322 4  
4400203 0.03322 12  
4400301 4.0 13  
4400601 0.0 13  
4400801 1.5e-4 0.0 13  
4400901 1.0 1.0 1  
4400902 0.216 0.216 2  
4400903 0.648 0.648 3  
4400904 0.0 0.0 4  
4400905 0.648 0.648 5  
4400906 0.216 0.216 6  
4400907 1.216 1.216 7  
4400908 0.0 0.0 8  
4400909 0.216 0.216 9  
4400910 0.216 0.216 10  
4400911 0.0 0.0 11  
4400912 1.216 1.216 12  
4401001 00 13  
4401101 01000 6  
4401102 00000 7  
4401103 01000 12  
4401201 003 50. 100. 0. 0. 0. 13  
4401301 0.0 0.0 0.0 12

```

*
*   Single Junction (Component 41)
*
4410000 inletjun   sngljun
4410101 440010000 450000000 0.0 0.0 0.0 01100
4410201 1 0.0    0.0    0.0
*
*   pipe   (Component 50)
*
4500000 "18-GCB-8"   pipe
4500001 3
4500101 1.6467 3
4500301 4.0    3
4500601 0.0    3
4500801 1.5e-4 0.0    3
4500901 1.216 1.216 1
4500902 1.0    1.0    2
4501001 00     3
4501101 01000 2
4501201 003   50. 100. 0. 0. 0. 3
4501301 0.0   0.0 0.0 2
*
*   Single Junction (Component 51)
*
4510000 inletjun   sngljun
4510101 450010000 460000000 0.0 0.0 0.0 01100
4510201 1 0.0    0.0    0.0
*
*   pipe   (Component 60)
*
4600000 "18-HCB-1"   pipe
4600001 1
4600101 1.6941 1
4600301 4.0    1
4600601 0.0    1
4600801 1.5e-4 0.0    1
4601001 00     1
4601201 003   50. 100. 0. 0. 0. 1
*
*   Single Junction (Component 63)
*
4630000 inletjun   sngljun
4630101 460010000 480000000 0.0 0.0 0.0 01100
4630201 1 0.0    0.0    0.0
*
*   pipe   (Component 80)
*
4800000 "18-GCB-8"   pipe
4800001 2
4800101 1.6467 2
4800301 4.0    2
4800601 0.0    2
4800801 1.5e-4 0.0    2
4800901 0.0    0.0    1
4801001 00     2
4801101 01000 1
4801201 003   50. 100. 0. 0. 0. 2
4801301 0.0   0.0 0.0 1
*
*   Break for BS-2, located at DHR cooler 1-2
*
7230000 BREAK-1   valve   * fvcahs
7230101 080010000 902000000 1.6467 0.    0.    000100
7230201 1        0.    0.    0.
7230300 trpvlv
7230301 506
*
*   Break for BS-2, located at DHR cooler 1-1

```

```

*
7240000 BREAK-2 valve * fvcahs
7240101 480010000 902000000 1.6467 0. 0. 000100
7240201 1 0. 0. 0.
7240300 trpvlv
7240301 506

```

```

* Time-dependent volume downstream of the leak

```

```

*
9020000 AUXBLDG tmdpvol
9020101 18.40 0. 3000.
9020102 0 0 0
9020103 0 0 10
9020200 03 0
9020201 0.0 15. 213.

```

```

* ----- Heat Structures -----

```

```

* Core heat structure

```

```

*
15151000 12 9 2 1 0.
15151100 0 1
15151101 5 0.01542 1 0.01571 2 0.01792
15151201 2 5 3 6 4 8
15151301 .85 2 .9 3 1. 4 1.4 5 0. 6
15151400 0
15151401 2000. 6 760. 7 710. 8 650. 9
15151501 0 0 0 0 0 12
15151601 514010000 00000 1 0 4144.5 12
15151701 1 0.0778 0. 0. 1
15151702 1 0.0885 0. 0. 2
15151703 1 0.0877 0. 0. 3
15151704 1 0.0860 0. 0. 4
15151705 1 0.0847 0. 0. 5
15151706 1 0.0839 0. 0. 6
15151707 1 0.0840 0. 0. 7
15151708 1 0.0848 0. 0. 8
15151709 1 0.0862 0. 0. 9
15151710 1 0.0879 0. 0. 10
15151711 1 0.0859 0. 0. 11
15151712 1 0.0627 0. 0. 12
* dia ht lngf ht lngf g lngf g lngf glassf glassr boilf strno * 902000
15151801 0. 100. 100. 0. 0. 0. 0. 0. 1. 12 * 902000
15151901 0.0415 100. 100. 0. 0. 0. 0. 0. 1. 12 * 902000

```

```

* thermal properties of uo2 - composition 2

```

```

* -----
* mtrl type th.con ht.cap material
2P100200 tbl/fctn 1 1 * uo2
* -----

```

```

* thermal properties of uo2

```

```

*
* temperature th.cond
* 20100201 188.6 1.284e-3
20100201 0. 1.284e-3
20100202 332.6 1.1235e-3
20100203 440.6 9.951e-4
20100204 500.0 9.2806e-4
20100205 650.0 7.4194e-4
20100206 800.0 7.4361e-4
20100207 950.0 6.7750e-4
20100208 1100.0 6.2278e-4
20100209 1250.0 5.7722e-4
20100210 1400.0 5.3889e-4
20100211 1500.0 5.0639e-4

```



20100212	1700.0	1.7889e-4
20100213	1850.0	4.5528e-4
20100214	2000.0	4.3556e-4
20100215	2150.0	4.1861e-4
20100216	2300.0	4.0472e-4
20100217	2450.0	3.9306e-4
20100218	2600.0	3.8389e-4
20100219	3100.0	3.6750e-4
20100220	3600.0	3.7028e-4
20100221	4100.0	3.9056e-4
20100222	4600.0	4.2722e-4
20100223	5100.0	4.8057e-4

	temperature	vol ht ca <sub>r</sub>
* 20100251	32.0	34.45
20100251	0.	34.45
20100252	122.0	38.35
20100253	212.0	40.95
20100254	392.0	43.55
20100255	752.0	46.80
20100256	2012.0	51.35
20100257	2732.0	52.65
20100258	3092.0	56.55
20100259	3452.0	63.05
20100260	3812.0	77.80
20100261	4352.0	83.70
20100262	4532.0	94.25
20100263	4712.0	98.15
20100264	4892.0	100.10
20100265	5144.0	101.40
20100266	8000.0	101.40

\*\*\*\*\*  
 \* thermal properties of fuel gap - composition 3  
 \*\*\*\*\*

* mtrl type	th.con	ht.cap	material
20100300 tbl/fctn	1	1	* fuel gap

-----  
 \* thermal properties of fuel gap  
 -----

\*values of thermal conductivity were derived from matpro and a frapcon  
 \*computer run at constant power over the total burnup interval  
 \*

\*burnup = 0.00000 pressure = .12362e+04 gap width = .00213  
 \*he frac = .10000e+01 kr frac = 0. xe frac = 0.

* 20100301	temperature	th. cond.
20100301	70.000	2.52892e-05
20100301	0.000	2.52892e-05
20100302	300.000	3.14014e-05
20100303	500.000	3.70561e-05
20100304	700.000	4.23747e-05
20100305	900.000	4.74311e-05
20100306	1100.000	5.22745e-05
20100307	1300.000	5.69395e-05
20100308	1500.000	6.14522e-05
20100309	1700.000	6.58324e-05
20100310	1900.000	7.00957e-05
20100311	2100.000	7.42548e-05
20100312	2300.000	7.83201e-05
20100313	2500.000	8.23004e-05
20100314	2700.000	8.62029e-05
20100315	2900.000	9.00341e-05
20100316	3100.000	9.37993e-05
20100317	3300.000	9.75033e-05
20100318	3500.000	1.01150e-04
20100319	3700.000	1.04744e-04
20100320	3900.000	1.08288e-04
20100321	4100.000	1.11784e-04

20100322	4300.000	1.15236e-04
20100323	4500.000	1.18646e-04
20100324	4700.000	1.22017e-04
20100325	4900.000	1.25349e-04
20100326	5100.000	1.28645e-04
20100327	5300.000	1.31907e-04

* temperature vol ht cap		
20100351	0.0	0.000075
20100352	5400.0	0.000075

\* thermal properties of cladding - composition 4

*crdno	mtrl type	th.con	ht.cap	material
20100400	tbl/fctn	1	1	* cladding

\* thermal properties of cladding

* temperature th.cond		
* 20100401	50.0	1.9267e-3
20100401	0.0	1.9267e-3
20100402	392.0	1.9267e-3
20100403	752.0	2.2478e-3
20100404	1112.0	2.7297e-3
20100405	1472.0	3.0508e-3
20100406	1832.0	3.5325e-3
20100407	2192.0	4.0142e-3
20100408	2552.0	4.8169e-3
20100409	2912.0	5.7803e-3
20100410	3272.0	7.0647e-3
20100411	3632.0	8.8311e-3
20100412	3992.0	1.0918e-2

* temperature vol ht cap		
20100451	0.0	28.392
20100452	1480.3	34.476
20100453	1675.00	85.176
20100454	1787.5	34.370
20100455	3500.0	34.476

\* table number 1 - core power vs. time

\* this table represents a best-estimate of fission product decay  
 \* heat using the ans standard plus a contribution from actinides.  
 \* reference: work by c. b. davis

\* Model modified to reflect the B&W Plant power level - John Schroeder

* type	trip	factor	power(mw)
* 20200100 power	0	1.0	2772.
* sec normalized power			
20200101	-1.	0.	* start at one second
* 20200101	-1.	1.0	
* 20200102	0.	1.0	
* 20200103	.1	.8382	
* 20200104	.2	.5720	
* 20200105	.3	.3806	
* 20200106	.4	.2792	
* 20200107	.5	.2246	
* 20200108	.6	.1904	
* 20200109	.7	.1672	
* 20200110	.8	.1503	
* 20200111	.9	.1376	
20200112	1.0	.1275	

```

20200113      1.5      .1032
20200114      2.      .09884
20200115      3.      .09209
20200116      4.      .08690
20200117      5.      .08271
20200118      6.      .07922
20200119      8.      .07375
20200120     10.      .06967
20200121     15.      .06251
20200122     20.      .05751
20200123     30.      .05050
20200124     40.      .04591
20200125     50.      .04246
20200126     60.      .03977
20200127     80.      .03604
20200128    100.      .03357
20200129    125.      .03145
20200130    150.      .02997
20200131    200.      .02798
20200132    300.      .02565
20200133    400.      .02418
20200134    500.      .02307
20200135    600.      .02217
20200136    800.      .02073
20200137   1000.      .01959
20200138   1250.      .01844
20200139   1500.      .01749
20200140   2000.      .01600
20200141   2500.      .01489
20200142   3000.      .01401
20200143   3500.      .01331
20200144   4000.      .01274
20200145   5000.      .01185
20200146   6000.      .01118
20200147   7000.      .01067
20200148   8000.      .01025
20200149   9000.      .009895
20200150  10000.      .009596
20200151  15000.      .008553
20200152  20000.      .007902

```

```

*
* ===== Control Variables =====
*

```

```

20500000 4095

```

```

* Sum of total eccs

```

```

*      name      type      factor      init      f      c
20501100 "ecctot"  sum      2.2046      0.0      1
*
*      a0      coeff      name      parameter no.
20501101 0.0      1.0      mflowj      711000000
20501102      1.0      mflow      712000000

```

```

* Integrate eccs mass flow rate

```

```

*      name      type      factor      init      f c      min      max
20501200 "inteccs"  integral 1.0      0.0      0.3      0.0      4.8e6

```

```

*      name      no.
20501201 cntrlvar 110

```

```

* Controller for break vapor enthalpy - output SI units, break conditions
* taken from donor volume.

```

```

* hg = ug + p*vg

```

```

20501300 "v-enth" sum      1.      0.      1

```

```

20501301 0.      1.      ug      080020000
20501302      1.      cntrlvar 140
*
20501400 "v-p*vg" mult  1.      0.      1
20501401      p      080020000
20501402      cntrlvar 150
*
20501500 "v-1/rho" div 1.      1.      1
20501501      rhog      080020000
*
* Controller for break liquid enthalpy
*
* hf = uf + p*vf
*
20501600 "f-enth" sum  1.      0.      1
20501601 0.      1.      uf      080020000
20501602      1.      cntrlvar 170
*
20501700 "f-pv" mult  1.      0.      1
20501701      p      080020000
20501702      cntrlvar 180
*
20501800 "1/rho" div 1.      1.      1
20501801      rho^      080020000
*
* Controller for break vapor mass flow rate
*
20501900 mflowg mult  0.05324 0.      1
20501901      voidgj      723000000
20501902      rhogj      723000000
20501903      velgj      723000000
*
* Controller for break fluid mass flow rate
*
20502000 mflowf mult  0.05324 0.      1
20502001      voidfj      723000000
20502002      rho^fj      723000000
20502003      velfj      723000000
*
.end

```

## LISTING 4 - RELAP5 Input for BS-4

```

* B&W Plant DHR LETDOWN INTERFACING LOCA - BS-2
*
* File:
*
*   rlp004.mdl
*
* Description:
*
*   This RELAP5/MOD3 input deck is used to obtain the source term
*   resulting from a ISLOCA in the B&W Plant decay heat removal pump
*   discharge line. The break occurs in auxiliary building room 113.
*   This model was constructed from a long-term cooling deck written by
*   Craig Kullberg, a low-pressure injection system piping model written
*   by Everett Gruen, and an Ocone "generic" core decay heat model.
*
* Written by:
*
*   John Schroeder 6/91
*
100  new      transient
101  run
102  british  british
* 104  none          * No restart file
*
*
*
*   alloc
105  1.0      2.0      10800.
*
*   air
*   1.0
*
*
*   end      min      max      opt      minor      major      restart
201  1.       1.0e-4  0.0010  3        10000     10000     50000
102  15.      1.0e-4  0.0100  3        100       1000      5000
203  1500.    1.0e-4  0.1000  3        100       1000      5000
204  3000.    1.0e-4  1.0000  3        100       1000      5000
*
* ===== Minor Edits =====
*
301  p          120010000 * Pressure at break
302  tempf      120010000 * Temperature at break
303  tempg      120010000 * Temperature at break
304  mflowj     723000000 * Total break flow rate
* 305  mflowj     021000000 *
* 306  mflowj     724000000 *
307  cntrlvar   190      * Break vapor mass flow rate
308  cntrlvar   130      * Break vapor enthalpy
309  cntrlvar   200      * Break liquid mass flow rate
310  cntrlvar   160      * Break liquid enthalpy
*
311  cputime    0
312  tmass      0
314  p          512010000 * top of vessel
315  mflowj     712000000 * chg
316  mflowj     711000000 * hpl
317  q          514010000 * mid plane energy
318  p          300010000 *
319  p          301010000 *
* 320  cntrlvar  110
* 321  cntrlvar  120      * Integrated injection flow
*
* ===== Trip Cards =====
*
* 501 trip card starts transient by opening motor operated valve
* 502 trip card keeps valve open for a long time

```

- \* Trip 502 exists only to meet code requirement for a closing trip.
- \* 503 opens the 1st relief valve PSV4848 on 320 psia
- \* 504 opens the 2nd relief valve FV5A on 75 psia
- \* 505 opens the 3rd relief valve PSV1550 on 450 psia

```

501   time    0          ge null 0  0.0  n   * open boundary MOV
502   time    0          ge null 0  1.e6 n
* 503   p      30010000 ge null 0  320. n
504   time    0          ge null 0  0.0  n   * open break at time 0.
*
598   time    0          lt null 0  1.e6 n
599   time    0          gt null 0  1.e6 n

```

\* ===== Hydrodynamic Components =====

\* Time dependent volume for charging junction

```

8990000 TDVCHG  tmdpvol
8990101 12.00  0.      3000.
8990102 0.      0.      0.
8990103 0.      0.      10
8990200 03      0
8990201 -1.0e99  2000.  70.
8990202 0.0     2000.  70.

```

\* CHARGING FLOW RATE  
 \* PERFORMANCE CURVES NOT AVAILABLE  
 \* APPROXIMATED TO 300 GPM AT 2200 PSIA  
 \* AND 700 GPM AT 200 PSIA.

\* at power chg rate = 300\*62.4\*.00223 = 41.74  
 \* run out mass flow rate, mass flow rate = 700\*62.4\*.00223=97.4 lbs/sec

```

7120000 CHGFLOW  tmdpjun      * LOOP chg FLOWRATE
7120101 899000000 3000000000 .0500
7120200 1          598      p      300010000
7120201 -1.00e+00 0.0      0.0      0.0
7120202 20.         97.4     0.0      0.0
7120203 200.        97.4     0.0      0.0
7120204 2200.       41.74    0.0      0.0

```

\* Time dependent volume for HPI and LPI junction

```

9000000 TDVLP1  tmdpvol
9000101 12.00  0.0     3000.
9000102 0.      0.      0.
9000103 0.      0.      10
9000200 03      0
9000201 -1.0e99  2000.  70.
9000202 0.0     2000.  70.

```

\* Sum of Lpi and Hpi mass flow rates

```

7110000 ECCSFLOW  tmdpjun      * 2 HPI + 1 LPI flow rate
7110101 900000000 3000000000 1.4
7110200 1          598      p      300010000
7110201 -1.00e+00 0.      0.0      0.0
7110202 0          843.     0.0      0.0
7110203 115.        843.     0.0      0.0
7110204 156.        701.     0.0      0.0
7110206 192.        353.     0.0      0.0
7110207 197.        214.     0.0      0.0
7110208 1615.       160.     0.0      0.0

```

\* Component 300:  
 \* 4 loops cold leg junction connection

```

*
3000000 COLDLG pipe
3000301 1
3000101 12.00 1
3000301 0.0 1
3000401 3024. 1
3000601 0.0 1
3000801 0.00015 2.42 1
3001001 00 1
3001201 003 2260. 557. 0. 0. 0. 1
*
* Component 508:
* the following data represent the downcomer and lower plenum
*
F080000 LWRPLM branch
5080001 2 0
5080101 0.0 12.000 1266.
5080102 0.0 0.0 0.0
5080103 0.00015 5.6655 00
5080200 003 2260. 557.
* from to area loss r loss vcats
5081101 300010000 508010000 12.0000 1.3180 1.3180 10100
5082101 508010000 514000000 32.8781 0.0 0.0 10100
* f vel. v vel. i vel.
5081201 0. 0. 0. * 37994.087
5082201 0. 0. 0. * 37994.087
*
* Component 514:
* the following data represent the core and upper plenum
*
5140000 CORE pipe
5140001 1
5140101 0.0 1
5140301 12. 1
5140401 1265. 1
5140601 90.0 1
5140701 12. 1
5140801 0.00015 0.040092 1
5141001 00 1
5141201 003 2194. 608. 0. 0. 0. 1
*
* Component 512:
* the following data represent the upper head and pressurizer
*
5120000 UPPRPLM branch
5120001 1 0
5120101 0.0 12.000 2808.
5120102 0.0 90.0 12.00
5120103 0.00015 10.0 00
5120200 003 2194. 608.
5121101 514010000 512000000 0.0 0.1979 0.1979 10100
5121201 0. 0. 0. * 36815.350
*
*
9240000 VESSLOUT anglun
9240101 512010000 301000000 12.00 0.1200 0.1200 00002
9240201 0 0.0 0.0
*
* Pipe
*
3010000 HOTLEG pipe
3010001 1
3010101 12.00 1
3010301 0.0 1
3010401 3025. 1
3010601 0.0 1
3010801 0.00015 2.42 1
3011001 00 1

```

3011201 2194. 608. 0. 0. 0. 1

\* pipe (next 120) INCLUDES 18, 12, AND 10 INCH PIPE

1200000 pipe \* first 35 volumes removed

1200001 25  
1200103 0.5731 25  
1200301 4.0 25  
1200601 0.0 25  
1200801 1.5e-4 0.0 25  
1200925 0.0 0.0 1  
1200926 3.0 3.0 2  
1200927 0.216 0.216 4  
1200928 0.0 0.0 5  
1200929 1.0 1.0 6  
1200930 0.0 0.0 8  
1200931 0.216 0.216 9  
1200932 0.0 0.0 10  
1200933 0.216 0.216 11  
1200934 0.0 4.0 13  
1200935 0.216 0.216 14  
1200936 0.0 0.0 15  
1200937 0.216 0.216 16  
1200938 0.0 0.0 20  
1200939 0.216 0.216 21  
1200940 0.0 0.0 24  
1201001 0.0 25  
1201101 01000 24  
1201201 003 90. 100. 0. 0. 0. 25  
1201301 0.0 0.0 0.0 24

\* Single Junction

1390000 inletjun sngljun  
1390101 120010000 140000000 0.0 0.0 0.0 01100  
1390201 1 0.0 0.0 0.0

\* LPI discharge piping

1400000 "10-CCB-6" pipe  
1400001 41  
1400101 0.5731 41  
1400201 0.3821 1  
1400202 0.5731 40  
1400301 4.0 41  
1400601 0.0 41  
1400801 1.5e-4 0.0 41  
1400901 0.0 0.0 2  
1400902 0.216 0.216 3  
1400903 0.0 0.0 5  
1400904 0.216 0.216 6  
1400905 0.0 0.0 7  
1400906 1.0 1.0 8  
1400907 0.0 0.0 10  
1400908 0.216 0.216 11  
1400909 0.0 0.0 13  
1400910 0.216 0.216 14  
1400911 0.108 0.108 16  
1400912 0.0 0.0 22  
1400913 0.108 0.108 23  
1400914 0.0 0.0 27  
1400915 0.216 0.216 28  
1400916 0.0 0.0 32  
1400917 0.216 0.216 33  
1400918 0.0 0.0 35  
1400919 0.216 0.216 36  
1400920 0.0 0.0 40  
1401001 0.0 41



```

1401101 01000 40
1401201 003 50. 100. 0. 0. 0. 41
1401301 0.0 0.0 0.0 40

```

\* Single Junction -- inlet to LPI discharge. check valves have failed

```

1410000 inletjun      sngljun
1410101 140010000 301010000 0.0 0.0 0.0 01100
1410201 1 0.0 0.0 0.0

```

\* Break for BS-7, located at DHR cooler 1-2

```

7230000 BREAK-1 valve * fvczhs
7230101 902000000 120000000 0.5731 0. 0. 000100
7230201 1 0. 0. 0.
7230300 trpvlv
7230301 506

```

\* Time-dependent volume downstream of the leak

```

9020000 AUXBLDG tmdpvol
9020101 18.40 0. 3000.
9020102 0 0 0
9020103 0 0 10
9020200 03 0
9020201 0.0 15. 213.

```

\* ===== Heat Structures =====

\* Core heat structure

```

15151000 12 9 2 1 0
15151100 0 1
15151101 5 0.01542 1 0.01571 2 0.01792
15151201 2 5 3 6 4 8
15151301 .85 2 .9 3 1.4 1.4 5 0.6
15151400 0
15151401 2000. 6 760. 7 710. 8 650.9
15151501 0 0 0 0 0 12
15151601 514010000 00000 1 0 4144.5 12
15151701 1 0.0778 0. 0. 1
15151702 1 0.0885 0. 0. 2
15151703 1 0.0877 0. 0. 3
15151704 1 0.0860 0. 0. 4
15151705 1 0.0847 0. 0. 5
15151706 1 0.0839 0. 0. 6
15151707 1 0.0840 0. 0. 7
15151708 1 0.0848 0. 0. 8
15151709 1 0.0852 0. 0. 9
15151710 1 0.0879 0. 0. 10
15151711 1 0.0859 0. 0. 11
15151712 1 0.0627 0. 0. 12
* dia ht lngf ht lngf g lngf g lngf g lossf g lossf boilf strng * 902000
15151801 0. 100. 100. 0. 0. 0. 0. 0. 1. 12 * 902000
15151901 0.0415 100. 100. 0. 0. 0. 0. 0. 1. 12 * 902000

```

\* thermal properties of uo2 - composition 2

```

* mtrl type th.con ht.cap material
20100200 tb1/fctn 1 1 * uo2

```

\* thermal properties of uo2

```

* temperature th.cond
* 20100201 188.6 1.284e-3

```

20100201	0.	1.284e-3
20100202	332.6	1.1235e-3
20100203	440.6	9.951e-4
20100204	500.0	9.2806e-4
20100205	650.0	7.4194e-4
20100206	900.0	7.4361e-4
20100207	950.0	6.7750e-4
20100208	1100.0	6.7278e-4
20100209	1250.0	5.7722e-4
20100210	1400.0	5.3889e-4
20100211	1500.0	5.0639e-4
20100212	1700.0	4.7889e-4
20100213	1850.0	4.5528e-4
20100214	2000.0	4.3556e-4
20100215	2150.0	4.1861e-4
20100216	2300.0	4.0472e-4
20100217	2450.0	3.9306e-4
20100218	2600.0	3.8389e-4
20100219	3100.0	3.6750e-4
20100220	3600.0	3.7028e-4
20100221	4100.0	3.9056e-4
20100222	4600.0	4.2722e-4
20100223	5100.0	4.8056e-4

	temperature	vol ht cap
* 20100251	32.0	34.45
20100251	0.	34.45
20100252	122.0	38.35
20100253	212.0	40.95
20100254	392.0	43.55
20100255	752.0	46.80
20100256	2012.0	51.35
20100257	2732.0	52.65
20100258	3092.0	56.55
20100259	3452.0	63.05
20100260	3812.0	72.80
20100261	4352.0	89.70
20100262	4532.0	94.25
20100263	4712.0	98.15
20100264	4892.0	100.10
20100265	5144.0	101.40
20100266	8000.0	101.40

\*\*\*\*\*  
 \* thermal properties of fuel gap - composition 3  
 \*\*\*\*\*

* mtrl type	th.con	ht.cap	material
20100300 tbl/fctn	1	1	* fuel gap

-----  
 \* thermal properties of fuel gap  
 -----

\*values of thermal conductivity were derived from matpro and a frapcon

\*computer run at constant power over the total burnup interval

\* burnup = 0.00000 pressure = .12362e+04 gap width = .00213

\* he frac = .10000e+01 kr frac = 0. xe frac = 0.

* 20100301	temperature	th cond.
20100301	70.000	52897e-05
20100301	0.000	2.5102e-05
20100302	300.000	3.14114e-05
20100303	500.000	3.70561e-05
20100304	700.000	4.23747e-05
20100305	10.000	4.74311e-05
20100306	1100.000	5.22745e-05
20100307	1300.000	5.69395e-05
20100308	1500.000	6.14522e-05
20100309	1700.000	6.58324e-05
20100310	1900.000	7.00957e-05

20100311	2100.000	7.42548e-05
20100312	2300.000	7.83201e-05
20100313	2500.000	8.23004e-05
20100314	2700.000	8.62029e-05
20100315	2900.000	9.00341e-05
20100316	3100.000	9.37893e-05
20100317	3300.000	9.75033e-05
20100318	3500.000	1.01150e-04
20100319	3700.000	1.04744e-04
20100320	3900.000	1.08288e-04
20100321	4100.000	1.11784e-04
20100322	4300.000	1.15236e-04
20100323	4500.000	1.18646e-04
20100324	4700.000	1.22017e-04
20100325	4900.000	1.25349e-04
20100326	5100.000	1.28645e-04
20100327	5300.000	1.31907e-04

	temperature	vol ht cap
20100351	0.0	0.000075
20100352	5400.0	0.000075

\*\*\*\*\*  
 \* thermal properties of cladding - composition 4  
 \*\*\*\*\*

*crdno	mtpl type	th.con	ht.cap	material
20100400	th1/fctn	1	1	* cladding

\*\*\*\*\*  
 \* thermal properties of cladding  
 \*\*\*\*\*

	temperature	th.cond
* 20100401	50.0	1.9267e-3
20100401	0.0	1.9267e-3
20100402	392.0	1.9267e-3
20100403	752.0	2.2478e-3
20100404	1112.0	2.7297e-3
20100405	1472.0	3.0508e-3
20100406	1832.0	3.5325e-3
20100407	2192.0	4.0142e-3
20100408	2552.0	4.8169e-3
20100409	2912.0	5.7803e-3
20100410	3272.0	7.0647e-3
20100411	3632.0	8.8311e-3
20100412	3992.0	1.0918e-2

	temperature	vol ht cap
20100451	0.0	26.392
20100452	1480.3	34.476
20100453	1675.00	85.176
20100454	1787.5	34.370
20100455	3500.0	34.476

\*\*\*\*\*  
 \* table number 1 - core power vs. time  
 \*\*\*\*\*

\* this table represents a best-estimate of fission product decay  
 \* heat using the ans standard plus a contribution from actinides.  
 \* reference: work by c. b. davis

\* Model modified to reflect the B&W Plant power level - John Schroeder

	type	trip	factor	power(mw)
20200100	power	0	1.0	2772.

	sec	normalized power
20200101	-1.	0. * start at one second
* 20200101	-1.	1.0

```

* 20200102      0.      1.0
* 20200103      .1      .8382
* 20200104      .2      .5720
* 20200105      .3      .3806
* 20200106      .4      .2792
* 20200107      .5      .2246
* 20200108      .6      .1904
* 20200109      .7      .1672
* 20200110      .8      .1503
* 20200111      .9      .1376
20200112      1.0      .1275
20200113      1.5      .1032
20200114      2.      .09884
20200115      3.      .09209
20200116      4.      .08690
20200117      5.      .08271
20200118      6.      .07922
20200119      8.      .07375
20200120     10.      .06967
20200121     15.      .06251
20200122     20.      .05751
20200123     30.      .05090
20200124     40.      .04591
20200125     50.      .04246
20200126     60.      .03977
20200127     80.      .03604
20200128    100.      .03357
20200129    125.      .03145
20200130    150.      .02997
20200131    200.      .02798
20200132    300.      .02565
20200133    400.      .02418
20200134    500.      .02307
20200135    600.      .02217
20200136    800.      .02073
20200137   1000.      .01959
20200138   1250.      .01844
20200139   1500.      .01749
20200140   2000.      .01600
20200141   2500.      .01489
20200142   3000.      .01401
20200143   3500.      .01331
20200144   4000.      .01274
20200145   5000.      .01185
20200146   6000.      .01118
20200147   7000.      .01067
20200148   8000.      .01025
20200149   9000.      .009895
20200150  10000.      .009596
20200151  15000.      .008553
20200152  20000.      .007902

```

```

* ***** Control Variables *****

```

```

20500000 4095

```

```

* Sum of total eccls

```

```

*      name      type      factor      init      f      c
20501100 "ecctot"    sum      2.2046      0.0      1
*
*      a0      coeff      name      parameter no.
20501101 0.0      1.0      mflowj      711000000
20501102      1.0      mflowj      712000000

```

```

* Integrate eccls mass flow rate

```

```

*      name      type      factor      init      f c      min      max

```

```

20501200 "inteccs" integral 1.0 0.0 0 3 0.0 4.8e6
*
* name no.
20501201 cntrlvar 110
*
* Controller for break vapor enthalpy - output SI units, break conditions
* taken from donor volume.
*
*  $hg = ug + p \cdot vg$ 
*
20501300 "v-enth" sum 1. 0. 1
20501301 0. 1. ug 120010000
20501302 1. cntrlvar 140
*
20501400 "v-p*vg" mult 1. 0. 1
20501401 p 120010000
20501402 cntrlvar 150
*
20501500 "v-1/rho" div 1. 1. 1
20501501 rhog 120010000
*
* Controller for break liquid enthalpy
*
*  $hf = uf + p \cdot vf$ 
*
20501600 "f-enth" sum 1. 0. 1
20501601 0. 1. uf 120010000
20501602 1. cntrlvar 170
*
20501700 "f-pv" mult 1. 0. 1
20501701 p 120010000
20501702 cntrlvar 180
*
20501800 "1/rho" div 1. 1. 1
20501801 rhof 120010000
*
* Controller for break vapor mass flow rate
*
20501900 mflowg mult 0.05324 0. 1
20501901 voidgj 723000000
20501902 rhogj 723000000
20501903 velgj 723000000
*
* Controller for break fluid mass flow rate
*
20502000 mflowf mult 0.05324 0. 1
20502001 voidfj 723000000
20502002 rhofj 723000000
20502003 velfj 723000000
*
.end

```



```

502 time 0 ge null 0 1.e6 n
*
503 [ 301010000 ge null 0 2450. n * FORV
*
* ===== Hydrodynamic Components =====
*
* Time dependent volume for charging junction
*
8990000 TDVCHG tmdpvol
8990101 12.00 0. 3000.
8990102 0. 0. 0.
8990103 0. 0. 10
8990200 03 0
8990201 -1.0e99 2000. 70.
8990202 0.0 2000. 70.
*
* Charging flow rate
* approximated to 300 gpm at 2200 psia
* and 700 gpm at 200 psia.
*
* at power chg rate = 300*62.4*.00223 = 41.74
* run out mass flow rate, mass flow rate = 700*62.4*.00223 = 97.4 lbs/sec
*
7120000 CHGFLOW tmdpjun * LOOP chg FLOWRATE
7120101 899000000 300000000 .0500
7120200 1 501 p 300010000
7120201 -1.00e+00 0.0 0.0 0.0
7120202 20. 97.4 0.0 0.0
7120203 200. 97.4 0.0 0.0
7120204 2200. 41.74 0.0 0.0
*
* Time dependent volume for HPI and LPI junction
*
9000000 TDVLP1 tmdpvol
9000101 12.00 0.0 3000.
9000102 0. 0. 0.
9000103 0. 0. 10
9000200 03 0
9000201 -1.0e99 2000. 70.
9000202 0.0 2000. 70.
*
* Sum of LPI and HPI mass flow rates.
*
7110000 ECCSFLOW tmdpjun * 1 HPI + 2 LPI flow rate
7110101 900000000 300000000 1.4
7110200 1 501 p 300010000
7110201 -1.00e+00 0. 0.0 0.0
7110202 0. 1361. 0.0 0.0
7110203 115. 1361. 0.0 0.0
7110204 134. 1220. 0.0 0.0
7110206 156. 1081. 0.0 0.0
7110207 166. 942. 0.0 0.0
7110208 177. 811. 0.0 0.0
7110209 184. 664. 0.0 0.0
7110210 188. 524. 0.0 0.0
7110211 192. 385. 0.0 0.0
7110212 197. 107. 0.0 0.0
7110213 215. 107. 0.0 0.0
7110214 615. 102. 0.0 0.0
7110215 1615. 80.0 0.0 0.0
*
* Cold leg -- 4 loops combined
*
3000000 COLDLG pipe
3000001 1
3000101 12.00 1
3000301 0.0 1
3000401 3024. 1

```

3000601	0.0	1					
3000801	0.00015	2.42	1				
3001001	00	1					
3001201	003	2260.	557.	0.	0.	0.	1

\* The downcomer and lower plenum  
\*

5080000	LOWRPLM	branch					
5080001	2	0					
5080101	0.0	12.000	1266.				
5080102	0.0	0.0	0.0				
5080103	0.00015	5.6655	00				
5080200	003	2260.	557.				
* from	to	area	f loss	r loss	vcahs		
5081101	300010000	508010000	12.0000	1.3180	1.3180	10100	
5082101	508010000	514000000	32.8781	0.0	0.0	10100	
* f vel.	v vel.	i vel.					
5081201	0.	0.	0.	* 37994.087			
5082201	0.	0.	0.	* 37994.087			

\* The core and upper plenum  
\*

5140000	CORE	pipe					
5140001	1						
5140101	0.0	1					
5140301	12.	1					
5140401	1265.	1					
5140601	90.0	1					
5140701	12.	1					
5140801	0.00015	0.040092	1				
5141001	00	1					
5141201	003	2194.	608.	0.	0.	0.	1

\* The upper head and pressurizer  
\*

5120000	UPPRPLM	branch					
5120001	1	0					
5120101	0.0	12.000	2808.				
5120102	0.0	0.0	12.00				
5120103	0.00015	10.0	00				
5120200	003	2194.	608.				
5121101	514010000	512000000	0.0	0.1979	0.1979	10100	
5121201	0.	0.	0.	* 36815.350			

\* Vessel outlet to hotleg  
\*

9240000	VESSLOUT	single jun					
9240101	512010000	301000000	12.00	0.1200	0.1200	00002	
9240201	0	0. b. 0.0					

\* Hotleg -- all loops combined  
\*

3010000	HOTLEG	pipe					
3010001	1						
3010101	12.00	1					
3010301	0.0	1					
3010401	3025.	1					
3010601	0.0	1					
3010801	0.00015	2.42	1				
3011001	00	1					
3011201	003	2194.	608.	0.	0.	0.	1

\* Hotleg to high-pressure injection piping. The injection point should be the vessel downcomer but is placed on the hotleg to provide a continuous flow path from injection point to break.  
\*

0150000	inletjun	single jun					
0150101	301010000	020000000	0.0	0.0	0.0	01100	



0150201 1 0.0 0.0 0.0

\* 83 ft of 2 1/2 inch pipe between the RCS and HP-2A

0200000 up-ream pipe  
 0200001 10  
 0200101 0.02463 10  
 0200301 8.3 10  
 0200601 0.0 10  
 0200801 1.5e-4 0.0 10  
 0200901 0.864 0.864 1  
 0200902 0.0 0.0 9  
 0201001 00 10  
 0201101 00000 9  
 0201201 003 2194. 608. 0. 0. 0. 10  
 0201301 0.0 0.0 0.0 9

\* 2 1/2 inch valve HP-2A

0250000 HP-2A valve  
 0250101 020010000 030000000 0.02463 0.144 0.144 01100  
 0250201 1 0.0 0.0 0.0  
 0250300 mtrvlv  
 0250301 501 501 1.0 1.0

\* Piping between HP-2A and break at suction of pump 1-2. Total length of piping is about 72 feet. Pressure losses from bends and valves is neglected. This will produce a conservative break flow.

0300300 HPI pipe  
 0300001 3  
 0300101 0.02463 3 \* Flow area (ft<sup>2</sup>) 2.5 inch pipe  
 0300301 7.2 3 \* Volume lengths (ft)  
 0300601 0.0 3  
 0300801 1.5e-4 0.0 3  
 0300901 0.0 0.0 2 \* Loss coefficients  
 0301001 00 3  
 0301101 00000 2  
 0301201 003 50. 100. 0. 0. 0. 3  
 0301301 0.0 0.0 0.0 2

\* Break, located at suction to HPI pump 1-2

7230000 BREAK-5 valve \* fvcahs  
 7230101 030010000 902000000 0.02463 0. 0. 000100  
 7230201 1 0. 0. 0.  
 7230300 trpvlv  
 7230301 501

\* PORV - area does not matter so long as pressure is controlled

7240000 PORV valve \* fvcahs  
 7240101 301010000 902000000 0.05 0. 0. 000100  
 7240201 1 0. 0. 0.  
 7240300 trpvlv  
 7240301 503

\* Time-dependent volume downstream of the leak

9020000 AUXBLDG tmdpvc1  
 9020101 18.40 0. 3000.  
 9020102 0 0 0  
 9020103 0 0 10  
 9020200 03 0  
 9020201 0.0 15. 213.

\* ===== Heat Structures =====

\* Core heat structure

15151000	12	9	2	1	0.					
15151100	0	1								
15151101	5	0.01542	1		0.01571	2	0.1	2		
15151201	2	5	3		6	4	8			
15151301	.85	2	.9	3	1.4	1.4	5	0.8		
15151400	0									
15151471	2000.	6		700.	7		710.	8	650.	9
15151501	0	0	0	0	0.			12		
15151601	514010000	00000	1	0		4144.5		12		
15151701	1	0.0778	0.	0.		1				
15151702	1	0.0885	0.	0.		2				
15151703	1	0.0877	0.	0.		3				
15151704	1	0.0860	0.	0.		4				
15151705	1	0.0847	0.	0.		5				
15151706	1	0.0839	0.	0.		6				
15151707	1	0.0840	0.	0.		7				
15151708	1	0.0848	0.	0.		8				
15151709	1	0.0862	0.	0.		9				
15151710	1	0.0879	0.	0.		10				
15151711	1	0.0858	0.	0.		11				
15151712	1	0.0627	0.	0.		12				

	dia	htlngf	htlngr	gngf	gngr	glossf	glossr	boilf	strno	
15151801	0.	100.	100.	0.	0.	0.	0.	1.	12	* 902000
15151901	0.0415	100.	100.	0.	0.	0.	0.	1.	12	* 902000

\* thermal properties of uo2 - composition 2

	matl type	th.con	ht.cap	material
20100200	tbl/fctn	1	1	* uo2

	temperature	th.cond
* 20100201	188.6	1.284e-3
20100201	0.	1.284e-3
20100202	332.6	1.1235e-3
20100203	440.6	9.951e-4
20100204	500.0	9.2806e-4
20100205	650.0	7.4194e-4
20100206	800.0	7.4361e-4
20100207	950.0	6.7750e-4
20100208	1100.0	6.2278e-4
20100209	1250.0	5.7772e-4
20100210	1400.0	5.3889e-4
20100211	1500.0	5.0639e-4
20100212	1700.0	4.7889e-4
20100213	1850.0	4.5528e-4
20100214	2000.0	4.3556e-4
20100215	2150.0	4.1861e-4
20100216	2300.0	4.0472e-4
20100217	2450.0	3.9306e-4
20100218	2600.0	3.8389e-4
20100219	3100.0	3.6750e-4
20100220	3600.0	3.7028e-4
20100221	4100.0	3.9056e-4
20100222	4600.0	4.2722e-4
20100223	5100.0	4.8056e-4

	temperature	ht.cap
* 20100251	32.0	34.45
20100251	0.	34.45
20100252	122.0	38.35
20100253	212.0	40.95
20100254	392.0	43.55
20100255	752.0	46.80
20100256	2012.0	51.35
20100257	2732.0	52.65

20100258	3092.0	56.55
20100259	3452.0	63.05
20100260	3812.0	72.80
20100261	4352.0	89.70
20100262	4532.0	94.25
20100263	4712.0	98.15
20100264	4892.0	100.10
20100265	5144.0	101.40
20100266	8000.0	101.40

\*

\*

\* thermal properties of fuel gap - composition 3

\*

* mtrl type	th.con	ht.cap	material
20100300 tbl/fctn	1	1	* fuel gap

\*

\* values of thermal conductivity were derived from matpro and a fraccon computer run at constant power over the total burnup interval

\*

\* burnup = 0.00000 pressure = .12362e+04 gap width = .00213  
 \* he frac = .10000e+01 kr frac = 0. xe frac = 0.

\*

* 20100301	temperature	th. cond.
20100301	70.000	2.52892e-05
20100301	0.000	2.52892e-05
20100302	300.000	3.14014e-05
20100303	500.000	3.70561e-05
20100304	700.000	4.23747e-05
20100305	900.000	4.74311e-05
20100306	1100.000	5.22745e-05
20100307	1300.000	5.69395e-05
20100308	1500.000	6.14522e-05
20100309	1700.000	6.58324e-05
20100310	1900.000	7.00957e-05
20100311	2100.000	7.42548e-05
20100312	2300.000	7.83201e-05
20100313	2500.000	8.23004e-05
20100314	2700.000	8.62029e-05
20100315	2900.000	9.00341e-05
20100316	3100.000	9.37993e-05
20100317	3300.000	9.75033e-05
20100318	3500.000	1.01150e-04
20100319	3700.000	1.04744e-04
20100320	3900.000	1.08288e-04
20100321	4100.000	1.11784e-04
20100322	4300.000	1.15236e-04
20100323	4500.000	1.18646e-04
20100324	4700.000	1.22017e-04
20100325	4900.000	1.25349e-04
20100326	5100.000	1.28645e-04
20100327	5300.000	1.31907e-04

\*

* 20100351	temperature	vol ht cap
20100351	0.0	0.000075
20100352	5400.0	0.000075

\*

\*

\* thermal properties of cladding - composition 4

\*

* crdno	mtrl type	th.con	ht.cap	material
20100400	tbl/fctn	1	1	* cladding

\*

* 20100401	temperature	th. cond.
20100401	50.0	1.9267e-3
20100401	0.0	1.9267e-3
20100402	392.0	1.9267e-3
20100403	752.0	2.2478e-3
20100404	1112.0	2.7297e-3
20100405	1472.0	3.0508e-3

20100406	1832.0	3.5325e-3
20100407	2192.0	4.0142e-3
20100408	2552.0	4.8169e-3
20100409	2912.0	5.7803e-3
20100410	3272.0	7.0647e-3
20100411	3632.0	8.8311e-3
20100412	3992.0	1.0918e-2

	temperature	vol ht cap
20100451	0.0	28.392
20100452	1480.3	34.476
20100453	1675.00	85.176
20100454	1787.5	34.370
20100455	3500.0	34.476

-----

\*  
\*  
\* Table Number 1 - Core Power vs. Time

\* this table represents a best-estimate of fission product decay  
\* heat using the ans standard plus a contribution from actinides.  
\* reference: work by c. b. davis

\* Model modified to reflect the B&W Plant power level - John Schroeder

	type	trip	factor	power(mw)
20200100	power	0	1.0	2772.

	sec	normalized power
20200101	-1.	0. * start at one second
* 20200101	-1.	1.0
* 20200102	0.	1.0
* 20200103	.1	.8382
* 20200104	.2	.5720
* 20200105	.3	.3806
* 20200106	.4	.2792
* 20200107	.5	.2246
* 20200108	.6	.1904
* 20200109	.7	.1672
* 20200110	.8	.1503
* 20200111	.9	.1376
20200112	1.0	.1275
20200113	1.5	.1032
20200114	2	.09884
20200115	3.	.09209
20200116	4.	.08690
20200117	5.	.08271
20200118	6.	.07922
20200119	8.	.07375
20200120	10.	.06967
20200121	15.	.06251
20200122	20.	.05751
20200123	30.	.05060
20200124	40.	.04591
20200125	50.	.04246
20200126	60.	.03977
20200127	80.	.03604
20200128	100.	.03357
20200129	125.	.03145
20200130	150.	.02997
20200131	200.	.02798
20200132	300.	.02565
20200133	400.	.02418
20200134	500.	.02307
20200135	600.	.02217
20200136	800.	.02073
20200137	1000.	.01959
20200138	1250.	.01844

```

20200139 1500. .01749
20200140 2000. .01600
20200141 2500. .01489
20200142 3000. .01401
20200143 3500. .01331
20200144 4000. .01274
20200145 5000. .01185
20200146 6000. .01118
20200147 7000. .01067
20200148 8000. .01025
20200149 9000. .009895
20200150 10000. .009596
20200151 15000. .008553
20200152 20000. .007902

```

\* \*\*\*\*\* Control Variables \*\*\*\*\*

20500000 4095

\* Sum of total eccs

	name	type	factor	init	f	c
20501100	"ecctot"	sum	2.2046	0.0	1	

	a0	coeff	name	parameter no.
20501101	0.0	1.0	mflowj	717000000
20501102		1.0	mflowj	712000000

\* Integrate eccs mass flow rate

	name	type	factor	init	f	c	min	max
20501200	"inteccs"	integral	1.0	0.0	0.3		0.0	4.8e5

2050120. cntrlvar 110

\* Controller for break vapor enthalpy - output SI units, break conditions taken from donor volume.

\*  $hg = ug + p \cdot vg$

20501300	"v-enth"	sum	1.	0.	1
20501301	0.	1.	ug	030030000	
20501302		1.	cntrlvar	140	

20501400	"v-p*vg"	mult	1.	0.	1
20501401		p		030030000	
20501402		cntrlvar	150		

20501500	"\ -1/rho"	div	1.	1.	1
20501501		rhog		03.030000	

\* Controller for break liquid enthalpy

\*  $hf = uf + p \cdot vf$

20501600	"f-enth"	sum	1.	0.	1
20501601	0.	1.	uf	030030000	
20501602		1.	cntrlvar	170	

20501700	"f-pv"	mult	1.	0.	1
20501701		p		030030000	
20501702		cntrlvar	180		

20501800	"1/rho"	div	1.	1.	1
20501801		rhof		030030000	

\* Controller for break vapor mass flow rate

```
*
20501900 mflow mult 0.00229 0. 1
20501901 voidg 723000000
20501902 rhog 723000000
20501903 velg 723000000
*
```

```
* Controller for break fluid mass flow rate
```

```
*
20502000 mflow mult 0.00229 0. 1
20502001 voidf 723000000
20502002 rhof 723000000
20502003 velf 723000000
*
```

```
.end
```

## LISTING 6 - CONTAIN Input for BS-1

```

&& ***** Model Description *****
&&
&& File:
&&   cnt001.mdl
&&
&& Description:
&&   BS-1. This input deck describes a five volume model of the B&W Plant
&&   auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 12 inch break in the decay heat removal
&&   pump suction piping located in room 236. This model does not include
&&   water aerosols (the dropout option is used).
&&
&& Written by:
&&   John Schroeder 6/91
&&
&& ***** Machine Control Input *****
cray
eol
&& ***** Global Input *****
&&
&& Section 3.2 p. 3-11
&&
&&   Atmospheric Gases
&&
&&   Material   Description
&&   -----   -
&&   o2         oxygen
&&   n2         nitrogen
&&   h2ov       steam
&&   h2ol       water
&&
&& control
&&   ncells   = 6      && Number of cells
&&   nttl     = 2      && Number of title lines
&&   ntzone   = 5      && Number of time zones
&&   nsc      = 0      && Number of aerosol groups
&&   nsectn   = 0      && Number of aerosol sections
&&
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
&& material
&&   compound
&&     n2 o2      && Air
&&     h2ov h2ol  && Steam and water
&&     conc      && Structural materials
&&
&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17
&&
&& thermal      && Water-cooled reactor
&&
&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
&& flows
&&

```

```

&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&& 1, 2, 3.
&&
&& area(1,5) = 8.88    && Cross-sectional area of flow path      (m2)
&& avl(1,5) = 14.8    && Ratio of area to inertial length, A/L      (m)
&& cfc(1,5) = 1.00    && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&& area(1,2) = 12.6
&& avl(1,2) = 20.7
&& cfc(1,2) = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&& area(2,5) = 0.892
&& avl(2,5) = 1.46
&& cfc(2,5) = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&& area(2,3) = 1.95
&& avl(2,3) = 3.2
&& cfc(2,3) = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&& area(3,5) = 1.95
&& avl(3,5) = 3.2
&& cfc(3,5) = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&& area(3,4) = 2.97
&& avl(3,4) = 4.88
&& cfc(3,4) = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&& 10, 11, 12, and 13.
&&
&& area(4,5) = 29.1
&& avl(4,5) = 157.
&& cfc(4,5) = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&& paths.
&&
&& area(5,6) = 46.5
&& avl(5,6) = 250.
&& cfc(5,6) = 1.00
&&
&& implicit
&& dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments
&&
&& elevcl(1) = 169.    && Center of mass elevation for Rm 105      (m)
&& elevcl(2) = 169.    && Center of mass elevation for Rm 113      (m)
&& elevcl(3) = 169.    && Center of mass elevation for Rm 115      (m)
&& elevcl(4) = 175.    && Center of mass elevation for Rm 236      (m)
&& elevcl(5) = 185.    && Center of mass elevation for Rm BOP      (m)
&& elevcl(6) = 185.    && Center of mass elevation for Environment (m)
&&
&& Junctions
&&
&& elevfp(1,5) = 167.

```



```

elevfp(5,1)= 167.

elevfp(1,2)= 170.
elevfp(2,1)= 170.

elevfp(2,5)= 172.
elevfp(5,2)= 172.

elevfp(2,3)= 170.
elevfp(3,2)= 170.

elevfp(3,5)= 170.
elevfp(5,3)= 170.

elevfp(3,4)= 172.
elevfp(4,3)= 172.

elevfp(4,5)= 173.
elevfp(5,4)= 173.

elevfp(5,6)= 211.
elevfp(6,5)= 211.

&&
&& ----- Aerosol Options -----
&&
&& Section 3.2.4, p. 3-29
&&
&& aerosol
&&   h2ov 1.0e-8 0.693
&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
  3600.          && Maximum CPU time limit          (s)
   0.           && Problem start time                (s)
&&
&& Time zone data
&&
&& System  Edit  End of
&& Max Ts   Ts   Zone
&& -----
&&          1.   10.  10.
&&          5.   50. 100.
&&         10.  100. 1000.
&&         50.  100. 2000.
&&        100.  100. 3600.
&&
&& -----
&&
&&
&& ----- Output Control -----
&&
&& Section 3.2.7, p. 3-38
&&
shortedt      = 1      && System ts between short edits
longedt       = 1      && Ts edits between long edits
prflow       && Print intercell flow data
praer        && detailed aerosol inventories
prlow-cl     && lower cell model
prheat       && heat transfer structure model
prengsys     && engineered system model
title
&&          B&W Plant Auxiliary Building Steam Propagation Model
&&          Five Compartment Model -- BS-1
&&
&&
&& ===== Cell Input and Cell Control =====

```

```

&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=7 nnensy=1 jconc=1 jpool=1
eoi
title
  Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e3 5.49 && Cell volume and height (m3, m)
  atmos = 3 && Number of materials
        1.01e5 && Pressure (Pa)
        305. && Temperature (K)
  n2 = 0.75 && Initial nitrogen fraction
  o2 = 0.20 && Initial oxygen fraction
  h2ov = 0.05 && Initial water vapor fraction
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 18.7 && Characteristic length of structure (m)
  slarea = 295. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc
  x = 0. .046 .092 .138 .184 230 .276 .322 .368 .414 .457 && (m)
eoi
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 298. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eoi
&&
condense
ht-tran on on on on on
overflow 1
&&
&& Lower cell input
&&
low-cell
  geometry= 295. && Area of layers in lower cell (m2)
  bc = 305. && Basemat bc.ndary condition temperature (K)
  concrete
    compos = 1 && Number of materials
            conc && Material
            43200. && Mass of material
    temp = 305. && Initial temperature
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 1 5 -.152
overflow 1 5 1.74
eoi

```

```

&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=0 naensy=1 jconc=5 jpool=1
eoi
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e2 6.10 && Cell volume and height (m3, m)
  atmos = 3
           1.01e5 && Pressure (Pa)
           305. && Temperature (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 17.7 && Characteristic length of structure (m)
  slarea = 86.4 && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 254. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 .396 && (m)
eoi
&&
condense
ht-tran on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell
  geometry= 86.4 && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
             conc && Material
             19000. && Mass of material (kg)
    temp = 305. && Initial temperature (K)
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&
&& Engineered safety systems
&&
engineer spill 1 2 1 0.0
overflow 2 1 3.05
eoi
&&

```

```

&& ----- Cell 3, Room 115 -----
cell 3
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eoi
title
  Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height (m3, m)
  atmos = 3
    1.01e5 && Pressure
    305. && Temperature
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 14.6 && Characteristic length of structure (m)
  slarea = 107. && Area (m2)
  tunif = 305. && Initial uniform temperature (C)
  compound= conc conc conc conc conc conc conc conc conc c .c
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
  name = Walls && Name of structure
  type = wall
  shape = slab
  nslab = 10
  chrlen = 5.49
  slarea = 241.
  tunif = 305.
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
&&
low-cell
  geometry= 107. && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
    conc && Material
    23500. && Mass of material
    temp = 305. && Initial temperature
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 3 2 0.
  overflow 3 2 3.05
eoi
&&
&& ----- Cell 4, Room 236 -----
cell 4

```

```

control
  nhtm=1 mxslab=11 nsoatm=2 nspat=300 jcnrc=1 jpool=1 naensy=2
  nsoeng=1 nspeng=4
eol
title
  Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height (m3, m)
  atmos = 3
    1.01e5 && Pressure
    305. && Temperature
  o2 = 0.25
  n2 = 0.75
  h2ov = 0.05

```

```

source=2
&&
&& Blowdown of saturated primary system water
&&

```

```

h2ov = 299
iflag = 2
t =

```

0.0	1.0	2.0	3.0	4.0
5.0	6.0	7.0	8.0	9.0
10.0	11.0	12.0	13.0	14.0
15.0	25.0	35.0	45.0	55.0
65.0	75.0	85.0	95.0	105.0
115.0	125.0	135.0	145.0	155.0
165.0	175.0	185.0	195.0	205.0
215.0	225.0	235.0	245.0	255.0
265.0	275.0	285.0	295.0	305.0
315.0	325.0	335.0	345.0	355.0
365.0	375.0	385.0	395.0	405.0
415.0	425.0	435.0	445.0	455.0
465.0	475.0	485.0	495.0	505.0
515.0	525.0	535.0	545.0	555.0
565.0	575.0	585.0	595.0	605.0
615.0	625.0	635.0	645.0	655.0
665.0	675.0	685.0	695.0	705.0
715.0	725.0	735.0	745.0	755.0
765.0	775.0	785.0	795.0	805.0
815.0	825.0	835.0	845.0	855.0
865.0	875.0	885.0	895.0	905.0
915.0	925.0	935.0	945.0	955.0
965.0	975.0	985.0	995.0	1005.0
1015.0	1025.0	1035.0	1045.0	1055.0
1065.0	1075.0	1085.0	1095.0	1105.0
1115.0	1125.0	1135.0	1145.0	1155.0
1165.0	1175.0	1185.0	1195.0	1205.0
1215.0	1225.0	1235.0	1245.0	1255.0
1265.0	1275.0	1285.0	1295.0	1305.0
1315.0	1325.0	1335.0	1345.0	1355.0
1365.0	1375.0	1385.0	1395.0	1405.0
1415.0	1425.0	1435.0	1445.0	1455.0
1465.0	1475.0	1485.0	1495.0	1505.0
1515.0	1525.0	1535.0	1545.0	1555.0
1565.0	1575.0	1585.0	1595.0	1605.0
1615.0	1625.0	1635.0	1645.0	1655.0
1665.0	1675.0	1685.0	1695.0	1705.0
1715.0	1725.0	1735.0	1745.0	1755.0
1765.0	1775.0	1785.0	1795.0	1805.0
1815.0	1825.0	1835.0	1845.0	1855.0
1865.0	1875.0	1885.0	1895.0	1905.0
1915.0	1925.0	1935.0	1945.0	1955.0
1965.0	1975.0	1985.0	1995.0	2005.0
2015.0	2025.0	2035.0	2045.0	2055.0
2065.0	2075.0	2085.0	2095.0	2105.0
2115.0	2125.0	2135.0	2145.0	2155.0



710.3	710.3	710.3	710.4	710.4
710.4	710.4	710.4	710.4	710.4
710.4	710.4	710.4	710.4	710.4
710.4	710.4	710.4	710.4	710.4
710.4	710.4	710.4	710.4	710.4
710.4	710.4	710.4	710.4	710.4
710.4	710.4	710.4	710.4	710.4
710.4	710.4	710.4	710.4	710.4

enth *	158000.0	885000.0	1025000.0	1060000.0	1100000.0
	1140000.0	1160000.0	1210000.0	1260000.0	1270000.0
	1270000.0	1270000.0	1260000.0	1260000.0	1260000.0
	1250000.0	1240000.0	1150000.0	1180000.0	1160000.0
	1110000.0	1170000.0	1070000.0	1040000.0	976000.0
	947000.0	917000.0	886000.0	857000.0	830000.0
	804000.0	781000.0	759000.0	739000.0	722000.0
	707000.0	693000.0	680000.0	669000.0	660000.0
	651000.0	642000.0	635000.0	629000.0	622000.0
	616000.0	610000.0	603000.0	597000.0	592000.0
	646000.0	653000.0	665000.0	661000.0	651000.0
	651000.0	653000.0	651000.0	650000.0	648000.0
	646000.0	642000.0	642000.0	661000.0	664000.0
	642000.0	614000.0	615000.0	602000.0	536000.0
	573000.0	595000.0	624000.0	618000.0	612000.0
	605000.0	597000.0	588000.0	580000.0	571000.0
	562000.0	554000.0	543000.0	532000.0	523000.0
	513000.0	504000.0	493000.0	483000.0	473000.0
	463000.0	453000.0	443000.0	433000.0	423000.0
	413000.0	403000.0	394000.0	385000.0	376000.0
	367000.0	358000.0	350000.0	342000.0	334000.0
	326000.0	319000.0	312000.0	305000.0	298000.0
	292000.0	286000.0	280000.0	274000.0	269000.0
	263000.0	258000.0	254000.0	249000.0	244000.0
	240000.0	236000.0	232000.0	229000.0	225000.0
	222000.0	219000.0	216000.0	213000.0	210000.0
	207000.0	205000.0	202000.0	200000.0	198000.0
	196000.0	194000.0	192000.0	190000.0	189000.0
	187000.0	186000.0	184000.0	183000.0	182000.0
	180000.0	179000.0	178000.0	177000.0	176000.0
	175000.0	174000.0	173000.0	172000.0	172000.0
	171000.0	170000.0	169000.0	169000.0	168000.0
	168000.0	167000.0	167000.0	166000.0	166000.0
	165000.0	165000.0	164000.0	164000.0	163000.0
	163000.0	163000.0	162000.0	162000.0	162000.0
	161000.0	161000.0	161000.0	160000.0	160000.0
	160000.0	160000.0	159000.0	159000.0	159000.0
	159000.0	158000.0	158000.0	158000.0	158000.0
	158000.0	157000.0	157000.0	157000.0	157000.0
	157000.0	157000.0	156000.0	156000.0	156000.0
	156000.0	156000.0	156000.0	156000.0	155000.0
	155000.0	155000.0	155000.0	155000.0	155000.0
	155000.0	154000.0	154000.0	154000.0	154000.0
	154000.0	154000.0	154000.0	153000.0	153000.0
	153000.0	153000.0	153000.0	153000.0	153000.0
	153000.0	152000.0	152000.0	152000.0	152000.0
	152000.0	152000.0	152000.0	152000.0	152000.0
	151000.0	151000.0	151000.0	151000.0	151000.0
	151000.0	151000.0	151000.0	151000.0	151000.0
	150000.0	150000.0	150000.0	150000.0	150000.0
	150000.0	150000.0	150000.0	150000.0	150000.0
	149000.0	149000.0	149000.0	149000.0	149000.0
	149000.0	149000.0	149000.0	149000.0	149000.0
	149000.0	148000.0	148000.0	148000.0	148000.0
	148000.0	148000.0	148000.0	148000.0	148000.0
	148000.0	148000.0	147000.0	147000.0	147000.0
	147000.0	147000.0	147000.0	147000.0	147000.0
	147000.0	147000.0	147000.0	147000.0	146000.0
	146000.0	146000.0	146000.0	146000.0	146000.0
	146000.0	146000.0	146000.0	146000.0	146000.0

```

eol
&& Blowdown of primary system steam
&&

```

```

h2ov = 299
iflag = 2

```

t	=	0.0	1.0	2.0	3.0	4.0
		5.0	6.0	7.0	8.0	9.0
		10.0	11.0	12.0	13.0	14.0
		15.0	25.0	35.0	45.0	55.0
		65.0	75.0	85.0	95.0	105.0
		115.0	125.0	135.0	145.0	155.0
		165.0	175.0	185.0	195.0	205.0
		215.0	225.0	235.0	245.0	255.0
		265.0	275.0	285.0	295.0	305.0
		315.0	325.0	335.0	345.0	355.0
		365.0	375.0	385.0	395.0	405.0
		415.0	425.0	435.0	445.0	455.0
		465.0	475.0	485.0	495.0	505.0
		515.0	525.0	535.0	545.0	555.0
		565.0	575.0	585.0	595.0	605.0
		615.0	625.0	635.0	645.0	655.0
		665.0	675.0	685.0	695.0	705.0
		715.0	725.0	735.0	745.0	755.0
		765.0	775.0	785.0	795.0	805.0
		815.0	825.0	835.0	845.0	855.0
		865.0	875.0	885.0	895.0	905.0
		915.0	925.0	935.0	945.0	955.0
		965.0	975.0	985.0	995.0	1005.0
		1015.0	1025.0	1035.0	1045.0	1055.0
		1065.0	1075.0	1085.0	1095.0	1105.0
		1115.0	1125.0	1135.0	1145.0	1155.0
		1165.0	1175.0	1185.0	1195.0	1205.0
		1215.0	1225.0	1235.0	1245.0	1255.0
		1265.0	1275.0	1285.0	1295.0	1305.0
		1315.0	1325.0	1335.0	1345.0	1355.0
		1365.0	1375.0	1385.0	1395.0	1405.0
		1415.0	1425.0	1435.0	1445.0	1455.0
		1465.0	1475.0	1485.0	1495.0	1505.0
		1515.0	1525.0	1535.0	1545.0	1555.0
		1565.0	1575.0	1585.0	1595.0	1605.0
		1615.0	1625.0	1635.0	1645.0	1655.0
		1665.0	1675.0	1685.0	1695.0	1705.0
		1715.0	1725.0	1735.0	1745.0	1755.0
		1765.0	1775.0	1785.0	1795.0	1805.0
		1815.0	1825.0	1835.0	1845.0	1855.0
		1865.0	1875.0	1885.0	1895.0	1905.0
		1915.0	1925.0	1935.0	1945.0	1955.0
		1965.0	1975.0	1985.0	1995.0	2005.0
		2015.0	2025.0	2035.0	2045.0	2055.0
		2065.0	2075.0	2085.0	2095.0	2105.0
		2115.0	2125.0	2135.0	2145.0	2155.0
		2165.0	2175.0	2185.0	2195.0	2205.0
		2215.0	2225.0	2235.0	2245.0	2255.0
		2265.0	2275.0	2285.0	2295.0	2305.0
		2315.0	2325.0	2335.0	2345.0	2355.0
		2365.0	2375.0	2385.0	2395.0	2405.0
		2415.0	2425.0	2435.0	2445.0	2455.0
		2465.0	2475.0	2485.0	2495.0	2505.0
		2515.0	2525.0	2535.0	2545.0	2555.0
		2565.0	2575.0	2585.0	2595.0	2605.0
		2615.0	2625.0	2635.0	2645.0	2655.0
		2665.0	2675.0	2685.0	2695.0	2705.0
		2715.0	2725.0	2735.0	2745.0	2755.0
		2765.0	2775.0	2785.0	2795.0	2805.0
		2815.0	2825.0	2835.0	2845.0	

```

mass *      0.0      106.3      161.0      180.2      194.6

```







```

overflow 4
&&
&& Lower cell input
&&
low-cell
  geometry= 91.9      && Area of layers in lower cell      (m2)
  bc = 305.         && Basement boundary condition temperature (K)
  concrete
    compos = 1      && Number of materials
    conc    && Material
    mass    6730.   && Mass of material
    temp    = 305.  && Initial temperature
  eoi
  pool
    temp    = 305.  && Initial temperature
  eoi

```

```

1
  Engineered safety systems

```

```

  & Spillage from Room 236 to Room 115 via the connecting pipe chase

```

```

&&
engineer  Spill 1 4 3 5.79
overflow 4 3 0.025

```

```

eoi
&&
&& Fire water sprinkler system, activated on high temperature.
&&

```

```

engineer  Sprinklr 2 4 4 0.
spray
  spdiam = .001    &C Spray droplet diameter      (m)
  sphite = 5.49   && Spray fall height              (m)
  spsttm = 373.   && Temperature at which system activates (K)
eoi
  source = 1      && Sprays provide 336 gpm (21.1 kg/s) after
  h2ol = 3       && activation
  iflag = 2
  t = 0.0 100. 1.00e5
  mass = 21.1 21.1 21.1
  temp = 305. 305. 305.

```

```

eoi
eoi
&&
&& ----- Cell 5, Balance of Plant -----

```

```

cell 5
control
eoi
title
  Balance of Plant
geometry 1.87e5 38.8
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05

```

```

&&
&& ----- Cell 6, Environment -----

```

```

cell 6
control
eoi
title
  Environment Cell
geometry 1.e10 1.e30
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05
eoi

```

## LISTING 7 - CONTAIN Input for BS-2

```

&& ----- Model Description -----
&&
&& File:
&&   cont002.mdl
&&
&& Description:
&&
&&   BS-2. This input deck describes a five volume model of the B&W Plant
&&   auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 10 inch break in the decay heat removal
&&   system suction piping in room 113. This model does not include
&&   water aerosols (the dropout option is used).
&&
&& Written by:
&&
&&   John Schroeder 6/91
&&
&& ----- Machine Control Input -----
cray
eol
&& ----- Global Input -----
&&
&& Section 3.2, p. 3-11
&&
&&   Atmospheric Gases
&&
&&   Material      Description
&&   -----
&&   o2            oxygen
&&   n2            nitrogen
&&   h2ov          steam
&&   h2oi         water
&&
control
  ncells = 6      && Number of cells
  nttl = 2        && Number of title lines
  ntzone = 5     && Number of time zones
  nac = 0        && Number of aerosol groups
  nsectn = 0     && Number of aerosol sections
eol
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-12
&&
material
  compound
    n2 o2        && Air
    h2ov h2oi    && Steam and water
    conc        && Structural materials
&&
&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17
&&
&& thermal      && Water-cooled reactor
&&
&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
&& flows
&&

```

```

&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&&      1, 2, 3.
&&
&& area(1,5) = 8.88    && Cross-sectional area of flow path      (m2)
&& avl(1,5)  = 14.6   && Ratio of area to inertial length, A/L      (m)
&& cfc(1,5)  = 1.00   && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&& area(1,2) = 12.6
&& avl(1,2)  = 20.7
&& cfc(1,2)  = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&& area(2,3) = 0.892
&& avl(2,5)  = 1.46
&& cfc(2,5)  = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&& area(2,3) = 1.95
&& avl(2,3)  = 3.2
&& cfc(2,3)  = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&& area(3,5) = 1.95
&& avl(3,5)  = 3.2
&& cfc(3,5)  = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&& area(3,4) = 2.97
&& avl(3,4)  = 4.88
&& cfc(3,4)  = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&      10, 11, 12, and 13.
&&
&& area(4,5) = 29.1
&& avl(4,5)  = 157.
&& cfc(4,5)  = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&      paths.
&&
&& area(5,6) = 46.5
&& avl(5,6)  = 250.
&& cfc(5,6)  = 1.00
&&
&& implicit
&& dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments
&&
&& elevcl(1) = 169.    && Center of mass elevation for Rm 105      (m)
&& elevcl(2) = 169.    && Center of mass elevation for Rm 113      (m)
&& elevcl(3) = 169.    && Center of mass elevation for Rm 115      (m)
&& elevcl(4) = 175.    && Center of mass elevation for Rm 236      (m)
&& elevcl(5) = 185.    && Center of mass elevation for Rm BOP      (m)
&& elevcl(6) = 185.    && Center of mass elevation for Environment (m)
&&
&& Junctions
&&
&& elevfp(1,5) = 167.

```

```

elevfp(5,1)= 167.

elevfp(1,2)= 170.
elevfp(2,1)= 170.

elevfp(2,5)= 172.
elevfp(5,2)= 172.

elevfp(2,3)= 170.
elevfp(3,2)= 170.

elevfp(3,5)= :70.
elevfp(5,3)= 170.

elevfp(3,4)= 172.
elevfp(4,3)= 172.

elevfp(4,5)= 173.
elevfp(5,4)= 173.

elevfp(5,6)= 211.
elevfp(6,5)= 211.

&& ----- Aerosol Options -----
&&
&& Section 3.2.4, p. 3-29
&&
&& aerosol
&&   h2ov 1.0e-8 0.693
&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
  1800.          && Maximum CPU time limit          (s)
    0.           && Problem start time              (s)
&&
&& Time zone data
&&
&& System  Edit  End of
&&  Ts     Ts    Zone
&& -----
&&      1.   10.   10.
&&      5.   50.  100.
&&     20.  200.  500.
&&     50.  100. 1000.
&&     50.  100. 3600.
&& -----
&&
&&
&& ----- Output Control -----
&&
&& Section 3.2.7, p. 3-38
&&
shortedt   = 2    && System ts between short edits
longedt    = 1    && Ts edits between long edits
prflow     && Print intercell flow data
praer      && detailed aerosol inventories
prlow-cl   && low-r cell model
prheat     && heat transfer structure model
prengsys   && engineered system model
title
          B&W Plant Auxilliary Building Steam Propagation Model
          Five Compartment Model -- BS-2
&&
&&
&& ----- Cell Input and Cell Control -----

```

```

&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eoi
title
  Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e3 5.49 && Cell volume and height (m3, m)
  atmos = 3 && Number of materials
          1.01e5 && Pressure (Pa)
          305. && Temperature (K)
  n2 = 0.75 && Initial nitrogen fraction
  o2 = 0.20 && Initial oxygen fraction
  h2ov = 0.05 && Initial water vapor fraction
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chlren = 18.7 && Characteristic length of structure (m)
  slarea = 295. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .046 .092 .138 .184 .230 .276 .322 .368 .414 .457 && (m)
eoi
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  ch.len = 5.49 && Characteristic length of structure (m)
  slarea = 298. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eoi
&&
condense
ht-tran on on on on on
overflow 1
&&
&& Lower cell input
&&
low-cell
  geometry= 295. && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
            conc && Material
            43200. && Mass of material
    temp = 305. && Initial temperature
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 1 5 .152
overflow 1 5 1.74
eoi

```

```

&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  nhtm=2 mxslab=11 nsoatm=4 nspatm=1000 naensy=1 jconc=5 jpool=1
eol
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e2 6.10 && Cell volume and height (m3, m)
  atmos = 3
          1.01e5 && Pressure (Pa)
          305. && Temperature (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
source=4
&&
&& Blowdown of saturated primary system water
&&
h2ov = 914
iflag = 2
t =
      0.0      0.5      1.5      2.5      3.5
      4.5      5.5      6.5      7.5      8.5
      9.5     10.5     11.5     12.5     13.5
      14.5    15.5    16.5    17.5    18.5
      19.5    20.5    21.5    22.5    23.5
      24.5    25.5    26.5    27.5    28.5
      29.5    30.5    31.5    32.5    33.5
      34.5    35.5    36.5    37.5    38.5
      39.5    40.5    41.5    42.5    43.5
      44.5    45.5    46.5    47.5    48.5
      49.5    50.5    51.5    52.5    53.5
      54.5    55.5    56.5    57.5    58.5
      59.5    60.5    61.5    62.5    63.5
      64.5    65.5    66.5    67.5    68.5
      69.5    70.5    71.5    72.5    73.5
      74.5    75.5    76.5    77.5    78.5
      79.5    80.5    81.5    82.5    83.5
      84.5    85.5    86.5    87.5    88.5
      89.5    90.5    91.5    92.5    93.5
      94.5    95.5    96.5    97.5    98.5
      99.5   100.0   110.0   120.0   130.0
     140.0   150.0   160.0   170.0   180.0
     190.0   200.0   204.8   214.8   224.8
     234.8   244.8   254.8   264.8   274.8
     284.8   294.8   304.8   314.8   324.8
     334.8   344.8   354.8   364.8   374.8
     384.8   394.8   404.8   414.8   424.8
     434.8   444.8   454.8   464.8   474.8
     484.8   494.8   504.8   514.8   524.8
     534.8   544.8   554.8   564.8   574.8
     584.8   594.8   604.8   614.8   624.8
     634.8   644.8   654.8   664.8   674.8
     684.8   694.8   704.8   714.8   724.8
     734.8   744.8   754.8   764.8   774.8
     784.8   794.8   804.8   814.8   824.8
     834.8   844.8   854.8   864.8   874.8
     884.8   894.8   904.8   914.8   924.8
     934.8   944.8   954.8   964.8   974.8
     984.8   994.8  1004.8  1014.8  1024.8
    1034.8  1044.8  1054.8  1064.8  1074.8
    1084.8  1094.8  1104.8  1114.8  1123.1
    1133.1  1143.1  1153.1  1163.1  1173.1
    1183.1  1193.1  1203.1  1213.1  1223.1

```



1233.1	1243.1	1251.9	1261.9	1271.9
1281.9	1291.9	1301.9	1311.9	1321.9
1331.9	1341.9	1351.9	1361.9	1371.9
1381.9	1391.9	1401.7	1402.7	1403.7
1404.7	1405.7	1406.7	1407.7	1408.7
1409.7	1410.7	1411.7	1412.7	1413.7
1414.7	1415.7	1416.7	1417.7	1418.7
1419.7	1420.7	1421.7	1422.7	1423.7
1424.7	1425.7	1426.7	1427.7	1428.7
1429.7	1430.7	1431.7	1432.7	1433.7
1434.7	1435.7	1436.7	1437.7	1438.7
1439.7	1440.7	1441.7	1442.7	1443.7
1444.7	1445.7	1446.7	1447.7	1448.7
1449.7	1450.7	1451.7	1452.7	1453.7
1454.7	1455.7	1456.7	1457.7	1458.7
1459.7	1460.7	1461.7	1462.7	1463.7
1464.7	1465.7	1466.7	1467.7	1468.7
1469.7	1470.7	1471.7	1472.7	1473.7
1474.7	1475.7	1476.7	1477.7	1478.7
1479.7	1480.7	1481.7	1482.7	1483.7
1484.7	1485.7	1486.7	1487.7	1488.7
1489.7	1490.7	1491.7	1492.7	1493.7
1494.7	1495.7	1496.7	1497.7	1498.7
1499.7	1500.7	1501.7	1502.7	1503.7
1504.7	1505.7	1506.7	1507.7	1508.7
1509.7	1510.7	1511.7	1512.7	1513.7
1514.7	1515.7	1516.7	1517.7	1518.7
1519.7	1520.7	1521.7	1522.7	1523.7
1524.7	1525.7	1526.7	1527.7	1528.7
1529.7	1530.7	1531.7	1532.7	1533.7
1534.7	1535.7	1536.7	1537.7	1538.7
1539.7	1540.7	1541.7	1542.7	1543.7
1544.7	1545.7	1546.7	1547.7	1548.7
1549.7	1550.7	1551.7	1552.7	1553.7
1554.7	1555.7	1556.7	1557.7	1558.7
1559.7	1560.7	1561.7	1562.7	1563.7
1564.7	1565.7	1566.7	1567.7	1568.7
1569.7	1570.7	1571.7	1572.7	1573.7
1574.7	1575.7	1576.7	1577.7	1578.7
1579.7	1580.7	1581.7	1582.7	1583.7
1584.7	1585.7	1586.7	1587.7	1588.7
1589.7	1590.7	1591.7	1592.7	1593.7
1594.7	1595.7	1596.7	1597.7	1598.7
1599.7	1600.7	1601.7	1602.7	1603.7
1604.7	1605.7	1606.7	1607.7	1608.7
1609.7	1610.7	1611.7	1612.7	1613.7
1614.7	1615.7	1616.7	1617.7	1618.7
1619.7	1620.7	1621.7	1622.7	1623.7
1624.7	1625.7	1626.7	1627.7	1628.7
1629.7	1630.7	1631.7	1632.7	1633.7
1634.7	1635.7	1636.7	1637.7	1638.7
1639.7	1640.7	1641.7	1642.7	1643.7
1644.7	1645.7	1646.7	1647.7	1648.7
1649.7	1650.7	1651.7	1652.7	1653.7
1654.7	1655.7	1656.7	1657.7	1658.7
1659.7	1660.7	1661.7	1662.7	1663.7
1664.7	1665.7	1666.7	1667.7	1668.7
1669.7	1670.7	1671.7	1672.7	1673.7
1674.7	1675.7	1676.7	1677.7	1678.7
1679.7	1680.7	1681.7	1682.7	1683.7
1684.7	1685.7	1686.7	1687.7	1688.7
1689.7	1690.7	1691.7	1692.7	1693.7
1694.7	1695.7	1696.7	1697.7	1698.7
1699.7	1700.7	1701.7	1702.7	1703.7
1704.7	1705.7	1706.7	1707.7	1708.7
1709.7	1710.7	1711.7	1712.7	1713.7
1714.7	1715.7	1716.7	1717.7	1718.7
1719.7	1720.7	1721.7	1722.7	1723.7



2631.7	2641.7	2651.7	2661.7	2671.7
2681.7	2691.7	2701.7	2711.7	2721.7
2731.7	2741.7	2751.7	2761.7	2771.7
2781.7	2791.7	2801.7	2803.2	2813.1
2823.1	2833.1	2843.1	2853.1	2863.1
2873.1	2883.1	2893.1	2903.1	2913.1
2923.1	2933.1	2943.1	2953.1	2963.1
2973.1	2983.1	2993.1	3003.1	3013.1
3023.1	3033.1	3043.1	3053.1	3063.1
3073.1	3083.1	3093.1	3103.1	3113.1
3123.1	3133.1	3143.1	3153.1	3163.1
3173.1	3183.1	3193.1	3203.1	3213.1
3223.1	3233.1	3243.1	3253.1	3263.1
3273.1	3283.1	3293.1	3303.1	3313.1
3323.1	3333.1	3343.1	3353.1	3363.1
3373.1	3383.1	3393.1	3403.1	3413.1
3423.1	3433.1	3443.1	3453.1	3463.1
3473.1	3483.1	3493.1	3503.1	3513.1
3523.1	3533.1	3543.1	3553.1	3563.1
3573.1	3583.1	3593.1		

mass =	0.4	129.6	180.3	192.7	193.1
	316.4	1081.9	1858.9	138.5	87.6
	73.9	70.7	70.0	70.0	70.0
	70.0	70.5	71.8	73.1	74.3
	75.4	76.2	76.9	77.5	78.2
	78.8	79.4	79.9	80.5	81.0
	81.5	82.0	82.4	82.8	83.2
	83.6	84.0	84.3	84.6	84.9
	85.2	85.4	85.6	85.8	86.0
	86.2	86.4	86.5	86.6	86.7
	86.8	86.9	87.0	87.0	87.1
	87.1	87.1	87.1	87.0	87.0
	86.9	86.9	86.8	86.7	86.6
	86.4	86.3	86.1	86.0	85.8
	85.6	85.4	85.2	85.0	84.8
	84.5	84.3	84.0	83.7	83.4
	83.2	82.9	82.6	82.3	82.0
	81.7	81.3	81.0	80.6	80.2
	79.9	79.5	79.1	78.8	78.4
	78.0	77.5	77.0	76.5	76.0
	75.5	75.3	71.6	70.8	71.1
	69.4	68.5	67.2	65.9	64.4
	62.6	60.5	59.5	57.3	54.9
	52.3	49.7	47.1	55.6	54.2
	52.9	51.7	50.5	49.5	48.7
	48.1	47.6	47.2	46.8	46.2
	45.6	45.0	44.2	43.4	42.6
	41.7	40.8	39.9	38.9	37.8
	36.3	35.3	34.1	33.0	32.1
	31.6	30.7	30.5	29.7	28.9
	28.0	27.1	26.3	25.5	24.7
	24.0	23.4	22.8	22.2	21.7
	21.4	20.6	23.2	22.8	22.5
	22.1	21.7	21.3	20.9	21.9
	20.3	20.1	20.0	19.9	19.7
	19.6	19.5	19.4	19.3	19.1
	19.0	18.9	18.9	18.6	18.4
	18.2	18.0	17.8	17.6	17.4
	17.3	17.1	17.0	16.9	16.8
	16.7	16.6	16.5	16.4	16.4
	15.3	16.2	16.2	16.2	16.2
	16.1	16.0	15.9	15.8	15.7
	15.6	15.6	15.4	15.3	15.3
	15.2	15.3	15.3	15.1	15.4
	15.3	15.3	15.3	15.7	16.0
	16.7	15.8	13.9	15.6	16.0
	15.9	14.4	16.0	16.4	16.0



18.6	18.5	18.4	18.4	18.5
18.6	18.4	18.3	18.3	18.3
18.3	18.3	18.1	17.5	17.7
17.6	17.8	17.6	17.4	17.5
17.3	17.3	17.2	17.1	17.1
17.0	17.0	17.0	17.0	16.9
16.9	16.9	16.9	16.9	16.9
16.9	17.0	17.0	17.0	17.0
17.1	17.1	17.1	17.2	17.2
17.2	17.3	17.3	17.4	17.4
17.5	17.5	17.5	17.6	17.6
17.7	17.7	17.8	17.9	17.9
17.9	18.0	18.0	18.0	18.1
18.1	18.1	18.1	18.1	18.1
18.1	18.2	18.2	18.2	18.2
18.2	18.2	18.2	18.1	18.0
18.0	18.0	18.0	18.0	18.0
18.0	18.0	18.0	18.0	18.0
18.0	18.0	17.9	17.9	17.9
17.9	17.9	17.9	17.9	17.9
17.8	17.8	17.8	17.8	17.8
17.8	17.8	17.8	17.7	17.7
17.7	17.7	17.7	17.6	17.6
17.6	17.6	17.5	17.5	17.5
17.5	17.5	17.4	17.4	17.4
17.4	17.4	17.3	17.3	17.3
17.3	17.2	17.2	17.2	17.2
17.2	17.1	17.1	17.1	17.1
17.1	17.1	17.1	17.0	17.0
17.0	17.0	17.0	17.0	17.0
17.0	17.0	17.0	16.9	16.9
16.9	16.9	16.9	16.9	16.9
16.9	16.9	16.9	16.9	16.9
16.9	16.9	16.9	16.9	16.9
16.9	16.9	16.9	16.9	16.9
16.9	16.9	16.9	16.8	16.8
16.8	16.8	16.8	16.8	16.8
16.8	16.8	16.8	16.8	16.8
16.8	16.7	16.7	16.7	16.7
16.7	16.6	16.6	16.6	16.6
16.6	16.5	16.5	16.5	16.6
16.5	16.6	16.5	16.5	16.5
16.5	16.4	16.4	16.4	16.4
16.3	16.3	16.3	16.3	16.3
16.3	16.2	16.2	16.2	16.2
16.2	16.1	16.1	16.1	16.1
16.1	16.1	16.0	16.0	16.0
16.0	16.0	15.9	15.9	15.9
15.9	15.9	15.9	15.8	15.8
15.8	15.8	15.8	15.8	15.7
15.7	15.7	15.5	15.3	15.2
15.1	14.9	14.7	14.6	14.4
14.3	14.1	14.0	13.4	17.8
12.7	17.8	10.3	12.3	15.5
13.4	12.2	10.8	10.6	17.7
10.5	15.6	9.5	10.5	19.7
10.1	10.4	21.7	10.6	10.1
11.8	23.0	13.3	10.1	10.2
18.3	13.8	24.8	30.1	25.9
30.1	31.5	35.3	35.8	40.4
42.2	43.6	44.8	40.7	38.3
47.8	47.3	47.8	48.3	48.7
49.1	49.4	49.7	50.0	50.2
50.5	50.7	51.0	51.2	51.4
51.0	51.8	53.8	58.2	45.5
46.8	61.8	52.4	47.1	46.0
51.0	48.9	43.4	49.4	59.0

53.9	56.7	43.3	48.5	48.2
18.1	65.5	35.9	44.9	16.5
39.5	193.3	56.4	33.5	44.2
36.0	34.5	69.8	30.0	36.7
40.6	167.6	29.4	30.3	17.0
76.6	46.1	35.2	23.6	22.3
24.9	20.1	33.4	39.7	12.9
148.4	15.0	12.7	25.4	28.3
11.0	21.6	75.8	9.0	7.1
38.7	47.6	18.3	37.9	14.2
19.4	20.1	13.9	27.4	35.1
46.0	59.9	343.8	20.4	22.1
24.6	15.8	45.6	51.6	13.9
36.5	36.0	22.5	46.4	40.5
33.3	67.3	40.5	25.3	25.8
10.2	21.4	38.6		

enth	158119.7	158227.3	158224.4	158225.9	158227.3
	158231.8	158290.1	200020.9	801773.9	739475.9
	717309.5	710926.9	709328.2	708997.9	708972.0
	709051.6	709962.1	712237.8	714723.1	716948.4
	719030.4	720731.1	722092.6	723370.2	724584.8
	725732.9	726830.3	727881.6	728883.3	729840.0
	730755.5	721626.6	732454.2	733232.6	733982.9
	734699.7	735379.2	735984.2	736521.3	737021.4
	737490.4	737931.1	738343.2	738727.2	739081.0
	739406.4	739701.6	739975.8	740219.4	740435.4
	740627.1	740785.1	740918.6	741025.1	741105.0
	741159.0	741187.4	741190.4	741186.6	741122.0
	741053.6	740961.8	740846.1	740707.2	740546.2
	740365.8	740159.9	739935.2	739690.4	739426.2
	739143.2	738841.9	738522.9	738185.7	737829.4
	737450.4	737038.1	736603.1	736156.5	735705.2
	735750.3	734792.2	734320.8	733828.8	733315.4
	732781.4	732212.5	731618.5	731010.4	730393.1
	729769.6	729142.3	728513.2	727984.8	727258.9
	726560.8	725671.6	724754.8	723847.2	722956.5
	722086.6	721659.0	715014.9	713975.0	713141.8
	712611.8	711530.6	709910.0	708015.9	705624.1
	702664.4	699061.7	697194.5	693005.6	688192.2
	682777.9	676902.8	670659.7	664372.2	659257.0
	680095.4	683054.6	686163.1	684603.9	683478.6
	682749.9	682227.4	681986.2	681537.4	680834.9
	67976.2	678834.3	677556.9	675880.1	673988.2
	671933.6	669684.8	667475.7	664668.4	661817.4
	657678.0	654055.8	650935.4	647915.2	644864.2
	643106.8	639898.3	636623.4	635707.2	632431.1
	629020.4	625527.4	622024.9	618310.1	615047.8
	611596.8	78399.0	705316.4	602375.1	599389.2
	596320.0	583215.0	616752.3	614416.6	612202.2
	606997.1	60608.5	605179.7	602860.1	603460.2
	597045.3	595503.9	593669.6	591843.9	590032.1
	588299.5	586453.2	584804.4	583027.2	581271.2
	579531.1	577794.5	576019.1	573958.9	571776.8
	569679.8	567515.6	565414.3	563159.6	561125.9
	559112.1	557095.1	555105.3	553148.6	551217.9
	549311.2	547424.7	545566.2	543758.9	541994.4
	540798.2	538603.6	537009.8	535496.8	534296.5
	532671.4	530901.1	529160.1	527457.2	525799.1
	524603.6	523587.1	520874.9	519416.4	518017.0
	516685.8	516124.5	513376.3	512901.8	512945.8
	511718.2	510283.4	509077.4	507801.2	510549.6
	512647.0	507684.8	492006.9	503425.8	505358.6
	503450.1	492980.8	502774.3	504377.4	502896.8
	503098.3	503112.8	503109.9	503008.1	502207.0
	502842.4	502780.0	502705.6	502618.7	502531.2
	502451.3	502371.4	502287.2	502201.0	502115.3
	502030.5	501945.4	501856.8	501775.7	501685.3

501599.9	501516.4	501426.1	501338.3	501251.2
501163.5	501075.0	500986.8	500899.3	500811.4
500722.4	500633.9	500545.9	500455.6	500362.3
500272.1	500185.2	500099.2	499992.4	499910.4
499820.7	499730.2	499640.6	499550.4	499460.1
499370.6	499298.7	499241.4	499151.8	499073.4
498993.8	498909.8	498803.6	498682.7	498594.9
498503.6	498412.0	498314.3	498216.3	498124.2
498031.7	497937.2	497839.9	497741.2	497644.0
497545.8	497445.5	497344.8	497242.9	497139.8
497036.5	496931.6	496824.6	496719.2	496613.4
496506.6	496400.4	496293.4	496185.1	496077.3
495968.8	495859.2	495750.0	495640.2	495529.2
495418.6	495307.2	495194.8	495082.8	494970.3
494856.8	494744.2	494631.1	494516.7	494402.8
494288.7	494173.3	494058.7	493943.2	493826.2
493710.1	493593.7	493475.8	493358.4	493240.3
493121.0	493002.4	492883.5	492763.7	492644.5
492523.6	492403.7	492286.3	492167.2	492043.1
491923.4	491802.4	491680.3	491557.5	491436.0
491318.1	491200.4	491080.7	490958.8	490831.9
490693.2	490561.7	490446.4	490329.2	490210.9
490095.2	489976.7	489856.3	489736.2	489615.6
489493.7	489403.6	489118.8	488625.4	488695.8
488665.6	488621.4	488523.4	488448.1	488325.8
488162.0	488033.8	487904.6	487785.2	487628.8
487503.8	487413.2	487305.3	487233.6	487132.5
487026.6	486932.0	486839.6	486743.4	486647.6
486550.8	486454.2	486365.1	486265.2	486179.0
486077.0	486009.0	485938.0	485856.3	485807.5
485738.7	485684.3	485617.9	485555.1	485492.9
485428.5	485366.0	485305.1	485242.7	485162.1
485123.0	485061.6	485003.9	484947.5	484886.0
484826.4	484761.9	484694.4	484632.8	484580.8
484740.7	484684.0	484758.4	484785.6	484674.5
484862.9	484856.4	484628.3	484227.8	484035.3
484376.7	484049.7	484154.8	484109.4	484041.3
484038.5	484063.7	484094.8	484105.8	484072.1
484042.4	484035.3	484011.9	483977.5	483931.2
483881.2	483833.6	483775.8	483715.9	483806.5
484104.0	484102.3	483784.3	483999.2	484097.2
484283.9	484217.7	483661.2	483412.4	483142.9
483167.7	483321.6	483441.3	483550.2	483781.1
485563.1	486109.5	482082.7	481911.0	481994.3
481958.0	482195.5	482398.5	482023.8	481575.0
481915.9	482057.5	482242.2	482317.6	481837.1
481344.8	481243.8	481138.5	481129.9	481354.5
481736.1	481891.2	481780.8	482605.9	484615.5
485701.1	486569.8	486403.9	478936.3	471353.8
476089.3	480330.4	480356.5	481788.5	483664.2
484686.2	485813.9	487225.6	488244.0	489258.5
490229.2	491248.3	492209.3	493156.8	493976.9
494784.8	495519.2	496221.2	496876.7	497467.4
498914.8	498535.7	499009.5	499430.2	499722.4
500109.3	500612.6	501056.4	501165.0	501408.8
501654.8	501759.9	501864.0	501980.3	502044.3
502104.0	502151.2	502192.2	502208.8	502220.8
502222.0	502211.1	502191.5	502171.2	502123.3
502071.8	502022.2	501951.2	501872.1	501781.8
501682.3	501573.1	501449.1	501341.9	501191.6
501039.6	500879.3	500701.2	500497.9	500250.5
499914.3	499532.5	499202.6	499026.2	498848.2
498746.8	498589.8	498435.0	498342.0	498282.0
498140.3	497891.6	497652.3	497332.9	497096.8
496874.6	496551.5	496060.6	496262.5	496523.2
497200.3	496384.6	495783.5	495979.4	495983.6
495919.8	495702.1	495201.9	494372.8	493506.3
492932.0	492866.3	492920.5	492296.8	491639.2

491628.3	491638.1	491294.1	490949.2	490843.3
490721.5	490580.2	490554.4	490431.1	490311.6
490366.2	490356.9	490299.6	490411.7	490387.4
490473.5	490619.8	490728.8	490830.2	490899.1
491086.6	491285.1	491444.7	491620.2	491833.6
492043.6	492247.8	492469.4	492691.2	492912.8
493146.3	493376.9	493598.4	493829.0	494053.5
494226.2	494479.4	494669.3	495184.7	495363.0
495480.6	495686.9	495878.5	496005.3	496112.4
496194.5	496355.1	496417.6	496616.8	496643.9
496893.2	496725.4	496819.3	496915.2	496883.5
496908.6	496974.7	496981.4	496883.0	496530.7
496331.5	496333.7	496432.3	496436.7	496538.5
496539.7	496528.8	496486.8	496528.0	496559.4
496612.4	496597.6	496612.3	496595.8	496625.6
496616.3	496641.1	496619.7	496589.2	496604.2
496550.6	496595.7	496591.0	496636.2	496553.0
496619.4	496626.2	496562.3	496500.8	496519.6
496494.7	496435.9	496430.2	496405.0	496357.4
496354.4	496322.7	496272.8	496276.1	496244.7
496194.8	496195.5	496168.1	496120.5	496125.4
496099.0	496039.4	496032.2	496009.4	495992.2
496030.2	496057.6	496061.2	496050.8	496097.9
496138.9	496164.5	496191.4	496224.6	496264.4
496307.2	496343.2	496387.2	496434.6	496477.7
496528.3	496584.4	496589.5	496647.7	496716.5
496921.0	496914.6	496911.1	496987.5	497050.8
497133.3	497316.2	497234.7	497385.7	497452.6
497470.9	497552.2	497727.9	497782.8	497839.7
497904.3	498015.5	498126.8	498176.3	498284.5
498360.7	498437.2	498514.6	498621.3	498684.6
498813.7	498955.1	499024.7	499094.3	499118.1
499294.7	499253.2	499439.5	499555.1	499576.8
499698.7	499725.7	499843.1	499991.8	499995.7
500087.3	500217.1	500253.8	500465.8	500588.2
500616.2	500605.5	500697.4	500806.1	500867.6
500875.8	500967.2	501065.7	501243.8	501374.4
501358.4	501218.0	501476.2	501414.1	501833.2
502089.8	501984.8	501847.2	501905.6	502063.9
502186.2	502233.2	502247.1	502329.1	502443.2
502560.7	502653.4	502731.0	502824.6	502936.9
503055.0	503171.3	503286.6	503471.1	503520.1
503630.4	503745.3	503861.3	503966.8	504112.2
504239.9	504368.7	504497.4	504631.8	504769.8
504907.4	505047.6	505189.9	505332.3	505478.6
505627.9	505776.6	505928.7	506081.8	506236.2
506391.8	506551.6	506709.8	506871.8	507035.3
507200.9	507255.7	508830.2	510269.1	512467.3
514797.2	517280.5	519964.8	522849.5	525973.6
529298.2	532546.1	536079.9	536775.9	529923.5
17303.6	516278.6	517827.9	508366.2	506544.3
507008.1	503415.7	502145.2	514348.3	507249.9
509043.2	504951.2	514045.5	498842.8	510093.9
508808.2	500493.4	507479.2	511664.1	499990.9
500438.6	507298.9	511570.2	506069.8	498170.8
503978.9	517406.3	523997.4	554966.4	562750.3
553098.6	569402.8	575856.3	575055.0	580318.0
585552.4	589292.8	592230.4	582566.3	572876.5
594416.9	598138.9	599301.4	600233.2	601018.4
600986.7	602255.6	602763.5	603216.8	603617.4
605375.0	604320.1	604619.5	604697.0	605155.8
598220.9	605572.7	611807.5	610863.6	604977.0
604008.9	605815.1	620290.3	610443.5	597061.5
620321.1	596579.9	600616.5	606329.9	601491.9
630472.3	612820.9	54136.8	591190.7	611101.1
609474.1	599093.1	624696.5	602110.7	569970.2
576664.2	593093.4	576145.4	620684.4	591197.6
	573551.6	593672.5	565813.9	562640.9



601482.4	585634.5	572019.6	552365.2	565140.4
585228.1	557787.9	559249.9	527572.1	531403.7
564263.6	549020.9	549939.1	558838.2	580349.6
581261.8	605545.5	599064.2	603206.9	570482.6
560178.6	600449.8	572579.2	564005.6	536288.3
559654.4	550652.9	606809.3	567090.9	584522.1
558326.2	571625.2	574650.6	541837.4	563282.1
564436.1	584453.8	545579.2	553446.7	577896.8
569475.7	551011.0	593928.9	591056.8	566946.3
575514.6	563008.6	587210.4	566057.7	581234.0
574262.8	567689.1	577991.0	575992.9	564074.6
562345.1	569967.5	570910.3		

eo1

&&

&& Blowdown of primary system steam

&&

n2ov = 914

iflag = 2

t	=	0.0	0.5	1.5	2.5	3.5
		4.5	5.5	6.5	7.5	8.5
		9.5	10.5	11.5	12.5	13.5
		14.5	15.5	16.5	17.5	18.5
		19.5	20.5	21.5	22.5	23.5
		24.5	25.5	26.5	27.5	28.5
		29.5	30.5	31.5	32.5	33.5
		34.5	35.5	36.5	37.5	38.5
		39.5	40.5	41.5	42.5	43.5
		44.5	45.5	46.5	47.5	48.5
		49.5	50.5	51.5	52.5	53.5
		54.5	55.5	56.5	57.5	58.5
		59.5	60.5	61.5	62.5	63.5
		64.5	65.5	66.5	67.5	68.5
		69.5	70.5	71.5	72.5	73.5
		74.5	75.5	76.5	77.5	78.5
		79.5	80.5	81.5	82.5	83.5
		84.5	85.5	86.5	87.5	88.5
		89.5	90.5	91.5	92.5	93.5
		94.5	95.5	96.5	97.5	98.5
		99.5	100.0	110.0	120.0	130.0
		140.0	150.0	160.0	170.0	180.0
		190.0	200.0	204.8	214.8	224.8
		234.8	244.8	254.8	264.8	274.8
		284.8	294.8	304.8	314.8	324.8
		334.8	344.8	354.8	364.8	374.8
		384.8	394.8	404.8	414.8	424.8
		434.8	444.8	454.8	464.8	474.8
		484.8	494.8	504.8	514.8	524.8
		534.8	544.8	554.8	564.8	574.8
		584.8	594.8	604.8	614.8	624.8
		634.8	644.8	654.8	664.8	674.8
		684.8	694.8	704.8	714.8	724.8
		734.8	744.8	754.8	764.8	774.8
		784.8	794.8	804.8	814.8	824.8
		834.8	844.8	854.8	864.8	874.8
		884.8	894.8	904.8	914.8	924.8
		934.8	944.8	954.8	964.8	974.8
		984.8	994.8	1004.8	1014.8	1024.8
		1034.8	1044.8	1054.8	1064.8	1074.8
		1084.8	1094.8	1104.8	1114.8	1123.1
		1133.1	1143.1	1153.1	1163.1	1173.1
		1183.1	1193.1	1203.1	1213.1	1223.1
		1233.1	1243.1	1251.9	1261.9	1271.9
		1281.9	1291.9	1301.9	1311.9	1321.9
		1331.9	1341.9	1351.9	1361.9	1371.9
		1381.9	1391.9	1401.7	1402.7	1403.7
		1404.7	1405.7	1406.7	1407.7	1408.7
		1409.7	1410.7	1411.7	1412.7	1413.7
		1414.7	1415.7	1416.7	1417.7	1418.7

1419.7	1420.7	1421.7	1422.7	1423.7
1424.7	1425.7	1426.7	1427.7	1428.7
1429.7	1430.7	1431.7	1432.7	1433.7
1434.7	1435.7	1436.7	1437.7	1438.7
1439.7	1440.7	1441.7	1442.7	1443.7
1444.7	1445.7	1446.7	1447.7	1448.7
1449.7	1450.7	1451.7	1452.7	1453.7
1454.7	1455.7	1456.7	1457.7	1458.7
1459.7	1460.7	1461.7	1462.7	1463.7
1464.7	1465.7	1466.7	1467.7	1468.7
1469.7	1470.7	1471.7	1472.7	1473.7
1474.7	1475.7	1476.7	1477.7	1478.7
1479.7	1480.7	1481.7	1482.7	1483.7
1484.7	1485.7	1486.7	1487.7	1488.7
1489.7	1490.7	1491.7	1492.7	1493.7
1494.7	1495.7	1496.7	1497.7	1498.7
1499.7	1500.7	1501.7	1502.7	1503.7
1504.7	1505.7	1506.7	1507.7	1508.7
1509.7	1510.7	1511.7	1512.7	1513.7
1514.7	1515.7	1516.7	1517.7	1518.7
1519.7	1520.7	1521.7	1522.7	1523.7
1524.7	1525.7	1526.7	1527.7	1528.7
1529.7	1530.7	1531.7	1532.7	1533.7
1534.7	1535.7	1536.7	1537.7	1538.7
1539.7	1540.7	1541.7	1542.7	1543.7
1544.7	1545.7	1546.7	1547.7	1548.7
1549.7	1550.7	1551.7	1552.7	1553.7
1554.7	1555.7	1556.7	1557.7	1558.7
1559.7	1560.7	1561.7	1562.7	1563.7
1564.7	1565.7	1566.7	1567.7	1568.7
1569.7	1570.7	1571.7	1572.7	1573.7
1574.7	1575.7	1576.7	1577.7	1578.7
1579.7	1580.7	1581.7	1582.7	1583.7
1584.7	1585.7	1586.7	1587.7	1588.7
1589.7	1590.7	1591.7	1592.7	1593.7
1594.7	1595.7	1596.7	1597.7	1598.7
1599.7	1600.7	1601.7	1602.7	1603.7
1604.7	1605.7	1606.7	1607.7	1608.7
1609.7	1610.7	1611.7	1612.7	1613.7
1614.7	1615.7	1616.7	1617.7	1618.7
1619.7	1620.7	1621.7	1622.7	1623.7
1624.7	1625.7	1626.7	1627.7	1628.7
1629.7	1630.7	1631.7	1632.7	1633.7
1634.7	1635.7	1636.7	1637.7	1638.7
1639.7	1640.7	1641.7	1642.7	1643.7
1644.7	1645.7	1646.7	1647.7	1648.7
1649.7	1650.7	1651.7	1652.7	1653.7
1654.7	1655.7	1656.7	1657.7	1658.7
1659.7	1660.7	1661.7	1662.7	1663.7
1664.7	1665.7	1666.7	1667.7	1668.7
1669.7	1670.7	1671.7	1672.7	1673.7
1674.7	1675.7	1676.7	1677.7	1678.7
1679.7	1680.7	1681.7	1682.7	1683.7
1684.7	1685.7	1686.7	1687.7	1688.7
1689.7	1690.7	1691.7	1692.7	1693.7
1694.7	1695.7	1696.7	1697.7	1698.7
1699.7	1700.7	1701.7	1702.7	1703.7
1704.7	1705.7	1706.7	1707.7	1708.7
1709.7	1710.7	1711.7	1712.7	1713.7
1714.7	1715.7	1716.7	1717.7	1718.7
1719.7	1720.7	1721.7	1722.7	1723.7
1724.7	1725.7	1726.7	1727.7	1728.7
1729.7	1730.7	1731.7	1732.7	1733.7
1734.7	1735.7	1736.7	1737.7	1738.7
1739.7	1740.7	1741.7	1742.7	1743.7
1744.7	1745.7	1746.7	1747.7	1748.7
1749.7	1750.7	1751.7	1752.7	1753.7
1754.7	1755.7	1756.7	1757.7	1758.7

1758.7	1760.7	1761.7	1762.7	1763.7
1764.7	1765.7	1766.7	1767.7	1768.7
1769.7	1770.7	1771.7	1772.7	1773.7
1774.7	1775.7	1776.7	1777.7	1778.7
1779.7	1780.7	1781.7	1782.7	1783.7
1784.7	1785.7	1786.7	1787.7	1788.7
1789.7	1790.7	1791.7	1792.7	1793.7
1794.7	1795.7	1796.7	1797.7	1798.7
1799.7	1800.7	1801.7	1802.7	1803.7
1804.7	1805.7	1806.7	1807.7	1808.7
1809.7	1810.7	1811.7	1812.7	1813.7
1814.7	1815.7	1816.7	1817.7	1818.7
1819.7	1820.7	1821.7	1822.7	1823.7
1824.7	1825.7	1826.7	1827.7	1828.7
1829.7	1830.7	1831.7	1832.7	1833.7
1834.7	1835.7	1836.7	1837.7	1838.7
1839.7	1840.7	1841.7	1842.7	1843.7
1844.7	1845.7	1846.7	1847.7	1848.7
1849.7	1850.7	1851.7	1852.7	1853.7
1854.7	1855.7	1856.7	1857.7	1858.7
1859.7	1860.7	1861.7	1862.7	1863.7
1864.7	1865.7	1866.7	1867.7	1868.7
1869.7	1870.7	1871.7	1872.7	1873.7
1874.7	1875.7	1876.7	1877.7	1878.7
1879.7	1880.7	1881.7	1882.7	1883.7
1884.7	1885.7	1886.7	1887.7	1888.7
1889.7	1890.7	1891.7	1892.7	1893.7
1894.7	1895.7	1896.7	1897.7	1898.7
1899.7	1900.7	1901.7	1902.7	1903.7
1904.7	1905.7	1906.7	1907.7	1908.7
1909.7	1910.7	1911.7	1912.7	1913.7
1914.7	1915.7	1916.7	1917.7	1918.7
1919.7	1920.7	1921.7	1922.7	1923.7
1924.7	1925.7	1926.7	1927.7	1928.7
1929.7	1930.7	1931.7	1932.7	1933.7
1934.7	1935.7	1936.7	1937.7	1938.7
1939.7	1940.7	1941.7	1942.7	1943.7
1944.7	1945.7	1946.7	1947.7	1948.7
1949.7	1950.7	1951.7	1952.7	1953.7
1954.7	1955.7	1956.7	1957.7	1958.7
1959.7	1960.7	1961.7	1962.7	1963.7
1964.7	1965.7	1966.7	1967.7	1968.7
1969.7	1970.7	1971.7	1972.7	1973.7
1974.7	1975.7	1976.7	1977.7	1978.7
1979.7	1980.7	1981.7	1982.7	1983.7
1984.7	1985.7	1986.7	1987.7	1988.7
1989.7	1990.7	1991.7	1992.7	1993.7
1994.7	1995.7	1996.7	1997.7	1998.7
1999.7	2000.0	2010.0	2020.0	2030.0
2040.0	2050.0	2060.0	2070.0	2080.0
2090.0	2100.0	2110.0	2120.0	2130.0
2140.0	2150.0	2160.0	2170.0	2180.0
2190.0	2200.0	2210.0	2220.0	2230.0
2240.0	2250.0	2260.0	2270.0	2280.0
2290.0	2300.0	2310.0	2320.0	2330.0
2340.0	2350.0	2360.0	2370.0	2380.0
2390.0	2400.0	2410.0	2420.0	2430.0
2440.0	2450.0	2460.0	2470.0	2480.0
2490.0	2500.0	2510.0	2520.0	2521.7
2531.7	2541.7	2551.7	2561.7	2571.7
2581.7	2591.7	2601.7	2611.7	2621.7
2631.7	2641.7	2651.7	2661.7	2671.7
2681.7	2691.7	2701.7	2711.7	2721.7
2731.7	2741.7	2751.7	2761.7	2771.7
2781.7	2791.7	2801.7	2803.2	2813.1
2823.1	2833.1	2843.1	2853.1	2863.1
2873.1	2883.1	2893.1	2903.1	2913.1
2923.1	2933.1	2943.1	2953.1	2963.1

2973.1	2983.1	2993.1	3003.1	3013.1
3023.1	3033.1	3043.1	3053.1	3063.1
3073.1	3083.1	3093.1	3103.1	3113.1
3123.1	3133.1	3143.1	3153.1	3163.1
3173.1	3183.1	3193.1	3203.1	3213.1
3223.1	3233.1	3243.1	3253.1	3263.1
3273.1	3283.1	3293.1	3303.1	3313.1
3323.1	3333.1	3343.1	3353.1	3363.1
3373.1	3383.1	3393.1	3403.1	3413.1
3423.1	3433.1	3443.1	3453.1	3463.1
3473.1	3483.1	3493.1	3503.1	3513.1
3523.1	3533.1	3543.1	3553.1	3563.1
3573.1	3583.1	3593.1		

mass =	0.0	0.0	0.0	0.0	0.0
	0.0	0.0	0.0	50.5	39.4
	35.2	33.8	33.4	33.3	33.3
	33.3	33.4	33.8	34.3	34.7
	35.2	35.6	35.9	36.1	36.4
	36.7	36.9	37.1	37.3	37.6
	37.8	38.0	38.1	38.3	38.5
	38.6	38.8	38.9	39.1	39.2
	39.3	39.4	39.5	39.6	39.7
	39.8	39.8	39.9	40.0	40.0
	40.1	40.1	40.1	40.2	40.2
	40.2	40.2	40.3	40.3	40.3
	40.2	40.2	40.2	40.2	40.2
	40.1	40.1	40.1	40.0	40.0
	39.9	39.9	39.8	39.7	39.7
	39.6	39.5	39.4	39.3	39.3
	39.2	39.1	39.0	38.9	38.8
	38.7	38.6	38.4	38.3	38.2
	38.1	38.0	37.8	37.7	37.6
	37.4	37.3	37.1	36.9	36.7
	36.6	36.5	35.2	35.1	35.1
	35.2	35.2	35.1	34.9	34.6
	34.2	33.7	33.4	32.8	32.0
	31.1	30.1	29.1	34.2	34.0
	33.8	33.5	33.4	33.2	33.2
	33.2	33.3	33.4	33.4	33.4
	33.4	33.3	33.1	33.0	32.8
	32.5	32.2	32.0	31.6	31.2
	30.7	30.2	29.9	29.6	29.3
	29.0	28.7	28.5	28.1	27.8
	27.4	27.0	26.7	26.3	25.9
	25.5	25.1	24.8	24.4	24.1
	23.7	23.3	23.4	27.0	26.7
	26.4	26.1	25.7	25.4	24.9
	24.5	24.2	23.9	23.5	23.2
	22.9	22.5	22.3	21.9	21.6
	21.3	21.0	20.7	20.4	20.1
	19.8	19.5	19.2	18.9	18.6
	18.3	18.0	17.7	17.4	17.1
	16.9	16.6	16.3	16.0	15.7
	15.5	15.2	15.0	14.7	14.5
	14.3	14.1	13.9	13.7	13.5
	13.3	13.2	12.9	12.7	12.5
	12.3	12.2	11.8	11.8	11.6
	11.5	11.3	11.1	10.9	10.8
	10.7	10.6	9.7	10.1	10.1
	9.8	9.5	9.7	9.6	9.7
	9.6	9.6	9.6	9.6	9.6
	9.6	9.6	9.6	9.5	9.5
	9.5	9.5	9.5	9.5	9.5
	9.5	9.4	9.4	9.4	9.4
	9.4	9.4	9.4	9.3	9.3
	9.3	9.3	9.3	9.3	9.3
	9.3	9.2	9.2	9.2	9.2

9.2	9.2	9.2	9.2	9.1
9.1	9.1	9.1	9.1	9.1
9.1	9.1	9.0	9.0	9.0
9.0	9.0	9.0	9.0	9.0
8.9	8.9	8.9	8.9	8.9
8.9	8.9	8.9	8.8	8.8
8.8	8.8	8.8	8.8	8.8
8.8	8.7	8.7	8.7	8.7
8.7	8.7	8.7	8.7	8.6
8.6	8.6	8.6	8.6	8.6
8.6	8.6	8.6	8.5	8.5
8.5	8.5	8.5	8.5	8.5
8.5	8.4	8.4	8.4	8.4
8.4	8.4	8.4	8.4	8.3
8.3	8.3	8.3	8.3	8.3
8.3	8.3	8.3	8.2	8.2
8.2	8.2	8.2	8.2	8.2
8.2	8.1	8.1	8.1	8.1
8.1	8.1	8.1	8.1	8.0
8.0	8.0	8.0	8.0	8.0
8.0	8.0	7.9	7.9	7.9
7.9	7.9	7.9	7.9	7.9
7.8	7.8	7.8	7.8	7.8
7.8	7.8	7.8	7.7	7.7
7.7	7.7	7.7	7.7	7.7
7.7	7.7	7.7	7.6	7.6
7.6	7.6	7.6	7.6	7.6
7.6	7.6	7.6	7.5	7.5
7.5	7.5	7.5	7.5	7.5
7.5	7.5	7.4	7.4	7.4
7.4	7.4	7.4	7.4	7.4
7.4	7.4	7.4	7.4	7.4
7.3	7.3	7.3	7.3	7.3
7.3	7.3	7.3	7.2	7.2
7.2	7.2	7.2	7.2	7.2
7.2	7.2	7.1	7.1	7.1
7.1	7.1	7.1	7.1	7.1
7.1	7.1	7.1	7.1	7.1
7.1	7.0	7.0	7.0	7.0
7.0	7.0	7.0	7.0	7.0
7.1	7.0	7.1	7.0	7.0
7.0	7.0	7.0	7.0	7.0
6.9	6.9	6.9	6.9	6.9
6.9	6.9	6.9	6.8	6.8
6.8	6.8	6.7	6.8	6.7
6.7	6.7	6.6	6.2	6.0
5.7	5.8	5.9	5.9	5.9
6.0	6.0	6.0	6.1	6.1
6.1	6.1	6.2	6.2	6.2
6.2	6.2	6.2	6.3	6.3
6.3	6.3	6.3	6.3	6.3
6.3	6.3	6.3	6.3	6.3
6.3	6.3	6.3	6.3	6.3
6.3	6.3	6.3	6.3	6.3
6.3	6.3	6.3	6.3	6.3
6.3	6.2	6.2	6.2	6.2
6.2	6.2	6.2	6.2	6.2
6.2	6.1	6.1	6.1	6.1
6.1	6.0	6.0	6.0	6.0
6.0	6.0	6.0	5.9	5.9
5.9	5.9	5.9	5.9	5.9
5.8	5.8	5.8	5.8	5.8
5.8	5.8	5.8	5.8	5.8
5.8	5.8	5.7	5.7	5.6
5.6	5.6	5.6	5.6	5.6
5.5	5.5	5.5	5.5	5.5
5.5	5.5	5.5	5.5	5.5
5.4	5.4	5.4	5.4	5.4



0.1	0.6	8.8	2.7	3.1
6.2	3.4	0.2	3.7	5.8
3.9	2.6	3.6	2.7	1.9
4.7	4.8	1.0	7.0	0.0
0.1	0.2	0.2	0.0	0.5
1.9	3.4	2.4	0.1	2.1
0.5	0.1	0.9	0.0	0.9
1.6	0.0	1.2	0.5	1.2
1.5	0.6	1.3		

enth =	2547525.0	2678332.0	2676740.0	2676744.0	2676692.0
	2677138.0	2672659.0	2699500.0	2781961.0	2770659.0
	2766118.0	2764730.0	2764384.0	2764313.0	2764308.0
	2764327.0	2764541.0	2765058.0	2765616.0	2766113.0
	2766577.0	2766954.0	2767244.0	2767512.0	2767766.0
	2768007.0	2768236.0	2768456.0	2768664.0	2768864.0
	2769054.0	2769235.0	2769407.0	2769569.0	2769724.0
	2769873.0	2770014.0	2770138.0	2770250.0	2770353.0
	2770450.0	2770541.0	2770626.0	2770705.0	2770778.0
	2770846.0	2770907.0	2770963.0	2771013.0	2771057.0
	2771096.0	2771129.0	2771156.0	2771178.0	2771194.0
	2771205.0	2771211.0	2771211.0	2771206.0	2771196.0
	2771182.0	2771163.0	2771139.0	2771110.0	2771076.0
	2771038.0	2770996.0	2770949.0	2770898.0	2770844.0
	2770785.0	2770722.0	2770656.0	2770586.0	2770512.0
	2770433.0	2770347.0	2770287.0	2770164.0	2770070.0
	2769976.0	2769880.0	2769782.0	2769680.0	2769573.0
	2769462.0	2769343.0	2769219.0	2769092.0	2768963.0
	2768833.0	2768702.0	2768571.0	2768439.0	2768306.0
	2768161.0	2767974.0	2767782.0	2767592.0	2767404.0
	2767221.0	2767132.0	2766962.0	2766815.0	2766623.0
	2765109.0	2764862.0	2764493.0	2764063.0	2763518.0
	2762782.0	2761877.0	2761406.0	2760343.0	2759118.0
	2757737.0	2756237.0	2754642.0	2760676.0	2760135.0
	2759584.0	2759062.0	2758579.0	2758180.0	2757891.0
	2757703.0	2757568.0	2757504.0	2757388.0	2757206.0
	2756970.0	2756692.0	2756364.0	2755932.0	2755446.0
	2754919.0	2754342.0	2753773.0	2753056.0	2752326.0
	2751265.0	2750334.0	2749540.0	2748766.0	2747980.0
	2747529.0	2746700.0	2746374.0	2745620.0	2744771.0
	2743885.0	2742975.0	2742058.0	2741070.0	2740148.0
	2739168.0	2738256.0	2737377.0	2736497.0	2735591.0
	2734657.0	2733710.0	2740603.0	2739942.0	2739314.0
	2738688.0	2738007.0	2737314.0	2736624.0	2736848.0
	2734953.0	2734395.0	2733838.0	2733282.0	2732730.0
	2732184.0	2731640.0	2731137.0	2730595.0	2730060.0
	2729529.0	2729000.0	2728459.0	2727830.0	2727163.0
	2726508.0	2725862.0	2725222.0	2724534.0	2723914.0
	2723301.0	2722686.0	2722080.0	2721484.0	2720896.0
	2720315.0	2719740.0	2719173.0	2718621.0	2718081.0
	2717550.0	2717043.0	2716554.0	2716090.0	2715720.0
	2715214.0	2714636.0	2714066.0	2713509.0	2712966.0
	2712573.0	2712290.0	2711352.0	2710872.0	2710413.0
	2709976.0	2709811.0	2708739.0	2708783.0	2708822.0
	2708254.0	2707835.0	2707499.0	2707079.0	2706826.0
	2708632.0	2707076.0	2702243.0	2705495.0	2706256.0
	2705855.0	2702095.0	2705342.0	2705978.0	2705435.0
	2705524.0	2705524.0	2705524.0	2705488.0	2705453.0
	2705432.0	2705410.0	2705385.0	2705355.0	2705325.0
	2705298.0	2705270.0	2705241.0	2705212.0	2705182.0
	2705153.0	2705124.0	2705094.0	2705066.0	2705035.0
	2705006.0	2704977.0	2704946.0	2704916.0	2704886.0
	2704856.0	2704826.0	2704795.0	2704766.0	2704735.0
	2704704.0	2704674.0	2704644.0	2704613.0	2704580.0
	2704550.0	2704520.0	2704490.0	2704454.0	2704426.0
	2704394.0	2704364.0	2704333.0	2704302.0	2704270.0
	2704240.0	2704215.0	2704196.0	2704165.0	2704138.0
	2704110.0	2704081.0	2704045.0	2704003.0	2703973.0

2703942.0	2703910.0	2703876.0	2703842.0	2703810.0
2703778.0	2703746.0	2703712.0	2703678.0	2703645.0
2703611.0	2703576.0	2703542.0	2703506.0	2703470.0
2703435.0	2703399.0	2703362.0	2703326.0	2703289.0
2703252.0	2703216.0	2703178.0	2703141.0	2703104.0
2703066.0	2703028.0	2702990.0	2702952.0	2702914.0
2702876.0	2702837.0	2702798.0	2702760.0	2702721.0
2702681.0	2702643.0	2702603.0	2702564.0	2702524.0
2702485.0	2702444.0	2702405.0	2702365.0	2702324.0
2702295.0	2702244.0	2702203.0	2702163.0	2702122.0
2702080.0	2702040.0	2701998.0	2701956.0	2701916.0
2701874.0	2701832.0	2701792.0	2701750.0	2701707.0
2701666.0	2701624.0	2701581.0	2701539.0	2701496.0
2701456.0	2701415.0	2701374.0	2701331.0	2701287.0
2701239.0	2701193.0	2701154.0	2701113.0	2701072.0
2701032.0	2700991.0	2700949.0	2700908.0	2700866.0
2700829.0	2700790.0	2700691.0	2700521.0	2700548.0
2700537.0	2700523.0	2700488.0	2700462.0	2700416.0
2700363.0	2700317.0	2700272.0	2700232.0	2700176.0
2700133.0	2700102.0	2700066.0	2700041.0	2700006.0
2699968.0	2699935.0	2699904.0	2699870.0	2699838.0
2699804.0	2699771.0	2699740.0	2699704.0	2699676.0
2699640.0	2699617.0	2699592.0	2699564.0	2699547.0
2699524.0	2699505.0	2699482.0	2699460.0	2699439.0
2699416.0	2699395.0	2699374.0	2699352.0	2699332.0
2699312.0	2699290.0	2699270.0	2699252.0	2699231.0
2699210.0	2699188.0	2699165.0	2699143.0	2699126.0
2699185.0	2699271.0	2699185.0	2699200.0	2699229.0
2699226.0	2699227.0	2699140.0	2699002.0	2698937.0
2698918.0	2698946.0	2698982.0	2698965.0	2698942.0
2698942.0	2698952.0	2698963.0	2698966.0	2698954.0
2698945.0	2698942.0	2698934.0	2698923.0	2698906.0
2698890.0	2698874.0	2698853.0	2698833.0	2698872.0
2698974.0	2698958.0	2698859.0	2698934.0	2698969.0
2699033.0	2699005.0	2698811.0	2698726.0	2698635.0
2698647.0	2698701.0	2698743.0	2698780.0	2698866.0
2699516.0	2699678.0	2698231.0	2698215.0	2698232.0
2698225.0	2698312.0	2698379.0	2698233.0	2698092.0
2698213.0	2698260.0	2698326.0	2698349.0	2698175.0
2698009.0	2697976.0	2697939.0	2697939.0	2698022.0
2698155.0	2698202.0	2698171.0	2698478.0	2699179.0
2699547.0	2699853.0	2699732.0	2697478.0	2694474.0
2696282.0	2697695.0	2697691.0	2698214.0	2698862.0
2699214.0	2699614.0	2700106.0	2700458.0	2700814.0
2701152.0	2701508.0	2701844.0	2702170.0	2702454.0
2702737.0	2702991.0	2703236.0	2703463.0	2703668.0
2703858.0	2704038.0	2704202.0	2704346.0	2704450.0
2704580.0	2704765.0	2704908.0	2704947.0	2705035.0
2705117.0	2705154.0	2705188.0	2705230.0	2705250.0
2705272.0	2705288.0	2705304.0	2705308.0	2705313.0
2705314.0	2705308.0	2705304.0	2705294.0	2705278.0
2705262.0	2705247.0	2705220.0	2705194.0	2705162.0
2705125.0	2705089.0	2705046.0	2705010.0	2704958.0
2704906.0	2704851.0	2704788.0	2704718.0	2704630.0
2704514.0	2704380.0	2704270.0	2704208.0	2704148.0
2704114.0	2704090.0	2704002.0	2703974.0	2703981.0
2703901.0	2703820.0	2703756.0	2703625.0	2703569.0
2703490.0	2703343.0	2703184.0	2703265.0	2703335.0
2703555.0	2703283.0	2703093.0	2703157.0	2703184.0
2703132.0	2703043.0	2702875.0	2702578.0	2702263.0
2702074.0	2702050.0	2702065.0	2701882.0	2701630.0
2701619.0	2701667.0	2701509.0	2701382.0	2701384.0
2701310.0	2701252.0	2701290.0	2701209.0	2701163.0
2701220.0	2701184.0	2701155.0	2701222.0	2701180.0
2701248.0	2701169.0	2701305.0	2701342.0	2701364.0
2701432.0	2701503.0	2701555.0	2701619.0	2701695.0
2701766.0	2701839.0	2701918.0	2701992.0	2702072.0
2702154.0	2702232.0	2702312.0	2702394.0	2702470.0



2702530.0	2702620.0	2702689.0	2702868.0	2702928.0
2702970.0	2703045.0	2703111.0	2703152.0	2703190.0
2703237.0	2703316.0	2703332.0	2703401.0	2703386.0
2703397.0	2703397.0	2703432.0	2703505.0	2703476.0
2703482.0	2703510.0	2703508.0	2703474.0	2703345.0
2703283.0	2703283.0	2703320.0	2703319.0	2703357.0
2703354.0	2703353.0	2703336.0	2703354.0	2703362.0
2703383.0	2703374.0	2703383.0	2703374.0	2703388.0
2703382.0	2703394.0	2703382.0	2703372.0	2703361.0
2703355.0	2703372.0	2703371.0	2703396.0	2703358.0
2703382.0	2703393.0	2703362.0	2703339.0	2703357.0
2703339.0	2703316.0	2703326.0	2703308.0	2703288.0
2703300.0	2703280.0	2703258.0	2703273.0	2703253.0
2703231.0	2703246.0	2703227.0	2703205.0	2703222.0
2703204.0	2703176.0	2703189.0	2703172.0	2703162.0
2703180.0	2703194.0	2703192.0	2703189.0	2703209.0
2703220.0	2703229.0	2703243.0	2703250.0	2703265.0
2703284.0	2703292.0	2703308.0	2703329.0	2703340.0
2703358.0	2703382.0	2703386.0	2703404.0	2703429.0
2703436.0	2703502.0	2703493.0	2703528.0	2703535.0
2703566.0	2703632.0	2703611.0	2703644.0	2703673.0
2703678.0	2703713.0	2703767.0	2703787.0	2703812.0
2703830.0	2703869.0	2703913.0	2703926.0	2703962.0
2703997.0	2704017.0	2704050.0	2704086.0	2704112.0
2704168.0	2704210.0	2704226.0	2704271.0	2704266.0
2704336.0	2704312.0	2704394.0	2704420.0	2704428.0
2704483.0	2704479.0	2704522.0	2704572.0	2704572.0
2704605.0	2704650.0	2704666.0	2704741.0	2704779.0
2704791.0	2704786.0	2704820.0	2704858.0	2704878.0
2704882.0	2704914.0	2704950.0	2705012.0	2705055.0
2705049.0	2705001.0	2705093.0	2705071.0	2705224.0
2705300.0	2705269.0	2705219.0	2705242.0	2705299.0
2705340.0	2705355.0	2705361.0	2705390.0	2705430.0
2705471.0	2705503.0	2705530.0	2705563.0	2705603.0
2705643.0	2705684.0	2705724.0	2705764.0	2705806.0
2705844.0	2705883.0	2705924.0	2705968.0	2706011.0
2706056.0	2706106.0	2706144.0	2706192.0	2706239.0
2706284.0	2706332.0	2706380.0	2706426.0	2706476.0
2706526.0	2706574.0	2706626.0	2706677.0	2706728.0
2706780.0	2706834.0	2706886.0	2706940.0	2706995.0
2707050.0	2707068.0	2707558.0	2708070.0	2708805.0
2709576.0	2710400.0	2711289.0	2712244.0	2713287.0
2714376.0	2715441.0	2716575.0	2717479.0	2715764.0
2709244.0	2717533.0	2709940.0	2706765.0	2707916.0
2707356.0	2705743.0	2704562.0	2709009.0	2716900.0
2706804.0	2712316.0	2709003.0	2704124.0	2721174.0
2706813.0	2704932.0	2723279.0	2707968.0	2703828.0
2705493.0	2725673.0	2707572.0	2705907.0	2703822.0
2717379.0	2710476.0	2724490.0	2725371.0	2724520.0
2721841.0	2726314.0	2728248.0	2728045.0	2730173.0
2731730.0	2732871.0	2733789.0	2730711.0	2728088.0
2735208.0	2735571.0	2735926.0	2736210.0	2736449.0
2736650.0	2736825.0	2736980.0	2737118.0	2737239.0
2737352.0	2737452.0	2737543.0	2737625.0	2737700.0
2737763.0	2737820.0	2740064.0	2739390.0	2736644.0
2735412.0	2742554.0	2745561.0	2737230.0	2734979.0
2737278.0	2735304.0	2735570.0	2736638.0	2737875.0
2747108.0	2739805.0	2743914.0	2736192.0	2739179.0
2781715.0	2738770.0	2755562.0	2736250.0	2720564.0
2738154.0	2718860.0	2735820.0	2759214.0	2733628.0
2728885.0	2729542.0	2749347.0	2724204.0	2726526.0
2767421.0	2781681.0	2727220.0	2722144.0	2720087.0
2739568.0	2723116.0	2732810.0	2714422.0	2713701.0
2717686.0	2720572.0	2722932.0	2734807.0	2726082.0
2814093.0	2782506.0	2730763.0	2729831.0	2726293.0
2720432.0	2736754.0	2743232.0	2723444.0	2715190.0
2725543.0	2729064.0	2737420.0	2725943.0	2736436.0
2722402.0	2726602.0	2750201.0	2714150.0	2743469.0

2744726.0	2731505.0	2819061.0	2737245.0	2753844.0
2727543.0	2721452.0	2771315.0	2751222.0	2725396.0
2736274.0	2725186.0	2735294.0	2731813.0	2737567.0
2728285.0	2745799.0	2722172.0	2731546.0	2725140.0
2723374.0	2737963.0	2727181.0		

eor

```

&&
&& Blowdown of saturated primary system water
&&

```

h2ov = 914

iflag = 2

t =	0.0	0.5	1.5	2.5	3.5
	4.5	5.5	6.5	7.5	8.5
	9.5	10.5	11.5	12.5	13.5
	14.5	15.5	16.5	17.5	18.5
	19.5	20.5	21.5	22.5	23.5
	24.5	25.5	26.5	27.5	28.5
	29.5	30.5	31.5	32.5	33.5
	34.5	35.5	36.5	37.5	38.5
	39.5	40.5	41.5	42.5	43.5
	44.5	45.5	46.5	47.5	48.5
	49.5	50.5	51.5	52.5	53.5
	54.5	55.5	56.5	57.5	58.5
	59.5	60.5	61.5	62.5	63.5
	64.5	65.5	66.5	67.5	68.5
	69.5	70.5	71.5	72.5	73.5
	74.5	75.5	76.5	77.5	78.5
	79.5	80.5	81.5	82.5	83.5
	84.5	85.5	86.5	87.5	88.5
	89.5	90.5	91.5	92.5	93.5
	94.5	95.5	96.5	97.5	98.5
	99.5	100.0	110.0	120.0	130.0
	140.0	150.0	160.0	170.0	180.0
	190.0	200.0	204.8	214.8	224.8
	234.8	244.8	254.8	264.8	274.8
	284.8	294.8	304.8	314.8	324.8
	334.8	344.8	354.8	364.8	374.8
	384.8	394.8	404.8	414.8	424.8
	434.8	444.8	454.8	464.8	474.8
	484.8	494.8	504.8	514.8	524.8
	534.8	544.8	554.8	564.8	574.8
	584.8	594.8	604.8	614.8	624.8
	634.8	644.8	654.8	664.8	674.8
	684.8	694.8	704.8	714.8	724.8
	734.8	744.8	754.8	764.8	774.8
	784.8	794.8	804.8	814.8	824.8
	834.8	844.8	854.8	864.8	874.8
	884.8	894.8	904.8	914.8	924.8
	934.8	944.8	954.8	964.8	974.8
	984.8	994.8	1004.8	1014.8	1024.8
	1034.8	1044.8	1054.8	1064.8	1074.8
	1084.8	1094.8	1104.8	1114.8	1123.1
	1133.1	1143.1	1153.1	1163.1	1173.1
	1183.1	1193.1	1203.1	1213.1	1223.1
	1233.1	1243.1	1251.9	1261.9	1271.9
	1281.9	1291.9	1301.9	1311.9	1321.9
	1331.9	1341.9	1351.9	1361.9	1371.9
	1381.9	1391.9	1401.7	1402.7	1403.7
	1404.7	1405.7	1406.7	1407.7	1408.7
	1409.7	1410.7	1411.7	1412.7	1413.7
	1414.7	1415.7	1416.7	1417.7	1418.7
	1419.7	1420.7	1421.7	1422.7	1423.7
	1424.7	1425.7	1426.7	1427.7	1428.7
	1429.7	1430.7	1431.7	1432.7	1433.7
	1434.7	1435.7	1436.7	1437.7	1438.7
	1439.7	1440.7	1441.7	1442.7	1443.7
	1444.7	1445.7	1446.7	1447.7	1448.7
	1449.7	1450.7	1451.7	1452.7	1453.7

1454.7	1455.7	1456.7	1457.7	1458.7
1459.7	1460.7	1461.7	1462.7	1463.7
1464.7	1465.7	1466.7	1467.7	1468.7
1469.7	1470.7	1471.7	1472.7	1473.7
1474.7	1475.7	1476.7	1477.7	1478.7
1479.7	1480.7	1481.7	1482.7	1483.7
1484.7	1485.7	1486.7	1487.7	1488.7
1489.7	1490.7	1491.7	1492.7	1493.7
1494.7	1495.7	1496.7	1497.7	1498.7
1499.7	1500.7	1501.7	1502.7	1503.7
1504.7	1505.7	1506.7	1507.7	1508.7
1509.7	1510.7	1511.7	1512.7	1513.7
1514.7	1515.7	1516.7	1517.7	1518.7
1519.7	1520.7	1521.7	1522.7	1523.7
1524.7	1525.7	1526.7	1527.7	1528.7
1529.7	1530.7	1531.7	1532.7	1533.7
1534.7	1535.7	1536.7	1537.7	1538.7
1539.7	1540.7	1541.7	1542.7	1543.7
1544.7	1545.7	1546.7	1547.7	1548.7
1549.7	1550.7	1551.7	1552.7	1553.7
1554.7	1555.7	1556.7	1557.7	1558.7
1559.7	1560.7	1561.7	1562.7	1563.7
1564.7	1565.7	1566.7	1567.7	1568.7
1569.7	1570.7	1571.7	1572.7	1573.7
1574.7	1575.7	1576.7	1577.7	1578.7
1579.7	1580.7	1581.7	1582.7	1583.7
1584.7	1585.7	1586.7	1587.7	1588.7
1589.7	1590.7	1591.7	1592.7	1593.7
1594.7	1595.7	1596.7	1597.7	1598.7
1599.7	1600.7	1601.7	1602.7	1603.7
1604.7	1605.7	1606.7	1607.7	1608.7
1609.7	1610.7	1611.7	1612.7	1613.7
1614.7	1615.7	1616.7	1617.7	1618.7
1619.7	1620.7	1621.7	1622.7	1623.7
1624.7	1625.7	1626.7	1627.7	1628.7
1629.7	1630.7	1631.7	1632.7	1633.7
1634.7	1635.7	1636.7	1637.7	1638.7
1639.7	1640.7	1641.7	1642.7	1643.7
1644.7	1645.7	1646.7	1647.7	1648.7
1649.7	1650.7	1651.7	1652.7	1653.7
1654.7	1655.7	1656.7	1657.7	1658.7
1659.7	1660.7	1661.7	1662.7	1663.7
1664.7	1665.7	1666.7	1667.7	1668.7
1669.7	1670.7	1671.7	1672.7	1673.7
1674.7	1675.7	1676.7	1677.7	1678.7
1679.7	1680.7	1681.7	1682.7	1683.7
1684.7	1685.7	1686.7	1687.7	1688.7
1689.7	1690.7	1691.7	1692.7	1693.7
1694.7	1695.7	1696.7	1697.7	1698.7
1699.7	1700.7	1701.7	1702.7	1703.7
1704.7	1705.7	1706.7	1707.7	1708.7
1709.7	1710.7	1711.7	1712.7	1713.7
1714.7	1715.7	1716.7	1717.7	1718.7
1719.7	1720.7	1721.7	1722.7	1723.7
1724.7	1725.7	1726.7	1727.7	1728.7
1729.7	1730.7	1731.7	1732.7	1733.7
1734.7	1735.7	1736.7	1737.7	1738.7
1739.7	1740.7	1741.7	1742.7	1743.7
1744.7	1745.7	1746.7	1747.7	1748.7
1749.7	1750.7	1751.7	1752.7	1753.7
1754.7	1755.7	1756.7	1757.7	1758.7
1759.7	1760.7	1761.7	1762.7	1763.7
1764.7	1765.7	1766.7	1767.7	1768.7
1769.7	1770.7	1771.7	1772.7	1773.7
1774.7	1775.7	1776.7	1777.7	1778.7
1779.7	1780.7	1781.7	1782.7	1783.7
1784.7	1785.7	1786.7	1787.7	1788.7
1789.7	1790.7	1791.7	1792.7	1793.7

1794.7	1795.7	1796.7	1797.7	1798.7
1799.7	1800.7	1801.7	1802.7	1803.7
1804.7	1805.7	1806.7	1807.7	1808.7
1809.7	1810.7	1811.7	1812.7	1813.7
1814.7	1815.7	1816.7	1817.7	1818.7
1819.7	1820.7	1821.7	1822.7	1823.7
1824.7	1825.7	1826.7	1827.7	1828.7
1829.7	1830.7	1831.7	1832.7	1833.7
1834.7	1835.7	1836.7	1837.7	1838.7
1839.7	1840.7	1841.7	1842.7	1843.7
1844.7	1845.7	1846.7	1847.7	1848.7
1849.7	1850.7	1851.7	1852.7	1853.7
1854.7	1855.7	1856.7	1857.7	1858.7
1859.7	1860.7	1861.7	1862.7	1863.7
1864.7	1865.7	1866.7	1867.7	1868.7
1869.7	1870.7	1871.7	1872.7	1873.7
1874.7	1875.7	1876.7	1877.7	1878.7
1879.7	1880.7	1881.7	1882.7	1883.7
1884.7	1885.7	1886.7	1887.7	1888.7
1889.7	1890.7	1891.7	1892.7	1893.7
1894.7	1895.7	1896.7	1897.7	1898.7
1899.7	1900.7	1901.7	1902.7	1903.7
1904.7	1905.7	1906.7	1907.7	1908.7
1909.7	1910.7	1911.7	1912.7	1913.7
1914.7	1915.7	1916.7	1917.7	1918.7
1919.7	1920.7	1921.7	1922.7	1923.7
1924.7	1925.7	1926.7	1927.7	1928.7
1929.7	1930.7	1931.7	1932.7	1933.7
1934.7	1935.7	1936.7	1937.7	1938.7
1939.7	1940.7	1941.7	1942.7	1943.7
1944.7	1945.7	1946.7	1947.7	1948.7
1949.7	1950.7	1951.7	1952.7	1953.7
1954.7	1955.7	1956.7	1957.7	1958.7
1959.7	1960.7	1961.7	1962.7	1963.7
1964.7	1965.7	1966.7	1967.7	1968.7
1969.7	1970.7	1971.7	1972.7	1973.7
1974.7	1975.7	1976.7	1977.7	1978.7
1979.7	1980.7	1981.7	1982.7	1983.7
1984.7	1985.7	1986.7	1987.7	1988.7
1989.7	1990.7	1991.7	1992.7	1993.7
1994.7	1995.7	1996.7	1997.7	1998.7
1999.7	2000	2010.0	2020.0	2030.0
2040.0	2050	2060.0	2070.0	2080.0
2090.0	2100	2110.0	2120.0	2130.0
2140.0	2150	2160.0	2170.0	2180.0
2190.0	2200.0	2210.0	2220.0	2230.0
2240.0	2250.0	2260.0	2270.0	2280.0
2290.0	2300.0	2310.0	2320.0	2330.0
2340.0	2350.0	2360.0	2370.0	2380.0
2390.0	2400.0	2410.0	2420.0	2430.0
2440.0	2450.0	2460.0	2470.0	2480.0
2490.0	2500.0	2510.0	2520.0	2521.7
2531.7	2541.7	2551.7	2561.7	2571.7
2581.7	2591.7	2601.7	2611.7	2621.7
2631.7	2641.7	2651.7	2661.7	2671.7
2681.7	2691.7	2701.7	2711.7	2721.7
2731.7	2741.7	2751.7	2761.7	2771.7
2781.7	2791.7	2801.7	2803.2	2813.1
2823.1	2833.1	2843.1	2853.1	2863.1
2873.1	2883.1	2893.1	2903.1	2913.1
2923.1	2933.1	2943.1	2953.1	2963.1
2973.1	2983.1	2993.1	3003.1	3013.1
3023.1	3033.1	3043.1	3053.1	3063.1
3073.1	3083.1	3093.1	3103.1	3113.1
3123.1	3133.1	3143.1	3153.1	3163.1
3173.1	3183.1	3193.1	3203.1	3213.1
3223.1	3233.1	3243.1	3253.1	3263.1
3273.1	3283.1	3293.1	3303.1	3313.1







	33.3	67.3	40.5	25.3	25.8
	10.2	21.4	38.6		
enth =	158119.7	158227.3	158224.4	158225.9	158227.3
	158231.8	158290.1	200020.9	801773.9	739475.9
	717309.5	710926.9	709328.2	708997.1	708972.0
	709051.6	709962.1	712237.8	714723.1	716948.4
	719030.4	720731.1	722092.6	723370.2	724584.8
	725732.9	726830.3	727881.6	728883.3	729840.0
	730753.5	731626.6	732454.2	733232.6	733982.1
	734699.7	735379.2	735984.2	736521.3	737021.4
	737490.4	737931.1	738343.2	738727.2	739081.0
	739406.4	739704.6	739975.8	740219.4	740435.4
	740624.1	740785.1	740918.6	741025.1	741105.0
	741159.0	741187.4	741190.4	741168.6	741122.0
	741053.6	740961.8	740846.1	740707.2	740546.2
	740363.8	740159.9	739935.2	739690.4	739426.2
	739143.2	738841.9	738522.9	738185.7	737829.4
	737450.4	737036.1	736603.1	736156.5	735711.2
	735250.3	734792.2	734320.8	733828.8	733315.4
	732781.4	732212.5	731618.5	731010.4	730393.1
	729769.6	729142.3	728513.2	727884.8	727258.9
	726560.8	725671.6	724754.8	723847.2	722956.5
	722085.6	721659.0	715014.9	713975.0	713141.6
	712611.8	711530.6	709910.0	708015.9	705624.1
	702664.4	699061.7	697194.5	693005.6	688192.2
	682777.9	676902.8	670659.7	664372.2	662257.0
	690095.4	688054.8	686163.1	684603.9	683478.6
	687749.9	682227.4	681986.2	681537.4	680834.9
	677716.2	678834.3	677556.9	675880.1	673988.2
	671933.6	669684.8	667475.7	664668.4	661817.4
	657370.0	654055.8	650935.4	647915.2	644864.2
	643106.8	639898.3	638623.4	635707.2	633431.1
	629020.4	625527.4	622024.9	618310.1	615047.8
	611596.8	608399.0	605316.4	602375.1	599389.2
	606320.0	593215.0	616752.3	614416.6	612202.2
	609997.1	607606.5	605179.7	602860.1	602460.2
	597345.3	595503.9	593668.8	591843.9	590032.1
	588239.5	586453.2	584804.4	583027.2	581271.2
	579531.1	577794.5	576019.1	573958.9	571776.8
	569629.8	567515.6	565414.3	563159.6	561125.8
	559112.1	557095.1	555105.3	553146.6	551217.9
	549311.2	547424.7	545565.2	543758.9	541994.4
	540258.2	538603.6	537009.8	535496.8	534296.5
	532671.4	530901.1	529160.1	527457.2	525799.1
	524603.6	523587.1	520874.9	519416.4	518017.0
	518685.0	516124.5	513376.3	512901.8	512945.8
	511716.2	510283.4	509077.4	507801.2	510549.6
	512647.0	507684.8	492406.9	503425.8	505358.6
	503450.1	492980.8	502774.3	504377.4	502896.8
	503098.3	503112.8	503109.9	503008.1	502907.0
	502842.4	502780.0	502705.6	502618.7	502531.2
	502451.3	502371.4	502287.2	502201.0	502115.3
	502030.5	501945.4	501856.8	501775.7	501685.3
	501599.9	501516.4	501426.1	501338.3	501251.2
	501163.6	501075.0	500986.8	500899.3	500811.4
	500722.4	500633.9	500545.9	500455.6	500362.3
	500272.1	500185.2	500099.2	499992.4	499910.4
	499820.7	499730.2	499640.6	499550.4	499460.1
	499370.6	499298.7	499241.4	499151.8	499073.4
	498993.8	498909.8	498803.6	498682.7	498594.9
	498503.6	498412.0	498314.3	498216.3	498124.2
	498031.7	497937.2	497839.9	497741.2	497644.0
	497545.8	497445.5	497344.8	497242.9	497139.8
	497036.5	496931.6	496824.6	496719.2	496613.4
	496506.6	496400.4	496293.4	496185.1	496077.3
	495968.8	495859.2	495750.0	495640.2	495529.2
	495418.6	495307.2	495194.8	495082.8	494970.3



494856.8	494744.2	494631.1	494516.7	494402.8
494288.7	494173.3	494058.7	493943.2	493826.2
493710.1	493593.7	493475.8	493358.4	493240.3
493121.0	493002.4	492883.5	492763.7	492644.8
492523.6	492403.7	492285.3	492167.2	492043.1
491923.4	491802.4	491680.3	491557.5	491436.0
491318.1	491200.4	491080.7	490958.8	490831.9
490693.2	490561.7	490446.4	490329.2	490210.9
490095.2	489976.7	489856.3	489736.2	489615.6
489493.7	489403.6	489118.8	488625.4	488695.8
488865.6	488621.4	488523.4	488448.1	488325.8
488161.0	488033.8	487904.6	487785.2	487628.8
487503.8	487413.2	487305.3	487233.6	487132.5
487026.6	486932.0	486839.6	486743.4	486647.6
486550.8	486454.2	486365.1	486265.2	486179.0
486077.0	486009.0	485938.0	485856.3	485807.5
485738.7	485684.3	485617.9	485555.1	485492.9
485428.5	485366.0	485305.1	485242.7	485182.1
485123.0	485061.6	485003.9	484947.5	484888.0
484826.4	484761.9	484694.4	484632.8	484580.8
484740.7	484684.9	484758.4	484785.8	484674.5
484662.9	484666.4	484628.3	484227.8	484035.3
483976.7	484049.7	484154.8	484109.4	484041.3
483738.5	484063.7	484094.8	484105.8	484072.1
484142.4	484035.3	484011.9	483977.5	483931.2
483881.2	483833.6	483775.8	483715.9	483808.5
484104.0	484102.3	483784.3	483999.7	484087.2
484283.9	484217.7	483661.2	483412.4	483142.9
483167.7	483321.6	483441.3	483550.2	483761.1
485663.1	486109.5	482082.7	481911.0	481994.3
481958.0	482195.5	482398.5	482023.8	481575.0
481915.9	482057.5	482242.2	482317.6	481837.1
481344.8	481243.8	481138.5	481129.9	481354.5
481736.1	481891.2	481780.8	482605.9	484616.5
485701.1	486569.8	486403.9	479936.3	471353.8
476089.3	480330.4	480356.5	481788.5	483664.2
484686.2	485813.9	487225.6	488244.0	403258.5
490229.2	491248.3	492209.3	493156.8	493976.9
494784.8	495519.2	496221.2	496876.2	497467.4
498014.8	498535.7	499009.5	499430.2	499722.4
500109.3	500612.6	501056.4	501165.0	501408.8
501654.8	501759.9	501864.0	501980.3	502044.3
502104.0	502151.2	502192.2	502208.6	502220.8
502222.0	502211.1	502191.5	502171.2	502123.3
502071.8	502022.2	501951.2	501872.1	501781.8
501682.3	501573.1	501449.1	501341.9	501191.6
501039.6	500879.3	500701.2	500497.9	500250.5
499914.3	499532.5	499202.6	499026.2	498848.2
498746.8	498589.8	498435.0	498342.0	498282.0
498140.3	497891.6	497652.3	497332.9	497096.8
496870.6	496551.5	496060.6	496262.5	496523.2
497200.3	496384.6	495783.5	495979.4	495983.6
495919.8	495702.1	495201.9	494372.8	493506.3
492932.0	492866.3	492920.5	492296.8	491639.2
491628.3	491630.1	491294.1	490949.2	490843.3
490721.5	490580.2	490554.4	490431.1	490311.6
490366.2	490356.9	490299.6	490411.7	490387.4
490473.5	490619.0	490728.8	490830.2	490899.1
491086.6	491285.1	491444.7	491620.2	491833.6
491043.6	492247.8	492469.4	492691.2	492912.8
493146.3	493376.8	493598.4	493829.0	494053.5
494226.2	494479.4	494669.3	495184.7	495363.0
495480.6	495686.9	495878.5	496005.3	496112.4
496104.5	496355.1	496417.6	496616.8	496643.9
496693.2	496725.4	496819.3	496916.2	496883.5
496908.6	496974.2	496981.4	496883.0	496530.7
496331.5	496333.7	496432.3	496436.7	496538.5
496539.7	496526.8	496486.8	496526.0	496559.4

496612.4	496557.6	496612.3	496595.8	496625.6
496616.3	496641.1	496619.7	496589.2	496604.2
496550.6	496595.7	496591.0	496636.2	496553.0
496619.4	496626.2	496562.3	496500.8	496519.6
496494.7	496435.9	496430.2	496405.0	496357.4
496354.4	496322.7	496272.6	496276.1	496244.7
496194.8	496195.5	496168.1	496120.5	496125.4
496099.0	496039.4	496032.3	496009.4	495992.2
496030.2	496057.8	496061.2	496050.8	496097.9
496138.9	496164.5	496191.4	496224.6	496264.4
496307.2	496343.2	496387.2	496434.6	496477.7
496528.3	496584.4	496589.5	496647.7	496716.5
496921.0	496914.6	496911.1	496987.5	497050.8
497133.3	497316.2	497234.7	497385.7	497452.6
497470.9	497552.2	497727.9	497782.3	497839.7
497904.3	498015.5	498126.8	498176.3	498284.5
498360.7	498437.2	498514.6	498621.3	498684.6
498813.7	49897.1	499024.2	499094.3	499118.1
499294.7	49925.1	499439.5	499555.1	499576.8
499698.7	499725.1	499843.1	499991.8	499995.7
500087.3	500217.1	500253.8	500465.8	500588.2
500616.2	500605.5	500697.4	500806.1	500867.4
500875.8	500967.2	501065.7	501143.8	501374.4
501358.4	501216.0	501476.2	501414.1	501833.2
502089.8	501984.8	501847.2	501905.6	502063.9
502186.2	502233.2	502247.1	502329.1	502443.2
502560.7	502653.4	502731.0	502824.6	502936.9
503055.0	503171.3	503286.6	503401.1	503520.1
503630.4	503745.3	503761.3	503986.3	504112.2
504239.9	504368.7	504497.4	504631.8	504769.8
504907.4	505047.6	505189.8	505332.3	505478.6
505627.9	505776.6	505928.7	506081.8	506236.2
506391.8	506551.6	506709.8	506871.8	507035.3
507200.9	507255.7	508830.2	510269.1	512467.3
514797.2	517280.5	519964.8	522849.5	525973.6
529298.2	532546.1	536079.9	536775.9	529923.5
517303.6	516278.6	517827.9	508366.2	506544.3
507008.1	503415.7	502145.2	514348.3	507249.9
509043.2	504951.2	514045.5	498842.8	510093.9
508808.2	500493.4	507479.2	511664.1	499990.9
500488.6	507298.9	511570.2	506069.8	498170.8
503978.9	517406.3	525997.4	554966.4	562750.3
553096.6	569402.8	575856.3	575055.0	580318.0
585552.4	589292.8	592230.4	582566.3	572876.5
596416.9	598138.9	599301.4	600233.2	601018.4
601679.1	602255.6	602763.5	603216.8	603617.4
603986.7	604320.1	604619.5	604897.0	605155.8
605375.0	605572.7	611807.5	6108E3.6	604977.0
598220.9	605815.1	620290.3	610643.5	597061.5
60406.9	596579.9	600616.5	606329.9	601491.9
620321.1	617820.9	554136.8	591190.7	611101.1
630472.3	599093.1	624696.5	602110.7	569970.2
609474.1	593093.4	576145.4	620694.4	591197.6
57661.2	573551.6	593672.5	565813.9	562640.9
601482.4	585034.5	572019.6	552365.1	565140.4
585228.1	557737.9	559249.9	527572.1	531403.7
564263.6	549020.9	549939.1	558638.2	580349.6
581261.8	605545.5	599054.2	603206.9	570482.6
560178.6	600449.8	572579.2	564005.6	536288.3
559654.4	550652.9	606809.3	567090.9	584522.1
558326.2	571625.7	574650.6	541837.4	567282.1
564436.1	584453.8	545579.2	553446.7	577896.8
579475.7	551011.0	593928.9	591056.8	566946.3
575514.3	563808.6	587210.4	566057.7	581234.0
574262.8	567689.1	577991.0	575092.9	564074.6
562345.1	569967.5	570910.3		

88 Blowdown of primary system steam

88

h2ov = 914

iflag = 2

t =

0.0	0.5	1.5	2.5	3.5
4.5	5.5	6.5	7.5	8.5
9.5	10.5	11.5	12.5	13.5
14.5	15.5	16.5	17.5	18.5
19.5	20.5	21.5	22.5	23.5
24.5	25.5	26.5	27.5	28.5
29.5	30.5	31.5	32.5	33.5
34.5	35.5	36.5	37.5	38.5
39.5	40.5	41.5	42.5	43.5
44.5	45.5	46.5	47.5	48.5
49.5	50.5	51.5	52.5	53.5
54.5	55.5	56.5	57.5	58.5
59.5	60.5	61.5	62.5	63.5
64.5	65.5	66.5	67.5	68.5
69.5	70.5	71.5	72.5	73.5
74.5	75.5	76.5	77.5	78.5
79.5	80.5	81.5	82.5	83.5
84.5	85.5	86.5	87.5	88.5
89.5	90.5	91.5	92.5	93.5
94.5	95.5	96.5	97.5	98.5
99.5	100.0	110.0	120.0	130.0
140.0	150.0	160.0	170.0	180.0
190.0	200.0	204.8	214.8	224.8
234.8	244.8	254.8	261.8	274.8
284.8	294.8	304.8	314.8	324.8
334.8	344.8	354.8	364.8	374.8
384.8	394.8	404.8	414.8	424.8
434.8	444.8	454.8	464.8	474.8
484.8	494.8	504.8	514.8	524.8
534.8	544.8	554.8	564.8	574.8
584.8	594.8	604.8	614.8	624.8
634.8	644.8	654.8	664.8	674.8
684.8	694.8	704.8	714.8	724.8
734.8	744.8	754.8	764.8	774.8
784.8	794.8	804.8	814.8	824.8
834.8	844.8	854.8	864.8	874.8
884.8	894.8	904.8	914.8	924.8
934.8	944.8	954.8	964.8	974.8
984.8	994.8	1004.8	1014.8	1024.8
1034.8	1044.8	1054.8	1064.8	1074.8
1084.8	1094.8	1104.8	1114.8	1123.1
1133.1	1143.1	1153.1	1163.1	1173.1
1183.1	1193.1	1203.1	1213.1	1223.1
1233.1	1243.1	1251.9	1261.9	1271.9
1281.9	1291.9	1301.9	1311.9	1321.9
1331.9	1341.9	1351.9	1361.9	1371.9
1381.9	1391.9	1401.7	1402.7	1403.7
1404.7	1405.7	1406.7	1407.7	1408.7
1409.7	1410.7	1411.7	1412.7	1413.7
1414.7	1415.7	1416.7	1417.7	1418
1419.7	1420.7	1421.7	1422.7	1423.7
1424.7	1425.7	1426.7	1427.7	1428.7
1429.7	1430.7	1431.7	1432.7	1433.7
1434.7	1435.7	1436.7	1437.7	1438.7
1439.7	1440.7	1441.7	1442.7	1443.7
1444.7	1445.7	1446.7	1447.7	1448.7
1449.7	1450.7	1451.7	1452.7	1453.7
1454.7	1455.7	1456.7	1457.7	1458.7
1459.7	1460.7	1461.7	1462.7	1463.7
1464.7	1465.7	1466.7	1467.7	1468.7
1469.7	1470.7	1471.7	1472.7	1473.7
1474.7	1475.7	1476.7	1477.7	1478.7
1479.7	1480.7	1481.7	1482.7	1483.7
1484.7	1485.7	1486.7	1487.7	1488.7

1489.7	1490.7	1491.7	1492.7	1493.7
1494.7	1495.7	1496.7	1497.7	1498.7
1499.7	1500.7	1501.7	1502.7	1503.7
1504.7	1505.7	1506.7	1507.7	1508.7
1509.7	1510.7	1511.7	1512.7	1513.7
1514.7	1515.7	1516.7	1517.7	1518.7
1519.7	1520.7	1521.7	1522.7	1523.7
1524.7	1525.7	1526.7	1527.7	1528.7
1529.7	1530.7	1531.7	1532.7	1533.7
1534.7	1535.7	1536.7	1537.7	1538.7
1539.7	1540.7	1541.7	1542.7	1543.7
1544.7	1545.7	1546.7	1547.7	1548.7
1549.7	1550.7	1551.7	1552.7	1553.7
1554.7	1555.7	1556.7	1557.7	1558.7
1559.7	1560.7	1561.7	1562.7	1563.7
1564.7	1565.7	1566.7	1567.7	1568.7
1569.7	1570.7	1571.7	1572.7	1573.7
1574.7	1575.7	1576.7	1577.7	1578.7
1579.7	1580.7	1581.7	1582.7	1583.7
1584.7	1585.7	1586.7	1587.7	1588.7
1589.7	1590.7	1591.7	1592.7	1593.7
1594.7	1595.7	1596.7	1597.7	1598.7
1599.7	1600.7	1601.7	1602.7	1603.7
1604.7	1605.7	1606.7	1607.7	1608.7
1609.7	1610.7	1611.7	1612.7	1613.7
1614.7	1615.7	1616.7	1617.7	1618.7
1619.7	1620.7	1621.7	1622.7	1623.7
1624.7	1625.7	1626.7	1627.7	1628.7
1629.7	1630.7	1631.7	1632.7	1633.7
1634.7	1635.7	1636.7	1637.7	1638.7
1639.7	1640.7	1641.7	1642.7	1643.7
1644.7	1645.7	1646.7	1647.7	1648.7
1649.7	1650.7	1651.7	1652.7	1653.7
1654.7	1655.7	1656.7	1657.7	1658.7
1659.7	1660.7	1661.7	1662.7	1663.7
1664.7	1665.7	1666.7	1667.7	1668.7
1669.7	1670.7	1671.7	1672.7	1673.7
1674.7	1675.7	1676.7	1677.7	1678.7
1679.7	1680.7	1681.7	1682.7	1683.7
1684.7	1685.7	1686.7	1687.7	1688.7
1689.7	1690.7	1691.7	1692.7	1693.7
1694.7	1695.7	1696.7	1697.7	1698.7
1699.7	1700.7	1701.7	1702.7	1703.7
1704.7	1705.7	1706.7	1707.7	1708.7
1709.7	1710.7	1711.7	1712.7	1713.7
1714.7	1715.7	1716.7	1717.7	1718.7
1719.7	1720.7	1721.7	1722.7	1723.7
1724.7	1725.7	1726.7	1727.7	1728.7
1729.7	1730.7	1731.7	1732.7	1733.7
1734.7	1735.7	1736.7	1737.7	1738.7
1739.7	1740.7	1741.7	1742.7	1743.7
1744.7	1745.7	1746.7	1747.7	1748.7
1749.7	1750.7	1751.7	1752.7	1753.7
1754.7	1755.7	1756.7	1757.7	1758.7
1759.7	1760.7	1761.7	1762.7	1763.7
1764.7	1765.7	1766.7	1767.7	1768.7
1769.7	1770.7	1771.7	1772.7	1773.7
1774.7	1775.7	1776.7	1777.7	1778.7
1779.7	1780.7	1781.7	1782.7	1783.7
1784.7	1785.7	1786.7	1787.7	1788.7
1789.7	1790.7	1791.7	1792.7	1793.7
1794.7	1795.7	1796.7	1797.7	1798.7
1799.7	1800.7	1801.7	1802.7	1803.7
1804.7	1805.7	1806.7	1807.7	1808.7
1809.7	1810.7	1811.7	1812.7	1813.7
1814.7	1815.7	1816.7	1817.7	1818.7
1819.7	1820.7	1821.7	1822.7	1823.7
1824.7	1825.7	1826.7	1827.7	1828.7

1829.7	1833.7	1831.7	1832.7	1833.7
1834.7	1835.7	1836.7	1837.7	1838.7
1839.7	1840.7	1841.7	1842.7	1843.7
1844.7	1845.7	1846.7	1847.7	1848.7
1849.7	1850.7	1851.7	1852.7	1853.7
1854.7	1855.7	1856.7	1857.7	1858.7
1859.7	1860.7	1861.7	1862.7	1863.7
1864.7	1865.7	1866.7	1867.7	1868.7
1869.7	1870.7	1871.7	1872.7	1873.7
1874.7	1875.7	1876.7	1877.7	1878.7
1879.7	1880.7	1881.7	1882.7	1883.7
1884.7	1885.7	1886.7	1887.7	1888.7
1889.7	1890.7	1891.7	1892.7	1893.7
1894.7	1895.7	1896.7	1897.7	1898.7
1899.7	1900.7	1901.7	1902.7	1903.7
1904.7	1905.7	1906.7	1907.7	1908.7
1909.7	1910.7	1911.7	1912.7	1913.7
1914.7	1915.7	1916.7	1917.7	1918.7
1919.7	1920.7	1921.7	1922.7	1923.7
1924.7	1925.7	1926.7	1927.7	1928.7
1929.7	1930.7	1931.7	1932.7	1933.7
1934.7	1935.7	1936.7	1937.7	1938.7
1939.7	1940.7	1941.7	1942.7	1943.7
1944.7	1945.7	1946.7	1947.7	1948.7
1949.7	1950.7	1951.7	1952.7	1953.7
1954.7	1955.7	1956.7	1957.7	1958.7
1959.7	1960.7	1961.7	1962.7	1963.7
1964.7	1965.7	1966.7	1967.7	1968.7
1969.7	1970.7	1971.7	1972.7	1973.7
1974.7	1975.7	1976.7	1977.7	1978.7
1979.7	1980.7	1981.7	1982.7	1983.7
1984.7	1985.7	1986.7	1987.7	1988.7
1989.7	1990.7	1991.7	1992.7	1993.7
1994.7	1995.7	1996.7	1997.7	1998.7
1999.7	2000.0	2010.0	2020.0	2030.0
2040.0	2050.0	2060.0	2070.0	2080.0
2090.0	2100.0	2110.0	2120.0	2130.0
2140.0	2150.0	2160.0	2170.0	2180.0
2190.0	2200.0	2210.0	2220.0	2230.0
2240.0	2250.0	2260.0	2270.0	2280.0
2290.0	2300.0	2310.0	2320.0	2330.0
2340.0	2350.0	2360.0	2370.0	2380.0
2390.0	2400.0	2410.0	2420.0	2430.0
2440.0	2450.0	2460.0	2470.0	2480.0
2490.0	2500.0	2510.0	2520.0	2521.7
2531.7	2541.7	2551.7	2561.7	2571.7
2581.7	2591.7	2601.7	2611.7	2621.7
2631.7	2641.7	2651.7	2661.7	2671.7
2681.7	2691.7	2701.7	2711.7	2721.7
2731.7	2741.7	2751.7	2761.7	2771.7
2781.7	2791.7	2801.7	2803.2	2813.1
2823.1	2833.1	2843.1	2853.1	2863.1
2873.1	2883.1	2893.1	2903.1	2913.1
2923.1	2933.1	2943.1	2953.1	2963.1
2973.1	2983.1	2993.1	3003.1	3013.1
3023.1	3033.1	3043.1	3053.1	3063.1
3073.1	3083.1	3093.1	3103.1	3113.1
3123.1	3133.1	3143.1	3153.1	3163.1
3173.1	3183.1	3193.1	3203.1	3213.1
3223.1	3233.1	3243.1	3253.1	3263.1
3273.1	3283.1	3293.1	3303.1	3313.1
3323.1	3333.1	3343.1	3353.1	3363.1
3373.1	3383.1	3393.1	3403.1	3413.1
3423.1	3433.1	3443.1	3453.1	3463.1
3473.1	3483.1	3493.1	3503.1	3513.1
3523.1	3533.1	3543.1	3553.1	3563.1
3573.1	3583.1	3593.1		

mass	x	0.0	0.0	0.0	0.0	0.0
0.0	0.0	0.0	0.0	0.0	50.5	39.4
35.2	33.8	33.4	33.3	33.3	33.3	33.3
33.3	33.4	33.8	33.8	34.7	34.7	34.7
35.2	35.6	35.9	36.1	36.1	36.4	36.4
36.7	36.9	37.1	37.3	37.3	37.6	37.6
37.8	38.0	38.1	38.3	38.3	38.5	38.5
38.6	38.8	38.9	39.1	39.1	39.2	39.2
39.3	39.4	39.5	39.6	39.6	39.7	39.7
39.8	39.8	39.9	40.0	40.0	40.0	40.0
40.1	40.1	40.1	40.2	40.2	40.2	40.2
40.2	40.2	40.3	40.3	40.3	40.3	40.3
40.2	40.2	40.2	40.2	40.2	40.2	40.2
40.1	40.1	40.1	40.0	40.0	40.0	40.0
39.9	39.9	39.8	39.7	39.7	39.7	39.7
39.6	39.5	39.4	39.3	39.3	39.3	39.3
39.2	39.1	39.0	38.9	38.9	38.8	38.8
38.7	38.6	38.4	38.3	38.3	38.2	38.2
38.1	38.0	37.8	37.7	37.7	37.6	37.6
37.4	37.3	37.1	36.9	36.9	36.7	36.7
36.6	36.5	35.2	35.1	35.1	35.1	35.1
35.2	35.2	35.1	34.9	34.9	34.6	34.6
34.2	33.7	33.4	32.8	32.8	32.0	32.0
31.1	30.1	29.1	34.2	34.2	34.0	34.0
33.8	33.5	33.4	33.2	33.2	33.2	33.2
33.2	33.3	33.4	33.4	33.4	33.4	33.4
33.4	33.3	33.1	33.0	33.0	32.8	32.8
32.5	32.2	32.0	31.6	31.6	31.2	31.2
30.7	30.2	29.9	29.6	29.6	29.3	29.3
29.0	28.7	28.5	28.1	28.1	27.8	27.8
27.4	27.7	26.7	26.3	26.3	25.9	25.9
25.5	25.1	24.8	24.4	24.4	24.1	24.1
23.7	23.3	27.4	27.0	27.0	26.7	26.7
26.4	26.1	25.7	25.4	25.4	24.9	24.9
24.5	24.2	23.9	23.5	23.5	23.2	23.2
22.9	22.5	22.3	21.9	21.9	21.6	21.6
21.3	21.0	20.7	20.4	20.4	20.1	20.1
19.8	19.5	19.2	18.9	18.9	18.6	18.6
18.3	18.0	17.7	17.4	17.4	17.1	17.1
16.9	16.6	16.3	16.0	16.0	15.7	15.7
15.5	15.2	15.0	14.7	14.7	14.5	14.5
14.3	14.1	13.9	13.7	13.7	13.5	13.5
13.3	13.2	12.9	12.7	12.7	12.5	12.5
12.3	12.2	11.8	11.8	11.8	11.6	11.6
11.5	11.3	11.1	10.9	10.9	10.8	10.8
10.7	10.6	9.7	10.1	10.1	10.1	10.1
9.8	9.5	9.7	9.6	9.6	9.7	9.7
9.6	9.6	9.5	9.6	9.6	9.6	9.6
9.6	9.6	9.6	9.5	9.5	9.5	9.5
9.5	9.5	9.5	9.5	9.5	9.5	9.5
9.5	9.4	9.4	9.4	9.4	9.4	9.4
9.4	9.4	9.4	9.3	9.3	9.3	9.3
9.3	9.3	9.3	9.3	9.3	9.3	9.3
9.3	9.2	9.2	9.2	9.2	9.2	9.2
9.2	9.2	9.2	9.2	9.2	9.1	9.1
9.1	9.1	9.1	9.1	9.1	9.1	9.1
9.1	9.1	9.0	9.0	9.0	9.0	9.0
9.0	9.0	9.0	9.0	9.0	9.0	9.0
8.9	8.9	8.9	8.9	8.9	8.9	8.9
8.9	8.9	8.9	8.8	8.8	8.8	8.8
8.8	8.8	8.8	8.8	8.8	8.8	8.8
8.8	8.7	8.7	8.7	8.7	8.7	8.7
8.7	8.7	8.7	8.7	8.7	8.6	8.6
8.6	8.6	8.6	8.6	8.6	8.6	8.6
8.6	8.6	8.6	8.5	8.5	8.5	8.5
8.5	8.5	8.5	8.5	8.5	8.5	8.5
8.5	8.4	8.4	8.4	8.4	8.4	8.4
8.4	8.4	8.4	8.4	8.4	8.3	8.3



5.2	5.2	5.1	5.1	5.1
5.1	5.1	5.1	5.1	5.1
5.1	5.1	5.1	5.1	5.0
5.0	5.0	5.0	5.0	5.0
5.0	5.0	5.0	5.0	4.9
4.9	4.9	4.9	4.9	4.9
4.9	4.9	4.9	4.9	4.9
4.9	4.8	4.8	4.8	4.8
4.8	4.8	4.8	4.8	4.8
4.8	4.8	4.8	4.8	4.8
4.7	4.7	4.7	4.7	4.7
4.7	4.7	4.7	4.7	4.7
4.7	4.7	4.7	4.7	4.7
4.7	4.7	4.6	4.6	4.6
4.6	4.6	4.6	4.6	4.6
4.6	4.6	4.6	4.6	4.6
4.6	4.6	4.6	4.5	4.5
4.5	4.5	4.5	4.5	4.5
4.5	4.5	4.5	4.5	4.5
4.5	4.5	4.4	4.4	4.4
4.4	4.4	4.4	4.4	4.4
4.4	4.4	4.4	4.4	4.4
4.4	4.4	4.4	4.4	4.4
4.4	4.4	4.3	4.3	4.3
4.3	4.3	4.3	4.3	4.3
4.3	4.3	4.3	4.2	4.2
4.2	4.2	4.2	4.2	4.2
4.2	4.2	4.2	4.2	4.2
4.1	4.1	4.1	4.1	4.1
4.1	4.1	4.1	4.1	4.1
4.1	4.1	4.0	4.0	4.0
4.0	4.0	4.0	3.9	3.8
3.7	3.6	3.5	3.5	3.4
3.3	3.2	3.1	3.0	3.2
3.7	2.4	3.3	3.6	3.2
3.2	3.4	3.5	2.8	2.0
3.3	2.4	3.0	3.2	1.7
3.2	3.0	1.4	2.8	3.3
2.9	1.1	2.6	3.2	3.1
1.7	2.8	2.0	3.3	4.0
4.8	4.8	5.1	5.8	5.5
5.6	5.7	5.7	5.6	5.5
5.6	5.8	5.8	5.8	5.8
5.8	5.7	5.7	5.7	5.6
5.6	5.6	5.5	5.5	5.4
5.4	5.4	4.9	5.2	6.3
6.1	4.1	4.0	6.1	6.4
5.2	5.8	6.1	6.7	4.4
3.7	4.3	6.5	4.3	3.9
1.2	3.9	0.0	4.6	10.5
4.0	1.5	3.9	0.5	4.4
5.4	4.3	0.5	5.8	4.5
3.9	0.5	4.5	4.5	8.4
0.1	4.1	3.4	7.0	6.5
3.5	6.4	4.2	3.7	6.8
0.1	0.6	8.8	2.7	3.1
6.2	3.4	0.2	3.7	5.8
3.9	2.6	3.6	2.7	1.9
4.7	4.8	1.0	7.0	0.0
0.1	0.2	0.2	0.0	0.5
1.9	3.4	2.4	0.1	2.1
0.5	0.1	0.9	0.0	0.9
1.6	0.0	1.2	0.5	1.2
1.5	0.6	1.3		

enth = 2547525.0 2678332.0 2676740.0 2676744.0 2676692.0  
2677138.0 2672659.0 2699500.0 2781961.0 2770659.0  
2766118.0 2764730.0 2764384.0 2764313.0 2764398.0  
2764327.0 2764541.0 2765058.0 2765616.0 2766113.0



2766577.0	2766954.0	2767244.0	2767512.0	2767766.0
2768007.0	2768236.0	2768456.0	2768664.0	2768864.0
2769054.0	2769235.0	2769407.0	2769569.0	2769724.0
2769673.0	2770014.0	2770136.0	2770250.0	2770353.0
2770450.0	2770541.0	2770626.0	2770705.0	2770778.0
2770846.0	2770907.0	2770963.0	2771013.0	2771057.0
2771096.0	2771129.0	2771156.0	2771178.0	2771194.0
2771205.0	2771211.0	2771211.0	2771206.0	2771196.0
2771182.0	2771123.0	2771139.0	2771110.0	2771076.0
2771038.0	2770996.0	2770949.0	2770898.0	2770844.0
2770785.0	2770722.0	2770656.0	2770586.0	2770512.0
2770433.0	2770347.0	2770257.0	2770164.0	2770070.0
2769976.0	2769880.0	2769782.0	2769680.0	2769573.0
2769462.0	2769343.0	2769219.0	2769092.0	2768963.0
2768833.0	2768702.0	2768571.0	2768439.0	2768308.0
2768161.0	2767774.0	2767782.0	2767592.0	2767404.0
2767221.0	2767132.0	2766552.0	2765415.0	2765231.0
2765109.0	2764862.0	2764493.0	2764063.0	2763518.0
2762782.0	2761877.0	2761406.0	2760343.0	2759118.0
2757737.0	2756237.0	2754642.0	2760676.0	2760135.0
2759584.0	2759362.0	2758579.0	2758180.0	2757891.0
2757703.0	2757568.0	2757504.0	2757388.0	2757206.0
2756970.0	2756692.0	2756364.0	2755932.0	2755446.0
2754919.0	2754342.0	2753773.0	2753056.0	2752326.0
2751265.0	2750334.0	2749540.0	2748766.0	2747980.0
2747529.0	2746700.0	2746374.0	2745620.0	2744771.0
2743865.0	2742975.0	2742058.0	2741074.0	2740148.0
2739168.0	2738256.0	2737377.0	2736497.0	2735591.0
2734657.0	2733710.0	2740603.0	2739942.0	2739314.0
2738668.0	2736007.0	2737314.0	2736624.0	2736848.0
2734953.0	2734395.0	2733838.0	2733282.0	2732730.0
2732184.0	2731640.0	2731137.0	2730595.0	2730060.0
2729529.0	2729000.0	2728459.0	2727830.0	2727163.0
2726508.0	2725862.0	2725222.0	2724534.0	2723914.0
2723301.0	2722686.0	2722080.0	2721484.0	2720896.0
2720315.0	2719740.0	2719173.0	2718621.0	2718081.0
2717550.0	2717043.0	2716554.0	2716090.0	2715720.0
2715214.0	2714636.0	2714066.0	2713509.0	2712966.0
2712573.0	2712290.0	2711352.0	2710872.0	2710413.0
2709976.0	2709811.0	2708789.0	2708783.0	2708822.0
2708254.0	2707835.0	2707499.0	2707079.0	2708026.0
2708632.0	2707076.0	2702243.0	2705495.0	2706256.0
2705555.0	2702099.0	2705342.0	2705978.0	2705435.0
2705524.0	2705524.0	2705524.0	2705488.0	2705453.0
2705432.0	2705410.0	2705385.0	2705355.0	2705325.0
2705298.0	2705270.0	2705241.0	2705212.0	2705182.0
2705153.0	2705124.0	2705094.0	2705066.0	2705035.0
2705006.0	2704977.0	2704946.0	2704916.0	2704886.0
2704856.0	2704826.0	2704795.0	2704766.0	2704735.0
2704704.0	2704674.0	2704644.0	2704613.0	2704580.0
2704550.0	2704520.0	2704490.0	2704459.0	2704426.0
2704394.0	2704364.0	2704333.0	2704302.0	2704270.0
2704240.0	2704215.0	2704195.0	2704165.0	2704138.0
2704110.0	2704081.0	2704045.0	2704003.0	2703973.0
2703942.0	2703910.0	2703876.0	2703842.0	2703810.0
2703778.0	2703746.0	2703712.0	2703678.0	2703645.0
2703611.0	2703576.0	2703542.0	2703506.0	2703470.0
2703435.0	2703398.0	2703362.0	2703326.0	2703289.0
2703252.0	2703216.0	2703178.0	2703141.0	2703104.0
2703066.0	2703028.0	2702990.0	2702952.0	2702914.0
2702876.0	2702837.0	2702798.0	2702760.0	2702721.0
2702681.0	2702643.0	2702603.0	2702564.0	2702524.0
2702485.0	2702447.0	2702405.0	2702365.0	2702324.0
2702295.0	2702244.0	2702203.0	2702163.0	2702122.0
2702080.0	2702040.0	2701998.0	2701956.0	2701916.0
2701874.0	2701832.0	2701792.0	2701750.0	2701707.0
2701666.0	2701624.0	2701581.0	2701539.0	2701496.0
2701456.0	2701415.0	2701374.0	2701331.0	2701287.0

2701239.0	2701193.0	2701154.0	2701113.0	2701072.0
2701032.0	2700991.0	2700949.0	2700908.0	2700866.0
2700823.0	2700790.0	2700691.0	2700521.0	2700548.0
2700537.0	2700523.0	2700488.0	2700462.0	2700418.0
2700363.0	2700317.0	2700272.0	2700232.0	2700176.0
2700133.0	2700102.0	2700066.0	2700041.0	2700006.0
2699968.0	2699935.0	2699904.0	2699870.0	2699838.0
2699804.0	2699771.0	2699740.0	2699704.0	2699676.0
2699640.0	2699617.0	2699592.0	2699564.0	2699547.0
2699524.0	2699505.0	2699482.0	2699460.0	2699439.0
2699416.0	2699375.0	2699374.0	2699352.0	2699332.0
2699312.0	2699290.0	2699270.0	2699252.0	2699231.0
2699210.0	2699188.0	2699165.0	2699143.0	2699126.0
2699185.0	2699271.0	2699185.0	2699200.0	2699229.0
2699226.0	2699227.0	2699140.0	2699002.0	2698937.0
2698918.0	2698946.0	2698982.0	2698965.0	2698942.0
2698942.0	2698952.0	2698963.0	2698966.0	2698954.0
2698945.0	2698942.0	2698934.0	2698923.0	2698905.0
2698890.0	2698874.0	2698853.0	2698833.0	2698872.0
2698974.0	2698958.0	2698859.0	2698934.0	2698969.0
2699033.0	2699005.0	2698811.0	2698726.0	2698635.0
2698647.0	2698701.0	2698743.0	2698780.0	2698866.0
2699516.0	2699678.0	2698234.0	2698215.0	2698232.0
2698225.0	2698312.0	2698379.0	2698233.0	2698092.0
2698213.0	2698260.0	2698326.0	2698349.0	2698175.0
2698009.0	2697976.0	2697939.0	2697939.0	2698022.0
2699155.0	2698202.0	2698171.0	2698478.0	2699179.0
2699147.0	2699133.0	2699732.0	2697478.0	2694474.0
2696282.0	2697695.0	2697691.0	2698214.0	2698862.0
2699214.0	2699614.0	2700106.0	2700458.0	2700814.0
2701152.0	2701508.0	2701844.0	2702170.0	2702454.0
2702737.0	2702991.0	2703236.0	2703463.0	2703668.0
2703858.0	2704038.0	2704202.0	2704346.0	2704450.0
2704580.0	2704765.0	2704908.0	2704947.0	2705035.0
2705117.0	2705154.0	2705188.0	2705230.0	2705250.0
2705272.0	2705288.0	2705304.0	2705309.0	2705313.0
2705314.0	2705308.0	2705304.0	2705294.0	2705278.0
2705262.0	2705247.0	2705220.0	2705194.0	2705162.0
2705125.0	2705089.0	2705046.0	2705010.0	2704958.0
2704906.0	2704851.0	2704788.0	2704718.0	2704630.0
2704514.0	2704380.0	2704270.0	2704208.0	2704148.0
2704114.0	2704090.0	2704002.0	2703974.0	2703981.0
2703901.0	2703820.0	2703756.0	2703625.0	2703569.0
2703490.0	2703343.0	2703184.0	2703265.0	2703335.0
2703555.0	2703283.0	2703093.0	2703157.0	2703184.0
2703132.0	2703043.0	2702875.0	2702578.0	2702263.0
2702074.0	2702050.0	2702065.0	2701882.0	2701630.0
2701618.0	2701667.0	2701509.0	2701381.0	2701384.0
2701310.0	2701252.0	2701290.0	2701209.0	2701163.0
2701220.0	2701184.0	2701155.0	2701222.0	2701180.0
2701248.0	2701269.0	2701375.0	2701342.0	2701364.0
2701432.0	2701503.0	2701555.0	2701619.0	2701695.0
2701766.0	2701839.0	2701918.0	2701992.0	2702072.0
2702154.0	2702232.0	2702312.0	2702394.0	2702470.0
2702530.0	2702620.0	2702689.0	2702268.0	2702928.0
2702970.0	2703045.0	2703111.0	2703152.0	2703190.0
2703237.0	2703316.0	2703337.0	2703401.0	2703388.0
2703397.0	2703397.0	2703432.0	2703505.0	2703476.0
2703432.0	2703510.0	2703508.0	2703474.0	2703345.0
2703283.0	2703283.0	2703320.0	2703319.0	2703357.0
2703354.0	2703353.0	2703336.0	2703354.0	2703362.0
2703383.0	2703374.0	2703383.0	2703374.0	2703388.0
2703382.0	2703394.0	2703382.0	2703372.0	2703381.0
2703355.0	2703372.0	2703371.0	2703396.0	2703358.0
2703382.0	2703393.0	2703362.0	2703339.0	2703357.0
2703339.0	2703316.0	2703326.0	2703308.0	2703288.0
2703300.0	2703280.0	2703258.0	2703273.0	2703255.0
2703231.0	2703246.0	2703227.0	2703205.0	2703222.0

```

2703204.0 2703176.0 2703189.0 2703172.0 2703162.0
2703160.0 2703194.0 2703192.0 2703189.0 2703209.0
2703220.0 2703229.0 2703243.0 2703250.0 2703265.0
2703284.0 2703292.0 2703308.0 2703329.0 2703340.0
2703358.0 2703382.0 2703386.0 2703404.0 2703429.0
2703496.0 2703502.0 2703493.0 2703528.0 2703535.0
2703566.0 2703632.0 2703611.0 2703644.0 2703673.0
2703678.0 2703713.0 2703757.0 2703787.0 2703812.0
2703830.0 2703869.0 2703913.0 2703926.0 2703962.0
2703997.0 2704017.0 2704050.0 2704086.0 2704112.0
2704168.0 2704210.0 2704226.0 2704271.0 2704266.0
2704336.0 2704312.0 2704394.0 2704420.0 2704428.0
2704483.0 2704479.0 2704522.0 2704572.0 2704572.0
2704605.0 2704650.0 2704666.0 2704741.0 2704779.0
2704791.0 2704786.0 2704820.0 2704856.0 2704878.0
2704882.0 2704914.0 2704950.0 2705012.0 2705055.0
2705049.0 2705001.0 2705093.0 2705071.0 2705224.0
2705300.0 2705269.0 2705219.0 2705242.0 2705299.0
2705340.0 2705355.0 2705361.0 2705390.0 2705430.0
2705471.0 2705503.0 2705530.0 2705563.0 2705603.0
2705643.0 2705684.0 2705724.0 2705764.0 2705806.0
2705844.0 2705883.0 2705924.0 2705968.0 2706011.0
2706056.0 2706100.0 2706144.0 2706192.0 2706239.0
2706284.0 2706332.0 2706380.0 2706426.0 2706476.0
2706526.0 2706574.0 2706626.0 2706677.0 2706728.0
2706780.0 2706834.0 2706886.0 2706940.0 2706995.0
2707050.0 2707068.0 2707558.0 2708070.0 2708805.0
2709576.0 2710400.0 2711289.0 2712244.0 2713287.0
2714376.0 2713441.0 2716575.0 2717479.0 2715764.0
2709244.0 2717533.0 2709940.0 2706765.0 2707916.0
2707356.0 2705743.0 2704562.0 2709009.0 2716900.0
2706804.0 2712316.0 2709003.0 2704124.0 2721174.0
2706813.0 2704932.0 2723279.0 2707968.0 2703828.0
2705493.0 2725673.0 2707572.0 2705907.0 2703822.0
2717379.0 2710476.0 2724490.0 2725371.0 2724520.0
2721841.0 2726314.0 2728248.0 2728045.0 2730173.0
2731730.0 2732871.0 2733769.0 2730711.0 2728088.0
2735208.0 2735571.0 2735926.0 2736210.0 2736449.0
2736650.0 2736825.0 2736980.0 2737116.0 2737239.0
2737352.0 2737452.0 2737543.0 2737625.0 2737700.0
2737763.0 2737820.0 2740064.0 2739390.0 2755644.0
2735412.0 2742554.0 2745561.0 2737230.0 2734979.0
2737278.0 2735304.0 2735570.0 2736636.0 2737875.0
2747108.0 2739805.0 2743914.0 2736192.0 2739179.0
2781715.0 2738770.0 2755562.0 2736250.0 2720564.0
2738154.0 2718860.0 2735820.0 2759214.0 2733628.0
2728685.0 2729542.0 2749347.0 2724204.0 2726526.0
2767421.0 2781681.0 2727220.0 2722144.0 2720087.0
2739568.0 2723116.0 2732810.0 2714422.0 2713701.0
2717686.0 2720572.0 2722932.0 2734807.0 2726087.0
2814093.0 2782506.0 2730763.0 2729831.0 2726293.0
2720432.0 2736754.0 2743232.0 2723444.0 2715190.0
2725543.0 2729064.0 2737420.0 2725943.0 2736436.0
2722402.0 2726602.0 2750201.0 2714150.0 2743469.0
2744726.0 2731505.0 2819061.0 2737245.0 2753844.0
2727543.0 2721452.0 2771315.0 2751222.0 2725396.0
2736274.0 2725186.0 2735294.0 2731813.0 2737567.0
2728285.0 2745799.0 2722172.0 2731546.0 2725140.0
2723374.0 2737963.0 2727181.0

```

```

eot
&&
struc
  name = Ceiling      && Name of structure
  type = roof         && Type of structure
  shape = slab        && Shape of structure
  nslab = 10          && Number of nodes in structure
  chrLen = 17.7       && Characteristic length of structure (m)
  slarea = 86.4       && Area (m2)

```

```

tunif = 305.          && Initial uniform temperature          (K)
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eol

&&
name = Walla          && Name of structure
type = wall           && Type of structure
shape = slab          && Shape of structure
nslab = 10            && Number of nodes in structure
chrlen = 5.49         && Characteristic length of structure      (m)
slarea = 254.         && Area (m2)
tunif = 305.         && Initial uniform temperature          (K)
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 30. && (m)
eol

&&
condense
ht-tran on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell
geometry= 86.4        && Area of layers in lower cell          (m2)
bc = 305.            && Basemat boundary condition temperature          (K)
concrete
  compos = 1          && Number of materials
              conc    && Material
              19000.   && Mass of material (kg)
  temp = 305.         && Initial temperature          (K)
eol
pool
  temp = 305.         && Initial temperature
eol

eol
&&
&& Engineered safety systems
&&
engineer Spill 1 2 3 0.0
overflow 2 3 3.05
eol
&&
&& ----- Cell 3, Room 115 -----
cell 3
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eol
title
  Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height          (m3, m)
atmos = 3
          1.01e5      && Pressure
          305.        && Temperature
o2 = 0.20
n2 = 0.75
h2ov = 0.05
struc
name = Ceiling        && Name of structure
type = roof           && Type of structure
shape = slab          && Shape of structure
nslab = 10            && Number of nodes in structure
chrlen = 14.6         && Characteristic length of structure      (m)
slarea = 107.         && Area (m2)
tunif = 305.         && Initial uniform temperature          (K)
compound= conc conc conc conc conc conc conc conc conc conc

```

```

x      = 0.  .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eol
&&
name   = Walls           && Name of structure
type   = wall
shape  = slab
nslab  = 10
chrlen = 5.49
slarea = 241.
tunif  = 305.
compound= conc conc conc conc conc conc conc conc conc conc
x      = 0.  .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eol
&&
condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
t:
!x cell
  geometry= 107.         && Area of layers in lower cell           (m2)
  t: = 305.             && Basemat boundary condition temperature (K)
  concrete
    compos = 1         && Number of materials
                conc   && Material
                23500. && Mass of material
    temp = 305.        && Initial temperature
  eol
  pool
    temp = 305.        && Initial temperature
  eol
eol
&&
&& Engineered safety systems
&&
engineer Spill 1 3 2 0.
overflow 3 2 3.05
eol
&&
&& ----- Cell 4, Room 236 -----
cell 4
control
  nhtm=1 mxslab=11 nsoatm=2 nspatm=000 jconc=1 jpool=1 naensy=2
  nsoeng=1 nspeng=4
eol
title
  Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height           (m3, m)
atmos    = 3
          1.01e5      && Pressure
          305.        && Temperature
o2       = 0.25
n2       = 0.75
h2ov     = 0.05
&&
struc
name     = Walls           && Name of structure
type     = wall           && Type of structure
shape    = slab           && Shape of structure
nslab    = 10             && Number of nodes in structure
chrlen   = 5.49           && Characteristic length of structure (m)
slarea   = 450.           && Area (m2)
tunif    = 305.           && Initial uniform temperature (K)
compound= conc conc conc conc conc conc conc conc conc conc

```

```

x      = 0.  .015 .030 .045 .060 .075 .090 .105 .120 .135 .152
eol
&&
condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
  geometry= 91.9      && Area of layers in lower cell      (m2)
  bc = 305.          && Basemat boundary condition temperature (K)
  concrete
    compos = 1      && Number of materials
                conc && Material
                6730. && Mass of material
    temp = 305.    && Initial temperature
  eol
  pool
    temp = 305.    && Initial temperature
  eol
eol
&&
&& Engineered safety systems
&&
&& Spillage from Room 236 to Room 115 via the connecting pipe chase
&&
engineer Spill 1 4 3 5.79
overflow 4 3 0.025
eol
&&
&& Fire water sprinkler system, activated on high temperature.
&&
engineer Sprinkl 2 4 4 0.
spray
  spdiam = .001    && Spray droplet diameter      (m)
  sphte = 5.49    && Spray fall height      (m)
  spsttm = 373.   && Temperature at which system activates (K)
eol
  source = 1      && Sprays provide 336 gpm (21.1 kg/s) after
  h2o1 = 3      && activation
  iflag = 2
  t = 0.0      100.  1.00e5
  mass = 21.1   21.1  21.1
  temp = 305.   305.  305.
eol
eol
&&
&& ----- Cell 5, Balance of Plant -----
cell 5
control
eol
title
  Balance of Plant
geometry 1.87e5 38.8
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05
&&
&& ----- Cell 6, Environment -----
cell 6
control
eol
title
  Environment Cell
geometry 1.e10 1.e30
atmos=3 1.01e5 305.

```

o2 0.20  
n2 0.75  
h2ov 0.05

eof

## LISTING 8 - CONTAIN Input for BS-3

```

&& ----- Model Description -----
&&
&& File:
&&   cnt003.mdl
&&
&& Description:
&&
&&   BS-3. This input deck describes a five volume model of the B&W Plant
&&   auxilliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 18 inch break in the decay heat removal
&&   system suction piping in room 113. This model does not include
&&   water aerosols (the dropout option is used).
&&
&& Written by:
&&
&&   John Schroeder 6/91
&&
&& ----- Machine Control Input -----
cray
eol
&& ----- Global Input -----
&&
&& Section 3.2, p. 3-11
f&
&&   Atmospheric Gases
&&
&&   Material      Description
&&   -----
&&   o2            oxygen
&&   n2            nitrogen
&&   h2ov          steam
&&   h2o1          water
&&
control
  ncells = 6      && Number of cells
  ntitl  = 2      && Number of title lines
  ntzone = 5      && Number of time zones
  nac    = 0      && Number of aerosol groups
  nsectn = 0      && Number of aerosol sections
eol
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
material
  compound
    n2 o2          && Air
    h2ov h2o1     && Steam and water
    conc          && Structural materials
&&
&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17
&&
thermal          && Water-cooled reactor
&&
&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
flows
&&

```



```

&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&&      1, 2, 3.
&&
&& area(1,5) = 8.88    && Cross-sectional area of flow path      (m2)
&& avl(1,5)  = 14.6   && Ratio of area to inertial length, A/L      (m)
&& cfc(1,5)  = 1.00   && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&& area(1,2) = 12.6
&& avl(1,2)  = 20.7
&& cfc(1,2)  = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&& area(2,5) = 0.892
&& avl(2,5)  = 1.46
&& cfc(2,5)  = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&& area(2,3) = 1.95
&& avl(2,3)  = 3.2
&& cfc(2,3)  = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&& area(3,5) = 1.95
&& avl(3,5)  = 3.2
&& cfc(3,5)  = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&& area(3,4) = 2.97
&& avl(3,4)  = 4.88
&& cfc(3,4)  = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&      10, 11, 12, and 13.
&&
&& area(4,5) = 29.1
&& avl(4,5)  = 157.
&& cfc(4,5)  = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&      paths.
&&
&& area(5,6) = 46.5
&& avl(5,6)  = 250.
&& cfc(5,6)  = 1.00
&&
&& implicit
&& dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments
&&
&& elevc1(1) = 169.    && Center of mass elevation for Rm 105      (m)
&& elevc1(2) = 169.    && Center of mass elevation for Rm 113      (m)
&& elevc1(3) = 169.    && Center of mass elevation for Rm 115      (m)
&& elevc1(4) = 175.    && Center of mass elevation for Rm 236      (m)
&& elevc1(5) = 185.    && Center of mass elevation for Rm BOP      (m)
&& elevc1(6) = 185.    && Center of mass elevation for Environment (m)
&&
&& Junctions
&&
&& elevfp(1,5) = 167.

```

```

elevfp(5,1)= 167.

elevfp(1,2)= 170.
elevfp(2,1)= 170.

elevfp(2,5)= 172.
elevfp(5,2)= 172.

elevfp(2,3)= 170.
elevfp(3,2)= 170.

elevfp(3,5)= 170.
elevfp(5,3)= 170.

elevfp(3,4)= 172.
elevfp(4,3)= 172.

elevfp(4,5)= 173.
elevfp(5,4)= 173.

elevfp(5,6)= 211.
elevfp(6,5)= 211.
&&
&& ----- Aerosol Options -----
&&
&& Section 3.2.4, p. 3-29
&&
&& aerosol
&&   h2ov 1.0e-8 0.693
&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
1800.          && Maximum CPU time limit          (s)
0.             && Problem start time                    (s)
&&
&& Time zone data
&&
&& System   Edit   End of
&&  Ts      Ts      Zone
&& -----
&&          1.     10.     10.
&&          5.     50.     100.
&&         20.    200.    500.
&&         50.   1000.  1000.
&&         50.   1000.  3600.
&&
&& -----
&&
&& ----- Output Control -----
&&
&& Section 3.2.7, p. 3-38
&&
shortedt      = 2      && System ts between short edits
longedt      = 1      && Ts edits between long edits
prflow       && Print intercell flow data
praer        && detailed aerosol inventories
prlow-cl     && lower cell model
prheat       && heat transfer structure model
prengsys     && engineered system model
title
&&           B&W Plant Auxilliary Building Steam Propagation Model
&&           Five Compartment Model -- BS-3
&&
&&
&& ----- Cell Input and Cell Control -----

```

```

&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eol
title
  Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e3 5.49 && Cell volume and height (m3, m)
  atmos = 3 && Number of materials
        1.01e5 && Pressure (Pa)
        305. && Temperature (K)
  n2 = 0.75 && Initial nitrogen fraction
  o2 = 0.20 && Initial oxygen fraction
  h2ov = 0.05 && Initial water vapor fraction
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 18.7 && Characteristic length of structure (m)
  slarea = 295. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .046 .092 .138 .184 .230 .276 .322 .368 .414 .457 && (m)
eol
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 298. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eol
&&
condense
ht-tran on on on on on
overflow 1
&&
&& Lower cell input
&&
low-cell
  geometry= 295. && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
            conc && Material
            43200. && Mass of material
    temp = 305. && Initial temperature
  eol
  pool
    temp = 305. && Initial temperature
  eol
eol
&&
&& Engineered safety systems
&&
engineer Spill 1 1 5 .152
overflow 1 5 1.74
eol

```

```

&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  nhtm=2 mxslab=11 nsoatm=4 nspatm=302 naensy=1 j^onc=5 jpool=1
eol
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e2 6.10 && Cell volume and height (m3, m)
  atmos = 3
    1.01e5 && Pressure (Pa)
    305. && Temperature (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
source=4
&&
&& Blowdown of saturated primary system water
&&
h2ov = 301
iflag = 2
t =

```

0.0	1.0	6.0	11.0	15.0
20.0	25.0	30.0	35.0	40.0
45.0	50.0	55.0	60.0	65.0
70.0	75.0	80.0	85.0	90.0
95.0	100.0	105.0	110.0	115.0
120.0	125.0	130.0	135.0	140.0
145.0	150.0	155.0	160.0	165.0
170.0	175.0	180.0	185.0	190.0
195.0	200.0	205.0	210.0	215.0
220.0	225.0	230.0	235.0	240.0
245.0	250.0	255.0	260.0	265.0
270.0	275.0	280.0	285.0	290.0
295.0	300.0	305.0	310.0	315.0
320.0	325.0	330.0	335.0	340.0
345.0	350.0	355.0	360.0	365.0
370.0	375.0	380.0	385.0	390.0
395.0	400.0	405.0	410.0	415.0
420.0	425.0	430.0	435.0	440.0
445.0	450.0	455.0	460.0	465.0
470.0	475.0	480.0	485.0	490.0
495.0	500.0	510.0	518.6	528.5
538.5	548.5	558.5	568.5	578.5
588.5	598.5	608.5	618.5	628.5
634.6	644.6	654.6	664.6	674.6
684.6	694.6	704.6	714.6	724.6
734.6	744.6	754.6	764.6	774.6
784.6	794.6	804.6	814.6	824.6
834.6	844.6	854.6	864.6	874.6
884.6	894.6	904.6	914.6	924.6
934.6	944.6	954.6	964.6	974.6
984.6	994.6	1004.6	1014.6	1024.6
1034.6	1044.6	1054.6	1064.6	1074.6
1084.6	1094.6	1104.6	1114.6	1124.6
1134.6	1144.6	1154.6	1164.6	1174.6
1184.6	1194.6	1204.6	1214.6	1224.6
1234.6	1244.6	1254.6	1264.6	1274.6
1284.6	1294.6	1304.6	1314.6	1324.6
1334.6	1344.6	1354.6	1364.6	1374.6
1384.6	1394.6	1404.6	1414.6	1424.6
1434.6	1444.6	1454.6	1464.6	1474.6
1484.6	1494.6	1504.6	1514.6	1524.6
1534.6	1544.6	1554.6	1564.6	1574.6
1584.6	1594.6	1604.6	1614.6	1624.6

1634.6	1644.6	1654.6	1664.6	1674.6
1684.6	1694.6	1704.6	1714.6	1724.6
1734.6	1744.6	1754.6	1764.6	1774.6
1784.6	1794.6	1804.6	1814.6	1824.6
1834.6	1844.6	1854.6	1864.6	1874.6
1884.6	1894.6	1904.6	1914.6	1924.6
1934.6	1944.6	1954.6	1964.6	1974.6
1984.6	1994.6	2004.6	2014.6	2024.6
2034.6	2044.6	2054.6	2064.6	2074.6
2084.6	2094.6	2104.6	2114.6	2124.6
2134.6	2144.6	2154.6	2164.6	2174.6
2184.6	2194.6	2204.6	2214.6	2224.6
2234.6	2244.6	2254.6	2264.6	2274.6
2284.6	2294.6	2304.6	2314.6	2324.6
2334.6	2344.6	2354.6	2364.6	2374.6
2384.6	2394.6	2404.6	2414.6	2424.6
2434.6	2444.6	2454.6	2464.6	2474.6
3600.0				

mass =	0.0	58.9	40.8	22.5	22.7
	24.5	25.5	26.3	26.9	27.3
	27.7	27.9	27.9	27.8	27.6
	27.4	27.0	26.5	26.0	25.5
	24.8	24.1	23.4	22.9	22.7
	22.6	22.5	22.4	22.3	22.2
	22.1	21.9	21.7	21.5	21.3
	21.1	20.8	20.6	20.3	20.0
	19.7	19.3	19.0	18.6	18.3
	17.9	17.5	17.1	16.7	16.3
	15.8	15.4	15.0	14.6	17.7
	17.5	17.3	17.1	16.9	16.7
	16.5	16.3	16.1	15.9	15.8
	15.7	15.5	15.4	15.4	15.3
	15.2	15.1	15.1	15.0	14.9
	14.8	14.7	14.6	14.5	14.4
	14.3	14.2	14.1	14.0	13.8
	13.7	13.6	13.4	13.3	13.1
	13.0	12.8	12.7	12.5	12.4
	12.2	12.0	11.7	11.5	11.3
	11.2	11.0	10.7	10.5	10.2
	10.0	9.7	9.7	9.4	9.1
	8.8	8.7	8.3	8.1	7.8
	7.7	7.5	7.3	7.1	6.9
	6.8	6.6	7.4	7.3	7.2
	7.1	6.9	6.8	6.7	6.8
	6.5	6.4	6.4	6.4	6.3
	6.3	6.3	6.2	6.2	6.2
	6.1	6.1	6.1	6.0	5.9
	5.9	5.8	5.8	5.7	5.6
	5.6	5.6	5.5	5.5	5.5
	5.4	5.4	5.4	5.4	5.4
	5.3	5.3	5.3	5.3	5.3
	5.3	5.3	5.2	5.2	5.2
	5.2	5.1	5.1	5.1	5.1
	5.1	5.2	5.1	5.2	5.2
	5.2	5.2	5.2	4.9	5.2
	5.4	5.1	5.3	5.2	5.5
	5.6	5.6	5.5	5.8	5.7
	5.5	5.8	5.6	6.0	5.7
	5.5	5.5	5.5	5.6	5.6
	5.6	5.6	5.5	5.5	5.5
	5.5	5.5	5.5	5.5	5.6
	5.6	5.5	5.5	5.6	5.7
	5.0	9.1	6.8	7.1	7.1
	7.1	7.0	6.9	6.4	6.5
	6.2	6.4	6.6	6.2	6.3
	6.4	6.5	6.5	6.4	6.4
	6.3	6.3	6.2	6.2	6.2

6.2	6.1	5.2	4.0	6.6
3.9	6.6	7.0	3.3	4.5
5.2	6.9	4.8	3.8	14.2
3.8	3.8	3.6	3.6	5.0
3.6	4.4	4.1	4.8	4.1
4.2	4.5	4.5	5.9	2.1
3.7	3.8	3.6	4.0	4.2
4.3	9.2	2.6	2.0	3.9
3.1	2.7	3.3	3.0	3.4
4.3	4.8	4.5	5.9	6.5
7.2	6.9	12.0	8.7	12.0
12.0				

enth =	158119.7	158275.8	331924.2	552703.6	554112.1
	565071.1	571186.1	575964.7	579662.9	581960.0
	583640.2	584837.9	585163.9	584867.1	583998.0
	582617.8	580745.3	578453.6	575779.3	572597.9
	568974.1	564997.6	560503.9	557778.9	556453.7
	556132.1	555960.3	555741.1	555405.8	554961.5
	554362.6	553595.6	552702.4	551679.0	550649.1
	549483.5	548178.4	546723.9	545119.1	543265.4
	541452.8	539373.3	537238.6	534994.9	532601.8
	530140.9	527780.6	525566.7	523233.3	520761.2
	518472.8	516241.9	513916.0	511628.2	533126.2
	531866.9	530638.9	529410.8	528375.0	527438.9
	526531.0	525663.8	524851.6	524110.5	523452.9
	522885.6	522412.7	522028.0	521693.8	521383.4
	521207.9	521073.5	520923.6	520733.2	520493.1
	520209.4	519885.5	519529.9	519147.8	518736.6
	518286.1	517795.1	517240.5	516836.8	516015.3
	515362.6	514696.9	513945.6	513195.6	512395.0
	511556.3	510707.3	509870.1	509073.2	508154.1
	507273.1	506341.1	504785.4	503715.9	502625.2
	501673.4	500777.2	498836.6	497328.0	495623.8
	494730.8	493091.5	492639.4	491024.7	489371.3
	487640.5	485944.4	484167.1	482523.8	480884.3
	479949.2	478484.0	477100.0	475784.2	474469.8
	473141.4	471855.1	482094.3	480988.4	479933.3
	478871.4	477748.9	476615.6	475540.5	475143.4
	473162.5	472400.3	471653.9	470938.3	470235.5
	469568.4	468921.4	468320.5	467722.7	467155.9
	466633.7	466126.2	465656.4	465016.2	464392.2
	463822.8	463309.4	462847.0	462333.4	461992.8
	461721.5	461519.3	461394.1	461355.3	461412.9
	461556.7	461802.9	462129.6	462587.9	463157.8
	463869.1	464706.2	465691.8	466817.7	468097.7
	469248.4	470525.7	471941.8	473513.4	475259.4
	477210.5	479372.9	481774.0	484140.9	487257.4
	490505.0	493674.8	496827.6	500665.9	504094.7
	508738.5	512925.1	516243.0	519436.2	522322.4
	528308.7	515683.1	532306.6	537456.0	541702.9
	546845.5	547418.8	550125.1	552940.2	554273.6
	554419.9	560000.8	559846.9	561385.0	564972.2
	564713.8	565021.6	566278.1	570270.9	571498.9
	572499.9	573364.4	574136.4	574978.4	575677.9
	576331.2	577193.9	577550.3	578569.5	579780.4
	580188.9	578541.1	578648.6	580825.4	582249.4
	576068.2	585166.3	596068.1	595850.2	595234.6
	595152.0	594386.5	593164.8	591549.9	589204.8
	582857.7	585656.1	586104.9	583876.5	588144.9
	588147.8	588551.2	588622.6	588492.5	587991.8
	587107.5	586073.9	585218.3	584714.4	584623.9
	584680.5	584515.1	534110.8	548280.6	518546.9
	539126.8	516692.0	537548.1	546426.5	537509.2
	518799.8	508717.7	527707.6	513545.1	516439.7
	522333.5	504681.8	526250.9	511345.6	503418.3
	519864.8	506309.6	494335.5	515835.8	504503.2
	521978.7	496007.1	488067.3	483293.8	501916.2

495111.4	488512.5	482649.2	481143.2	477144.5
474706.4	481453.4	495235.0	484140.2	49211.0
504733.8	498843.1	487460.8	495541.4	489902.2
491831.8	505150.8	505089.0	520139.4	537697.3
550263.3	554174.9	575586.2	563304.8	546196.3
589868.3	584141.0	577716.0	615913.7	609414.1
609414.1				

```

eol
**
** Blowdown of primary system steam
**

```

```
h2ov = 301
```

```
iflag = 2
```

```
t =
```

0.0	1.0	6.0	11.0	15.0
20.0	25.0	30.0	35.0	40.0
45.0	50.0	55.0	60.0	65.0
70.0	75.0	80.0	85.0	90.0
95.0	100.0	105.0	110.0	115.0
120.0	125.0	130.0	135.0	140.0
145.0	150.0	155.0	160.0	165.0
170.0	175.0	180.0	185.0	190.0
195.0	200.0	205.0	210.0	215.0
220.0	225.0	230.0	235.0	240.0
245.0	250.0	255.0	260.0	265.0
270.0	275.0	280.0	285.0	290.0
295.0	300.0	305.0	310.0	315.0
320.0	325.0	330.0	335.0	340.0
345.0	350.0	355.0	360.0	365.0
370.0	375.0	380.0	385.0	390.0
395.0	400.0	405.0	410.0	415.0
420.0	425.0	430.0	435.0	440.0
445.0	450.0	455.0	460.0	465.0
470.0	475.0	480.0	485.0	490.0
495.0	500.0	510.0	515.0	520.0
538.5	548.5	558.5	568.5	570.5
588.5	598.5	608.5	618.5	628.5
634.7	644.6	654.6	664.6	674.6
684.6	694.6	704.6	714.6	724.6
734.6	744.6	754.6	764.6	774.6
784.6	794.6	804.6	814.6	824.6
834.6	844.6	854.6	864.6	874.6
884.6	894.6	904.6	914.6	924.6
934.6	944.6	954.6	964.6	974.6
984.6	994.6	1004.6	1014.6	1024.6
1034.6	1044.6	1054.6	1064.6	1074.6
1084.6	1094.6	1104.6	1114.6	1124.6
1134.6	1144.6	1154.6	1164.6	1174.6
1184.6	1194.6	1204.6	1214.6	1224.6
1234.6	1244.6	1254.6	1264.6	1274.6
1284.6	1294.6	1304.6	1314.6	1324.6
1334.6	1344.6	1354.6	1364.6	1374.6
1384.6	1394.6	1404.6	1414.6	1424.6
1434.6	1444.6	1454.6	1464.6	1474.6
1484.6	1494.6	1504.6	1514.6	1524.6
1534.6	1544.6	1554.6	1564.6	1574.6
1584.6	1594.6	1604.6	1614.6	1624.6
1634.6	1644.6	1654.6	1664.6	1674.6
1684.6	1694.6	1704.6	1714.6	1724.6
1734.6	1744.6	1754.6	1764.6	1774.6
1784.6	1794.6	1804.6	1814.6	1824.6
1834.6	1844.6	1854.6	1864.6	1874.6
1884.6	1894.6	1904.6	1914.6	1924.6
1934.6	1944.6	1954.6	1964.6	1974.6
1984.6	1994.6	2004.6	2014.6	2024.6
2034.6	2044.6	2054.6	2064.6	2074.6
2084.6	2094.6	2104.6	2114.6	2124.6
2134.6	2144.6	2154.6	2164.6	2174.6
2184.6	2194.6	2204.6	2214.6	2224.6

2234.6	2244.6	2254.6	2264.6	2274.6
2284.6	2294.6	2304.6	2314.6	2324.6
2334.6	2344.6	2354.6	2364.6	2374.6
2384.6	2394.6	2404.6	2414.6	2424.6
2434.6	2444.6	2454.6	2464.6	2474.6
3600.0				

mass =	0.0	0.0	19.2	13.5	13.6
	14.5	15.0	15.5	15.8	16.0
	17.2	16.3	16.4	16.4	16.3
	16.2	16.1	15.9	15.6	15.4
	15.1	14.8	14.4	14.2	14.1
	14.1	14.1	14.1	14.1	14.1
	14.1	14.1	14.1	14.0	14.0
	13.9	13.9	13.8	13.7	13.6
	13.5	13.4	13.2	13.1	13.0
	12.8	12.6	12.4	12.2	12.0
	11.8	11.6	11.4	11.2	11.0
	13.4	13.4	13.3	13.2	13.2
	13.1	13.1	13.0	13.0	13.0
	12.9	12.9	12.9	12.9	12.9
	12.9	13.0	13.0	13.0	13.0
	13.0	13.0	12.9	12.9	12.9
	12.9	12.8	12.8	12.8	12.7
	12.7	12.6	12.6	12.5	12.4
	12.4	12.3	12.2	12.2	12.1
	12.0	11.9	11.8	11.7	11.6
	11.5	11.4	11.2	11.1	11.0
	10.9	10.8	10.7	10.5	10.4
	10.2	10.1	9.9	9.8	9.6
	9.5	9.4	9.2	9.1	9.0
	8.8	8.7	10.2	10.0	9.9
	9.8	9.7	9.5	9.4	9.3
	9.1	9.0	8.9	8.7	8.6
	8.5	8.4	8.3	8.1	8.0
	7.9	7.8	7.7	7.6	7.4
	7.3	7.2	7.1	7.0	6.9
	6.8	6.7	6.6	6.4	6.3
	6.2	6.1	6.0	5.9	5.8
	5.7	5.6	5.5	5.4	5.3
	5.3	5.2	5.1	5.0	4.9
	4.8	4.8	4.7	4.6	4.5
	4.4	4.4	4.3	4.2	4.1
	4.1	4.0	3.9	3.8	3.8
	3.7	3.1	3.6	3.5	3.6
	3.4	3.4	3.3	3.3	3.2
	3.0	3.1	3.1	3.1	3.0
	2.9	2.8	2.8	2.8	2.7
	2.7	2.6	2.6	2.5	2.5
	2.5	2.4	2.4	2.3	2.3
	2.3	2.3	2.2	2.2	2.1
	1.8	2.3	1.9	1.9	1.9
	1.9	1.8	1.8	1.7	1.7
	1.7	1.6	1.7	1.7	1.6
	1.6	1.6	1.6	1.5	1.5
	1.5	1.5	1.4	1.4	1.4
	1.4	1.4	1.5	1.2	1.5
	1.2	1.5	1.5	1.0	1.2
	1.2	1.4	1.2	1.1	1.9
	1.1	1.2	1.0	1.0	1.2
	0.9	1.1	1.1	1.1	1.0
	1.0	1.1	1.0	1.1	0.7
	0.9	1.0	1.0	0.9	1.0
	0.9	1.4	0.8	0.7	0.9
	0.8	0.7	0.9	0.7	0.9
	0.9	1.0	0.9	1.3	1.4
	1.4	1.6	.7	1.7	1.9
	1.4				







21.1	20.8	20.6	20.3	20.0
19.7	19.3	19.0	18.6	18.3
17.9	17.5	17.1	16.7	16.3
15.8	15.4	15.0	14.6	17.7
17.5	17.3	17.1	16.9	16.7
16.5	16.3	16.1	15.9	15.8
15.7	15.5	15.4	15.4	15.3
15.2	15.1	15.1	15.0	14.9
14.8	14.7	14.6	14.5	14.4
14.3	14.2	14.1	14.0	13.8
13.7	12.6	13.4	13.3	13.1
13.0	12.8	12.7	12.5	12.4
12.2	12.0	11.7	11.5	11.3
11.2	11.1	10.7	10.5	10.2
10.0	9.	9.7	9.4	9.1
8.8	8.6	8.3	8.1	7.8
7.7	7.5	7.3	7.1	6.9
6.8	6.6	7.4	7.3	7.2
7.1	6.9	6.8	6.7	6.8
6.5	6.4	6.4	6.4	6.3
6.3	6.3	6.2	6.2	6.2
6.1	6.1	6.1	6.0	5.9
5.9	5.8	5.8	5.7	5.6
5.6	5.6	5.5	5.5	5.5
5.4	5.4	5.4	5.4	5.4
5.3	5.3	5.3	5.3	5.3
5.3	5.3	5.2	5.2	5.2
5.2	5.1	5.1	5.1	5.1
5.1	5.2	5.1	5.2	5.2
5.2	5.2	5.2	4.9	5.2
5.4	5.1	5.3	5.2	5.5
5.6	5.6	5.5	5.8	5.7
5.5	5.8	5.6	6.0	5.7
5.5	5.5	5.5	5.6	5.6
5.6	5.6	5.5	5.5	5.5
5.5	5.5	5.5	5.5	5.6
5.6	5.5	5.5	5.6	5.7
5.0	9.1	6.9	7.1	7.1
7.1	7.0	6.9	6.4	6.5
6.2	6.4	6.6	6.2	6.3
6.4	6.5	6.5	6.4	6.4
6.3	6.3	6.2	6.2	6.2
6.2	6.1	5.2	4.0	6.6
3.9	6.6	7.0	3.3	4.5
5.2	6.9	4.8	3.8	14.2
3.8	3.8	3.6	3.6	5.0
3.6	4.4	4.1	4.8	4.1
4.2	4.5	4.5	5.9	2.1
3.7	3.8	3.6	4.0	4.2
4.3	9.2	2.6	2.0	3.9
3.1	2.7	3.3	3.0	3.4
4.3	4.8	4.5	5.9	6.5
7.2	6.9	12.0	8.7	12.0
12.0				

enth =	158119.7	158275.8	631924.2	552701.6	554112.1
	565071.1	571186.1	575944.7	579662.9	581960.0
	583840.2	584837.9	585163.9	584867.1	583998.0
	582617.8	580745.3	578453.6	575779.3	572597.9
	568974.1	564997.6	560503.9	557778.9	556453.7
	556132.1	555960.3	555741.1	555405.8	554961.5
	554362.6	553595.6	552702.4	551679.0	550649.1
	549483.5	548178.4	546723.9	545119.1	543365.4
	541452.8	539373.3	537238.6	534994.9	532601.8
	530140.9	527780.6	525566.7	523233.3	520761.2
	518472.8	516241.9	513916.0	511628.2	533176.2
	531866.9	530638.9	529410.8	528375.0	527438.9
	526531.0	525663.8	524851.6	524110.5	523452.9

522885.6	522412.7	522028.0	521693.8	521383.4
521207.9	521073.5	520923.6	520733.2	520493.1
520209.4	519885.5	519529.9	519147.8	518736.6
518286.1	517795.1	517240.5	516636.8	516015.3
515362.6	514696.9	513945.6	513195.6	512395.0
511556.3	510707.3	509870.1	509073.2	508154.1
507273.1	506341.1	504785.4	503715.9	502625.2
501673.4	500777.2	498836.6	497328.0	495623.8
494730.8	493091.5	492639.4	491024.7	489371.3
487640.5	485944.4	484167.1	482523.8	480884.3
479949.2	478484.0	477100.0	475784.2	474469.8
473141.4	471855.1	482094.3	480988.4	479933.3
478871.4	477748.9	476615.6	475540.5	475143.4
473162.5	472400.3	471653.9	470938.3	470235.5
469588.4	468921.4	468320.5	467722.7	467155.9
466633.7	466126.2	465656.4	465016.2	464392.2
463822.8	463309.4	462847.0	462333.4	461992.8
461721.5	461519.3	461394.1	461355.3	461412.9
461556.7	461802.9	462129.6	462587.9	463157.8
463869.1	464706.2	465691.8	466817.7	468097.7
469248.4	470525.7	471941.8	473513.4	475259.4
477210.5	479372.9	481774.0	484140.9	487257.4
490505.0	493674.8	496827.6	500665.9	504094.7
508738.5	512925.1	516243.0	513436.2	522322.4
528308.7	515683.1	532306.6	537458.0	541702.9
546845.5	547418.8	550251.1	552940.2	554273.6
554419.9	560000.8	559846.9	561385.0	564972.2
564713.8	565021.6	566278.1	570270.9	571498.9
572499.9	573364.4	574136.4	574978.4	575677.9
576331.2	577193.9	577550.3	578569.5	579780.4
580188.9	578541.1	578648.6	580825.4	582249.4
576068.2	58166.3	596068.1	595850.2	595234.6
595152.0	594386.5	593164.8	591549.9	589204.8
582857.7	585656.1	586104.9	583676.5	588144.9
588147.8	588551.2	588622.6	588492.5	587991.8
587107.5	586073.9	585218.3	584714.4	584623.9
584680.5	584515.1	584110.8	58280.6	518546.9
539126.8	516692.0	537548.1	546426.5	537509.2
516799.8	508717.7	527707.6	513545.1	516439.7
522333.5	504681.8	526250.9	511345.6	503418.3
519864.8	506309.6	494335.5	515835.8	504503.2
521978.7	496007.1	488067.3	483293.8	501916.2
495111.4	488512.5	482649.2	481143.2	477344.5
474706.4	481453.4	495235.0	484140.2	492881.0
504733.8	498843.1	487460.8	495541.4	489902.2
491831.8	505150.6	505089.0	520139.4	537697.3
550263.3	554174.9	575586.2	563304.8	546196.3
589868.3	584141.0	577716.0	615913.7	609414.1
609414.1				

```

    eol
&&
&& Blowdown of primary system steam - second break
&&
    h2ov = 301
    iflag = 2
    t =
        0.0      1.0      6.0      11.0     15.0
        20.0     25.0     30.0     35.0     40.0
        45.0     50.0     55.0     60.0     65.0
        70.0     75.0     80.0     85.0     90.0
        95.0    100.0    105.0    110.0    115.0
        120.0    125.0    130.0    135.0    140.0
        145.0    150.0    155.0    160.0    165.0
        170.0    175.0    180.0    185.0    190.0
        195.0    200.0    205.0    210.0    215.0
        220.0    225.0    230.0    235.0    240.0
        245.0    250.0    255.0    260.0    265.0
        270.0    275.0    280.0    285.0    290.0
        295.0    300.0    305.0    310.0    315.0

```

320.0	325.0	330.0	335.0	340.0
345.0	350.0	355.0	360.0	365.0
370.0	375.0	380.0	385.0	390.0
395.0	400.0	405.0	410.0	415.0
420.0	425.0	430.0	435.0	440.0
445.0	450.0	455.0	460.0	465.0
470.0	475.0	480.0	485.0	490.0
495.0	500.0	510.0	518.6	528.5
538.5	548.5	558.5	568.5	578.5
588.5	598.5	608.5	618.5	628.5
634.7	644.6	654.6	664.6	674.6
684.6	694.6	704.6	714.6	724.6
734.6	744.6	754.6	764.6	774.6
784.6	794.6	804.6	814.6	824.6
834.6	844.6	854.6	864.6	874.6
884.6	894.6	904.6	914.6	924.6
934.6	944.6	954.6	964.6	974.6
984.6	994.6	1004.6	1014.6	1024.6
1034.6	1044.6	1054.6	1064.6	1074.6
1084.6	1094.6	1104.6	1114.6	1124.6
1134.6	1144.6	1154.6	1164.6	1174.6
1184.6	1194.6	1204.6	1214.6	1224.6
1234.6	1244.6	1254.6	1264.6	1274.6
1284.6	1294.6	1304.6	1314.6	1324.6
1334.6	1344.6	1354.6	1364.6	1374.6
1384.6	1394.6	1404.6	1414.6	1424.6
1434.6	1444.6	1454.6	1464.6	1474.6
1484.6	1494.6	1504.6	1514.6	1524.6
1534.6	1544.6	1554.6	1564.6	1574.6
1584.6	1594.6	1604.6	1614.6	1624.6
1634.6	1644.6	1654.6	1664.6	1674.6
1684.6	1694.6	1704.6	1714.6	1724.6
1734.6	1744.6	1754.6	1764.6	1774.6
1784.6	1794.6	1804.6	1814.6	1824.6
1834.6	1844.6	1854.6	1864.6	1874.6
1884.6	1894.6	1904.6	1914.6	1924.6
1934.6	1944.6	1954.6	1964.6	1974.6
1984.6	1994.6	2004.6	2014.6	2024.6
2034.6	2044.6	2054.6	2064.6	2074.6
2084.6	2094.6	2104.6	2114.6	2124.6
2134.6	2144.6	2154.6	2164.6	2174.6
2184.6	2194.6	2204.6	2214.6	2224.6
2234.6	227.6	2254.6	2264.6	2274.6
2284.6	2294.6	2304.6	2314.6	2324.6
2334.6	2344.6	2354.6	2364.6	2374.6
2384.6	2394.6	2404.6	2414.6	2424.6
2434.6	2444.6	2454.6	2464.6	2474.6
3600.0				

mass =	0.0	0.0	19.2	13.5	13.6
	14.5	15.0	15.5	15.8	16.0
	16.2	16.3	16.4	16.4	16.3
	16.2	16.1	15.9	15.6	15.4
	15.1	14.8	14.4	14.2	14.1
	14.1	14.1	14.1	14.1	14.1
	14.1	14.1	14.1	14.0	14.0
	13.9	13.9	13.8	13.7	13.6
	13.5	13.4	13.2	13.1	13.0
	12.8	12.6	12.4	12.2	12.0
	11.8	11.6	11.4	11.2	11.0
	13.4	13.4	13.3	13.2	13.2
	13.1	13.1	13.0	13.0	13.0
	12.9	12.9	12.9	12.9	12.9
	12.9	13.0	13.0	13.0	13.0
	13.0	13.0	12.9	12.9	12.9
	12.9	12.8	12.8	12.8	12.7
	12.7	12.6	12.6	12.5	12.4
	12.4	12.3	12.2	12.2	12.1

12.0	11.9	11.8	11.7	11.6
11.5	11.4	11.2	11.1	11.0
10.9	10.8	10.7	10.5	10.4
10.2	10.1	9.9	9.8	9.6
9.5	9.4	9.2	9.1	9.0
8.8	8.7	10.2	10.0	9.9
9.8	9.7	9.5	9.4	9.3
9.1	9.0	8.9	8.7	8.6
8.5	8.4	8.3	8.1	8.0
7.9	7.8	7.7	7.6	7.4
7.3	7.2	7.1	7.0	6.9
6.8	6.7	6.6	6.4	6.3
6.2	6.1	6.0	5.9	5.8
5.7	5.6	5.5	5.4	5.3
5.3	5.2	5.1	5.0	4.9
4.8	4.8	4.7	4.6	4.5
4.4	4.4	4.3	4.2	4.1
4.1	4.0	3.9	3.6	3.8
3.7	3.1	3.6	3.5	3.6
3.4	3.4	3.3	3.3	3.2
3.0	3.1	3.1	3.1	3.0
2.9	2.8	2.8	2.8	2.7
2.7	2.6	2.6	2.5	2.5
2.5	2.4	2.4	2.3	2.3
2.3	2.3	2.2	2.2	2.1
1.8	2.3	1.9	1.9	1.9
1.9	1.8	1.8	1.7	1.7
1.7	1.6	1.7	1.7	1.6
1.6	1.6	1.6	1.5	1.5
1.5	1.5	1.4	1.4	1.4
1.4	1.4	1.5	1.2	1.5
1.2	1.5	1.5	1.0	1.2
1.3	1.4	1.2	1.1	1.9
1.1	1.2	1.0	1.0	1.2
0.9	1.1	1.1	1.1	1.0
1.0	1.1	1.0	1.1	0.7
0.9	1.0	1.0	0.9	1.0
0.9	1.4	0.8	0.7	0.9
0.8	0.7	0.9	0.7	0.9
0.9	1.0	0.9	1.3	1.4
1.4	1.6	1.7	1.7	1.9
1.4				

enth =	2547525.0	2676858.0	2743692.0	2721457.0	2721903.0
	2725257.0	2727124.0	2728585.0	2729715.0	2730415.0
	2730991.0	2731295.0	2731393.0	2731300.0	2731032.0
	2730608.0	2730032.0	2729329.0	2728508.0	2727532.0
	2726418.0	2725173.0	2723830.0	2722999.0	2722596.0
	2722498.0	2722444.0	2722376.0	2722273.0	2722136.0
	2721951.0	2721715.0	2721440.0	2721126.0	2720809.0
	2720451.0	2720049.0	2719602.0	2719108.0	2718568.0
	2717978.0	2717336.0	2716676.0	2715980.0	2715232.0
	2714424.0	2713650.0	2712922.0	2712152.0	2711328.0
	2710574.0	2709844.0	2709082.0	2708336.0	2707539.0
	2714981.0	2714577.0	2714174.0	2713833.0	2713526.0
	2713227.0	2712942.0	2712674.0	2712426.0	2712206.0
	2712017.0	2711858.0	2711703.0	2711617.0	2711512.0
	2711454.0	2711410.0	2711360.0	2711297.0	2711218.0
	2711124.0	2711017.0	2710900.0	2710774.0	2710639.0
	2710451.0	2710330.0	2710148.0	2709949.0	2709745.0
	2709530.0	2709311.0	2709074.0	2708827.0	2708564.0
	2708288.0	2708009.0	2707734.0	2707472.0	2707169.0
	2706879.0	2706571.0	2706068.0	2705706.0	2705331.0
	2705002.0	2704693.0	2704008.0	2703482.0	2702766.0
	2702477.0	2701920.0	2701764.0	2701302.0	2700726.0
	2700129.0	2699540.0	2698924.0	2698352.0	2697784.0
	2697462.0	2696954.0	2696476.0	2696020.0	2695566.0
	2695106.0	2694663.0	2694178.0	2693796.0	2693431.0

```

2697064.0 2696676.0 2696284.0 2695914.0 2695760.0
2695104.0 2694942.0 2694585.0 2694340.0 2694098.0
2693870.0 2693547.0 2693442.0 2693237.0 2693034.0
2692870.0 2692692.0 2692533.0 2692313.0 2692100.0
2691905.0 2691730.0 2691572.0 2691397.0 2691282.0
2691191.0 2691124.0 2691076.0 2691066.0 2691104.0
2691158.0 2691247.0 2691280.0 2691437.0 2691640.0
2691898.0 2692194.0 2692541.0 2692938.0 2693398.0
2693789.0 2694269.0 2694767.0 2695322.0 2695928.0
2696622.0 2697371.0 2698220.0 2699120.0 2700212.0
2701344.0 2702611.0 2704848.0 2705405.0 2705859.0
2708701.0 2710116.0 2708931.0 2710256.0 2713141.0
2712044.0 2708803.0 2712948.0 2715801.0 2720412.0
2720611.0 2722590.0 2720473.0 2722578.0 2722698.0
2723385.0 2723462.0 2723672.0 2724362.0 2725252.0
2726813.0 2726945.0 2726110.0 2726871.0 2727242.0
2727539.0 2727832.0 2728090.0 2728359.0 2728572.0
2728786.0 2729054.0 2729182.0 2729510.0 2729654.0
2731041.0 2729509.0 2729559.0 2730712.0 2730834.0
2729684.0 2727474.0 2735914.0 2734277.0 2734103.0
2734077.0 2733836.0 2733468.0 2733969.0 2732331.0
2731103.0 2732778.0 2731183.0 2730996.0 2732334.0
2732176.0 2732219.0 2732254.0 2732219.0 2732064.0
2731793.0 2731482.0 2731233.0 2731101.0 2731095.0
2731125.0 2731087.0 2713090.0 2724582.0 2707130.0
2720626.0 2707452.0 2716646.0 2731465.0 2717582.0
2707785.0 2708294.0 2715388.0 2712087.0 2708559.0
271770.0 2704618.0 2717096.0 2710193.0 2705517.0
2709296.0 2705628.0 2702882.0 2712806.0 2708881.0
2712098.0 2704066.0 2701733.0 2696203.0 2706609.0
2705730.0 2701440.0 2701676.0 2698232.0 2696337.0
2694984.0 2696794.0 2709314.0 2707635.0 2704769.0
2705347.0 2706318.0 2700150.0 2706632.0 2699273.0
2704890.0 2706400.0 2709671.0 2715150.0 2719166.0
2724875.0 2725396.0 2729803.0 2725863.0 2724320.0
2724320.0

```

```

eoi
&&
struc
  name = Ceiling      && Name of structure
  type = roof         && Type of structure
  shape = slab        && Shape of structure
  nslab = 10          && Number of nodes in structure
  chrlen = 17.7       && Characteristic length of structure (m)
  slarea = 86.4       && Area (m2)
  tunif = 305.        && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .067 .103 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi

&&
  name = Walls        && Name of structure
  type = wall         && Type of structure
  shape = slab        && Shape of structure
  nslab = 10          && Number of nodes in structure
  chrlen = 5.49       && Characteristic length of structure (m)
  slarea = 254.       && Area (m2)
  tunif = 305.        && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 .396 && (m)
eoi

&&
condense
ht-tran on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell

```

```

geometry= 86.4      && Area of layers in lower cell      (m2)
bc = 305.          && Basemat boundary condition temperature (K)
concrete
  compos = 1       && Number of materials
                conc && Material
                19000. && Mass of material              (kg)
  temp = 305.     && Initial temperature              (K)
eoi
pool
  temp = 305.     && Initial temperature
eoi
eoi
&&
&& Engineered safety systems
&&
engineer spill 1 2 3 0.0
overflow 2 3 3.0
eoi
&&
&& ----- Cell 3, Room 115 -----
cell 3
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eoi
title
  Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height      (m3, m)
atmos = 3
      1.01e5      && Pressure
      305.        && Temperature
o2 = 0.20
n2 = 0.75
h2ov = 0.05
struc
  name = Ceiling && Name of structure
  type = roof    && Type of structure
  shape = slab   && Shape of structure
  nslab = 10     % Number of nodes in structure
  chrlen = 14.6  && Characteristic length of structure (m)
  slarea = 107.  && Area (m2)
  tunif = 305.  && Initial uniform temperature (K)
compound= conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
  name = Walls && Name of structure
  type = wall
  shape = slab
  nslab = 10
  chrlen = 5.49
  slarea = 241.
  tunif = 305.
compound= conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
&&
low-cell
  geometry= 107.  && Area of layers in lower cell      (m2)
  bc = 305.      && Basemat boundary condition temperature (K)

```



```

concrete
  compos = 1      && Number of materials
              conc && Material
              23500. && Mass of material
  temp = 305.    && Initial temperature
eol
pool
  temp = 305.    && Initial temperature
eol

eol
&&
&& Engineered safety systems
&&
engineer  Spill 1 3 2 0.
         overflow 3 2 3.05
eol
&&
&& ----- Cell 4, Room 236 -----
cell 4
control
  nhtm=1 mxslab=11 nsoatm=2 nspatm=000 jconc=1 jpool=1 naensy=2
  nsoeng=1 nspeng=4
eol
title
  Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height (m3, m)
  atmos = 3
          1.01e5      && Pressure
          305.        && Temperature
  o2 = 0.25
  n2 = 0.75
  h2ov = 0.05
&&
struc
  name = Walls      && Name of structure
  type = wall       && Type of structure
  shape = slab      && Shape of structure
  nslab = 10        && Number of nodes in structure
  chrlen = 5.49     && Characteristic length of structure (m)
  slarea = 450.     && Area (m2)
  tunif = 305.     && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .015 .030 .045 .060 .075 .090 .105 .120 .135 .152
eol

&&
condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
  geometry= 91.9     && Area of layers in lower cell (m2)
  bc = 305.         && Basement boundary condition temperature (K)
  concrete
    compos = 1      && Number of materials
                conc && Material
                6700. && Mass of material
    temp = 305.    && Initial temperature
  eol
  pool
    temp = 305.    && Initial temperature
  eol
eol
&&

```

```

&& Engineered safety systems
&&
&& Spillage from Room 236 to Room 115 via the collecting pipe chase
&&
engineer Spill 1 4 3 5.79
overflow 4 3 0.025
eoi
&&
&& Fire water sprinkler system, activated on high temperature.
&&
engineer Sprinklr 2 4 4 0.
spray
  spdiam = .001  && Spray droplet diameter          (m)
  sphite = 5.49  && Spray fall height                (m)
  spsttm = 373.  && Temperature at which system activates (K)
eoi
source = 1      && Sprays provide 336 gpm (21.1 kg/s) after
h2o1 = 3        && activation
iflag = 2
t = 0.0 100. 1.00e5
mass = 21.1 21.1 21.1
temp = 305. 305. 305.
eoi
eoi
&&
&& ----- Cell 5, Balance of Plant -----
cell 5
control
eoi
title
  Balance of Plant
geometry 1.87e5 38.0
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05
&&
&& ----- Cell 6, Environment -----
cell 6
control
eoi
title
  Environment Cell
geometry 1.e10 1.e30
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05
eof

```

## LISTING 9 - CONTAIN Input for BS-4

```

&& ===== Model Description =====
&&
&& File:
&&
&&   cnt004.mdl
&&
&& Description:
&&
&&   BS-4. This input deck describes a five volume model of the B&W Plant
&&   auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 10 inch break in the decay heat removal
&&   heat exchangers located in room 113. This model does not include
&&   water aerosols (the dropout option is used).
&&
&& Written by:
&&
&&   John Schroeder 6/91
&&
&& ===== Machine Control Input =====
cray
eol
&& ===== Global Input =====
&&
&& Section 3.2, p. 3-11
&&
&&   Atmospheric Gases
&&
&&   Material      Description
&&   -----      -
&&   o2            oxygen
&&   n2            nitrogen
&&   h2ov          steam
&&   h2ol          water
&&
control
  ncell = 6      && Number of cells
  ntit  = 2      && Number of title lines
  ntzone = 5     && Number of time zones
  nac   = 0      && Number of aerosol groups
  nsectn = 0     && Number of aerosol sections
eol
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
material
  compound
    n2 o2          && Air
    h2ov h2ol      && Steam and water
    conc          && Structural materials
&&
&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17
&&
thermal          && Water-cooled reactor
&&
&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
flows
&&

```

```

&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&&      1, 2, 3.
&&
&&      area(1,5) = 8.88    && Cross-sectional area of flow path      (m2)
&&      avl(1,5)  = 14.6    && Ratio of area to inertial length, A/L      (m)
&&      cfc(1,5)  = 1.00    && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path
&&
&&      area(1,2) = 12.6
&&      avl(1,2)  = 20.7
&&      cfc(1,2)  = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&&      area(2,5) = 0.892
&&      avl(2,5)  = 1.46
&&      cfc(2,5)  = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&&      area(2,3) = 1.95
&&      avl(2,3)  = 3.2
&&      cfc(2,3)  = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&&      area(3,5) = 1.95
&&      avl(3,5)  = 3.2
&&      cfc(3,5)  = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&&      area(3,4) = 2.97
&&      avl(3,4)  = 4.88
&&      cfc(3,4)  = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&      10, 11, 12, and 13.
&&
&&      area(4,5) = 20.1
&&      avl(4,5)  = 157.
&&      cfc(4,5)  = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&      paths.
&&
&&      area(5,6) = 46.5
&&      avl(5,6)  = 250.
&&      cfc(5,6)  = 1.00
&&
&&      implicit
&&      dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments
&&
&&      elevcl(1) = 169.    && Center of mass elevation for Rm 105      (m)
&&      elevcl(2) = 169.    && Center of mass elevation for Rm 113      (m)
&&      elevcl(3) = 169.    && Center of mass elevation for Rm 115      (m)
&&      elevcl(4) = 175.    && Center of mass elevation for Rm 236      (m)
&&      elevcl(5) = 185.    && Center of mass elevation for Rm BOP      (m)
&&      elevcl(6) = 185.    && Center of mass elevation for Environment (m)
&&
&& Junctions
&&
&&      elevfp(1,5) = 167.

```

```

elevfp(5,1)= 167.
elevfp(1,2)= 170.
elevfp(2,1)= 170.

elevfp(2,5)= 172.
elevfp(5,2)= 172.

elevfp(2,3)= 170.
elevfp(3,2)= 170.

elevfp(3,5)= 170.
elevfp(5,3)= 170.

elevfp(3,4)= 172
elevfp(4,3)= 172.

elevfp(4,5)= 173.
elevfp(5,4)= 173.

elevfp(5,6)= 211.
elevfp(6,5)= 211.

&&
&& ----- Aerosol Options -----
&&
&& Section 3.2.4, p. 3-29
&&
&& aerosol
&&   h2ov 1.0e-8 0.693
&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
  30.          && Maximum CPU time limit          (s)
   0.          && Problem start time                    (s)
&&
&& Time zone data
&&
&& System  Edit  End of
&&   Ts     Ts   Zone
&& -----
&&          10.  10.
&&          50.  100.
&&         200.  500.
&&         100. 1000.
&&         100. 13000.
&&
&& -----
&& eoi
&&
&& ----- Output Control -----
&&
&& Section 3.2.7, p. 3-38
&&
shortedt   = 2      && System ts between short edits
longedt    = 1      && Ts edits between long edits
prflow     && Print intercell flow data
praer      && detailed aerosol inventories
prlow-cl   && lower cell model
prheat     && heat transfer structure model
prengsys   && engineered system model
title      &&
&&
&& B&W Plant Auxilliary Building Steam Propagation Model
&& Five Compartment Model -- 85-4
&&
&&
&& ===== Cell Input and Cell Control =====

```

```

&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=2 mxslab=1 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eoi
title
  Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e3 5.49 && Cell volume and height (m3, m)
  atwor = 3 && Number of materials
        1.01e5 && Pressure (Pa)
        305. && Temperature (K)
  n2 = 0.75 && Initial nitrogen fraction
  o2 = 0.20 && Initial oxygen fraction
  h2ov = 0.05 && Initial water vapor fraction
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 18.7 && Characteristic length of structure (m)
  slarea = 295. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .046 .092 .138 .164 .250 .276 .322 .368 .414 .457 && (m)
eoi
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 298. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eoi
&&
condense
ht-tran on on on on on
overflow 1
&&
&& Lower cell input
&&
low-cell
  geometry= 295. && Area of layers in lower cell (m2)
  bc = 305. && Basement boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
            conc && Material
            43200. && Mass of material
    temp = 305. && Initial temperature
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 1 5 .152
overflow 1 5 1.74
eoi

```

```

&& ----- Cell 2, Room 113 -----
cell 2
control
  nhtm=2 mxslat=11 nsoatm=2 nspatm=365 naensy=1 jconc=5 jpool=1
eol
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e? 6.10 && Cell volume and height (m3, m)
  atmos = 5
    1.01e5 && Pressure (Pa)
    305. && Temperature (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
source=2
&&
&& Blowdown of saturated primary system water
&&
n2ov = 361
iflag = 2
t =
  0.0 1.0 2.0 3.0 4.0
  5.0 6.0 7.0 8.0 9.0
  10.0 11.0 12.0 13.0 14.0
  15.0 25.0 35.0 45.0 55.0
  65.0 75.0 85.0 95.0 105.0
  115.0 125.0 135.0 145.0 155.0
  165.0 175.0 185.0 195.0 205.0
  215.0 225.0 235.0 245.0 255.0
  265.0 275.0 285.0 295.0 305.0
  315.0 325.0 335.0 345.0 355.0
  365.0 375.0 382.8 392.8 402.8
  412.8 422.8 432.8 442.8 452.8
  462.8 472.8 482.8 492.8 497.7
  507.7 517.7 527.7 537.7 547.7
  557.7 567.7 577.7 587.7 597.7
  607.7 617.7 627.7 637.7 647.7
  657.7 667.7 677.7 687.7 697.7
  707.7 717.7 727.7 737.7 747.7
  757.7 767.7 777.7 787.7 797.7
  807.7 817.7 827.7 837.7 847.7
  857.7 867.7 877.7 887.7 897.7
  907.7 917.7 927.7 937.7 947.7
  957.7 967.7 977.7 987.7 993.5
  1000.0 1010.0 1020.0 1030.0 1040.0
  1050.0 1060.0 1070.0 1080.0 1090.0
  1100.0 1110.0 1120.0 1130.0 1140.0
  1150.0 1160.0 1170.0 1180.0 1190.0
  1200.0 1210.0 1220.0 1230.0 1240.0
  1250.0 1260.0 1270.0 1280.0 1290.0
  1300.0 1310.0 1320.0 1330.0 1340.0
  1350.0 1360.0 1370.0 1380.0 1390.0
  1400.0 1410.0 1420.0 1430.0 1440.0
  1450.0 1460.0 1470.0 1480.0 1490.0
  1500.0 1510.0 1520.0 1530.0 1540.0
  1550.0 1560.0 1570.0 1580.0 1590.0
  1600.0 1610.0 1620.0 1630.0 1640.0
  1650.0 1660.0 1670.0 1680.0 1690.0
  1700.0 1710.0 1720.0 1730.0 1740.0
  1750.0 1760.0 1770.0 1780.0 1790.0
  1800.0 1810.0 1820.0 1830.0 1840.0
  1850.0 1860.0 1870.0 1880.0 1890.0
  1900.0 1910.0 1920.0 1930.0 1940.0
  1950.0 1960.0 1970.0 1980.0 1990.0

```

2000.0	2010.0	2020.0	2030.0	2040.0
2050.0	2060.0	2070.0	2080.0	2090.0
2100.0	2110.0	2120.0	2130.0	2140.0
2150.0	2160.0	2170.0	2180.0	2190.0
2200.0	2210.0	2220.0	2230.0	2240.0
2250.0	2260.0	2270.0	2280.0	2290.0
2300.0	2310.0	2320.0	2330.0	2340.0
2350.0	2360.0	2370.0	2380.0	2390.0
2400.0	2410.0	2420.0	2430.0	2440.0
2450.0	2460.0	2470.0	2480.0	2490.0
2500.0	2510.0	2520.0	2530.0	2540.0
2550.0	2560.0	2570.0	2580.0	2590.0
2600.0	2610.0	2620.0	2630.0	2640.0
2650.0	2660.0	2670.0	2680.0	2690.0
2700.0	2710.0	2720.0	2730.0	2740.0
2750.0	2760.0	2770.0	2780.0	2790.0
2800.0	2810.0	2820.0	2830.0	2840.0
2850.0	2860.0	2870.0	2880.0	2890.0
2900.0	2910.0	2920.0	2930.0	2940.0
2950.0	2960.0	2970.0	2980.0	2990.0
3000.0	3010.0	3020.0	3030.0	3040.0
3050.0	3060.0	3070.0	3080.0	3090.0
3100.0	3110.0	3120.0	3130.0	3140.0
3150.0	3160.0	3170.0	3180.0	3190.0
3200.0	3210.0	3220.0	3230.0	3240.0
3250.0	3260.0	3270.0	3280.0	3290.0
3300.0	3310.0	3320.0	3330.0	3340.0
3350.0	3360.0	3370.0	3380.0	3390.0
3400.0	3410.0	3420.0	3430.0	3440.0
3444.0				

mass =	0.0	2400.9	1795.8	852.8	858.3
	867.9	878.3	887.5	894.6	899.2
	901.0	900.1	896.8	891.6	884.5
	876.0	833.9	798.1	753.4	645.9
	586.4	631.6	508.1	378.6	337.1
	228.8	316.4	258.1	207.6	161.9
	18.7	94.8	70.8	47.6	35.6
	27.7	22.2	18.3	15.4	13.3
	11.9	10.6	9.6	8.7	8.1
	7.5	7.1	6.7	6.5	6.3
	6.2	6.1	6.1	6.1	6.2
	6.3	6.4	6.6	6.8	7.1
	7.4	20.8	25.0	23.1	29.0
	29.1	33.8	31.4	36.5	37.3
	38.2	41.1	42.7	43.8	45.2
	47.1	48.8	50.5	52.3	53.8
	55.0	56.4	57.4	58.5	59.5
	60.3	61.1	61.9	62.3	61.7
	57.0	51.1	45.7	41.0	40.3
	44.1	48.1	49.9	49.9	52.2
	55.5	58.7	61.2	63.0	64.1
	64.5	64.6	66.2	69.0	73.2
	75.1	74.2	29.3	45.3	45.1
	223.7	23.1	290.3	10.5	25.7
	59.5	36.2	172.3	8.6	6.4
	28.3	78.8	189.7	80.3	150.0
	153.0	64.6	14.5	87.1	67.1
	141.1	72.1	126.9	386.7	276.3
	365.1	344.1	409.0	384.5	399.4
	404.7	404.3	416.8	402.1	403.1
	418.2	395.8	403.5	409.9	409.9
	407.9	407.3	412.9	402.8	412.1
	411.0	329.6	406.3	411.7	411.5
	413.6	413.5	411.6	413.6	412.4
	414.1	412.4	418.2	415.0	416.2
	418.8	413.3	420.8	414.3	412.1
	403.3	419.4	415.6	417.0	420.5



419.7	422.3	419.0	417.9	419.0
418.6	419.4	420.8	419.8	420.0
417.4	423.7	420.7	419.2	419.5
420.8	417.9	425.6	411.2	420.7
421.5	424.7	422.4	425.2	417.8
421.3	419.1	422.9	425.6	420.2
418.5	424.2	422.5	422.5	417.4
428.2	424.2	420.8	424.8	423.9
425.5	423.7	424.1	423.1	425.2
417.6	426.1	426.0	427.4	423.1
425.2	415.4	421.2	423.8	424.1
422.3	427.0	426.2	425.5	427.0
423.8	427.6	426.1	420.7	425.5
428.4	427.7	417.7	425.4	417.7
426.5	428.8	427.8	424.1	421.4
425.3	423.9	426.0	421.2	426.3
425.9	425.8	421.1	422.9	425.5
426.2	425.1	420.5	427.8	425.6
421.6	425.8	426.9	425.2	427.5
427.8	426.0	424.5	426.6	427.3
429.1	426.1	426.7	424.1	423.7
425.3	426.3	425.9	426.6	427.0
426.0	426.0	426.5	427.7	427.0
426.3	417.6	426.0	424.3	425.2
428.1	421.2	426.0	423.2	425.0
427.1	424.8	428.1	414.1	421.1
426.8	426.2	421.3	424.3	423.8
421.4	425.4	422.6	425.9	423.7
425.2	419.5	425.8	427.0	424.7
427.0	428.5	426.6	426.7	426.7
426.6	428.1	424.0	426.5	426.2
425.1	426.4	422.3	423.8	417.2
425.5	427.1	417.7	426.0	428.2
422.5	424.5	427.7	423.1	426.0
423.4	423.7	426.7	425.1	426.4
426.0				

enth =	158119.7	159940.5	1149073.0	1196146.0	1197744.0
	1200599.0	1203784.0	1206669.0	1208980.0	1210529.0
	1211204.0	1210940.0	1209931.0	1208330.0	1206208.0
	1203732.0	1193696.0	1187646.0	1179592.0	1118249.0
	1098122.0	1148469.0	1170119.0	1175558.0	1074509.0
	1042971.0	1061448.0	1038122.0	1013479.0	987731.6
	963405.7	941195.8	921489.1	903148.1	886067.9
	870344.2	855714.1	842109.6	829451.8	817508.1
	805975.7	795139.2	784777.9	774890.1	765441.1
	756320.7	747493.5	738975.9	730759.2	722844.2
	715226.9	707883.0	702302.2	695412.3	688891.4
	682787.6	677190.7	672051.5	667327.3	662980.5
	658950.4	649344.8	654414.2	650910.6	657595.5
	657522.9	662380.2	658880.6	664424.5	664785.4
	665867.8	668383.5	669768.4	670583.0	671659.8
	673122.8	674222.0	675430.8	676722.2	67792.7
	678514.2	679417.2	679999.6	680608.0	681130.4
	681435.1	681691.7	681651.9	681778.8	680592.1
	674782.5	666972.2	658911.1	649648.9	645002.0
	646580.4	648774.4	647686.9	644494.2	644701.8
	646726.4	648724.3	649993.4	650362.5	649831.0
	648366.6	646659.9	646774.2	648275.9	650953.1
	652826.6	655765.0	592682.9	598766.9	593585.8
	567223.9	570355.0	585558.2	614321.5	539718.6
	601192.6	597851.7	546948.5	572213.8	597235.9
	584162.2	598062.1	581966.1	596423.4	596189.9
	602085.1	598207.8	595952.1	596077.9	596189.5
	590186.2	588352.4	420003.8	570783.7	552039.4
	549792.3	545060.8	540088.3	535239.9	530094.5
	524456.9	518517.2	511716.6	508206.8	502604.6
	497046.0	491163.7	485556.3	479697.9	474216.6

468319.9	462816.5	457035.6	451361.8	445875.5
440640.6	433755.7	429288.6	423932.2	418533.1
411147.2	407828.2	402980.9	397114.7	405840.7
387761.3	387171.6	361200.9	373139.5	364667.3
345090.7	372471.8	324835.5	350704.1	355836.8
338760.2	340918.5	294192.8	335888.4	341130.2
301957.3	239182.0	298674.4	320222.8	326511.4
300836.9	285529.1	299765.4	293134.8	310318.4
292353.2	286335.5	293988.8	266926.6	313583.2
253159.5	288213.8	251325.9	245431.6	308942.8
270734.7	256135.9	275098.3	250019.7	252025.9
214782.7	318806.5	237763.5	239555.4	235444.8
348079.6	226885.9	244002.6	264313.2	213269.9
140767.7	204349.1	225517.4	254998.4	223122.1
233729.8	229030.1	198064.7	235995.4	204547.2
229826.8	269524.8	189354.1	164797.8	264127.9
209705.8	307274.0	265882.8	241938.3	228125.8
241499.0	174663.0	183645.6	207617.2	162024.7
156858.6	210005.1	198855.7	251549.2	210441.9
71926.2	136117.0	323067.8	218240.2	272234.5
179677.6	132219.7	130824.2	228835.7	266675.5
178645.8	228047.0	184180.0	185855.0	144537.0
184345.0	191200.1	238823.1	244096.8	202703.4
171678.0	199983.3	203701.8	109655.6	75879.9
213093.9	195335.6	173736.2	210305.3	148084.3
132247.9	189820.3	183900.3	214575.9	155154.3
177773.7	194552.1	166820.1	204808.9	206734.8
168832.9	173595.3	191519.0	167682.0	155401.9
190639.2	191949.5	172974.5	144767.7	158155.9
183463.7	315483.8	184298.9	214395.1	153411.2
121167.6	268270.8	188005.1	233527.8	212178.5
156741.5	215305.7	128521.5	333436.1	267925.5
137849.9	179222.9	266782.6	223382.1	213497.1
219283.8	194644.6	241268.9	171866.1	190489.0
203040.8	283064.4	108594.5	164981.6	210411.3
160033.1	85402.5	172830.2	170064.0	171093.8
156757.4	107313.2	225335.7	173815.0	183069.2
203724.0	175712.8	211125.3	226096.8	313536.6
195856.8	68646.1	250831.0	185159.2	102833.9
195688.5	267347.4	138103.1	238664.8	186352.8
205391.3	207035.7	171595.6	204985.7	174484.8
173873.8				

eor

&&

&& Blowdown of primary system steam

&&

h2ov = 361

iflag = 2

t	=	0.0	1.0	2.0	3.0	4.0
		5.0	6.0	7.0	8.0	9.0
		10.0	11.0	12.0	13.0	14.0
		15.0	25.0	35.0	45.0	55.0
		65.0	75.0	85.0	95.0	105.0
		115.0	125.0	135.0	145.0	155.0
		165.0	175.0	185.0	195.0	205.0
		215.0	225.0	235.0	245.0	255.0
		265.0	275.0	285.0	295.0	305.0
		315.0	325.0	335.0	345.0	355.0
		365.0	375.0	382.8	392.8	402.8
		412.8	422.8	432.8	442.8	452.8
		462.8	472.8	482.8	492.8	497.7
		507.7	517.7	527.7	537.7	547.7
		557.7	567.7	577.7	587.7	597.7
		607.7	617.7	627.7	637.7	647.7
		657.7	667.7	677.7	687.7	697.7
		707.7	717.7	727.7	737.7	747.7
		757.7	767.7	777.7	787.7	797.7
		807.7	817.7	827.7	837.7	847.7

857.7	867.7	877.7	887.7	897.7
907.7	917.7	927.7	937.7	947.7
957.7	967.7	977.7	987.7	993.5
1000.0	1010.0	1020.0	1030.0	1040.0
1050.0	1060.0	1070.0	1080.0	1090.0
1100.0	1110.0	1120.0	1130.0	1140.0
1150.0	1160.0	1170.0	1180.0	1190.0
1200.0	1210.0	1220.0	1230.0	1240.0
1250.0	1260.0	1270.0	1280.0	1290.0
1300.0	1310.0	1320.0	1330.0	1340.0
1350.0	1360.0	1370.0	1380.0	1390.0
1400.0	1410.0	1420.0	1430.0	1440.0
1450.0	1460.0	1470.0	1480.0	1490.0
1500.0	1510.0	1520.0	1530.0	1540.0
1550.0	1560.0	1570.0	1580.0	1590.0
1600.0	1610.0	1620.0	1630.0	1640.0
1650.0	1660.0	1670.0	1680.0	1690.0
1700.0	1710.0	1720.0	1730.0	1740.0
1750.0	1760.0	1770.0	1780.0	1790.0
1800.0	1810.0	1820.0	1830.0	1840.0
1850.0	1860.0	1870.0	1880.0	1890.0
1900.0	1910.0	1920.0	1930.0	1940.0
1950.0	1960.0	1970.0	1980.0	1990.0
2000.0	2010.0	2020.0	2030.0	2040.0
2050.0	2060.0	2070.0	2080.0	2090.0
2100.0	2110.0	2120.0	2130.0	2140.0
2150.0	2160.0	2170.0	2180.0	2190.0
2200.0	2210.0	2220.0	2230.0	2240.0
2250.0	2260.0	2270.0	2280.0	2290.0
2300.0	2310.0	2320.0	2330.0	2340.0
2350.0	2360.0	2370.0	2380.0	2390.0
2400.0	2410.0	2420.0	2430.0	2440.0
2450.0	2460.0	2470.0	2480.0	2490.0
2500.0	2510.0	2520.0	2530.0	2540.0
2550.0	2560.0	2570.0	2580.0	2590.0
2600.0	2610.0	2620.0	2630.0	2640.0
2650.0	2660.0	2670.0	2680.0	2690.0
2700.0	2710.0	2720.0	2730.0	2740.0
2750.0	2760.0	2770.0	2780.0	2790.0
2800.0	2810.0	2820.0	2830.0	2840.0
2850.0	2860.0	2870.0	2880.0	2890.0
2900.0	2910.0	2920.0	2930.0	2940.0
2950.0	2960.0	2970.0	2980.0	2990.0
3000.0	3010.0	3020.0	3030.0	3040.0
3050.0	3060.0	3070.0	3080.0	3090.0
3100.0	3110.0	3120.0	3130.0	3140.0
3150.0	3160.0	3170.0	3180.0	3190.0
3200.0	3210.0	3220.0	3230.0	3240.0
3250.0	3260.0	3270.0	3280.0	3290.0
3300.0	3310.0	3320.0	3330.0	3340.0
3350.0	3360.0	3370.0	3380.0	3390.0
3400.0	3410.0	3420.0	3430.0	3440.0
3444.0				

mass =	0.0	0.0	20.7	151.3	151.1
	151.2	151.3	151.3	151.3	151.3
	151.3	151.4	151.6	151.9	152.1
	152.3	154.8	159.5	165.0	157.8
	164.4	183.1	166.8	189.5	202.0
	188.6	185.5	183.4	178.9	172.4
	159.8	150.8	142.4	134.1	126.6
	119.3	112.2	105.6	99.3	93.7
	88.5	83.8	79.5	75.6	72.0
	68.7	65.7	62.9	60.4	58.0
	55.8	53.7	52.2	50.4	48.7
	47.1	45.6	44.5	43.4	42.3
	41.4	37.2	36.0	36.1	34.6
	34.5	33.3	33.6	32.4	32.0



2776362.0	2773889.0	2771476.0	2769245.0	2767068.0
2764930.0	2762840.0	2760824.0	2758956.0	2757234.0
2755628.0	2754083.0	2752994.0	2751653.0	2750380.0
2749182.0	2748085.0	2747075.0	2746148.0	2745296.0
2744400.0	2748807.0	2750224.0	2749335.0	2751086.0
2751070.0	2752346.0	2751433.0	2752895.0	2753005.0
2753290.0	2753947.0	2754319.0	2754542.0	2754823.0
2755204.0	2755510.0	2755820.0	2756163.0	2756446.0
2756628.0	2756879.0	2757037.0	2757196.0	2757338.0
2757446.0	2757479.0	2757548.0	2757533.0	2757218.0
2755716.0	2753698.0	2751616.0	2749228.0	2748062.0
2748516.0	2749121.0	2748866.0	2748067.0	2748153.0
2748705.0	2749242.0	2749586.0	2749696.0	2749571.0
2749204.0	2748777.0	2748823.0	2749232.0	2749942.0
2750416.0	2751354.0	2732419.0	2727607.0	2734098.0
2763592.0	2691029.0	2742713.0	2737747.0	2717149.0
2725838.0	2734611.0	2714874.0	2757554.0	2749563.0
2764313.0	2742226.0	2746332.0	2737528.0	2734979.0
2733536.0	2741034.0	2782116.0	2774922.0	2730948.0
2711929.0	2729599.0	2755906.0	2728360.0	2696576.0
2717914.0	2720170.0	271190.0	2716209.0	2705809.0
2750050.0	2711621.0	2708299.0	2711853.0	2699404.0
2706848.0	2701470.0	2699525.0	2698382.0	2695769.0
2693572.0	2691375.0	2722910.0	2686803.0	2685663.0
2684226.0	2654062.0	2676506.0	2677629.0	2676575.0
2676550.0	2669325.0	2677034.0	2681659.0	2675723.0
2673636.0	2656123.0	2679910.0	2691487.0	2660805.0
2676506.0	2676656.0	2637265.0	2665955.0	2674022.0
2730987.0	2717096.0	2701628.0	2676592.0	2669910.0
2677334.0	2676578.0	2676594.0	2667681.0	2676549.0
2675879.0	2676659.0	2655718.0	2675664.0	2676602.0
2724700.0	2707120.0	2660317.0	2676666.0	2659821.0
2719000.0	2725855.0	2631458.0	2677925.0	2673642.0
2676597.0	2637036.0	2676633.0	2669027.0	2693838.0
2676775.0	2676587.0	2676527.0	2638242.0	2672320.0
2669761.0	2673232.0	2674432.0	2676578.0	2685808.0
2676528.0	2665899.0	2724844.0	2671973.0	2688857.0
2665858.0	2676381.0	2675882.0	2732469.0	2679861.0
2676786.0	2671435.0	2675984.0	2643804.0	2676592.0
2674307.0	2676700.0	2668176.0	2688464.0	2679065.0
2709532.0	2648346.0	2679904.0	2676596.0	2676420.0
2676410.0	2671401.0	2676428.0	2676197.0	2670914.0
2676476.0	2676530.0	2676580.0	2676516.0	2696390.0
2676578.0	2676436.0	2676497.0	2676176.0	2673885.0
2684536.0	2677129.0	2675134.0	2676887.0	2677626.0
2678262.0	2673512.0	2676342.0	2676532.0	2676571.0
2671593.0	2669536.0	2720130.0	2676500.0	2676404.0
2675912.0	2664673.0	2673150.0	2676544.0	2676447.0
2676520.0	2676112.0	2675633.0	2672073.0	2676503.0
2667949.0	2676379.0	2676556.0	2676515.0	2676321.0
2683896.0	2676309.0	2676352.0	2676511.0	2676507.0
2676336.0	2676445.0	2676391.0	2676434.0	2676042.0
2676276.0	2676515.0	2676518.0	2676546.0	2675674.0
2676503.0	2676520.0	2676504.0	2676437.0	2676547.0
2676174.0	2676533.0	2676436.0	2676347.0	2676431.0
2676442.0	2676509.0	2676513.0	2676547.0	2675865.0
2675894.0	2676519.0	2676470.0	2686776.0	2676240.0
2676365.0	2676364.0	2673355.0	2676354.0	2677744.0
2676408.0	2676473.0	2676073.0	2676446.0	2676384.0
2676428.0	2676480.0	2676504.0	2676428.0	2677458.0
2677393.0	2676562.0	2675955.0	2676356.0	2676487.0
2676282.0	2676364.0	2675357.0	2675978.0	2676481.0
2675048.0	2676187.0	2676395.0	2677881.0	2676548.0
2675838.0	2676187.0	2676484.0	2677189.0	2676518.0
2676104.0				

eof

&&  
struc

```

name = Ceiling      && Name of structure
type = roof        && Type of structure
shape = slab       && Shape of structure
nslab = 10         && Number of nodes in structure
chrlen = 17.7      && Characteristic length of structure (m)
slarea = 80.4      && Area (m2)
tunif = 305.       && Initial uniform temperature (K)
compound= conc ronc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
name = Walls       && Name of structure
type = wall        && Type of structure
shape = slab       && Shape of structure
nslab = 10         && Number of nodes in structure
chrlen = 5.49      && Characteristic length of structure (m)
slarea = 254.      && Area (m2)
tunit = 305.       && Initial uniform temperature (K)
compound= conc conc conc conc conc conc conc conc conc
x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 .396 && (m)
eoi
&&
condense
ht-tran on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell
geometry= 86.4      && Area of layers in lower cell (m2)
bc = 305.          && Basemat boundary condition temperature (K)
concrete
compos = 1         && Number of materials
conc && Material
19000. && Mass of material (kg)
temp = 305.        && Initial temperature (K)
eoi
pool
temp = 305.        && Initial temperature
eoi
eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 2 3 0.0
overflow 2 3 3.05
eoi
&&
&& ----- Cell 3, Room 115 -----
cell 3
control
nhtm=2 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eoi
title
Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height (m3, m)
atmos = 3
1.01e5 && Pressure
305. && Temperature
o2 = 0.20
n2 = 0.75
h2ov = 0.05
struc
name = Ceiling      && Name of structure
type = roof        && Type of structure

```

```

    shape = slab          && Shape of structure
    nslab = 10           && Number of nodes in structure
    chr len = 14.6       && Characteristic length of structure (m)
    slarea = 107.       && Area (m2)
    tunif = 305.        && Initial uniform temperature (K)
    compound= conc conc conc conc conc conc conc conc conc conc
    x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
    eoi

&&
name = Walls           && Name of structure
type = wall
shape = slab
nslab = 10
chr len = 5.49
slarea = 241.
tunif = 305.
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi

&&
condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
&&
low-cell
geometry= 107.        && Area of layers in lower cell (m2)
bc = 305.            && Basemat boundary condition temperature (K)
concrete
compos = 1          && Number of materials
conc && Material
23500. && Mass of material
temp = 305.        && Initial temperature
eoi
pool
temp = 305.        && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 3 2 0.
overflow 3 2 3.05
eoi
&&
&& ----- Cell 4, Room 236 -----
cell 4
control
nhtm=1 mxslab=11 nsoatm=2 .spatm=000 jconc=1 jpool=1 naensy=2
nsdeng=1 nspeng=4
eoi
title
Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height (m3, m)
atmos = 3
1.01e5 && Pressure
305. && Temperature
o2 = 0.25
n2 = 0.75
h2ov = 0.05
&&
struc
name = Walls        && Name of structure
type = wall         && Type of structure

```

```

shape = slab          && Shape of structure
nslab = 10           && Number of nodes in structure
chrlen = 5.49        && Characteristic length of structure (m)
slarea = 450.        && Area (m2)
tunif = 305.         && Initial uniform temperature (K)
compound= conc conc conc conc conc conc conc conc conc
x = 0. .015 .030 .045 .060 .075 .090 .105 .120 .135 .152
eoi

&&
condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
geometry= 91.9       && Area of layers in lower cell (m2)
bc = 305.           && Basemat boundary condition temperature (K)
concrete
compos = 1          && Number of materials
conc      && Material
6730.     && Mass of material
temp = 305.        && Initial temperature
eoi
pool
tamp = 305.        && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
&& Spillage from Room 236 to Room 115 via the connecting pipe chase
&&
engineer Spill 1 4 3 5.79
overflow 4 3 0.025
eoi
&&
&& Fire water sprinkler system, activated on high temperature.
&&
engineer Sprinklr 2 4 4 0.
spray
spdiam = .001      && Spray droplet diameter (m)
sphite = 5.49      && Spray fall height (m)
spsttm = 373.      && Temperature at which system activates (K)
eoi
source = 1          && Sprays provide 336 gpm (21.1 kg/s) after
h2o1 = 3            && activation
iflag = 2
t = 0.0 100. 1.00e5
mass = 21.1 21.1 21.1
temp = 305. 305. 305.
eoi
eoi
&&
&& ----- Cell 5, Balance of Plant -----
cell 5
control
eoi
title
Balance of Plant
geometry 1.87e5 38.8
atmos=3 1.01e5 305.
o2 0.20
n2 0.75
h2ov 0.05
&&
&& ----- Cell 6, Environment -----
cell 6

```



```
control
eof
title      Environment Cell
geometry 1.e10 1.e30
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05
eof
```

## LISTING 10 - CONTAIN Input for BS-5

```

&& ===== Model Description =====
&&
&& File:
&&
&&   cnt005.mdl
&&
&& Description:
&&
&&   BS-5. This input deck describes a five volume model of the B&W Plant
&&   auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 6 inch break in the HPI pump suction piping in
&&   room 115. Break flow is limited by the 2.5 inch HPI injection piping.
&&   This model does not include water aerosols (the dropout option is used).
&&
&& Written by:
&&
&&   John Schroeder 7/91
&&
&& ===== Machine Control Input =====
cray
eoi
&& ===== Global Input =====
&&
&& Section 3.2, p. 3-11
&&
&&   Atmospheric Gases
&&
&&   Material      Description
&&   -----
&&   o2             oxygen
&&   n2             nitrogen
&&   h2ov           steam
&&   h2o1           water
&&
control
  ncells = 6      && Number of cells
  ntitl  = 2      && Number of title lines
  ntzone = 5      && Number of time zones
  nac    = 0      && Number of aerosol groups
  nsectn = 0      && Number of aerosol sections
eoi
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
material
  compound
    n2 o2          && Air
    h2ov h2o1     && Steam and water
    conc          && Structural materials
&&
&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17
&&
thermal          && Water-cooled reactor
&&
&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
flows
&&

```

```

&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&&      1, 2, 3.
&&
&&      area(1,5) = 8.88      && Cross-sectional area of flow path      (m2)
&&      avl(1,5) = 14.6      && Ratio of area to inertial length, A/L      (m)
&&      cfc(1,5) = 1.00      && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&&      area(1,2) = 12.6
&&      avl(1,2) = 20.7
&&      cfc(1,2) = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&&      area(2,5) = 0.892
&&      avl(2,5) = 1.46
&&      cfc(2,5) = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&&      area(2,3) = 1.76
&&      avl(2,3) = 3.2
&&      cfc(2,3) = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&&      area(3,5) = 1.95
&&      avl(3,5) = 3.2
&&      cfc(3,5) = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&&      area(3,4) = 2.97
&&      avl(3,4) = 4.88
&&      cfc(3,4) = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&      10, 11, 12, and 13.
&&
&&      area(4,5) = 29.1
&&      avl(4,5) = 157.
&&      cfc(4,5) = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&      paths.
&&
&&      area(5,6) = 46.5
&&      avl(5,6) = 250.
&&      cfc(5,6) = 1.00
&&
&&      implicit
&&      dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments
&&
&&      elevcl(1) = 169.      && Center of mass elevation for Rm 105      (m)
&&      elevcl(2) = 169.      && Center of mass elevation for Rm 113      (m)
&&      elevcl(3) = 169.      && Center of mass elevation for Rm 115      (m)
&&      elevcl(4) = 175.      && Center of mass elevation for Rm 236      (m)
&&      elevcl(5) = 185.      && Center of mass elevation for Rm BOP      (m)
&&      elevcl(6) = 185.      && Center of mass elevation for Environment      (m)
&&
&& Junctions
&&
&&      elevfp(1,5) = 167.

```

```

elevfp(5,1)= 167.

elevfp(1,2)= 170.
elevfp(2,1)= 170.

elevfp(2,5)= 172.
elevfp(5,2)= 172.

elevfp(2,3)= 170.
elevfp(3,2)= 170.

elevfp(3,5)= 170.
elevfp(5,3)= 170.

elevfp(3,4)= 172.
elevfp(4,3)= 172.

elevfp(4,5)= 173.
elevfp(5,4)= 173.

elevfp(5,6)= 211.
elevfp(6,5)= 211.

&& ----- Aerosol Options -----
&&
&& Section 3.2.4, p. 3-29
&&
&& aerosol
&&   h2ov 1.0e-8 0.693
&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
  1800.          && Maximum CPU time limit          (s)
    0.          && Problem start time              (s)
&&
&& Time zone data
&&
&& System  Edit  End of
&&  Ts      Ts   Zone
&& -----
&&          1.   10.  10.
&&          5.   50.  100.
&&         20.  200.  500.
&&         50.  100. 1000.
&&         50.  100. 7200.
&&
&& -----
&& eoi
&&
&& ----- Output Control -----
&&
&& Section 3.2.7, p. 3-38
&&
shortedt   = 2    && System ts between short edits
longedt    = 1    && Ts edits between long edits
prflow     && Print intercell flow data
praer      && detailed aerosol inventories
prlow-cl   && lower cell model
prheat     && heat transfer structure model
prengsys   && engineered system model
title
          B&W Plant Auxilliary Building Steam Propagation Model
          Five Compartment Model -- BS-5
&&
&&
&& ===== Cell Input and Cell Control =====

```

```

&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eol
title
  Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e3 6.43 && Cell volume and height (m3, m)
  atmos = 3 && Number of materials
         1.01e5 && Pressure (Pa)
         305. && Temperature (K)
  n2 = 0.75 && Initial nitrogen fraction
  o2 = 0.20 && Initial oxygen fraction
  h2ov = 0.05 && Initial water vapor fraction
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 18.7 && Characteristic length of structure (m)
  slarea = 295. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .046 .092 .138 .184 .230 .276 .322 .368 .414 .457 && (m)
eol
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 208. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eol
&&
condense
ht-tran on on on on on
overflow 1
&&
&& Lower cell input
&&
low-cell
  geometry= 295. && Area of layers in lower cell (m2)
  t = 305. && Basement boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
            conc && Material
            43200. && Mass of material
    temp = 305. && Initial temperature
  eol
  pool
    temp = 305. && Initial temperature
  eol
eol
&&
&& Engineered safety systems
&&
engineer Spill 1 1 5 .152
  overflow 1 r 1.74
eol

```

```

&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  nntx=2 nxsxlab=11 nsoatm=0 nspuim=0 naensy=. jconc=5 jpool=1
eol
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e2 0.10 && Cell volume and height (m3, m)
  atmos = 3
          1.01e5 && Pressure (Pa)
          305. && Temperature (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
&& struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 17.7 && Characteristic length of structure (m)
  slarea = 86.4 && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eol
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 254. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 .396 && (m)
eol
&&
condense
ht-tran on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell
  geometry= 86.4 && Area of layers in lower cell (m2)
  bc = 305. && Basement boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
            conc && Material
            10000. && Mass of material (kg)
    temp = 305. && Initial temperature (K)
  eol
  pool
    temp = 305. && Initial temperature
  eol
eol
&&
&& Engineered safety systems
&&
engineer Spill 1 2 1 0.0
overflow 2 1 3.05
eol
&&

```

&& ----- Cell 3, Room 115 -----

cell 3

control

nhtm=2 mxslab=11 nsoatm=2 nspatm=736 naensy=1 jconc=1 jpool=1

eo1

title

Cell 3, Room 115

&&

&& Upper Cell Input

&&

geometry 5.267e2 5.49 && Cell volume and height (m3, m)

atmos = 3

1.01e5

&& Pressure

305.

&& Temperature

o2 = 0.20

n2 = 0.75

h2ov = 0.05

source=2

&&

&& Blowdown of saturated primary system water

&&

t2ov = 736

iflag = 2

t =

0.0	1.0	2.0	3.0	4.0
5.0	6.0	7.0	8.0	9.0
10.0	11.0	12.0	13.0	14.0
15.0	25.0	35.0	45.0	55.0
65.0	75.0	85.0	95.0	105.0
115.0	125.0	135.0	145.0	155.0
165.0	175.0	185.0	195.0	205.0
215.0	225.0	235.0	245.0	255.0
265.0	275.0	285.0	295.0	305.0
315.0	325.0	335.0	345.0	355.0
365.0	375.0	385.0	395.0	405.0
415.0	425.0	435.0	445.0	455.0
465.0	475.0	485.0	495.0	505.0
515.0	525.0	535.0	545.0	555.0
565.0	575.0	585.0	595.0	605.0
615.0	625.0	635.0	645.0	655.0
665.0	675.0	685.0	695.0	705.0
715.0	725.0	735.0	745.0	755.0
765.0	775.0	785.0	795.0	805.0
815.0	825.0	835.0	845.0	855.0
865.0	875.0	885.0	895.0	905.0
908.6	918.6	928.6	938.6	948.6
958.6	968.6	978.6	988.6	998.6
1000.0	1010.0	1020.0	1030.0	1040.0
1050.0	1060.0	1070.0	1080.0	1090.0
1100.0	1110.0	1120.0	1130.0	1140.0
1150.0	1160.0	1170.0	1180.0	1190.0
1200.0	1210.0	1220.0	1230.0	1240.0
1250.0	1260.0	1270.0	1280.0	1290.0
1300.0	1310.0	1320.0	1330.0	1340.0
1350.0	1360.0	1370.0	1380.0	1390.0
1400.0	1410.0	1420.0	1430.0	1440.0
1450.0	1460.0	1470.0	1480.0	1490.0
1500.0	1510.0	1520.0	1530.0	1540.0
1550.0	1560.0	1570.0	1580.0	1590.0
1600.0	1610.0	1620.0	1630.0	1640.0
1650.0	1660.0	1670.0	1680.0	1690.0
1700.0	1710.0	1720.0	1730.0	1740.0
1750.0	1760.0	1770.0	1780.0	1790.0
1800.0	1810.0	1820.0	1830.0	1840.0
1850.0	1860.0	1870.0	1880.0	1890.0
1900.0	1910.0	1920.0	1930.0	1940.0
1950.0	1960.0	1970.0	1980.0	1990.0
2000.0	2010.0	2020.0	2030.0	2040.0
2050.0	2060.0	2070.0	2080.0	2090.0

2100.0	2110.0	2120.0	2130.0	2140.0
2150.0	2160.0	2170.0	2180.0	2190.0
2200.0	2210.0	2220.0	2230.0	2240.0
2250.0	2260.0	2270.0	2280.0	2290.0
2300.0	2310.0	2320.0	2330.0	2340.0
2350.0	2360.0	2370.0	2380.0	2390.0
2400.0	2410.0	2420.0	2430.0	2440.0
2450.0	2460.0	2470.0	2480.0	2490.0
2500.0	2510.0	2520.0	2530.0	2540.0
2550.0	2560.0	2570.0	2580.0	2590.0
2600.0	2610.0	2620.0	2630.0	2640.0
2650.0	2660.0	2670.0	2680.0	2690.0
2700.0	2710.0	2720.0	2730.0	2740.0
2750.0	2760.0	2770.0	2780.0	2790.0
2800.0	2810.0	2820.0	2830.0	2840.0
2850.0	2860.0	2870.0	2880.0	2890.0
2900.0	2910.0	2920.0	2930.0	2940.0
2950.0	2960.0	2970.0	2980.0	2990.0
3000.0	3010.0	3020.0	3030.0	3040.0
3050.0	3060.0	3070.0	3080.0	3090.0
3100.0	3110.0	3120.0	3130.0	3140.0
3150.0	3160.0	3170.0	3180.0	3190.0
3200.0	3210.0	3220.0	3230.0	3240.0
3250.0	3260.0	3270.0	3280.0	3290.0
3300.0	3310.0	3320.0	3330.0	3340.0
3350.0	3360.0	3370.0	3380.0	3390.0
3400.0	3410.0	3420.0	3430.0	3440.0
3450.0	3460.0	3470.0	3480.0	3490.0
3500.0	3510.0	3520.0	3530.0	3540.0
3550.0	3560.0	3570.0	3580.0	3590.0
3600.0	3610.0	3620.0	3630.0	3640.0
3650.0	3660.0	3670.0	3680.0	3690.0
3700.0	3710.0	3720.0	3730.0	3740.0
3750.0	3760.0	3770.0	3780.0	3790.0
3800.0	3810.0	3820.0	3830.0	3840.0
3850.0	3860.0	3870.0	3880.0	3890.0
3900.0	3910.0	3920.0	3930.0	3940.0
3950.0	3960.0	3970.0	3980.0	3990.0
4000.0	4010.0	4020.0	4030.0	4040.0
4050.0	4060.0	4070.0	4080.0	4090.0
4100.0	4110.0	4120.0	4130.0	4140.0
4150.0	4160.0	4170.0	4180.0	4190.0
4200.0	4210.0	4220.0	4230.0	4240.0
4250.0	4260.0	4270.0	4280.0	4290.0
4300.0	4310.0	4320.0	4330.0	4340.0
4350.0	4360.0	4370.0	4380.0	4390.0
4400.0	4410.0	4420.0	4430.0	4440.0
4450.0	4460.0	4470.0	4480.0	4490.0
4500.0	4510.0	4520.0	4530.0	4540.0
4550.0	4560.0	4570.0	4580.0	4590.0
4600.0	4610.0	4620.0	4630.0	4640.0
4650.0	4660.0	4670.0	4680.0	4690.0
4700.0	4710.0	4720.0	4730.0	4740.0
4750.0	4760.0	4770.0	4780.0	4790.0
4800.0	4810.0	4820.0	4830.0	4840.0
4850.0	4860.0	4870.0	4880.0	4890.0
4900.0	4910.0	4920.0	4930.0	4940.0
4950.0	4960.0	4970.0	4980.0	4990.0
5000.0	5010.0	5020.0	5030.0	5040.0
5050.0	5060.0	5070.0	5080.0	5090.0
5100.0	5110.0	5120.0	5130.0	5140.0
5150.0	5160.0	5170.0	5180.0	5190.0
5200.0	5210.0	5220.0	5230.0	5240.0
5250.0	5260.0	5270.0	5280.0	5290.0
5300.0	5310.0	5320.0	5330.0	5340.0
5350.0	5360.0	5370.0	5380.0	5390.0
5400.0	5410.0	5420.0	5430.0	5440.0
5450.0	5460.0	5470.0	5480.0	5490.0



5500.0	5510.0	5520.0	5530.0	5540.0
5550.0	5560.0	5570.0	5580.0	5590.0
5600.0	5610.0	5620.0	5630.0	5640.0
5650.0	5660.0	5670.0	5680.0	5690.0
5700.0	5710.0	5720.0	5730.0	5740.0
5750.0	5760.0	5770.0	5780.0	5790.0
5800.0	5810.0	5820.0	5830.0	5840.0
5850.0	5860.0	5870.0	5880.0	5890.0
5900.0	5910.0	5920.0	5930.0	5940.0
5950.0	5960.0	5970.0	5980.0	5990.0
6000.0	6010.0	6020.0	6030.0	6040.0
6050.0	6060.0	6070.0	6080.0	6090.0
6100.0	6110.0	6120.0	6130.0	6140.0
6150.0	6160.0	6170.0	6180.0	6190.0
6200.0	6210.0	6220.0	6230.0	6240.0
6250.0	6260.0	6270.0	6280.0	6290.0
6300.0	6310.0	6320.0	6330.0	6340.0
6350.0	6360.0	6370.0	6380.0	6390.0
6400.0	6410.0	6420.0	6430.0	6440.0
6450.0	6460.0	6470.0	6480.0	6490.0
6500.0	6510.0	6520.0	6530.0	6540.0
6550.0	6560.0	6570.0	6580.0	6590.0
6600.0	6610.0	6620.0	6630.0	6640.0
6650.0	6660.0	6670.0	6680.0	6690.0
6700.0	6710.0	6720.0	6730.0	6740.0
6750.0	6760.0	6770.0	6780.0	6790.0
6800.0	6810.0	6820.0	6830.0	6840.0
6850.0	6860.0	6870.0	6880.0	6890.0
6900.0	6910.0	6920.0	6930.0	6940.0
6950.0	6960.0	6970.0	6980.0	6990.0
7000.0	7010.0	7020.0	7030.0	7040.0
7050.0	7060.0	7070.0	7080.0	7090.0
7100.0	7110.0	7120.0	7130.0	7140.0
7150.0	7160.0	7170.0	7180.0	7190.0
7200.0				

mass =	50.0	53.8	54.7	55.6	56.5
57.4	58.4	59.3	59.5	59.5	59.5
59.5	59.5	59.5	59.5	59.5	59.5
59.5	55.8	56.4	55.8	55.8	55.2
55.0	54.9	69.6	69.7	69.8	69.8
69.8	70.0	70.2	70.5	70.8	70.8
71.1	70.5	56.0	54.3	46.8	46.8
47.3	47.1	46.6	52.9	50.3	50.3
49.2	47.8	45.7	44.4	43.2	43.2
41.6	41.5	39.0	37.7	37.6	37.6
36.4	36.3	39.2	37.7	31.9	31.9
30.8	29.8	29.5	28.7	31.2	31.2
28.9	28.1	27.3	26.1	24.2	24.2
22.5	21.3	20.5	19.5	18.6	18.6
17.7	16.8	19.0	18.8	18.5	18.5
18.3	17.9	17.5	18.1	18.5	18.5
18.0	17.8	17.4	17.0	16.6	16.6
16.3	15.7	15.3	15.0	14.8	14.8
14.5	14.2	13.9	13.6	13.4	13.4
13.1	12.8	12.5	12.2	11.9	11.9
11.6	11.4	11.1	11.0	10.8	10.8
10.6	10.4	10.2	10.1	9.9	9.9
9.8	9.7	9.5	9.4	9.2	9.2
9.2	9.6	9.5	9.4	9.4	9.4
9.3	9.2	9.2	9.1	9.1	9.1
9.0	9.0	9.0	8.9	8.9	8.9
8.9	8.9	8.9	9.0	9.0	9.0
9.0	9.0	9.1	9.1	9.2	9.2
9.2	9.3	9.3	9.4	9.5	9.5
9.6	9.6	9.7	9.8	9.9	9.9
10.0	10.1	10.2	10.2	10.3	10.3
10.4	10.5	10.0	10.1	10.2	10.2

10.3	10.4	10.5	10.7	10.8
10.9	11.0	11.1	11.2	11.4
11.5	11.6	11.7	11.9	12.0
12.1	12.2	12.4	12.5	12.6
12.8	12.9	13.0	13.2	13.3
13.5	13.6	13.8	13.9	14.1
14.2	14.4	14.5	14.7	14.8
14.9	15.1	15.2	15.3	15.4
15.6	13.0	13.1	13.1	13.6
13.9	14.2	14.3	14.4	14.5
14.6	14.9	14.6	14.7	14.8
14.7	14.9	6.8	15.7	15.8
7.8	17.2	20.1	16.7	12.4
12.6	12.7	12.9	13.1	13.4
13.8	14.2	14.2	14.0	13.8
13.4	13.1	13.1	12.4	11.4
10.7	10.8	11.1	11.4	11.7
12.0	12.7	12.6	12.9	13.2
13.5	14.0	14.2	14.5	14.7
15.0	15.2	15.3	15.4	15.5
15.7	15.8	15.9	16.1	16.2
16.4	16.8	14.9	24.4	15.0
25.5	11.8	19.8	24.4	9.8
29.8	24.4	17.2	27.6	13.8
14.5	19.9	20.0	20.1	20.2
20.3	20.4	20.5	20.6	20.2
20.3	20.5	20.6	20.8	20.9
21.0	21.1	21.2	21.3	21.5
21.6	23.1	22.8	22.7	22.7
22.6	22.6	22.8	23.2	27.3
23.3	23.4	23.4	22.7	22.8
22.9	23.0	22.9	23.0	21.6
21.8	22.1	22.4	22.7	27.2
28.8	20.4	32.1	18.9	35.8
29.9	29.8	29.5	29.2	28.8
28.4	28.1	28.1	28.2	28.4
28.6	28.9	29.0	29.0	29.0
28.9	28.7	28.5	28.2	28.1
28.0	28.0	28.0	28.1	28.1
28.2	28.1	28.1	28.0	27.9
27.9	27.8	27.7	27.6	27.5
27.4	27.3	27.2	27.1	27.0
26.9	20.8	26.7	26.6	26.5
26.3	26.2	26.1	26.0	25.9
25.8	25.7	25.6	25.5	25.4
25.2	25.1	25.0	24.9	24.8
24.7	24.6	24.5	24.4	24.3
24.2	24.1	24.0	23.9	23.8
23.7	23.6	23.5	23.4	23.3
23.2	23.1	23.0	22.9	22.8
22.7	22.6	22.6	22.5	22.4
18.5	24.0	14.5	19.9	23.2
22.7	21.6	24.0	19.4	13.8
18.8	21.0	21.4	20.7	22.2
22.8	18.0	20.7	27.3	32.2
26.9	21.4	22.5	22.2	35.2
76.8	18.1	24.6	52.1	34.8
22.6	35.0	21.7	24.6	27.4
43.1	39.8	38.5	45.4	46.6
47.3	48.4	50.5	50.7	54.3
54.5	56.0	53.2	53.7	54.2
54.7	55.1	55.4	55.7	55.9
56.1	56.3	56.5	56.7	56.8
57.0	57.1	57.1	57.4	57.5
57.6	59.9	59.7	59.5	59.5
59.5	59.5	59.5	59.5	59.5
59.4	59.2	58.6	56.2	55.3
57.8	53.3	59.2	59.9	60.4

60.7	60.9	61.1	61.2	61.3
61.4	61.5	61.6	61.7	61.7
61.8	61.9	61.9	62.0	62.0
62.1	62.2	62.2	62.3	62.4
62.4	62.5	62.5	62.6	62.7
62.7	62.8	62.9	62.9	63.0
63.0	63.1	63.2	63.2	63.3
63.3	63.4	63.5	63.5	63.6
63.6	63.7	63.7	63.8	63.9
63.9	64.0	64.0	64.1	64.1
64.2	64.3	64.3	64.4	64.4
64.5	64.5	64.6	64.6	64.7
64.8	64.8	64.9	64.9	65.0
65.0	65.1	65.1	65.2	65.2
65.3	65.3	65.4	65.4	65.5
65.5	65.6	65.6	65.7	65.7
65.8	65.8	65.9	65.9	66.0
66.0	66.1	66.1	66.2	66.2
66.3	66.3	66.3	66.4	66.4
66.5	66.5	66.6	66.6	66.7
66.7	66.7	66.8	66.8	66.8
66.9	67.0	67.0	67.1	67.1
67.1	67.2	67.2	67.2	67.3
67.3	67.3	67.4	67.4	67.5
67.5	67.5	67.6	67.6	67.6
67.7	67.7	67.7	67.8	67.8
67.8	67.9	67.9	68.0	68.0
68.0	68.1	68.1	68.1	68.2
68.2	68.2	68.2	68.3	68.3
68.3	68.4	68.4	68.4	68.5
68.5	68.5	68.6	68.6	68.6
68.7	68.7	68.7	68.7	68.8
68.8	68.8	68.9	68.9	68.9
68.9	69.0	69.0	69.0	69.1
69.1	69.1	69.1	69.2	69.2
69.2	69.3	69.3	69.3	69.3
69.4	69.4	69.4	69.4	69.5
69.5	69.5	69.5	69.6	69.6
69.6	69.6	69.7	69.7	69.7
69.7	69.7	69.8	69.8	69.8
69.8	69.9	69.9	69.9	69.9
70.0	70.0	70.0	70.0	70.0
70.1	70.1	70.1	70.1	70.2
70.2	70.2	70.2	70.2	70.3
70.3	70.3	70.3	70.3	70.4
70.4	70.4	70.4	70.4	70.5
70.5	70.5	70.5	70.5	70.5
70.6				

enth =	158119.7	1315678.0	1319274.0	1322915.0	1326278.0
	1329812.0	1332963.0	1335866.0	1336738.0	1336759.0
	1336788.0	1336787.0	1336776.0	1336762.0	1336784.0
	1336780.0	1316393.0	1320209.0	1316496.0	1313436.0
	1313009.0	1313194.0	1383841.0	1384522.0	1385224.0
	1386094.0	1387132.0	1388411.0	1387058.0	1391758.0
	1394223.0	1400809.0	1353282.0	1355197.0	1358870.0
	1359778.0	1360359.0	1361359.0	1359062.0	1360367.0
	1361290.0	1362105.0	136372.0	1363782.0	1364715.0
	1365603.0	1366227.0	1367308.0	1367763.0	1367192.0
	1366610.0	1296113.0	1361702.0	1383374.0	1365304.0
	1260773.0	1255993.0	1258242.0	1254592.0	1389684.0
	1393473.0	1396441.0	1396441.0	1404121.0	1404725.0
	1413837.0	1420611.0	1420611.0	1433573.0	1441272.0
	1448001.0	1454929.0	1454929.0	1440578.0	1442571.0
	1443546.0	1447336.0	1447336.0	1445196.0	1443583.0
	1447129.0	1448696.0	1450414.0	1453375.0	1456304.0
	1459198.0	1250546.0	1250004.0	1249401.0	1248976.0
	1248382.0	1247885.0	1247879.0	1247224.0	1247224.0

1246445.0	1245819.0	1245162.0	1244534.0	1243917.0
1243304.0	1242736.0	1242222.0	1242031.0	1241570.0
1241193.0	1241320.0	1240968.0	1240639.0	1240353.0
1240580.0	1240408.0	1240151.0	1239974.0	1240579.0
1240558.0	1243775.0	1243652.0	1243555.0	1243526.0
1243458.0	1243352.0	1243377.0	1243306.0	1243284.0
1243220.0	1243185.0	1243182.0	1243151.0	1243130.0
1243136.0	1243146.0	1243110.0	1243021.0	1242910.0
1242768.0	1242551.0	1242388.0	1242166.0	1241915.0
1241651.0	1241390.0	1241114.0	1240827.0	1240536.0
1240220.0	1239890.0	1239556.0	1239197.0	1238826.0
1238450.0	1238700.0	1238274.0	1237848.0	1237400.0
1236938.0	1236481.0	1237911.0	1237397.0	1236881.0
1236310.0	1235806.0	1235260.0	1234704.0	1234137.0
1233564.0	1233015.0	1232426.0	1231833.0	1231234.0
1230633.0	1230032.0	1229425.0	1228775.0	1228116.0
1227455.0	1226834.0	1226171.0	1225508.0	1224848.0
1224196.0	1223540.0	1222880.0	1222229.0	1221571.0
1220917.0	1220288.0	1219626.0	1218965.0	1218308.0
1217629.0	1216505.0	1215849.0	1215136.0	1214404.0
1213625.0	1212840.0	1212032.0	1211201.0	1210358.0
1209488.0	1208815.0	1208165.0	1207398.0	1176431.0
1183866.0	1186729.0	1185528.0	1186336.0	1186151.0
1185986.0	1203584.0	1211424.0	1210512.0	1209606.0
1198625.0	1197997.0	707168.1	1185762.0	1185172.0
1401812.0	1181058.0	1321526.0	1175293.0	1092225.0
1094787.0	1096254.0	1095278.0	1102466.0	1104973.0
1112808.0	1116084.0	1115524.0	1112528.0	1108807.0
1103768.0	1098388.0	1097267.0	1087206.0	1067120.0
1050411.0	1052252.0	1059202.0	1065370.0	1071079.0
1076267.0	1080965.0	1085216.0	1089044.0	1092434.0
1095424.0	1100388.0	1102478.0	1104317.0	1105938.0
1107356.0	1108576.0	1108647.0	1108762.0	1108863.0
1108944.0	1109019.0	1109462.0	1109556.0	1109612.0
1109638.0	1178335.0	1159067.0	1156515.0	1155660.0
1169435.0	1221813.0	1192361.0	1151086.0	1035327.0
1221144.0	1150401.0	1113750.0	1198399.0	1209159.0
1208177.0	1129982.0	1128767.0	1126926.0	1125951.0
1124835.0	1123585.0	1122503.0	1121390.0	1119113.0
1118028.0	1116918.0	1114238.0	1113145.0	1112033.0
1110821.0	1109790.0	1108112.0	1107969.0	1105848.0
1104719.0	1107350.0	1106544.0	1104990.0	1102301.0
1100738.0	1099440.0	1099718.0	1100544.0	1099346.0
1098334.0	1097386.0	1096142.0	1093381.0	1092905.0
1092113.0	1091404.0	1088315.0	1087667.0	1109844.0
1107967.0	1107138.0	1106558.0	1105756.0	1150509.0
1149120.0	1081033.0	1078712.0	1140491.0	1121396.0
1103086.0	1101705.0	1099359.0	1097778.0	1095173.0
1092491.0	1090138.0	1089335.0	1088871.0	1088953.0
1089231.0	1089270.0	1088951.0	1088232.0	1086989.0
1085380.0	1083678.0	1081806.0	1080012.0	1078420.0
1077034.0	1076020.0	1075296.0	1074620.0	1073901.0
1073011.0	1071966.0	1070802.0	1069553.0	1068253.0
1066925.0	1065584.0	1064231.0	1062863.0	1061484.0
1060092.0	1058683.0	1057261.0	1055826.0	1054379.0
1052925.0	1051463.0	1049996.0	1048524.0	1047026.0
1045522.0	1044013.0	1042497.0	1040589.0	1039483.0
1037972.0	1036457.0	1034943.0	1033419.0	1031903.0
1030389.0	1028875.0	1027361.0	1025849.0	1024338.0
1022828.0	1021318.0	1019810.0	1018313.0	1016814.0
1015293.0	1013715.0	1012259.0	1010743.0	1009229.0
1007711.0	1006179.0	1004657.0	1003138.0	1001620.0
1000104.0	998591.8	997080.4	995573.2	994070.2
992592.1	991148.7	989722.0	988317.4	986930.9
1017446.0	1011037.0	1005642.0	1006755.0	1000073.0
1016224.0	1007882.0	986841.4	1003749.0	981246.5
1002118.0	1001727.0	1032144.0	1000070.0	977819.4
996948.8	988294.4	992275.9	994635.8	995009.3

1009643.0	1030662.0	1030099.0	1042376.0	1047106.0
1033281.0	1031242.0	1023219.0	1048438.0	1046795.0
1028726.0	1045297.0	1000508.0	1019591.0	1035438.0
1062547.0	1078606.0	1080366.0	1075304.0	1078629.0
1078427.0	1079007.0	1077010.0	1078099.0	1077353.0
1075502.0	1075311.0	1074424.0	1073383.0	1072280.0
1071060.0	1069894.0	1068690.0	1067462.0	1066214.0
1064944.0	1063655.0	1062346.0	1061070.0	1059677.0
1058325.0	1056959.0	1055579.0	1054183.0	1052774.0
1051349.0	1050377.0	1047926.0	1046465.0	1044996.0
1043516.0	1042026.0	1040524.0	1039010.0	1037479.0
1035927.0	1034339.0	1032656.0	1030674.0	1028763.0
1027458.0	1026228.0	1024895.0	1023493.0	1022034.0
1020533.0	1019002.0	1017450.0	1015885.0	1014308.0
1012722.0	1011128.0	1009528.0	1007921.0	1006310.0
1004693.0	1003073.0	1001448.0	999818.4	998187.1
996552.6	994915.7	993276.3	991634.4	989990.1
988343.6	986694.9	985044.2	983391.8	981737.4
980081.6	978424.3	976765.8	975106.0	973445.2
971783.4	970120.9	968457.7	966793.9	965129.7
963465.2	961800.5	960135.7	958470.9	956806.1
955141.4	953477.1	951813.1	950149.6	948486.6
946824.3	945162.8	943502.1	941842.2	940183.4
938525.7	936869.1	935213.9	933559.7	931907.1
930255.9	928606.2	926958.2	925311.8	923667.2
922024.4	920383.4	918744.3	917107.3	915472.2
913839.4	912208.6	910580.1	908953.9	907330.0
905708.5	904089.4	902472.8	900858.6	899247.0
897638.1	896031.8	894428.2	892827.4	891229.3
889634.1	888041.8	886452.4	884865.9	883282.5
881702.1	880124.8	878550.6	876979.6	875411.8
873847.2	872286.0	870728.1	869173.4	867622.2
866074.4	864530.1	862989.2	861451.9	859918.1
858387.8	856861.2	855238.2	853818.9	852303.2
850791.2	849282.9	84779.4	846277.2	844779.0
843284.8	841786.6	840291.9	838801.2	837314.6
835831.8	834352.9	832878.0	831406.9	829939.7
828476.4	827016.9	825561.4	824109.8	822662.1
821218.3	819778.4	818342.5	816910.5	815482.4
814058.4	812638.2	811222.1	809809.9	808401.8
806997.6	805597.4	804201.7	802809.1	801421.0
800036.9	798656.8	797280.0	795908.8	794540.6
793176.8	791816.9	790461.0	789109.2	787761.4
786417.7	785078.1	783742.6	782411.1	781083.7
779760.4	778441.2	777126.1	775815.0	774508.1
773205.2	771906.4	770611.8	769321.1	768034.6
766752.2	765473.9	764199.6	762929.5	761663.4
760401.4	759143.5	757883.7	756439.9	755394.2
754152.6	752915.1	751661.7	750452.2	749226.9
748005.7	746788.5	745575.3	744366.2	743161.2
741960.2	740763.2	739570.3	738381.4	737196.5
736015.6	734838.8	733665.9	732497.1	731332.3
730171.5	729014.7	727861.9	726713.0	725568.2
724427.2	723290.4	722157.4	721028.4	719903.3
718782.2	717665.1	716551.8	715442.5	714337.1
713235.6	712138.0	711044.4	709954.6	708868.6
707786.6	706708.4	705614.1	704563.7	703497.1
702434.3	701375.4	700520.3	699169.0	698221.5
697177.9	696137.9	695101.9	69369.6	693041.0
692016.2	690995.2	689977.9	688964.4	687954.5
686948.4				

end

##  
## Blowdown of primary system steam  
##

h2ov = 736

iflag = 2

t = 0.0 1.0 2.0 3.0 4.0

5.0	6.0	7.0	8.0	9.0
10.0	11.0	12.0	13.0	14.0
15.0	25.0	35.0	45.0	55.0
65.0	75.0	85.0	95.0	105.0
115.0	125.0	135.0	145.0	155.0
165.0	175.0	185.0	195.0	205.0
215.0	225.0	235.0	245.0	255.0
265.0	275.0	285.0	295.0	305.0
315.0	325.0	335.0	345.0	355.0
365.0	375.0	385.0	395.0	405.0
415.0	425.0	435.0	445.0	455.0
465.0	475.0	485.0	495.0	505.0
515.0	525.0	535.0	545.0	555.0
565.0	575.0	585.0	595.0	605.0
615.0	625.0	635.0	645.0	655.0
665.0	675.0	685.0	695.0	705.0
715.0	725.0	735.0	745.0	755.0
765.0	775.0	785.0	795.0	805.0
815.0	825.0	835.0	845.0	855.0
865.0	875.0	885.0	895.0	905.0
908.6	918.6	928.6	938.6	948.6
958.6	968.6	978.6	988.6	998.6
1000.0	1010.0	1020.0	1030.0	1040.0
1050.0	1060.0	1070.0	1080.0	1090.0
1100.0	1110.0	1120.0	1130.0	1140.0
1150.0	1160.0	1170.0	1180.0	1190.0
1200.0	1210.0	1220.0	1230.0	1240.0
1250.0	1260.0	1270.0	1280.0	1290.0
1300.0	1310.0	1320.0	1330.0	1340.0
1350.0	1360.0	1370.0	1380.0	1390.0
1400.0	1410.0	1420.0	1430.0	1440.0
1450.0	1460.0	1470.0	1480.0	1490.0
1500.0	1510.0	1520.0	1530.0	1540.0
1550.0	1560.0	1570.0	1580.0	1590.0
1600.0	1610.0	1620.0	1630.0	1640.0
1650.0	1660.0	1670.0	1680.0	1690.0
1700.0	1710.0	1720.0	1730.0	1740.0
1750.0	1760.0	1770.0	1780.0	1790.0
1800.0	1810.0	1820.0	1830.0	1840.0
1850.0	1860.0	1870.0	1880.0	1890.0
1900.0	1910.0	1920.0	1930.0	1940.0
1950.0	1960.0	1970.0	1980.0	1990.0
2000.0	2010.0	2020.0	2030.0	2040.0
2050.0	2060.0	2070.0	2080.0	2090.0
2100.0	2110.0	2120.0	2130.0	2140.0
2150.0	2160.0	2170.0	2180.0	2190.0
2200.0	2210.0	2220.0	2230.0	2240.0
2250.0	2260.0	2270.0	2280.0	2290.0
2300.0	2310.0	2320.0	2330.0	2340.0
2350.0	2360.0	2370.0	2380.0	2390.0
2400.0	2410.0	2420.0	2430.0	2440.0
2450.0	2460.0	2470.0	2480.0	2490.0
2500.0	2510.0	2520.0	2530.0	2540.0
2550.0	2560.0	2570.0	2580.0	2590.0
2600.0	2610.0	2620.0	2630.0	2640.0
2650.0	2660.0	2670.0	2680.0	2690.0
2700.0	2710.0	2720.0	2730.0	2740.0
2750.0	2760.0	2770.0	2780.0	2790.0
2800.0	2810.0	2820.0	2830.0	2840.0
2850.0	2860.0	2870.0	2880.0	2890.0
2900.0	2910.0	2920.0	2930.0	2940.0
2950.0	2960.0	2970.0	2980.0	2990.0
3000.0	3010.0	3020.0	3030.0	3040.0
3050.0	3060.0	3070.0	3080.0	3090.0
3100.0	3110.0	3120.0	3130.0	3140.0
3150.0	3160.0	3170.0	3180.0	3190.0
3200.0	3210.0	3220.0	3230.0	3240.0
3250.0	3260.0	3270.0	3280.0	3290.0

3300.0	3310.0	3320.0	3330.0	3340.0
3350.0	3360.0	3370.0	3380.0	3390.0
3400.0	3410.0	3420.0	3430.0	3440.0
3450.0	3460.0	3470.0	3480.0	3490.0
3500.0	3510.0	3520.0	3530.0	3540.0
3550.0	3560.0	3570.0	3580.0	3590.0
3600.0	3610.0	3620.0	3630.0	3640.0
3650.0	3660.0	3670.0	3680.0	3690.0
3700.0	3710.0	3720.0	3730.0	3740.0
3750.0	3760.0	3770.0	3780.0	3790.0
3800.0	3810.0	3820.0	3830.0	3840.0
3850.0	3860.0	3870.0	3880.0	3890.0
3900.0	3910.0	3920.0	3930.0	3940.0
3950.0	3960.0	3970.0	3980.0	3990.0
4000.0	4010.0	4020.0	4030.0	4040.0
4050.0	4060.0	4070.0	4080.0	4090.0
4100.0	4110.0	4120.0	4130.0	4140.0
4150.0	4160.0	4170.0	4180.0	4190.0
4200.0	4210.0	4220.0	4230.0	4240.0
4250.0	4260.0	4270.0	4280.0	4290.0
4300.0	4310.0	4320.0	4330.0	4340.0
4350.0	4360.0	4370.0	4380.0	4390.0
4400.0	4410.0	4420.0	4430.0	4440.0
4450.0	4460.0	4470.0	4480.0	4490.0
4500.0	4510.0	4520.0	4530.0	4540.0
4550.0	4560.0	4570.0	4580.0	4590.0
4600.0	4610.0	4620.0	4630.0	4640.0
4650.0	4660.0	4670.0	4680.0	4690.0
4700.0	4710.0	4720.0	4730.0	4740.0
4750.0	4760.0	4770.0	4780.0	4790.0
4800.0	4810.0	4820.0	4830.0	4840.0
4850.0	4860.0	4870.0	4880.0	4890.0
4900.0	4910.0	4920.0	4930.0	4940.0
4950.0	4960.0	4970.0	4980.0	4990.0
5000.0	5010.0	5020.0	5030.0	5040.0
5050.0	5060.0	5070.0	5080.0	5090.0
5100.0	5110.0	5120.0	5130.0	5140.0
5150.0	5160.0	5170.0	5180.0	5190.0
5200.0	5210.0	5220.0	5230.0	5240.0
5250.0	5260.0	5270.0	5280.0	5290.0
5300.0	5310.0	5320.0	5330.0	5340.0
5350.0	5360.0	5370.0	5380.0	5390.0
5400.0	5410.0	5420.0	5430.0	5440.0
5450.0	5460.0	5470.0	5480.0	5490.0
5500.0	5510.0	5520.0	5530.0	5540.0
5550.0	5560.0	5570.0	5580.0	5590.0
5600.0	5610.0	5620.0	5630.0	5640.0
5650.0	5660.0	5670.0	5680.0	5690.0
5700.0	5710.0	5720.0	5730.0	5740.0
5750.0	5760.0	5770.0	5780.0	5790.0
5800.0	5810.0	5820.0	5830.0	5840.0
5850.0	5860.0	5870.0	5880.0	5890.0
5900.0	5910.0	5920.0	5930.0	5940.0
5950.0	5960.0	5970.0	5980.0	5990.0
6000.0	6010.0	6020.0	6030.0	6040.0
6050.0	6060.0	6070.0	6080.0	6090.0
6100.0	6110.0	6120.0	6130.0	6140.0
6150.0	6160.0	6170.0	6180.0	6190.0
6200.0	6210.0	6220.0	6230.0	6240.0
6250.0	6260.0	6270.0	6280.0	6290.0
6300.0	6310.0	6320.0	6330.0	6340.0
6350.0	6360.0	6370.0	6380.0	6390.0
6400.0	6410.0	6420.0	6430.0	6440.0
6450.0	6460.0	6470.0	6480.0	6490.0
6500.0	6510.0	6520.0	6530.0	6540.0
6550.0	6560.0	6570.0	6580.0	6590.0
6600.0	6610.0	6620.0	6630.0	6640.0
6650.0	6660.0	6670.0	6680.0	6690.0

6700.0	6710.0	6720.0	6730.0	6740.0
6750.0	6760.0	6770.0	6780.0	6790.0
6800.0	6810.0	6820.0	6830.0	6840.0
6850.0	6860.0	6870.0	6880.0	6890.0
6900.0	6910.0	6920.0	6930.0	6940.0
6950.0	6960.0	6970.0	6980.0	6990.0
7000.0	7010.0	7020.0	7030.0	7040.0
7050.0	7060.0	7070.0	7080.0	7090.0
7100.0	7110.0	7120.0	7130.0	7140.0
7150.0	7160.0	7170.0	7180.0	7190.0
7200.0				

mass =	0.0	5.0	5.6	5.5	5.5
	5.4	5.4	5.4	5.4	5.4
	5.4	5.4	5.4	5.4	5.4
	5.4	5.4	5.4	5.5	5.7
	5.8	5.8	4.0	4.1	4.2
	4.2	4.3	4.4	4.6	4.7
	5.0	5.3	7.3	7.6	8.2
	8.4	8.7	8.9	8.8	9.1
	9.4	9.7	10.0	10.2	10.5
	10.7	10.9	11.2	11.4	11.5
	11.7	12.2	13.1	12.4	14.0
	14.3	14.5	14.8	15.0	16.4
	16.3	16.6	17.0	17.5	18.3
	18.9	19.3	20.1	20.8	21.5
	22.1	22.8	21.2	21.4	21.6
	21.7	22.0	22.3	21.8	21.6
	22.0	22.1	22.3	22.6	22.9
	23.2	18.6	18.9	19.0	19.1
	19.1	19.2	19.3	19.4	19.5
	19.7	19.8	19.9	20.1	20.2
	20.4	20.5	20.7	20.7	20.8
	20.9	21.1	21.1	21.2	21.3
	21.4	21.4	21.5	21.5	21.7
	21.7	21.5	21.8	21.8	21.9
	21.9	21.9	21.9	22.0	22.0
	22.0	22.0	22.0	22.0	22.0
	22.0	22.0	22.0	22.0	22.0
	22.0	21.9	21.9	21.9	21.8
	21.8	21.7	21.7	21.7	21.6
	21.6	21.5	21.4	21.4	21.3
	21.3	21.2	21.2	21.1	21.0
	21.0	20.9	21.4	21.3	21.2
	21.1	21.0	20.9	20.8	20.7
	20.7	20.6	20.5	20.4	20.3
	20.2	20.1	20.0	19.8	19.7
	19.6	19.5	19.4	19.3	19.2
	19.0	18.9	18.8	18.6	18.5
	18.4	18.2	18.1	17.9	17.8
	17.6	17.5	17.4	17.2	17.1
	17.0	16.8	16.7	16.6	16.4
	16.3	17.3	17.2	17.4	16.2
	15.7	15.7	15.6	15.5	15.4
	15.3	15.6	15.8	15.7	15.6
	15.4	15.3	14.3	14.6	14.5
	21.5	14.0	16.8	13.9	13.4
	13.3	13.3	13.2	13.0	13.1
	13.0	13.0	13.0	13.0	13.0
	12.9	13.0	12.9	12.9	12.9
	12.3	12.3	12.3	12.3	12.3
	12.3	12.2	12.1	12.0	11.9
	11.8	11.8	11.7	11.6	11.5
	11.4	11.4	11.3	11.2	11.2
	11.1	11.1	11.0	10.9	10.8
	10.7	10.0	11.1	9.7	11.0
	9.3	12.2	11.3	9.9	10.6
	9.9	9.9	9.8	9.7	11.2







2744673.0	2745257.0	2718558.0	2753736.0	2754596.0
2615714.0	2750942.0	2744078.0	2768560.0	2807262.0
2812034.0	2808992.0	2807841.0	2810174.0	2807472.0
2798563.0	2792507.0	2787254.0	2786860.0	2786910.0
2789831.0	2785432.0	2784016.0	2787781.0	2821215.0
2835317.0	2831448.0	2821558.0	2813961.0	2808057.0
2803404.0	2800273.0	2798738.0	2799783.0	2800961.0
2801406.0	2799009.0	2799633.0	2799985.0	2800144.0
2799462.0	2798621.0	2797864.0	2797594.0	2794422.0
2794259.0	2794192.0	2794223.0	2794809.0	2795518.0
2796297.0	2745054.0	2741040.0	2842940.0	2743822.0
2893040.0	2716236.0	2752486.0	2804690.0	2728378.0
2758283.0	2809124.0	2766088.0	2784465.0	2768140.0
2706151.0	2763938.0	2766588.0	2779654.0	2781125.0
2782989.0	2784596.0	2785927.0	2787145.0	2786800.0
2788206.0	2789502.0	2804140.0	2803844.0	2803660.0
2803509.0	2803394.0	2803336.0	2803188.0	2803076.0
2803046.0	2809124.0	2797172.0	2795136.0	2794424.0
2792411.0	2791213.0	2790264.0	2787880.0	2787707.0
2787672.0	2787824.0	2788229.0	2793350.0	2794939.0
2796602.0	2798248.0	2800451.0	2801946.0	2772915.0
2775292.0	2777134.0	2778989.0	2780524.0	2821942.0
2819989.0	2855368.0	2780719.0	2774354.0	2782410.0
2770324.0	2770164.0	2770258.0	2770478.0	2770944.0
2771234.0	2771313.0	2771111.0	2770640.0	2770063.0
2769770.0	2769881.0	2770228.0	2770625.0	2770964.0
2771209.0	2771348.0	2771414.0	2771462.0	2771572.0
2771811.0	2772248.0	2772889.0	2777714.0	2780693.0
2783465.0	2783872.0	2787941.0	2799737.0	2791336.0
2792796.0	2794151.0	2795404.0	2796547.0	2797588.0
2798532.0	2799379.0	2800137.0	2800814.0	2801418.0
2801954.0	2802400.0	2802833.0	2803194.0	2803508.0
2803788.0	2804037.0	2804236.0	2804402.0	2804539.0
2804524.0	2804124.0	2803933.0	2803869.0	2803888.0
2803958.0	2804053.0	2804156.0	2804253.0	2804334.0
2804395.0	2804410.0	2804419.0	2804382.0	2804328.0
2804268.0	2804202.0	2804133.0	2804058.0	2803976.0
2803814.0	2803786.0	2803662.0	2803543.0	2803427.0
2803315.0	2803206.0	2803100.0	2802998.0	2802899.0
2802804.0	2802712.0	2802623.0	2802538.0	2802456.0
2797644.0	2802294.0	2790236.0	2793144.0	2808463.0
2815043.0	2801995.0	2762822.0	2803948.0	2789982.0
2816635.0	2801662.0	2781376.0	2800536.0	2801023.0
2802288.0	2797031.0	2800884.0	2804190.0	2805882.0
2803132.0	2802120.0	2804420.0	2795206.0	2793611.0
2802386.0	2797258.0	2825878.0	2803542.0	2790794.0
2863319.0	2790778.0	2797307.0	2796198.0	2795194.0
2774604.0	2800875.0	2800743.0	2800152.0	2800949.0
2800454.0	2800733.0	2800380.0	2800706.0	2800959.0
2800783.0	2800901.0	2801162.0	2801211.0	2801264.0
2801307.0	2801356.0	2801399.0	2801467.0	2801512.0
2801558.0	2801604.0	2801650.0	2801698.0	2801745.0
2801788.0	2801830.0	2801874.0	2801917.0	2801960.0
2802004.0	2802086.0	2802033.0	2802054.0	2802076.0
2802096.0	2802117.0	2802137.0	2802156.0	2802175.0
2802193.0	2802209.0	2802222.0	2802226.0	2802268.0
2802252.0	2802306.0	2802320.0	2802335.0	2802338.0
2802334.0	2802330.0	2802324.0	2802319.0	2802313.0
2802307.0	2802300.0	2802291.0	2802272.0	2802238.0
2802205.0	2802170.0	2802136.0	2802100.0	2802064.0
2802028.0	2801990.0	2801952.0	2801914.0	2801875.0
2801836.0	2801795.0	2801754.0	2801712.0	2801670.0
2801627.0	2801583.0	2801538.0	2801483.0	2801414.0
2801344.0	2801274.0	2801204.0	2801132.0	2801060.0
2800988.0	2800906.0	2800798.0	2800690.0	2800581.0
2800472.0	2800362.0	2800252.0	2800142.0	2800031.0
2799920.0	2799808.0	2799695.0	2799582.0	2799469.0
2799356.0	2799242.0	2799127.0	2799012.0	2798897.0

```

2798781.0 2798665.0 2798548.0 2798431.0 2798313.0
2798195.0 2798076.0 2797958.0 2797838.0 2797718.0
2797598.0 2797476.0 2797355.0 2797233.0 2797107.0
2796918.0 2796759.0 2796600.0 2796440.0 2796280.0
2796120.0 2795960.0 2795800.0 2795640.0 2795479.0
2795318.0 2795156.0 2794994.0 2794832.0 2794664.0
2794473.0 2794282.0 2794082.0 2793901.0 2793710.0
2793519.0 2793328.0 2793138.0 2792947.0 2792757.0
2792566.0 2792376.0 2792185.0 2791994.0 2791804.0
2791613.0 2791423.0 2791232.0 2791042.0 2790851.0
2790660.0 2790470.0 2790279.0 2790087.0 2789893.0
2789656.0 2789465.0 2789282.0 2789100.0 2788919.0
2788738.0 2788557.0 2788377.0 2788198.0 2788019.0
2787840.0 2787662.0 2787485.0 2787308.0 2787131.0
2786955.0 2786779.0 2786604.0 2786430.0 2786256.0
2786062.0 2785908.0 2785736.0 2785564.0 2785392.0
2785221.0 2785050.0 2784880.0 2784710.0 2784541.0
2784372.0 2784204.0 2784036.0 2783869.0 2783702.0
2783535.0 2783367.0 2783199.0 2783032.0 2782865.0
2782698.0 2782532.0 2782367.0 2782202.0 2782038.0
2781873.0 2781693.0 2781511.0 2781330.0 2781150.0
2780970.0 2780790.0 2780612.0 2780434.0 2780257.0
2780080.0 2779904.0 2779729.0 2779555.0 2779381.0
2779208.0 2779035.0 2778863.0 2778692.0 2778521.0
2778351.0 2778181.0 2778012.0 2777844.0 2777676.0
2777510.0 2777343.0 2777177.0 2777012.0 2776847.0
2776683.0 2776520.0 2776356.0 2776194.0 2776022.0
2775847.0 2775672.0 2775498.0 2775324.0 2775152.0
2774980.0 2774808.0 2774638.0 2774468.0 2774298.0
2774131.0 2773963.0 2773796.0 2773630.0 2773465.0
2773300.0 2773136.0 2772973.0 2772811.0 2772649.0
2772488.0 2772328.0 2772168.0 2772010.0 2771852.0
2771694.0 2771537.0 2771382.0 2771225.0 2771069.0
2770913.0 2770758.0 2770604.0 2770451.0 2770298.0
2770146.0 2769995.0 2769844.0 2769694.0 2769545.0
2769397.0 2769247.0 2769102.0 2768955.0 2768810.0
2768664.0

```

```

    noi
    &&
    struc
    name = Ceiling      && Name of structure
    type = roof         && Type of structure
    shape = slab        && Shape of structure
    nslab = 10          && Number of nodes in structure
    chrlen = 14.6       && Characteristic length of structure (m)
    slarea = 157.       && Area (m2)
    tu,if = 305.       && initial uniform temperature (K)
    compound= conc conc conc conc conc conc conc conc conc conc
    x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
    eoi

    &&
    name = Walls        && Name of structure
    type = wall
    shape = slab
    nslab = 10
    chrlen = 5.49
    slarea = 241.
    tu,if = 305.
    compound= conc conc conc conc conc conc conc conc conc conc
    x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
    eoi

    &&
    condense
    ht-tran on on on on on
    overflow 3
    &&
    && Lower cell input
    &&

```

```

low-cell
  geometry= 107.      && Area of layers in lower cell      (m2)
  bc = 305           && Basement boundary condition temperature (K)
  concrete
    compos = 1      && Number of materials
                  conc && Material
                  23500. && Mass of material
    temp = 305.     && Initial temperature
  eoi
  pool
    temp = 305.     && Initial temperature
  eoi

eoi
&&
&& Engineered safety systems
&&
engineer  Spill i 3 2 0.
          overflow 3 2 3.05
eoi
&&
&& ----- Cell 4, Room 236 -----
cell 4
control
  nhtm=1 mxslab=11 nsoatm=2 nspatm=000 jconc=1 jpool=1 naensy=2
  nsoeng=1 upeng=4
eoi
title
  Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height      (m3, m)
  atmos = 3
          1.01e5      && Pressure
          305.        && Temperature
  o2 = 0.25
  n2 = 0.75
  h2ov = 0.05

&&
struc
  name = Walls      && Name of structure
  type = wall       && Type of structure
  shape = slab      && Shape of structure
  nslab = 10        && Number of nodes in structure
  chrlen = 5.49     && Characteristic length of structure (m)
  slarea = 450.     && Area (m2)
  tunif = 305.     && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc
  x = j. .015 .030 .015 .060 .075 .090 .105 .120 .135 .152
  eoi

&&
condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
  geometry= 91.9      && Area of layers in lower cell      (m2)
  bc = 305.           && Basement boundary condition temperature (K)
  concrete
    compos = 1      && Number of materials
                  conc && Material
                  6730. && Mass of material
    temp = 305.     && Initial temperature
  eoi
  pool
    temp = 305.     && Initial temperature
  eoi

```

```

    eoi
    &&
    && Engineered safety systems
    &&
    && Spillage from Room 236 to Room 115 via the connecting pipe chase
    &&
    engineer Spill1 1 4 3 5.79
    overflow 4 3 0.025
    eoi
    &&
    && Fire water sprinkler system, activated on high temperature.
    &&
    engineer Sprinklr 2 4 4 0.
    spray
    spdiam = .001 && Spray droplet diameter (m)
    sphite = 5.49 && Spray fall height (m)
    spsttm = 373. && Temperature at which system act °s (K)
    eoi
    source = 1 && Sprays provide 336 gpm (21.1 kg/s) after
    h2o1 = 3 && activation
    iflag = 2
    t = 0.0 100. 1.00e5
    mass = 21.1 21.1 21.1
    temp = 305. 305. 305.
    eoi
    eoi
    &&
    && ----- Cell 5, Balance of Plant -----
    cell 5
    control
    eoi
    title
    Balance of Plant
    geometry 1.87e5 38.8
    atmos=3 1.01e5 305.
    o2 0.20
    n2 0.75
    h2ov 0.05
    &&
    && ----- Cell 6, Environment -----
    cell 6
    control
    eoi
    title
    Environment Cell
    geometry 1.e10 1.e30
    atmos=3 1.01e5 305.
    o2 0.20
    n2 0.75
    h2ov 0.05
    eof

```

## LISTING 11 - CONTAIN Input for BS-5a

```

&& ===== Model Description =====
&&
&& File:
&&
&&   cnt005a.mdl
&&
&& Description:
&&
&&   BS-5. This input deck describes a five volume model of the B&W Plant
&&   auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 6 inch break in the HPI pump suction piping in
&&   room 115. Break flow is limited by the 2.5 inch HPI injection piping.
&&   This model does not include water aerosols (the dropout option is used).
&&
&&   a. this modification uses an Ocone blowdown from the B&W CSAU study
&&
&& Written by:
&&
&&   John Schroeder 7/91
&&
&& ===== Machine Control Input =====
cray
eol
&& ===== Global Input =====
&&
&& Section 3.2, p. 3-11
&&
&&   Atmospheric Gases
&&
&&   Material      Description
&&   -----
&&   o2             oxygen
&&   n2             nitrogen
&&   h2ov           steam
&&   h2o1           water
&&
control
  ncells = 6      && Number of cells
  ntitl  = 2      && Number of title lines
  ntzone = 5      && Number of time zones
  nac    = 0      && Number of aerosol groups
  nsectn = 0      && Number of aerosol sections
eol
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
material
  compound
    n2 o2          && Air
    h2ov h2o1     && Steam and water
    conc          && Structural materials
&&
&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17
&&
thermal          && Water-cooled reactor
&&
&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&

```

```

flows
&&
&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&&      1, 2, 3.
&&
&&      area(1,5) = 8.88    && Cross-sectional area of flow path      (m2)
&&      avl(1,5)  = 14.6   && Ratio of area to inertial length, A/L      (m)
&&      cfc(1,5)  = 1.00   && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&&      area(1,2) = 12.6
&&      avl(1,2)  = 20.7
&&      cfc(1,2)  = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&&      area(2,5) = 0.892
&&      avl(2,5)  = 1.46
&&      cfc(2,5)  = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&&      area(2,3) = 1.95
&&      avl(2,3)  = 3.2
&&      cfc(2,3)  = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&&      area(3,5) = 1.95
&&      avl(3,5)  = 3.2
&&      cfc(3,5)  = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&&      area(3,4) = 2.97
&&      avl(3,4)  = 4.88
&&      cfc(3,4)  = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&      10, 11, 12, and 13.
&&
&&      area(4,5) = 29.1
&&      avl(4,5)  = 157.
&&      cfc(4,5)  = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&      paths.
&&
&&      area(5,6) = 46.5
&&      avl(5,6)  = 250.
&&      cfc(5,6)  = 1.00
&&
&&      implicit
&&      dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments
&&
&&      elevcl(1) = 169.    && Center of mass elevation for Rm 105      (m)
&&      elevcl(2) = 169.    && Center of mass elevation for Rm 113      (m)
&&      elevcl(3) = 169.    && Center of mass elevation for Rm 115      (m)
&&      elevcl(4) = 175.    && Center of mass elevation for Rm 236      (m)
&&      elevcl(5) = 185.    && Center of mass elevation for Rm BOP      (m)
&&      elevcl(6) = 185.    && Center of mass elevation for Environment (m)
&&
&& Junctions

```



```

&&
  elevfp(1,5)= 167.
  elevfp(5,1)= 167.

  elevfp(1,2)= 170.
  elevfp(2,1)= 170.

  elevfp(2,5)= 172.
  elevfp(5,2)= 172.

  elevfp(2,3)= 170.
  elevfp(3,2)= 170.

  elevfp(3,5)= 170.
  elevfp(5,3)= 170.

  elevfp(3,4)= 172.
  elevfp(4,3)= 172.

  elevfp(4,5)= 173.
  elevfp(5,4)= 173.

  elevfp(5,6)= 211.
  elevfp(6,5)= 211.

&& ----- Aerosol Options -----
&&
&& Section 3.2.4, p. 3-29
&&
&& aerosol
&&   n2ov 1.0e-8 0.693
&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
  1800.          && Maximum CPU time limit          (s)
  0.             && Problem start time                (s)
&&
&& Time zone data
&&
&& System   Edit   End of
&&  Ts      Ts      Zone
&& -----
&&          1.     10.     10.
&&          5.     50.    100.
&&         20.    200.    500.
&&         50.   1000.  1000.
&&         50.   1000.  7200.
&& -----
&&
&&
&& ----- Output Control -----
&&
&& Section 3.2.7, p. 3-38
&&
shortedt      = 2      && System ts between short edits
longedt       = 1      && Ts edits between long edits
prflow        && Print intercell flow data
praer         && detailed aerosol inventories
prlow-cl      && lower cell model
prheat        && heat transfer structure model
prengsys      && engineered system model
title
  B&W Plant Auxiliary Building Steam Propagation Model
  Five Compartment Model -- BS-5
&&

```

```

&&
&& ===== Cell Input and Cell Control =====
&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eol
title
  Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e3 5.49 && Cell volume and height (m3, m)
  atmos = 3 && Number of materials
         1.01e5 && Pressure (Pa)
         305. && Temperature (K)
  n2 = 0.75 && Initial nitrogen fraction
  o2 = 0.20 && Initial oxygen fraction
  h2ov = 0.05 && Initial water vapor fraction
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrLen = 18.7 && Characteristic length of structure (m)
  slarea = 295. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .046 .092 .138 .184 .230 .276 .322 .358 .414 .457 && (m)
eol
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrLen = 5.49 && Characteristic length of structure (m)
  slarea = 298. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eol
&&
condense
ht-tran on on on on on
overflow 1
&&
&& Lower cell input
&&
low-cell
  geometry= 295. && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)
  concrete
    corpus = 1 && Number of materials
             conc && Material
             43200. && Mass of material
    temp = 305. && Initial temperature
eol
  pool
    temp = 305 && Initial temperature
eol
eol
&&
&& Engineered safety systems
&&
engineer Spill 1 1 5 .152

```

```

overflow 1 5 1.74
eoi
&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=0 naensy=1 jconc=5 jpool=1
eoi
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e2 6.10 && Cell volume and height (m3, m)
  atmos = 3
           1.01e5 && Pressure (Pa)
           305. && Temperature (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 17.7 && Characteristic length of structure (m)
  slarea = 86.4 && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 254. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 .396 && (m)
eoi
&&
condense
ht-tran on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell
  geometry= 86.4 && Area of layers in lower cell (m2)
  bc = 305. && Basement boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
             conc && Material
             19000. && Mass of material (kg)
    temp = 305. && Initial temperature (K)
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&
&& Engineered safe+v systems
&&
engineer Spill 1 2 1 0.0
overflow 2 1 3.05

```

```

eol
&&
&& ----- Cell 3, Room 115 -----
cell 3
control
  nhtm=2 mxslab=11 nsoatm=1 nspatm=10 naensy=1 jconc=1 jpool=1
eol
title
  Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height (m3, m)
  atmos = 3
           1.01e5 && Pressure
           305. && Temperature
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
source=1
&&
&& Blowdown of RCS - Ocone blowdown
&&
  h2ov = 6
  iflag = 2
  t = 0. 500. 501. 2000. 2001.
      4000.
  mass = 190.5 190.5 36.3 36.3 36.3
        36.3
  enth = 1250000. 1250000. 1900000. 2300000. 2000000.
        1500000.
eol
&&
&& struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chr len = 14.6 && Characteristic length of structure (m)
  slarea = 107 && Area (m2)
  tunif = 305 && initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eol
&&
&&
  name = Walls && Name of structure
  type = wall
  shape = slab
  nslab = 10
  chr len = 5.49
  slarea = 241.
  tunif = 305.
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eol
&&
&& condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
&&
low-cell
  geometry 107. && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)

```

```

concrete
  compos = 1      && Number of materials
              conc && Material
              23500. && Mass of material
  temp = 305.    && Initial temperature
eoi
pool
  temp = 305.    && Initial temperature
eoi
eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 3 2 0.
  overflow 3 2 3.05
eoi
&&
&& ----- Cell 4, Room 236 -----
csl 4
control
  nhtm=1 mxslab=11 nsoatm=2 nspatm=000 jconc=1 jpool=1 naensy=2
  nsoeng=1 nspeng=4
eoi
title
  Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height (m3, m)
  atmos = 3
              1.01e5 && Pressure
              305. && Temperature
  o2 = 0.25
  n2 = 0.75
  h2ov = 0.05
&&
struc
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 450. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .015 .030 .045 .060 .075 .090 .105 .120 .135 .152
eoi
&&
condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
  geometry= 91.9 && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
              conc && Material
              6730. && Mass of material
    temp = 305. && Initial temperature
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&

```

```

&& Engineered safety system:
&&
&& Spillage from Room 236 to Room 237 via the connecting pipe chase
&&
engineer Spill 1 4 3 5.71
overflow 4 3 0.025
eol
&&
&& Fire water sprinkler system, activated on high temperature.
&&
engineer Sprinklr 2 4 4 0.
spray
  spdiam = .001 && Spray droplet diameter (m)
  sphte = 5.49 && Spray fall height (m)
  spsttm = 373. && Temperature at which system activates (K)
eol
source = 1 && Sprays provide 336 gpm (21.1 kg/s) after
  h2o1 = 2 && activation
  iflag = 2
  + = 0.0 100. 1.00e5
  mass = 21.1 21.1 21.1
  temp = 305. 305. 305.
eol
eol
&&
&& ----- Cell 5, Balance of Plant -----
cell 5
control
eol
title
  Balance of Plant
geometry 1.87e5 38.8
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05
&&
&& ----- Cell 6, Environment -----
cell 6
control
eol
title
  Environment Cell
geometry 1.e10 1.e30
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05
eol
eof

```

## LISTING 12 - CONTAIN Input for BS-5b

```

&& ----- Model Description -----
&&
&& File:
&&   cn.005b.mdl
&&
&& Description:
&&
&&   BS-5. This input deck describes a five volume model of the B&W Plant
&&   auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 6 inch break in the HPI pump suction piping in
&&   room 115. Break flow is limited by the 2.5 inch HPI injection piping.
&&   This model does not include water aerosols (the dropout option is used).
&&
&&   a. this modification uses an Ocone blowdown from the B&W CSAU study
&&
&&   b. this modification uses an Ocone blowdown from the B&W CSAU study
&&      modified so the break enthalpy corresponds to fluid with a void
&&      fraction of 0. before 500 seconds, and 1. after 500 seconds.
&&
&& Written by:
&&   John Schroeder 7/91
&&
&& ----- Machine Control Input -----
cray
eol
&& ----- Global Input -----
&&
&& Section 3.2, p. 3-11
&&
&&   Atmospheric Gases
&&
&&   Material      Description
&&   -----
&&   o2            oxygen
&&   n2            nitrogen
&&   h2ov          steam
&&   h2ol          water
&&
&& control
&&   ncells = 6      && Number of cells
&&   ntitl  = 2      && Number of title lines
&&   ntzone = 5      && Number of time zones
&&   nac    = 0      && Number of aerosol groups
&&   nsectn = 0      && Number of aerosol sections
&&
&& eol
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
&& material
&&   compound
&&     n2 o2      && Air
&&     h2ov h2ol  && Steam and water
&&     conc      && Structural materials
&&
&&
&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17
&&
&& thermal      && Water-cooled reactor
&&

```

```

&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
&& flows
&&
&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&&      1, 2, 3.
&&
&&      area(1,5) = 8.88      && Cross-sectional area of flow path      (m2)
&&      avl(1,5) = 14.6      && Ratio of area to inertial length, A/L      (m)
&&      cfc(1,5) = 1.00      && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&&      area(1,2) = 12.6
&&      avl(1,2) = 20.7
&&      cfc(1,2) = 1.01
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&&      area(2,5) = 0.092
&&      avl(2,5) = 1.46
&&      cfc(2,5) = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&&      area(2,3) = 1.95
&&      avl(2,3) = 3.2
&&      cfc(2,3) = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&&      area(3,5) = 1.95
&&      avl(3,5) = 3.2
&&      cfc(3,5) = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&&      area(3,4) = 2.97
&&      avl(3,4) = 4.88
&&      cfc(3,4) = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&      10, 11, 12, and 13.
&&
&&      area(4,5) = 29.1
&&      avl(4,5) = 157.
&&      cfc(4,5) = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&      paths.
&&
&&      area(5,6) = 46.5
&&      avl(5,6) = 250.
&&      cfc(5,6) = 1.00
&&
&&      implicit
&&      dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments
&&
&&      elevcl(1) = 169.      && Center of mass elevation for Rm 105      (m)
&&      elevcl(2) = 169.      && Center of mass elevation for Rm 113      (m)
&&      elevcl(3) = 169.      && Center of mass elevation for Rm 115      (m)
&&      elevcl(4) = 175.      && Center of mass elevation for Rm 236      (m)

```



```

elevc(5) = 185.    && Center of mass elevation for Rm BOP          (m)
elevc(6) = 185.    && Center of mass elevation for Environment      (m)
&&
&& Junctions
&&
elevfp(1,5)= 167.
elevfp(5,1)= 167.

elevfp(1,2)= 170.
elevfp(2,1)= 170.

elevfp(2,5)= 172.
elevfp(5,2)= 172.

elevfp(2,3)= 170.
elevfp(3,2)= 170.

elevfp(3,5)= 170.
elevfp(5,3)= 170.

elevfp(4,5)= 172.
elevfp(5,4)= 172.

elevfp(4,5)= 173.
elevfp(5,4)= 173.

elevfp(5,6)= 211.
elevfp(6,5)= 211.
&&
&& ----- Aerosol Options -----
&&
&& See also 3.2.4, p. 3-29
&&
&& aerosol
&&   h2ov 1.0e-8 0.693
&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
  1800.    && Maximum CPU time limit          (s)
  0.       && Program start time                 (s)
&&
&& Time zone data
&&
&& System   Edit   End of
&&  Ts      Ts      Zone
&& -----
&&      1.    10.    10.
&&      5.    30.    100.
&&     20.   200.    500.
&&     50.   100.   1000.
&&     50.   100.   7200.
&&
&& -----
&&
&& ----- Output Control -----
&&
&& Section 3.2.7, p. 3-38
&&
shortedt   = 0    && System ts between short edits
longedt    = 1    && Ts edits between long edits
crflow     && Print intercell flow data
praer      && detailed aerosol inventories
prlow-cl   && lower cell model
prheat     && heat transfer structure model
prengsys   && engineered system model

```

```

title
      B&W Plant Auxiliary Building Steam Propagation Model
      Five Compartment Model -- BS-5

&&
&&
&& ===== Cell Input and Cell Control =====
&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=2 mxslab=11 nsoatm=0 ncr=7 nseasy=1 jconc=1 jpool=1
eoi
title
      Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e3 5.49 && Cell volume and height (m3)
  atmos = 3 && Number of materials
         1.01e5 && Pressure (Pa)
         305. && Temperature (K)
  n2 = 0.75 && Initial nitrogen fraction
  o2 = 0.20 && Initial oxygen fraction
  h2ov = 0.05 && Initial water vapor fraction

struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 18.7 && Characteristic length of structure (m)
  slarea = 295. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .046 .092 .138 .184 .230 .276 .322 .368 .414 .457 && (m)
eoi

&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 298. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eoi

&&
condense
ht-tran on on on on on
overflow 1
&&
&& Lower cell input
&&
low-cell
  geometry= 295. && Area of layers in lower cell (m2)
  bc = 305. && Bas. at boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
            conc && Material
            43200. && Mass of material
    temp = 305. && Initial temperature
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi

```

```

&&
&& Engineered safety systems
&&
engineer Spill 1 1 5 .152
overflow 1 5 1.74
eoi
&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  nhtm=2 mxslab=11 nsoatm=0 nspatm=0 naensy=1 jconc=5 jpool=1
eoi
title
  Cell 2, Room 113
&&
%& Upper Cell Input
&&
geometry 3.794e2 6.10 && Cell volume and height (m3, m)
  atmos = 3
           1.01e5 && Pressure (Pa)
           305. && Temperature (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
&& struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chlren = 17.7 && Characteristic length of structure (m)
  slarea = 86.4 && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chlren = 5.49 && Characteristic length of structure (m)
  slarea = 254. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 .395 && (m)
eoi
&&
condense
ht-tran on on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell
  geometry= 86.4 && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
             conc && Material
             19000. && Mass of material (kg)
    temp = 305. && Initial temperature (K)
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&

```

```

&& Engineered safety systems
&&
engineer Spill 1 2 1 0.0
overflow 2 1 3.05
eoi
&&
&& ----- Cell 3, Room 115 -----
cell 3
control
  nhtm=2 mxslab=11 nsoatm=1 nspatm=10 naensy=1 jconc=1 jpool=1
eoi
title
  Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height (m3, m)
  atmos = 3
          1.01e5 && Pressure
          305. && Temperature
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
source=1
&&
&& Blowdown of RCS - Ocone blowdown, void fraction 1. after 500 seconds
&&
  h2ov = 4
  iflag = 2
  t = 0. 500. 501. 4000.
  mass = 190.5 190.5 36.3 36.3
  enth = 1356000. 1356000. 2747000. 2747000.
eoi
&&
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chr len = 14.6 && Characteristic length of structure (m)
  slarea = 107. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
  name = Walls && Name of structure
  type = wall
  shape = slab
  nslab = 10
  chr len = 5.49
  slarea = 241.
  tunif = 305.
  compound= ronc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi
&&
condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
&&
low-cell
  geometry= 107. && Area of layers in lower cell (m2)

```

```

bc = 305.      && Basemat boundary condition temperature      (K)
concrete
  compos = 1    && Number of materials
              conc && Material
              23500. && Mass of material
  temp = 305.  && Initial temperature
eoi
pool
  temp = 305.  && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
engineer spill 1 3 2 0.
overflow 3 2 3.05
eoi
&&
&& ----- Cell 4, Room 236 -----
cell 4
control
  nhtm=1 mxslab=11 nsoatm=2 nspatm=000 jconc=1 jpool=1 naensy=2
  nsoeng=1 nspeng=4
eoi
title
  Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height      (m3, m)
  atmos = 3
          1.01e5      && Pressure
          305.      && Temperature
  o2 = 0.25
  n2 = 0.75
  h2ov = 0.05
&&
&& struc
  name = Walls      && Name of structure
  type = wall      && Type of structure
  shape = slab      && Shape of structure
  nslab = 10      && Number of nodes in structure
  chr len = 5.49      && Characteristic length of structure      (m)
  slarea = 450.      && Area      (m2)
  tunif = 305.      && Initial uniform temperature      (K)
  compound= conc conc conc conc conc conc conc conc conc
  x = 0. .015 .030 .045 .060 .075 .090 .105 .120 .135 .152
eoi

&&
condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
  geometry= 91.9      && Area of layers in lower cell      (m2)
  bc = 305.      && Basemat boundary condition temperature      (K)
  concrete
    compos = 1    && Number of materials
              conc && Material
              6730. && Mass of material
    temp = 305.  && Initial temperature
  eoi
  pool
    temp = 305.  && Initial temperature
  eoi
eoi

```

```

&&
&& Engineered safety systems
&&
&& Spillage from Room 236 to Room 115 via the connecting pipe chase
&&
engineer Spill 1 4 3 5.79
overflow 4 3 0.025
eof
&&
&& Fire water sprinkler system, activated on high temperature.
&&
engineer Sprinklr 2 4 4 0.
spray
  spdiam = .001    && Spray droplet diameter      (m)
  sphite = 5.49   && Spray fall height          (m)
  spsttm = 373.   && Temperature at which system activates (K)
eof
source = 1        && Sprays provide 336 gpm (21.1 kg/s) after
  h2o1 = 3        && activation
  iflag = 2
  t = 0.0         100.    1.00e5
  mass = 21.1     21.1    21.1
  temp = 305.     305.    305.
eof
eof
&&
&& ----- Cell 5, Balance of Plant -----
cell 5
control
eof
title
      Balance of Plant
geometry 1.87e5 38.8
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05
&&
&& ----- Cell 6, Environment -----
cell 6
control
eof
title
      Environment Cell
geometry 1.310 1.e30
atmos=3 1.01e5 305.
  o2 0.20
  n2 0.75
  h2ov 0.05
eof

```

## LISTING 13 - CONTAIN Input for BS-5c

```

&& ----- Model Description -----
&&
&& File:
&&
&&   cnt005c.mdl
&&
&& Description:
&&
&&   BS-5. This input deck describes a five volume model of the B&W Plant
&&   auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 6 inch break in the HPI pump suction piping in
&&   room 115. Break flow is limited by the 2.5 inch HPI injection piping.
&&   This model does not include water aerosols (the dropout option is used).
&&
&&   a. this modification uses an Ocone blowdown from the B&W CSAU study
&&
&&   b. this modification uses an Ocone blowdown from the B&W CSAU study
&&   modified so the break enthalpy corresponds to fluid with a void
&&   fraction of 0. before 500 seconds, and 1. after 500 seconds.
&&
&&   c. this modification adds 1000 lb of metal mass to each compartment.
&&
&& Written by:
&&
&&   John Schroeder 7/91
&&
&& ----- Machine Control Input -----
cray
eol
&& ----- Global Input -----
&&
&& Section 3.2, p. 3-11
&&
&&   Atmospheric Gases
&&
&&   Material      Description
&&   -----
&&   o2             oxygen
&&   n2             nitrogen
&&   h2ov          steam
&&   h2o1          water
&&
&& control
&&   ncells = 6      && Number of cells
&&   ntitl  = 2      && Number of title lines
&&   ntzone = 5      && Number of time zones
&&   nac    = 0      && Number of aerosol groups
&&   nsectn = 0      && Number of aerosol reactions
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
&& material
&&   compoun
&&     n2 o2        && Air
&&     h2ov h2o1    && Steam and water
&&     nnc ss      && Structural materials
&&
&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17

```

```

&&
+hermal                && Water-cooled reactor
&&
&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
flows
&&
&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&&           1, 2, 3.
&&
&&   area(1,5) = 9.88    && Cross-sectional area of flow path      (m2)
&&   avl(1,5)  = 14.6   && Ratio of area to normal length, A/L      (m)
&&   cfc(1,5)  = 1.00   && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&&   area(1,2) = 12.6
&&   avl(1,2)  = 20.7
&&   cfc(1,2)  = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&&   area(2,5) = 0.892
&&   avl(2,5)  = 1.46
&&   cfc(2,5)  = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&&   area(2,3) = 1.95
&&   avl(2,3)  = 3.2
&&   cfc(2,3)  = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&&   area(3,5) = 1.95
&&   avl(3,5)  = 3.2
&&   cfc(3,5)  = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&&   area(3,4) = 2.97
&&   avl(3,4)  = 4.88
&&   cfc(3,4)  = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&           10, 11, 12, and 13.
&&
&&   area(4,5) = 29.1
&&   avl(4,5)  = 157.
&&   cfc(4,5)  = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&           paths.
&&
&&   area(5,6) = 46.5
&&   avl(5,6)  = 250.
&&   cfc(5,6)  = 1.00
&&
&& implicit
&& dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments
&&
&&   elev(1) = 169.    && Center of mass elevation for Rm 105      (m)

```



```

elevcl(2) = 169.  && Center of mass elevation for Rm 113      (m)
elevcl(3) = 169.  && Center of mass elevation for Rm 115      (m)
elevcl(4) = 175.  && Center of mass elevation for Rm 236      (m)
elevcl(5) = 185.  && Center of mass elevation for Rm BOP      (m)
elevcl(6) = 185.  && Center of mass elevation for Environment (m)
&&
&& Junctions
&&
elevfp(1,5)= 167.
elevfp(5,1)= 167.

elevfp(1,2)= 170.
elevfp(2,1)= 170.

elevfp(2,5)= 172.
elevfp(5,2)= 172.

elevfp(2,3)= 170.
elevfp(3,2)= 170.

elevfp(3,5)= 170.
elevfp(5,3)= 170.

elevfp(3,4)= 172.
elevfp(4,3)= 172.

elevfp(4,5)= 173.
elevfp(5,4)= 173.

elevfp(5,6)= 211.
elevfp(6,5)= 211.
&&
&& ----- Aerosol Options -----
&&
&& Section 3.2.4, p. D-29
&&
&& aerosol
&&   h2ov 1.0e-8 0.693
&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
1800.          && Maximum CPU time limit      (s)
0.             && Problem start time                    (s)
&&
&& Time zone data
&&
&& System  Edit  End of
&&  Ts      Ts   Zone
&& -----
&&      1.    10.   10.
&&      5.    50.  100.
&&     20.   200.  500.
&&     50.   100. 1000.
&&     50.   100. 7200.
&&
&& -----
&&
&& ----- Output Control -----
&&
&& Section 3.2.7, p. 3-38
&&
shortedt      = 2      && System ts between short edits
longedt       = 1      && Ts edits between long edits
prflow        && Print intercell flow data
praer         && detailed aerosol inventories

```

```

prlow-cl          &&    lower cell model
prheat           &&    heat transfer structure model
prengsys         &&    engineered system model
title
                B&W Plant Auxiliary Building Steam Propagation Model
                Five Compartment Model -- BS-5

&&
&&
&& ===== Cell Input and Cell Control =====
&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
    nhtm=3 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eol
title
    Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e3 5.49 && Cell volume and height (m3, m)
    atmos = 3 && Number of materials
           1.01e5 && Pressure (Pa)
           305. && Temperature (K)
    n2 = 0.75 && Initial nitrogen fraction
    o2 = 0.20 && Initial oxygen fraction
    h2ov = 0.05 && Initial water vapor fraction

struc
    name = Ceiling && Name of structure
    type = roof && Type of structure
    shape = slab && Shape of structure
    nslab = 10 && Number of nodes in structure
    chrlen = 18.7 && Characteristic length of structure (m)
    slarea = 295. && Area (m2)
    tunif = 305. && Initial uniform temperature (K)
    compound = conc conc conc conc conc conc conc conc conc
    x = 0. .046 .092 .138 .184 .230 .276 .322 .368 .414 .457 && (m)
eol

&&
    name = Walls && Name of structure
    type = wall && Type of structure
    shape = slab && Shape of structure
    nslab = 10 && Number of nodes in structure
    chrlen = 5.49 && Characteristic length of structure (m)
    slarea = 298. && Area (m2)
    tunif = 305. && Initial uniform temperature (K)
    compound = conc conc conc conc conc conc conc conc conc
    x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eol

&&
    name = Metals && Name of structure
    type = wall && Type of structure
    shape = slab && Shape of structure
    nslab = 10 && Number of nodes in structure
    chrlen = 5.49 && Characteristic length of structure (m)
    slarea = 4.6 && Area (m2)
    tunif = 305. && Initial uniform temperature (K)
    compound = ss ss ss ss ss ss ss ss ss
    x = 0. .001 .002 .007 .004 .005 .006 .007 .008 .009 .013 && (m)
eol

&&
condense
ht-tran on on on on on
overflow 1
&&
&& Lower cell input

```

```

&&
low-cell
  geometry= 295.    && Area of layers in lower cell          (m2)
  bc = 305.    && Basemat boundary condition temperature    (K)
  concrete
    compos = 1    && Number of materials
    conc = 43200. && Mass of material
    temp = 305.   && Initial temperature
  eoi
  pool
    temp = 305.   && Initial temperature
  eoi

eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 1 5 .152
         overflow 1 5 1.74
eoi
&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  nhtm=3 mxslab=11 nsoatm=0 nspatm=0 naensy=1 jconc=5 jpool=1
eoi
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e2 6.10 && Cell volume and height          (m3, m)
  aimos = 3
    1.01e5 && Pressure (Pa)
    305.   && Temperature (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
&& struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chr len = 17.7 && Characteristic length of structure (m)
  slarea = 85.4 && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
  eoi

&&
&& name = Walls && Name of structure
&& type = wall && Type of structure
&& shape = slab && Shape of structure
&& nslab = 10 && Number of nodes in structure
&& chr len = 5.49 && Characteristic length of structure (m)
&& slarea = 254. && Area (m2)
&& tunif = 305. && Initial uniform temperature (K)
&& compound= conc conc conc conc conc conc conc conc conc conc
&& x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 .396 && (m)
&& eoi

&&
&& name = Metals && Name of structure
&& type = wall && Type of structure
&& shape = slab && Shape of structure
&& nslab = 10 && Number of nodes in structure
&& chr len = 5.49 && Characteristic length of structure (m)
&& slarea = 4.6 && Area (m2)

```

```

tunif = 305.          && Initial uniform temperature (K)
compound = ss ss ss ss ss ss ss ss ss ss
x = 0.001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eol

&&
condense
ht-tran on on on on on
overflow 2
- &
&& Lower cell input
&&
low-cell
geometry= 86.4      && Area of layers in lower cell (m2)
bc = 305.          && Basemat boundary condition temperature (K)
concrete
  compos = 1        && Number of materials
  conc = 19000.     && Material
  mass = 19000.     && Mass of material (kg)
  temp = 305.       && Initial temperature (K)
eol
pool
  temp = 305.       && Initial temperature
eol

eol
&&
&& Engineered safety systems
&&
engineer Spill 1 2 1 0.0
overflow 2 1 3.0
eol
&&
&& ----- Cell 3, Room 115 -----
cell 3
control
  nhtn=3 mxs{wb}=11 nsoatm=1 nspatm=10 naensy=1 jcunc=1 jpool=1
eol
title
  Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height (m3, m)
atmos = 3
  p = 1.01e5 && Pressure
  t = 305. && Temperature
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
source=1
&&
&& Blowdown of RCS - Dcone blowdown, void fraction 1, after 500 seconds
&&
h2ov = 4
irlag = 2
t = 0. 500. 501. 4000.
mass = 190.5 190.5 36.3 36.3
enth = 1354000. 1356000. 2747000. 2747000.
eol
&&
struc
name = Ceiling && Name of structure
type = roof && Type of structure
shape = slab && Shape of structure
nslab = 10 && Number of nodes in structure
chr.len = 14.6 && Characteristic length of structure (m)

```

```

slarea = 707.          && Area (m2)
tunif = 305.          && Initial uniform temperature (K)
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi

&&
name = Walls          && Name of structure
type = wall
shape = slab
nslab = 10
chrlen = 5.49
slarea = 241.
tunif = 305.
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi

&&
name = Metals         && Name of structure
type = wall           && Type of structure
shape = slab         && Shape of structure
nslab = 10           && Number of nodes in structure
chrlen = 5.49        && Characteristic length of structure (m)
slarea = 4.6         && Area (m2)
tunif = 305.         && Initial uniform temperature (K)
compound = ss ss ss ss ss ss ss ss ss ss
x = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eoi

&&
condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
&&
low-cell;
geometry= 107.        && Area of layers in lower cell (m2)
bc = 305.            && Basement boundary condition temperature (K)
concrete
corpos = 1          && Number of materials
conc              && Material
23500.            && Mass of material
temp = 305.         && Initial temperature
eoi
pool
temp = 305.         && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
engineer spill 1 3 2 0.
overflow 3 2 3.05
eoi
&&
&& ----- Cell 4, Room 236 -----
cell 4
control
nhtm=2 mxslab=11 nsoatm=2 nspatm=000 jconc=1 jpool=1 naensy=2
nsoeng=1 nspeng=4
eoi
title
Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height (m3, m)
atmos = 3
1.01e5 && Pressure

```

```

                305.          && Temperature
o2 = 0.25
n2 = 0.75
h2ov = 0.05
&&
&& struc
name = Wall;          && Name of structure
type = wall          && Type of structure
shape = slab         && Shape of structure
nslab = 10           && Number of nodes in structure
chrLen = 5.49       && Characteristic length of structure (m)
slarea = 450.       && Area (m2)
tunif = 305.        && Initial uniform temperature (K)
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .015 .030 .045 .060 .075 .090 .105 .120 .135 .152
eoi

&&
name = Metals        && Name of structure
type = wall          && Type of structure
shape = slab         && Shape of structure
nslab = 10           && Number of nodes in structure
chrLen = 5.49       && Characteristic length of structure (m)
slarea = 4.6        && Area (m2)
tunif = 305.        && Initial uniform temperature (K)
compound = ss ss ss ss ss ss ss ss ss ss
x = 0. .001 .007 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eoi

&&
condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
geometry= 91.3      && Area of layer in lower cell (m2)
bc = 305.          && Basement boundary condition temperature (K)
concrete
compos = 1         && Number of materials
conc          && Material
             6730.  && Mass of material
Cmp = 305.        && Initial temperature
eoi
pool
temp = 305.       && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
&& Spillage from Room 236 to Room 115 via the connecting pipe chase
&&
engineer Spill 1 4 3 5.79
overflow 4 3 0.025
eoi
&&
&& Fire water sprinkler system, activated on high temperature.
&&
engineer Sprinklr 2 4 4 0.
spray
spdiam = .001      && Spray droplet diameter (m)
sphte = 5.49       && Spray fall height (m)
spsttm = 373.     && Temperature at which system activates (K)
eoi
source = 1         && Sprays provide 336 gpm (21.1 kg/s) after
h2ol = 3          && activation
iflag = 2
t = 0.0 100. 1.00e5

```

```

      mass = 21.1  21.1  21.1
      temp = 305.  305.  305.
    eof
  eof
  &&
  && ----- Cell 5, Balance of Plant -----
  cell 5
  control
  eof
  title
    Balance of Plant
  geometry 1.87e5 38.8
  atmos=3 1.01e5 305.
    o2 0.20
    n2 0.75
    h2ov 0.05
  &&
  && ----- Cell 6, Environment -----
  cell 6
  control
  eof
  title
    Environment Cell
  geometry 1.e10 1.e30
  atmos=3 1.01e5 305.
    o2 0.20
    n2 0.75
    h2ov 0.05
  eof

```

## LISTING 4 - CONTAIN Input for BS-5d

```

&& ----- Model Description -----
&&
&& File:
&& cnt005d.mdl
&&
&& Description:
&&
&& BS-5. This input deck describes a five volume model of the B&W Plant
&& auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&& The steam source is a 6 inch break in the HPI pump suction piping in
&& room 115. Break flow is limited by the 2.5 inch HPI injection piping.
&& This model does not include water aerosols (the dropout option is used).
&&
&& a. this modification uses an Ocone blowdown from the B&W CSAU study
&&
&& b. this modification uses an Ocone blowdown from the B&W CSAU study
&& modified so the break reactivity corresponds to fluid with a void
&& fraction of 0. before 10 seconds, and 1. after 500 seconds.
&&
&& c. this modification adds 1000 lb of metal mass to each compartment.
&&
&& d. this modification changes the 1000 lb of metal mass to 10,000 lb.
&&
&&
&& Written by:
&& John Schroeder 7/91
&&
&& ----- Machine Control Input -----
cray
eoi
&& ----- Global Input -----
&&
&& Section 3.2, p. 3-11
&&
&& Atmospheric Gases
&&
&& Material Description
&& -----
&& o2 oxygen
&& n2 nitrogen
&& h2ov steam
&& h2ol water
&&
control
ncalls = 6 && Number of cells
ntitl = 2 && Number of title lines
nitzone = 5 && Number of time zones
nac = 0 && Number of aerosol groups
nsectn = 0 && Number of aerosol sections
eoi
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
material
compound
n2 o2 && Air
h2ov h2ol && Steam and water
conc ss && Structural materials
&&
&& ----- Reactor Type -----

```



```

&&
&& Section 3.2.2, p. 3-17
&&
thermal          && Water-cooled reactor
&&
&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
flows
&&
&& Junction 1 - Room 100 to Balance of Plant, includes flow paths
&&           1, 2, 3.
&&
&&   area(1,5) = 8.88      && Cross-sectional area of flow path      (m2)
&&   avl(1,5)  = 14.6     && Ratio of area to inertial length, A/L      (m)
&&   cfc(1,5)  = 1.00     && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&&   area(1,2) = 12.6
&&   avl(1,2)  = 20.7
&&   cfc(1,2)  = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&&   area(2,5) = 0.892
&&   avl(2,5)  = 1.46
&&   cfc(2,5)  = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&&   area(2,3) = 1.95
&&   avl(2,3)  = 3.2
&&   cfc(2,3)  = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&&   area(3,5) = 1.95
&&   avl(3,5)  = 3.2
&&   cfc(3,5)  = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&&   area(3,4) = 2.97
&&   avl(3,4)  = 4.88
&&   cfc(3,4)  = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&           10, 11, 12, and 13.
&&
&&   area(4,5) = 29.1
&&   avl(4,5)  = 157.
&&   cfc(4,5)  = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&           paths.
&&
&&   area(5,6) = 49.5
&&   avl(5,6)  = 250.
&&   cfc(5,6)  = 1.00
&&
&& implicit
&& dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments

```

```

&&
elevcl(1) = 169.   && Center of mass elevation for Rm 105      (m)
elevcl(2) = 169.   && Center of mass elevation for Rm 113      (m)
elevcl(3) = 169.   && Center of mass elevation for Rm 115      (m)
elevcl(4) = 175.   && Center of mass elevation for Rm 236      (m)
elevcl(5) = 185.   && Center of mass elevation for Rm BOP      (m)
elevcl(6) = 185.   && Center of mass elevation for Environment (m)

```

```

&&
&& Junctions
&&

```

```

elevfp(1,5)= 167.
elevfp(5,1)= 167.

```

```

elevfp(1,2)= 170.
elevfp(2,1)= 170.

```

```

elevfp(2,5)= 172.
elevfp(5,2)= 172.

```

```

elevfp(2,3)= 170.
elevfp(3,2)= 170.

```

```

elevfp(3,5)= 170.
elevfp(5,3)= 170.

```

```

elevfp(3,4)= 172.
elevfp(4,3)= 172.

```

```

elevfp(4,.)= 173.
elevfp(5,4)= 173.

```

```

elevfp(5,6)= 211.
elevfp(6,5)= 211.

```

```

&&
&& ----- Aerosol Options -----
&&

```

```

&& Section 3.2.4, p. 3-29

```

```

&& aerosol
&&   h2ov 1.0e-8 0.693

```

```

&& ----- Times -----

```

```

&& Section 3.2.6, p. 3-36

```

```

&&
times
1800.   && Maximum CPU time limit      (s)
0.       && Problem start time                (s)

```

```

&& Time zone data

```

```

&&
&& System  Edit  End of
&&   Ts     Ts     one
&& -----
&&      1.    10.    10.
&&      5.    50.   100.
&&     20.   200.   500.
&&     50.   100.  1000.
&&     50.   100.  7200.

```

```

&& ----- Output Control -----
&&

```

```

&& Section 3.2.7, p. 3-38

```

```

&&
shortedt = 2   && System ts between short edits
longedt  = 1   && Ts edits between long edits

```

```

prflow      && Print intercell flow data
praer      && detailed aerosol inventories
prlow-cl   && lower cell model
prheat     && heat transfer structure model
prengsys   && engineered system model
title
      B&W Plant Auxiliary Building Steam Propagation Model
      Five Compartment Model -- BS-5

&&
&&
&& ===== Cell Input and Cell Control =====
&&
&& section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=3 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
foi
title
  Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e3 5.49 && Cell volume and height (m3, m)
  atmos = 3 && Number of materials
         1.01e5 && Pressure (Pa)
         305. && Temperature (K)
  n2 = 0.75 && Initial nitrogen fraction
  o2 = 0.20 && Initial oxygen fraction
  h2ov = 0.05 && Initial water vapor fraction

struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 18.7 && Characteristic length of structure (m)
  slarea = 295. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .046 .092 .138 .184 .230 .276 .322 .368 .414 .457 && (m)
  eoi

&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 298. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
  eoi

&&
  name = Metals && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 46. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = ss ss ss ss ss ss ss ss ss ss
  x = 0. .031 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
  eoi

&&
condense
ht-tran on on on on on
overflow 1

```

```

&&
&& Lower cell input
&&
low-cell
  geometry= 295.      && Area of layers in lower cell      (m2)
    bc = 305.      && Basemat boundary condition temperature (K)
    concrete
      compos = 1      && Number of materials
        conc      && Material
          43200.    && Mass of material
        temp = 305.  && Initial temperature
    eol
    pool
      temp = 305.  && Initial temperature
    eol
eol
&&
&& Engineered safety systems
&&
engineer  Spill 1 1 5 .152
overflow 1 5 1.74
eol
&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  rhtm=3 mxslab=11 nsoatm=0 nspatm=0 naensy=1 jconc=5 jpool=1
eol
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e2 6.10 && Cell volume and height      (m3, m)
  atmos   = 3
    1.01e5 && Pressure      (Pa)
    305.   && Temperature  (K)
    o2 = 0.20
    n2 = 0.75
    h2ov = 0.05
&&
&& struc
  name = Ceiling      && Name of structure
  type = roof         && Type of structure
  shape = slab        && Shape of structure
  nslab = 10          && Number of nodes in structure
  chrlen = 17.7       && Characteristic length of structure (m)
  slarea = 86.4       && Area (m2)
  tunif = 305.       && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .263 .305 && (m)
  eol
&&
  name = Walls        && Name of structure
  type = wall         && Type of structure
  shape = slab        && Shape of structure
  nslab = 10          && Number of nodes in structure
  chrlen = 5.49       && Characteristic length of structure (m)
  slarea = 254.       && Area (m2)
  tunif = 305.       && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .010 .080 .120 .160 .200 .240 .280 .320 .360 .396 && (m)
  eol
&&
  name = Metals       && Name of structure
  type = wall         && Type of structure
  shape = slab        && Shape of structure
  nslab = 10          && Number of nodes in structure

```

```

chrLen = 5.49      && Characteristic length of structure (m)
slarea = 46.      && Area (m2)
tunif = 305.     P& Initial uniform temperature (K)
compound = ss ss ss ss ss ss ns ss ss ss
x = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eoi

&&
condense
ht-tran on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell
geometry= 86.4      && Area of layers in lower cell (m2)
bc = 305.          && Basemat boundary condition temperature (K)
concrete
  compos = 1      && Number of materials
              conc && Material
              19000. && Mass of material (kg)
  temp = 305.     && Initial temperature (K)
eoi
pool
  temp = 305.     && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 2 1 0.0
         overflow 2 1 3.05
eoi
&&
&& ----- Cell 3, Room 115 -----
cell 3
control
  nhtm=3 mxslab=11 nsostm=1 nspatm=10 naensy=1 jcrnc=1 jpool=1
eoi
title
  Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height (m3, m)
  atmos = 3
          1.01e5      && Pressure
          305.        && Temperature
  p2 = 0.20
  n2 = 0.75
  h2ov = 0.05
source=1
&&
&& Blowdown of RCS - Ocone blowdown, void fraction 1. after 500 seconds
&&
  h2ov = 4
  iflag = 2
  t = 0. 500. 501. 4000.

  mass = 190.5 190.5 36.3 36.3

  enth = 1356000. 1356000. 2747000. 2747000.

eoi
&&
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure

```

```

nslab = 10          && Number of nodes in structure
chrLen = 14.6      && Characteristic length of structure (m)
slarea = 107.     && Area (m2)
tunif = 305.      && Initial uniform temperature (K)
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi

&&
name = Walls      && Name of structure
type = wall
shape = slab
nslab = 10
chrLen = 5.49
slarea = 241.
tunif = 305.
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi

&&
name = Metals     && Name of structure
type = wall      && Type of structure
shape = slab     && Shape of structure
nslab = 10      && Number of nodes in structure
chrLen = 5.49   && Characteristic length of structure (m)
slarea = 46.    && Area (m2)
tunif = 305.    && Initial uniform temperature (K)
compound = ss ss ss ss ss ss ss ss ss ss
x = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eoi

&&
condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
&&
low-cell
geometry= 107.    && Area of layers in lower cell (m2)
bc = 305.        && Basemat boundary condition temperature (K)
concrete
compos = 1       && Number of materials
              conc && Material
              23500. && Mass of material
temp = 305.      && Initial temperature
eoi
pool
temp = 305.      && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 3 2 0.
overflow 3 2 3.05
eoi
&&
&& ----- Cell 4, Room 236 -----
cell 4
control
nhtm=2 mxslab=11 nsoatm=2 nspatm=000 jconc=1 jpool=1 naensy=2
nsoeng=1 nspeng=4
eoi
title
Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height (m3, m)

```

```

atmos = 3
      1.01e5    && Pressure
      305.      && Temperature
o2 = 0.25
n2 = 0.75
h2ov = 0.05

&&
struc
name = Walls    && Name of structure
type = wall     && Type of structure
shape = slab    && Shape of structure
nslab = 10      && Number of nodes in structure
chrlen = 5.49  && Characteristic length of structure (m)
slarea = 450.   && Area (m2)
tunif = 305.    && Initial uniform temperature (K)
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .015 .030 .045 .060 .075 .090 .105 .120 .135 .152
eoi

&&
name = Metals   && Name of structure
type = wall     && Type of structure
shape = slab    && Shape of structure
nslab = 10      && Number of nodes in structure
chrlen = 5.49  && Characteristic length of structure (m)
slarea = 46.    && Area (m2)
tunif = 305.    && Initial uniform temperature (K)
compound = ss ss ss ss ss ss ss ss ss ss
x = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eoi

&&
condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
geometry= 21.9   && Area of layers in lower cell (m2)
bc = 305.       && Basemat boundary condition temperature (K)
concrete
  compos = 1     && Number of materials
           conc  && Material
           6730. && Mass of material
  temp = 305.    && Initial temperature
eoi
pool
  temp = 305.    && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
&& Spillage from Room 236 to Room 115 via the connecting pipe chase
&&
engineer Spill 1 4 3 5.79
overflow 4 3 0.025
eoi
&&
&& Fire water sprinkler system, activated on high temperature.
&&
engineer Sprinklr 2 4 4 0.
spray
  spdiam = .001  && Spray droplet diameter (m)
  sphite = 5.49  && Spray fall height (m)
  spsttm = 373.  && Temperature at which system activates (K)
eoi
  source = 1     && Sprays provide 336 gpm (21.1 kg/s) after
  h2o1 = 3       && activation

```

```

    iflag = 2
    t      = 0.0   100.   1.00e5
    mass   = 21.1  21.1   21.1
    temp.  = 305.  305.   305.
eof
eof
&& ----- Cell 5, Balance of Plant -----
cell 5
control
eof
title
    Balance of Plant
geometry 1.87e5 38.6
atmos=3 1.01e5 305.
    o2 0.20
    n2 0.75
    h2ov 0.05
v
----- Cell 6, Environment -----
cell 6
control
eof
title
    Environment Cell
geometry 1.e10 1.e30
atmos=3 1.01e5 305.
    o2 0.20
    n2 0.75
    h2ov 0.05
eof

```



## LISTING 15 - CONTAIN Input for BS-3e

```

&& ===== Model Description =====
&&
&& File:
&&
&&   cnt005e.mdl
&&
&& Description:
&&
&&   BS-5. This input deck describes a five volume model of the B&W Plant
&&   auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 6 inch break in the HPI pump suction piping in
&&   room 115. Break flow is limited by the 2.5 inch HPI injection piping.
&&   This model does not include water aerosols (the dropout option is used).
&&
&&   a. this modification uses an Ocone blowdown from the B&W CSAU study
&&
&&   b. this modification uses an Ocone blowdown from the B&W CSAU study
&&   modified so the break enthalpy corresponds to fluid with a void
&&   fraction of 0. before 500 seconds, and 1. after 500 seconds.
&&
&&   c. this modification adds 1000 lb of metal mass to each compartment.
&&
&&   d. this modification changes the 1000 lb of metal mass to 10,000 lb.
&&
&&   e. this modification changes the 10,000 lb of metal mass to
&&   100,000 lb.
&&
&& Written by:
&&
&&   John Schroeder 7/91
&&
&& ===== Machine Control Input =====
cray
eol
&& ===== Global Input =====
&&
&& Section 3.2, p. 3-11
&&
&&   Atmospheric Gases
&&
&&   Material      Description
&&   -----
&&   o2            oxygen
&&   n2            nitrogen
&&   h2ov          steam
&&   h2ol          water
&&
control
  ncells = 6      && Number of cells
  ntitl  = 2      && Number of title lines
  ntzone = 5      && Number of time zones
  nac     = 0      && Number of aerosol groups
  nsectn  = 0      && Number of aerosol sections
eol
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
material
  compound
    n2 o2          && Air
    h2ov h2ol      && Steam and water
    conc ss        && Structural materials

```

```

&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17
&&
thermal          && Water-cooled reactor
&&
&& ----- Flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
flows
&&
&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&&           1, 2, 3.
&&
&&   area(1,5) = 8.88      && Cross-sectional area of flow path           (m2)
&&   avl(1,5)  = 14.6     && Ratio of area to inertial length, A/L      (m)
&&   cfc(1,5)  = 1.00     && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&&   area(1,2) = 12.6
&&   avl(1,2)  = 20.7
&&   cfc(1,2)  = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&&   area(2,5) = 0.892
&&   avl(2,5)  = 1.46
&&   cfc(2,5)  = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&&   area(2,3) = 1.95
&&   avl(2,3)  = 3.2
&&   cfc(2,3)  = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&&   area(3,5) = 1.95
&&   avl(3,5)  = 3.2
&&   cfc(3,5)  = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&&   area(3,4) = 2.97
&&   avl(3,4)  = 4.88
&&   cfc(3,4)  = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&           10, 11, 12, and 13.
&&
&&   area(4,5) = 29.1
&&   avl(4,5)  = 157.
&&   cfc(4,5)  = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&           paths.
&&
&&   area(5,6) = 46.5
&&   avl(5,6)  = 250.
&&   cfc(5,6)  = 1.00
&&
&& implicit
&& dropout
&&
&& Compartment and junction elevation data

```

```

&&
&& Compartments
&&
elevcl(1) = 169.   && Center of mass elevation for Rm 105      (m)
elevcl(2) = 169.   && Center of mass elevation for Rm 113      (m)
elevcl(3) = 169.   && Center of mass elevation for Rm 115      (m)
elevcl(4) = 175.   && Center of mass elevation for Rm 238      (m)
elevcl(5) = 185.   && Center of mass elevation for Rm 80P      (m)
elevcl(6) = 185.   && Center of mass elevation for Environment (m)

```

```

&&
&& Junctions
&&
elevfp(1,5)= 167.
elevfp(5,1)= 167.

elevfp(1,2)= 170.
elevfp(2,1)= 170.

elevfp(2,5)= 172.
elevfp(5,2)= 172.

elevfp(2,3)= 170.
elevfp(3,2)= 170.

elevfp(3,5)= 170.
elevfp(5,3)= 170.

elevfp(3,4)= 172.
elevfp(4,3)= 172.

elevfp(4,5)= 173.
elevfp(5,4)= 173.

elevfp(5,6)= 211.
elevfp(6,5)= 211.

```

```

&&
&& ----- Aerosol Options -----
&&
&& Section 3.2.4, p. 3-29
&&
&& aerosol
&&   h2ov 1.0e-8 0.693
&&

```

```

&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
1800.           && Maximum CPU time limit      (s)
0.             && Problem start time                (s)

```

```

&&
&& Time zone data
&&
&& System   Edit   End of
&&  Ts      Ts      Zone
&& -----
&&      1.    10.    10.
&&      5.    50.    100.
&&     20.   200.   500.
&&     50.   100.  1000.
&&     50.   100.  7200.
&&

```

```

&&
&& ----- Output Control -----
&&
&& Section 3.2.7, p. 3-38
&&

```

```

shortedt = 2      && System ts between short edits
longedt  = 1      && Ts edits between long edits
prflow   =        && Print intercell flow data
praer    =        && detailed aerosol inventories
prlow-cl =        && lower cell model
prheat   =        && heat transfer structure model
prengsys =        && engineered system model
title    =        B&W Plant Auxiliary Building Steam Propagation Model
                    Five Compartment Model -- BS-5

&&
&&
&& ----- Cell Input and Cell Control -----
&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=3 mxslab=11 nsoatm=0 nsnatm=7 naensy=1 jconc=1 jpool=1
eof
title
  Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.134e^2 5.49 && Cell volume and height (m3, m)
  atmos = 3      && Number of materials
          1.01e5 && Pressure (Pa)
          305.   && Temperature (K)
  n2 = 0.75 && Initial nitrogen fraction
  o2 = 0.20 && Initial oxygen fraction
  h2ov = 0.05 && Initial water vapor fraction
struc
  nme = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 18.7 && Characteristic length of structure (m)
  slarea = 295. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .046 .092 .138 .184 .230 .276 .322 .365 .414 .457 && (m)
eof
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 298. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eof
&&
  name = Metals && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 460. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = ss ss ss ss s- ss ss ss ss ss
  x = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eof
&&
condense

```

```

ht-tran on 6.1 on on on
overflow 1
&&
&& Lower cell input
&&
low-cell
  geometry= 295.    && Area of layers in lower cell      (m2)
  bc = 305.    && Basemat boundary condition temperature (K)
  concrete
    compos = 1    && Number of materials
    conc    && Material
    43200. && Mass of material
    temp = 305. && Initial temperature
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 1 5 .152
  overflow 1 5 1.74
eoi
&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  nhtm=3 mxslab=11 nsoatm=0 nspatm=0 naensy=1 jconc=5 jpool=1
eoi
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e2 6.10 && Cell volume and height      (m3, m)
  atmos = 3
    1.01e5 && Pressure      (Pa)
    305. && Temperature    (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chr len = 17.7 && Characteristic length of structure (m)
  slarea = 86.4 && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
  eoi
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chr len = 5.49 && Characteristic length of structure (m)
  slarea = 254. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 .396 && (m)
  eoi
&&
  name = Metals && Name of structure
  type = wall && Type of structure

```

```

shape = slab          && Shape of structure
nslab = 10           && Number of nodes in structure
chr len = 5.49       && Characteristic length of structure (m)
slarea = 460.        && Area (m2)
tunif = 305.         && Initial uniform temperature (K)
compound = ss ss ss ss ss ss ss ss ss ss
x = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eof

&&
condense
ht-tran on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell
geometry= 86.4       && Area of layers in lower cell (m2)
bc = 305.           && Basemat boundary condition temperature (K)
concrete
compos = 1          && Number of materials
conc = 19000.       && Material (kg)
temp = 305.         && Initial temperature (K)
eof
pool
temp = 305.         && Initial temperature
eof

eof
&&
&& Engineered safety systems
&&
engineer Spill 1 2 1 0.0
overflow 2 1 3.05
eof
&&
&& ----- Cell 3, Room 115 -----
cell 3
control
nhtm=3 mxslab=11 nsoat=1 nspat=10 taensy=1 jconc=1 jpool=1
eof
title
Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height (m3, m)
atmos = 3
      1.01e5      && Pressure
      305.        && Temperature
o2 = 0.20
n2 = 0.75
h2ov = 0.05
source=1
&&
&& Blowdown of RCS - Oconee blowdown, void fraction 1. after 500 seconds
&&
h2ov = 4
iflag = 2
t = 0. 500. 501. 4000.
mass = 190.5 190.5 36.3 36.3
enth = 1356000. 1356000. 2747000. 2747000.
eof
&&
struc
name = Ceiling && Name of structure

```

```

type = roof          && Type of structure
shape = slab        && Shape of structure
nslab = 10          && Number of nodes in structure
chrlen = 14.6       && Characteristic length of structure (m)
slarea = 107.       && Area (m2)
tunif = 305.        && Initial uniform temperature (K)
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi

&&
name = Walls        && Name of structure
type = wall
shape = slab
nslab = 10
chrlen = 5.49
slarea = 241.
tunif = 305.
compound= conc conc conc conc conc conc conc conc conc conc
x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
eoi

&&
name = Metals       && Name of structure
type = wall
shape = slab
nslab = 10
chrlen = 5.49
slarea = 460.
tunif = 305.
compound = ss ss ss ss ss ss ss ss ss ss
x = 0. .001 .001 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eoi

&&
condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
&&
low-cell
geometry= 107.      && Area of layers in lower cell (m2)
bc = 305.          && Basemat boundary condition temperature (K)
concrete
compos = 1         && Number of materials
conc = 23500.      && Material
&& Mass of material
temp = 305.        && Initial temperature
eoi
pool
temp = 305.        && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
engineer Spill 1 3 2 0.
overflow 3 2 3.05
eoi
&&
&& ----- Cell 4, Room 236 -----
cell 4
control
nhtm=2 mxslab=11 nsoatm=2 nspatm=000 jconc=1 jpool=1 naensy=2
nsoeng=1 nspeng=4
eoi
title
Cell 4, Room 236
&&
&& Upper Cell Input

```

```

&&
geometry 2.520e2 5.49 && Cell volume and height (m3, m)
  atmos = 3
    1.01e5 && Pressure
    305. && Temperature
  o2 = 0.25
  n2 = 0.75
  h2ov = 0.05
&&
struc
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrllen = 5.49 && Characteristic length of structure (m)
  slarea = 450. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .015 .030 .045 .060 .075 .090 .105 .120 .135 .152
  eoi
&&
  name = Metals && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrllen = 5.4 && Characteristic length of structure (m)
  slarea = . . . && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = ss ss ss ss ss ss ss ss ss ss
  x = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
  eoi
&&
condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
  geometry= 91.9 && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
      conc && Material
      6730. && Mass of material
    temp = 305. && Initial temperature
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&
&& Engineered safety systems
&&
&& Spillage from Room 236 to Room 115 via the connecting pipe phase
&&
engineer Spill 1 4 3 5.79
overflow 4 3 0.025
eoi
&&
&& Fire water sprinkler system, activated on high temperature.
&&
engineer Sprinkl 2 4 4 0.
  spray
    spdiam = .001 && Spray droplet diameter (m)
    sphite = 5.49 && Spray fall height (m)
    spsttm = 373. && Temperature at which system activates (K)
  eoi

```



```

source = 1      && Sprays provide 336 gpm (21.1 kg/s) after
             h2o1 = 3      && activation
             iflag = 2
             t = 0.0      100.      1.00e5
             mass = 21.1  21.1      21.1
             temp = 305.  305.      305.
eof
cp1
&&
&& ----- Cell 5, Balance of Plant -----
cell 5
control
eof
title
      Balance of Plant
geometry 1.87e5 38.8
atmos=3 1.01e5 305.
      o2 0.20
      n2 0.75
      h2ov 0.05
&&
&& ----- Cell 6, Environment -----
cell 6
control
eof
title
      Environment Cell
geometry 1.e10 1.e30
atmos=3 1.01e5 305.
      o2 0.20
      n2 0.75
      h2ov 0.05
eof

```

## LISTING 16 - CONTAIN Input for BS-5f

```

&& ===== Model Description =====
&&
&& File:
&&
&&   cnt005f.mdl
&&
&& Description:
&&
&&   BS-5. This input deck describes a five volume model of the B&W Plant
&&   auxiliary building. The rooms modeled are 105, 113, 115, and 236.
&&   The steam source is a 6 inch break in the HPI pump suction piping in
&&   room 115. Break flow is limited by the 2.5 inch HPI injection piping.
&&   This model does not include water aerosols (the dropout option is used).
&&
&&   a. this modification uses an Ocone blowdown from the B&W CSAU study
&&
&&   b. this modification uses an Ocone blowdown from the B&W CSAU study
&&   modified so the break enthalpy corresponds to fluid with a void
&&   fraction of 0. before 500 seconds, and 1. after 500 seconds.
&&
&&   c. this modification adds 1000 lb of metal mass to each compartment.
&&
&&   d. this modification changes the 1000 lb of metal mass to 10,000 lb.
&&
&&   e. this modification changes the 10,000 lb of metal mass to
&&   100,000 lb.
&&
&&   f. this modification changes the 100,000 lb of metal mass to
&&   1,000,000 lb.
&&
&& Written by:
&&
&&   John Schroeder 7/91
&&
&& ===== Machine Control Input =====
cray
eoi
&& ===== Global Input =====
&&
&& Section 3.2, p. 3-11
&&
&&   Atmospheric Gases
&&
&&   Material      Description
&&   -----
&&   o2            oxygen
&&   n2            nitrogen
&&   h2ov          steam
&&   h2o1          water
&&
control
  ncells = 6      && Number of cells
  ntitl  = 2      && Number of title lines
  ntzone = 5      && Number of time zones
  nac    = 0      && Number of aerosol groups
  nsectn = 0      && Number of aerosol sections
eoi
&&
&& ----- Material, Fission Product, and Aerosol Names -----
&&
&& Section 3.2.1, p. 3-13
&&
material
  compound

```

```

n2 o2          && Air
h2ov h2o1      && Steam and water
conc ss        && Structural materials
&&
&& ----- Reactor Type -----
&&
&& Section 3.2.2, p. 3-17
&&
thermal        && Water-cooled reactor
&&
&& ----- flow Options -----
&&
&& Section 3.2.3, p. 3-17
&&
flows
&&
&& Junction 1 - Room 105 to Balance of Plant, includes flow paths
&&      1, 2, 3.
&&
&&   area(1,5) = 8.88      && Cross-sectional area of flow path      (m2)
&&   avl(1,5)  = 14.6     && Ratio of arca to inertial length, A/L      (m)
&&   cfc(1,5)  = 1.00     && Flow loss coefficient
&&
&& Junction 2 - Room 105 to Room 113, includes only flow path 4.
&&
&&   area(1,2) = 12.6
&&   avl(1,2)  = 20.7
&&   cfc(1,2)  = 1.00
&&
&& Junction 3 - Room 113 to Balance of Plant, includes only flow path 5.
&&
&&   area(2,5) = 0.892
&&   avl(2,5)  = 1.46
&&   cfc(2,5)  = 1.0
&&
&& Junction 4 - Room 113 to Room 115, includes only flow path 6.
&&
&&   area(2,3) = 1.95
&&   avl(2,3)  = 3.2
&&   cfc(2,3)  = 1.0
&&
&& Junction 5 - Room 115 to Balance of Plant, includes only flow path 7.
&&
&&   area(3,5) = 1.95
&&   avl(3,5)  = 3.2
&&   cfc(3,5)  = 1.00
&&
&& Junction 6 - Room 115 to Room 236, includes only flow path 8.
&&
&&   area(3,4) = 2.97
&&   avl(3,4)  = 4.88
&&   cfc(3,4)  = 1.00
&&
&& Junction 7 - Room 236 to Balance of Plant, includes flow paths 9,
&&      10, 11, 12, and 13.
&&
&&   area(4,5) = 29.1
&&   avl(4,5)  = 157.
&&   cfc(4,5)  = 1.00
&&
&& Junction 8 - Balance of Plant to environment, includes only blowout
&&      paths.
&&
&&   area(5,6) = 46.5
&&   avl(5,6)  = 250.
&&   cfc(5,6)  = 1.00
&&
&& implicit

```

```

dropout
&&
&& Compartment and junction elevation data
&&
&& Compartments
&&
&& elevc1(1) = 169.    && Center of mass elevation for Rm 105      (m)
&& elevc1(2) = 169.    && Center of mass elevation for Rm 113      (m)
&& elevc1(3) = 169.    && Center of mass elevation for Rm 115      (m)
&& elevc1(4) = 175.    && Center of mass elevation for Rm 236      (m)
&& elevc1(5) = 185.    && Center of mass elevation for Rm BOP      (m)
&& elevc1(6) = 185.    && Center of mass elevation for Environment (m)
&&
&& Junctions
&&
&& elevfp(1,5)= 167.
&& elevfp(5,1)= 167.

&& elevfp(1,2)= 170.
&& elevfp(2,1)= 170.

&& elevfp(2,5)= 172.
&& elevfp(5,2)= 172.

&& elevfp(2,3)= 170.
&& elevfp(3,2)= 170.

&& elevfp(3,5)= 170.
&& elevfp(5,3)= 170.

&& elevfp(3,4)= 172.
&& elevfp(4,3)= 172.

&& elevfp(4,5)= 173.
&& elevfp(5,4)= 173.

&& elevfp(5,6)= 211.
&& elevfp(6,5)= 211.
&&
&& ----- Aerosol Options -----
&&
&& Section 3.2.4, p. 3-29
&&
&& aerosol
&&   h2ov 1.0e-8 0.693
&&
&& ----- Times -----
&&
&& Section 3.2.6, p. 3-36
&&
times
1800.          && Maximum CPU time limit      (s)
0.             && Problem start time                (s)
&&
&& Time zone data
&&
&& System   Edit   End of
&&   Ts     Ts     Zone
&& -----
&&         1.    10.    10.
&&         5.    50.   100.
&&        20.   200.  500.
&&        50.   100. 1000.
&&        50.   100. 7200.
&&
&& -----
&&
&& ----- Output Control -----

```

```

&&
&& Section 3.2.7, p. 3-38
&&
shortedt   = 2      && System ts between short edits
longedt    = 1      && Ts edits between long edits
prflow     && Print intercell flow data
praer      && detailed aerosol inventories
prlow-1    && lower cell model
prheat     && heat transfer structure model
prengsys   && engineered system model
title
      B&W Plant Auxiliary Building Steam Propagation Model
      Five Compartment Model -- 85-5
&&
&&
&& =====> Cell Input and Cell Control <=====
&&
&& Section 3.3, p. 3-40
&&
&& ----- Cell 1, Room 105 -----
cell 1
control
  nhtm=3 mxslab=11 nsoatm=0 nspatm=7 naensy=1 jconc=1 jpool=1
eol
title
  Cell 1, Room 105
&&
&& Upper Cell Input
&&
geometry 1.174e3 5.49 && Cell volume and height (m)
  atmos   = 3      && Number of materials
           = 1.01e5 && Pressure (Pa)
           = 305.   && Temperature (K)
  n2      = 0.75   && Initial nitrogen fraction
  o2      = 0.20   && Initial oxygen fraction
  h2o     = 0.05   && Initial water vapor fraction
struc
  name    = Ceiling && Name of structure
  type    = roof    && Type of structure
  shape   = slab    && Shape of structure
  nslab   = 10      && Number of nodes in structure
  chrlen  = 18.7    && Characteristic length of structure (m)
  slarea  = 295.    && Area (m2)
  tunif   = 305.    && Initial uniform temperature (K)
  compound = conc conc conc conc conc conc conc conc conc conc
  x       = 0. .046 .092 .138 .184 .230 .276 .322 .368 .414 .457 && (m)
eol
&&
  name    = Walls    && Name of structure
  type    = wall     && Type of structure
  shape   = slab     && Shape of structure
  nslab   = 10      && Number of nodes in structure
  chrlen  = 5.49    && Characteristic length of structure (m)
  slarea  = 295.    && Area (m2)
  tunif   = 305.    && Initial uniform temperature (K)
  compound = cc.c conc conc conc conc conc conc conc conc conc
  x       = 0. .035 .070 .105 .140 .175 .210 .245 .280 .315 .351 && (m)
eol
&&
  name    = Metals   && Name of structure
  type    = wall     && Type of structure
  shape   = slab     && Shape of structure
  nslab   = 10      && Number of nodes in structure
  chrlen  = 5.49    && Characteristic length of structure (m)
  slarea  = 4600.   && Area (m2)
  tunif   = 305.    && Initial uniform temperature (K)
  compound = ss ss ss ss ss ss ss ss ss ss
  x       = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)

```

```

eoi
&&
condense
ht-tran on on on on on
overflow 1
&&
&& Lower cell input
&&
low-cell
  geometry= 295.    && Area of layers in lower cell (m2)
  bc = 305.    && Basemat boundary condition temperature (K)
  concrete
    compos = 1    && Number of materials
              conc && Material
              43200. && Mass of material
    temp = 305.  && Initial temperature
  eoi
  pool
    temp = 305.  && Initial temperature
  eoi

eoi
&&
&& Engineered safety systems
&&
engineer spill 1 1 5 .152
overflow 1 5 1.74
eoi
&&
&& ----- Cell 2, Room 113 -----
cell 2
control
  nhtm=3 mxslab=11 hsoatm=0 nspatm=0 naensy=1 jconc=5 jpool=1
eoi
title
  Cell 2, Room 113
&&
&& Upper Cell Input
&&
geometry 3.794e2 5.10 && Cell volume and height (m3, m)
  atmos = 3
          1.01e5 && Pressure (Pa)
          305. && Temperature (K)
  o2 = 0.20
  n2 = 0.75
  h2ov = 0.05
&&
struc
  name = Ceiling && Name of structure
  type = roof && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 17.7 && Characteristic length of structure (m)
  slarea = 86.4 && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
  eoi
&&
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  ns' b = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 254. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .040 .080 .120 .160 .200 .240 .280 .320 .360 .396 && (m)
  eoi

```

```

&&
name      = Metals          && Name of structure
type      = wall           && Type of structure
shape     = slab           && Shape of structure
nslab    = 10              && Number of nodes in structure
chrlen   = 5.49           && Characteristic length of structure (m)
v*area   = 4600.          && Area (m2)
tunif    = 305.           && Initial uniform temperature (K)
compound = ss ss ss ss ss ss ss ss ss ss
x        = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
eoi

&&
condense
ht-tran  on on on on on
overflow 2
&&
&& Lower cell input
&&
low-cell
geometry= 88.4            && Area of layers in lower cell (m2)
bc      = 325.           && Basement boundary condition temperature (K)
concrete
compos  = 1             && Number of materials
conc    = 19000.        && Material (kg)
temp    = 305.          && Initial temperature (K)
eoi
pool
temp    = 305.          && Initial temperature
eoi

eoi
&&
&& Engineered safety systems
&&
engineer  Spill 1 2 1 0.0
overflow 2 1 3.05
eoi
&&
&& ----- Cell 3, Room 115 -----
cell 3
control
nhtm=3 nuxslab=11 nsoatm=1 nspatm=10 naensy=1 jconu=1 jpool=1
eoi
title
Cell 3, Room 115
&&
&& Upper Cell Input
&&
geometry 5.267e2 5.49 && Cell volume and height (r3, m)
atmos    = 3
          1.01e5      && Pressure
          305.        && Temperature
o2       = 0.20
n2       = 0.75
h2ov    = 0.05
source=1
&&
&& Blowdown of RCS - Dconee blowdown, void fraction 1. after 500 seconds
&&
h2ov    = 4
iflag   = 2
t       =          0.          500.          501.          4000.
mass    =          190.5        190.5        36.3         36.3
enth    =          1356000.     1356000.    2747000.    2747000.
eoi

```

```

&&
struc
  name   = Ceiling      && Name of structure
  type   = roof         && Type of structure
  shape  = slab         && Shape of structure
  nslab  = 10           && Number of nodes in structure
  chrlen = 14.6         && Characteristic length of structure (m)
  slarea = 107.         && Area (m2)
  tunif  = 305.         && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x      = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
  eoi
&&
  name   = Walls        && Name of structure
  type   = wall         && Type of structure
  shape  = slab         && Shape of structure
  nslab  = 10           && Number of nodes in structure
  chrlen = 5.49         && Characteristic length of structure (m)
  slarea = 241.         && Area (m2)
  tunif  = 305.         && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x      = 0. .031 .062 .093 .124 .155 .186 .221 .252 .283 .305 && (m)
  eoi
&&
  name   = Metals       && Name of structure
  type   = wall         && Type of structure
  shape  = slab         && Shape of structure
  nslab  = 10           && Number of nodes in structure
  chrlen = 5.49         && Characteristic length of structure (m)
  slarea = 4600.        && Area (m2)
  tunif  = 305.         && Initial uniform temperature (K)
  compound = ss ss ss ss ss ss ss ss ss ss
  x      = 0. .01 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
  eoi
&&
condense
ht-tran on on on on on
overflow 3
&&
&& Lower cell input
&&
low-cell
  geometry= 107.        && Area of layers in lower cell (m2)
  bc       = 305.        && Basement boundary condition temperature (K)
  concrete
    compos = 1          && Number of materials
             conc       && Material
             23500.     && Mass of material
    temp   = 305.        && Initial temperature
  eoi
  pool
    temp   = 305.        && Initial temperature
  eoi
eoi
&&
&& Engineered safety systems
&&
engineer  Spill 1 3 2 0.
overflow 3 2 3.05
eoi
&&
&& ----- Cell 4, Room 236 -----
cell 4
control
  nhtm=2 mxslab=11 nsoatm=2 nspatm=000 jconc=1 jpool=1 naensy=2
  nsoeng=1 nspeng=4
eoi
title

```



```

Cell 4, Room 236
&&
&& Upper Cell Input
&&
geometry 2.520e2 5.49 && Cell volume and height (m3, m)
  atmos = 3
    1.01e5 && Pressure
    305. && Temperature
  o2 = 0.25
  n2 = 0.75
  h2ov = 0.05
&&
&& struc
  name = Walls && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 450. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound= conc conc conc conc conc conc conc conc conc conc
  x = 0. .015 .030 .045 .060 .075 .090 .105 .120 .135 .152
  eoi
&&
  name = Metals && Name of structure
  type = wall && Type of structure
  shape = slab && Shape of structure
  nslab = 10 && Number of nodes in structure
  chrlen = 5.49 && Characteristic length of structure (m)
  slarea = 4600. && Area (m2)
  tunif = 305. && Initial uniform temperature (K)
  compound = ss ss ss ss ss ss ss ss ss ss
  x = 0. .001 .002 .003 .004 .005 .006 .007 .008 .009 .013 && (m)
  eoi
&&
&& condense
ht-tran on on on on on
overflow 4
&&
&& Lower cell input
&&
low-cell
  geometry= 91.9 && Area of layers in lower cell (m2)
  bc = 305. && Basemat boundary condition temperature (K)
  concrete
    compos = 1 && Number of materials
    conc && Material
    6730. && Mass of material
    temp = 305. && Initial temperature
  eoi
  pool
    temp = 305. && Initial temperature
  eoi
eoi
&&
&& Engineered safety systems
&&
&& Spillage from Room 236 to Room 115 via the connecting pipe chase
&&
engineer Spill 1 4 3 5.79
  overflow 4 3 0.025
eoi
&&
&& Fire water sprinkler system, activated on high temperature.
&&
engineer Sprinklr 2 4 4 0.
  spray
  spdiam = .001 && Spray droplet diameter (m)

```

```

    sphite = 5.49    && Spray fall height          (m)
    spsttm = 373.   && Temperature at which system activates (K)
eol
    source = 1      && Sprays provide 336 gpm (21.1 kg/s) after
    h2o1 = 3       && activation
    iflag = 2
    t      = 0.0    100.    1.00e5
    mass   = 21.1   21.1    21.1
    temp   = 305.   305.    305.
eol
eol
&&
&& ----- Cell 5, Balance of Plant -----
cell 5
control
eol
title
    Balance of Plant
geometry 1.87e5 38.8
atmos=2 1.01e5 305.
    o2 0.20
    n2 0.75
    h2ov 0.05
&&
&& ----- Cell 6, Environment -----
cell 6
control
eol
title
    Environment Cell
geometry 1.e10 1.e30
atmos=3 1.01e5 305.
    o2 0.20
    n2 0.75
    h2ov 0.05
eof

```

NRC FORM 333 2-89 NRCM 1102 3201, 3202	U.S. NUCLEAR REGULATORY COMMISSION  <b>BIBLIOGRAPHIC DATA SHEET</b> <i>(See instructions on the reverse)</i>	1. REPORT NUMBER <i>(Assigned by NRC. Add Vol., Subp., Rev., and Addendum Numbers, if any.)</i>  NUREG/CR-5604 EGG-2608 Vol. 3			
2. TITLE AND SUBTITLE  Assessment of ISLOCA Risk — Methodology and Application to a Babcock and Wilcox Nuclear Power Plant  Appendices I-M	3. DATE REPORT PUBLISHED <table border="1" style="width: 100%;"> <tr> <td style="width: 50%;">MONTH</td> <td style="width: 50%;">YEAR</td> </tr> <tr> <td>April</td> <td>1992</td> </tr> </table>	MONTH	YEAR	April	1992
MONTH	YEAR				
April	1992				
5. AUTHOR(S)  W. J. Galyean, D. I. Gertman	4. FIV OR GRANT NUMBER B5699				
8. PERFORMING ORGANIZATION — NAME AND ADDRESS <i>(If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)</i> Idaho National Engineering Laboratory EG&G Idaho, Inc. Idaho Falls, Idaho 83415	6. TYPE OF REPORT  Technical				
9. SPONSORING ORGANIZATION — NAME AND ADDRESS <i>(If NRC, type "Same as above". If contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission and mailing address.)</i> Division of Safety Issue Resolution Office of Nuclear Regulatory Research U.S. Nuclear Regulatory Commission Washington, D.C. 20555	7. PERIOD COVERED <i>(If Issue Dates)</i>				
10. SUPPLEMENTARY NOTES					
11. ABSTRACT <i>(200 words or less)</i>  This document presents information essential to understanding the risk associated with inter-system loss-of-coolant accidents (ISLOCAs). The methodology developed and presented in this document provides a state-of-the-art method for identifying and evaluating plant-specific hardware designs, human performance issues, and accident consequence factors relevant to the prediction of the ISLOCA risk. This ISLOCA methodology was developed and then applied to a Babcock and Wilcox (B&W) nuclear power plant. The results from this application are described in detail. For this particular B&W reference plant, the assessment indicated that the probability of a severe ISLOCA is approximately 2.2E-06/reactor-year.					
12. KEY WORDS/DESCRIPTORS <i>(List words or phrases that will assist researchers in locating the report.)</i>  Inter-system loss-of-coolant accident V-sequence probabilistic risk assessment core damage frequency	13. AVAILABILITY STATEMENT Unlimited  14. SECURITY CLASSIFICATION <i>(This Page)</i> Unclassified  <i>(This Report)</i> Unclassified  15. NUMBER OF PAGES  16. PRICE				

THIS DOCUMENT WAS PRINTED USING RECYCLED PAPER

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300

SPECIAL FOURTH-CLASS RATE  
POSTAGE AND FEES PAID  
USNRC  
PERMIT NO. G-67