

Commonwealth Edison Company  
LaSalle Generating Station  
2601 North 21st Road  
Marseilles, IL 61341-9757  
Tel 815-357-6761



January 23, 1996  
United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

The cancellation of Licensee Event Report #95-001-00, Docket #050-373 is being submitted to your office in accordance with 10 CFR 50.73 (a) (2) (i) (B).

Upon further review of this licensee event report, it has been determined that LaSalle County Station was not in a condition prohibited by Technical Specification 3.4.3.2. Technical Specification 3.4.3.2.d. states, "With one or more high/low pressure interface valve leakage pressure monitors inoperable, restore the inoperable monitor(s) to OPERABLE status within 7 days or verify the pressure to be less than the alarm setpoint at least once per 12 hours by local indication". Since local verification was accomplished on a shiftly (8 hour) basis by the Unit 1 Equipment Attendant, LaSalle was in full compliance with Tech Spec 3.4.3.2.

Our lack of thoroughness during the initial review of this event caused us to inappropriately classify this event as reportable under 10 CFR 50.73. LaSalle Station has implemented a more rigorous initial screening and technical review process.

Sincerely,

D. J. Ray

Station Manager

LaSalle County Station

Enclosure

cc: H. J. Miller, NRC Region III Administrator  
H. J. Simons, Acting NRC Senior Resident Inspector  
IDNS Resident Inspector  
F. Niziolek, IDNS Senior Reactor Analyst  
INPO- Records Center  
D. L. Farrar, Nuclear Regulatory Services Manager

28000  
9601260231 960123  
PDR ADOCK 05000373  
S PDR

A Unicom Company

JE 22/0