apph

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-11-92-35

This preliminary notification constitutes EARLY notice of events of POSSIBLE sifety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

 Georgia Power Company Vogtle-Unit 1 Docket No. 50-424	Licensee Emergency Classification: X_Notification of Unusual Event Alert
Waynesboro, GA	Site Area Emergency General Emergency Not Applicable

SUBJECT: UNUSUAL EVENT - REACTOR COOLANT SYSTEM (RCS) UNIDENTIFIED LEAKRATE OF 2.6 GPM

The licensee declared an unusual event at 3:37 a.m. on May 14, 1992, based on an RCS unidentified leak rate of 2.6 gpm (Tech Spec limit is 1 gpm unidentified). A controlled shutdown of Unit 1 was initiated from 100% power. The plant reached Mode 3 (Hot Standby) at 9:30 a.m.

The licensee will make an entry into the suspected area of the leak and corrective action will be determined pending identification of the source. The NRC resident inspector responded to the site and is monitoring the situation

The State of Georgia and Savannah River Site were informed by the licensee.

Local press inquiries have been received.

The NRC received initial notification of this event by telephone from the licensee at 4:17 a.m. (EDT) on May 14, 1992.

This information is current as of 10:00 a.m. In May 14, 1992.

CONTACT: P. Skinner - 841-6299

DISTRIBUTION:

One White Flint North Chairman Selin Comm. Rogers	M'land Nat'l <u>Bank Bldg</u> IRM LSSA	Regions MAIL TO: Region I Region II	DCS (Original IE 34) DOT (Transportation Only) 202			
Comm. Curtiss Comm. Remick Comm. de Planque OGC	AEOD NRC Ops Ctr	Region III <u>FAX TO</u> : Region IV Region V	Chairman Selin 2:00 OIG INPO LICENSEE (Corporate)			
OCA OPA OSP	Nicholson Lane RES	Phillips Bldg ACRS	and site RII Resident 2/2 PM, NRR			
EDO NRR NMSS	L Street PDR	EWW DIG	OPA 2:08 A. Byrdsong, NRR 2:10			
OE 9205270 PDR 18	0120 920514 ke -92-035 PDR					
5520:+05/14/92 . C						
			IE34			