

JANUARY 5, 1996

Georgia Power Company  
ATTN: Mr. J. T. Beckham, Jr.  
Vice President, Plant Hatch  
Nuclear Operations  
P. O. Box 1295  
Birmingham, AL 35201

SUBJECT: NRC INSPECTION REPORT NOS. 50-321/95-25 AND 50-366/95-25

Gentlemen:

This refers to the inspection conducted by E. Girard of this office on December 4 - 8, 1995. The inspection included a review of activities authorized for your Hatch facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the report.

This inspection evaluated your completion of Generic Letter (GL) 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance." The inspection consisted of interviews with personnel and selective examination of related documentation. The inspection identified several issues that remain to be resolved and we request that you provide a written response to aid in their resolution within 30 days of receipt of this letter. The issues relate to Inspector Followup Items 50-321, 366/95-02-01 and -05 and are described in the enclosed inspection report. They involve assumptions that were used in setting valves that were not dynamically tested and the scope of valves and valve functions included in your GL 89-10 program.

Within the scope of the inspection, violations or deviations were not identified.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be placed in the NRC Public Document Room.

Should you have any questions concerning this letter, please contact us.

Sincerely,

ORIGINAL SIGNED BY  
DAVID VERRELII FOR:

Paul E. Fredrickson, Chief  
Special Inspection Branch  
Division of Reactor Safety

9601260303 960105  
PDR ADDCK 05000321  
G PDR

Docket Nos. 50-321, 50-366  
License Nos. DPR-57, NPF-5

Enclosure: (See page 2)

260039

11  
JE 01

Enclosure: NRC Inspection Report

cc w/encl:

J. D. Woodard  
Senior Vice President  
Georgia Power Company  
Nuclear Operations  
P. O. Box 1295  
Birmingham, AL 35201

H. L. Sumner, Jr.  
General Manager, Plant Hatch  
Georgia Power Company  
Route 1, Box 439  
Baxley, GA 31513

D. M. Crowe  
Manager Licensing - Hatch  
Georgia Power Company  
P. O. Box 1295  
Birmingham, AL 35201

Ernest L. Blake, Esq.  
Shaw, Pittman, Potts and  
Trowbridge  
2300 N Street, NW  
Washington, D. C. 20037

Charles H. Badger  
Office of Planning and Budget  
Room 610  
270 Washington Street, SW  
Atlanta, GA 30334

Harold Reheis, Director  
Department of Natural Resources  
205 Butler Street, SE, Suite 1252  
Atlanta, GA 30334

Thomas Hill, Manager  
Radioactive Materials Program  
Department of Natural Resources  
4244 International Parkway  
Suite 114  
Atlanta, GA 30354

Chairman  
Appling County Commissioners  
County Courthouse  
Baxley, GA 31513

(cc w/encl cont'd - See page 3)

(cc w/encl cont'd)  
 Thomas P. Mazingo  
 Program Manager  
 Nuclear Operations  
 Oglethorpe Power Corporation  
 2100 E. Exchange Place  
 Tucker, GA 30085-1349

Charles A. Patrizia, Esq.  
 Paul, Hastings, Janofsky & Walker  
 10th Floor  
 1299 Pennsylvania Avenue  
 Washington, D. C. 20004-9500

Distribution w/encl:

K. N. Jabbour, NRR  
 P. H. Skinner, RII  
 R. V. Crlenjak, RII  
 G. A. Hallstrom, RII  
 T. G. Scarbrough, NRR  
 E. M. Kelly, RI  
 J. M. Jacobson, RIII  
 C. VanDenburgh, RIV  
 Document Control Desk

NRC Senior Resident Inspector  
 U.S. Nuclear Regulatory Commission  
 11030 Hatch Parkway North  
 Baxley, GA 31513

SEND TO PUBLIC DOCUMENT ROOM?					
YES NO					
OFFICE	RII:DRS	RII:DRP	NRR:EMEB	INEL	
SIGNATURE	<i>EGirard</i>	<i>For R. W. right</i>	<i>E. Durrant and E. Mail from R. Wessman</i>	<i>E. Durrant for Cain per teleph call</i>	
NAME	EGirard	PSkinner	RWessman	R. Cain	
DATE	01/5/96	01/5/96	01/5/96	01/5/96	01/ /96
COPY?	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY

DOCUMENT NAME: S:\DRS\SIB\HAT9525L.EHG