



Entergy  
Operations

Entergy Operations, Inc.

Route 2-Box 1283  
Portland, ME 04104  
Tel: 603-864-3100

May 20, 1992

1CAN059204

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 1  
Docket No. 50-313  
License No. DPR-51  
Once Through Steam Generator (OTSG)  
Inservice Inspection Report

Gentlemen:


Arkansas Nuclear One, Unit 1's (ANO-1) Technical Specification 4.18.6 requires the complete results of the inservice inspection of the OTSG tubes be submitted to the NRC within 45 days of the completion of the inspection. Attached is the Steam Generator Tubing Inservice Inspection Report for ANO-1's tenth refueling (1R10) outage.

The random sample inspections of the "A" OTSG had Category C-3 results and the inspections of the "B" OTSG had Category C-2 results. Attached are the complete results of the inspections of the steam generators.

This report supplements the information provided to the NRC in letter 1CAN049208 (dated April 14, 1992), which was required to be submitted per Technical Specification 4.18.6 and 6.12.5 as a result of the C-3 inspection results. This submittal completes the reporting requirements of Technical Specification 4.18.6 for 1R10.

Should you have any questions regarding this issue, please contact me.

Very truly yours,

  
for James J. Misicaro  
Director, Licensing

JJF/RWC/sjf  
Attachments

920527 7155 920520  
PDR M. LOCK 05000313  
G PLR

AD47

U. S. NRC  
May 20, 1992  
Page 2

cc: Mr. Robert Martin  
U. S. Nuclear Regulatory Commission  
Region IV  
511 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

NRC Senior Resident Inspector  
Arkansas Nuclear One - ANO-1 & 2  
Number 1, Nuclear Plant Road  
Russellville, Ak 72801

Mr. Thomas W. Alexion  
NRR Project Manager, Region IV/ANO-1  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 13-II-3  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852

Ms. Sheri Peterson  
NRR Project Manager, Region IV/ANO-2  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 13-H-3  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852