

Omaha Public Power District  
444 South 16th Street Mall  
Omaha, Nebraska 68102-2247  
402/635-2000

May 21, 1992  
LIC-92-170R

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

- References:
1. Docket No. 50-285
  2. Letter from OPPD (W. G. Gates) to NRC (Document Control Desk) dated April 12, 1990 (LIC-90-0284)
  3. Letter from NRC (A. Bournia) to OPPD (W. G. Gates) dated August 10, 1990 (TAC#69744)
  4. Letter from OPPD (W. G. Gates) to NRC (Document Control Desk) dated September 4, 1991 (LIC-91-201R)
  5. Letter from NRC (D. L. Wigginton) to OPPD (W. G. Gates) dated December 5, 1991
  6. Letter from OPPD (W. G. Gates) to NRC (Document Control Desk) Dated January 31, 1992 (LIC-92-018R)

Gentlemen:

SUBJECT: Completion of Generic Letter (GL) 88-17 Actions

In Reference 2, Omaha Public Power District (OPPD) provided plans for installation of two instrumentation enhancements beyond GL 88-17 requirements: a Shutdown Cooling Low Flow Alarm, and Suction Pressure Indication at the Low Pressure Safety Injection (LPSI) and Containment Spray (CS) Pumps. Reference 3 requested that OPPD inform the NRC when the modifications were completed.

As noted in Reference 4, OPPD revised the enhancement plans to cancel installation of the LPSI/CS Suction Pressure instrumentation. The NRC requested additional information in Reference 5; this was provided and discussed in a telephone conversation on February 6, 1992 between OPPD and Messrs. S. D. Bloom and W. C. Lyon of the NRC.

The Shutdown Cooling Low Flow Alarm instrumentation was installed during the 1992 Refueling Outage. All actions associated with GL 88-17 for Fort Calhoun Station are therefore considered complete.

9205270279 920521  
PDR ADDCK 05000285  
P PDR

45-0124

200086

Employment with Equal Opportunity  
Male/Female

A001  
110

U. S. Nuclear Regulatory Commission  
LIC-92-170R  
Page 2

If you should have any questions, please contact me.

Sincerely



*for* W. G. Gates  
Division Manager  
Nuclear Operations

WGG/sel

c: LeBoeuf, Lamb, Leiby & MacRae  
R. D. Martin, NRC Regional Administrator, Region IV  
R. P. Mullikin, NRC Senior Resident Inspector  
D. L. Wigginton, NRC Senior Project Manager  
S. D. Bloom, NRC Project Engineer