

January 11, 1996

Distribution w/encls:

Docket File	GHill(2)
PUBLIC	RJones
PD3-3 Reading	CGrimes
ACRS	JRoe
WAxelson, RIII	GMarcus

Mr. Donald C. Shelton
 Acting Vice President Nuclear - Perry
 Centerior Service Company
 P. O. Box 97, A200
 Perry, OH 44081

SUBJECT: AMENDMENT NO. 77 TO FACILITY OPERATING LICENSE NO. NPF-58 - PERRY
 NUCLEAR POWER PLANT, UNIT NO. 1 (TAC NO. M92191)

Dear Mr. Shelton:

The Commission has issued the enclosed Amendment No. 77 to Facility Operating License No. NPF-58 for the Perry Nuclear Power Plant, Unit No. 1. This amendment revises the Technical Specifications in response to your application dated May 1, 1995, supplemented December 20, 1995.

This amendment revises the Technical Specifications to eliminate selected response time testing requirements as described in the Boiling Water Reactor Owners' Group topical report, NEDO-32291, "System Analyses for Elimination of Selected Response Time Testing Requirements" and to incorporate Generic Letter 93-08 guidance regarding relocation of technical specification tables dealing with instrument response time limits.

A copy of the Safety Evaluation is also enclosed. Notice of issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,
 Original signed by:
 Jon B. Hopkins, Sr. Project Manager
 Project Directorate III-3
 Division of Reactor Projects III/IV
 Office of Nuclear Reactor Regulation

Docket No. 50-440
 Enclosures: 1. Amendment No. 77 to License No. NPF-58
 2. Safety Evaluation

cc w/encls: See next page

DOCUMENT NAME:G:\PERRY\PER92191.AMD

*See previous concurrences.

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PD3-3-LA	E	PD3-3-PM	N	PM:PD3-3		PD3-3	E	BC:HICB		OGC	
NAME	DFoster-Curseen		DPickett		WReckley*		JHopkins		JWermiel*		RBashmann*	
DATE	01/11/96		01/11/96		11/8/95		01/11/96		11/15/95		11/16/95	

OFFICIAL RECORD COPY

9601290166 960111
 PDR ADOCK 05000440
 P PDR

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

January 11, 1996

Mr. Donald C. Shelton
Acting Vice President Nuclear - Perry
Centerior Service Company
P. O. Box 97, A200
Perry, OH 44081

SUBJECT: AMENDMENT NO. 77 TO FACILITY OPERATING LICENSE NO. NPF-58 - PERRY
NUCLEAR POWER PLANT, UNIT NO. 1 (TAC NO. M92191)

Dear Mr. Shelton:

The Commission has issued the enclosed Amendment No. 77 to Facility Operating License No. NPF-58 for the Perry Nuclear Power Plant, Unit No. 1. This amendment revises the Technical Specifications in response to your application dated May 1, 1995, supplemented December 20, 1995.

This amendment revises the Technical Specifications to eliminate selected response time testing requirements as described in the Boiling Water Reactor Owners' Group topical report, NEDO-32291, "System Analyses for Elimination of Selected Response Time Testing Requirements" and to incorporate Generic Letter 93-08 guidance regarding relocation of technical specification tables dealing with instrument response time limits.

A copy of the Safety Evaluation is also enclosed. Notice of issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script that reads "Jon B. Hopkins, Sr.".

Jon B. Hopkins, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosures: 1. Amendment No. 77 to
License No. NPF-58
2. Safety Evaluation

cc w/encls: See next page

Mr. Donald C. Shelton
Centerior Service Company

Perry Nuclear Power Plant
Unit Nos. 1 and 2

cc:

Jay E. Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N. W.
Washington, D. C. 20037

Mr. James W. Harris, Director
Division of Power Generation
Ohio Dept. of Industrial Relations
P.O. Box 825
Columbus, Ohio 43216

Ms. Mary E. O'Reilly
Centerior Energy Corporation
300 Madison Avenue
Toledo, Ohio 43652

The Honorable Lawrence Logan
Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

The Honorable Robert V. Orosz
Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4531

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Lake County Prosecutor
Lake County Administration Bldg.
105 Main Street
Painesville, Ohio 44077

Radiological Health Program
Ohio Department of Health
P.O. Box 118
Columbus, Ohio 43266-0118

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Ohio Environmental Protection
Agency
DERR--Compliance Unit
ATTN: Mr. Zack A. Clayton
P.O. Box 1049
Columbus, Ohio 43266-0149

Terry J. Lodge, Esq.
618 N. Michigan Street, Suite 105
Toledo, Ohio 43624

Mr. Thomas Haas, Chairman
Perry Township Board of Trustees
3750 Center Rd., Box 65
Perry, Ohio 44081

Ashtabula County Prosecutor
25 West Jefferson Street
Jefferson, Ohio 44047

State of Ohio
Public Utilities Commission
East Broad Street
Columbus, Ohio 43266-0573

Mr. James D. Kloosterman
Regulatory Affairs Manager
Cleveland Electric Illuminating
Company
Perry Nuclear Power Plant
P. O. Box 97, E-210
Perry, Ohio 44081

Mr. Richard D. Brandt, Plant Manager
Cleveland Electric Illuminating
Company
Perry Nuclear Power Plant
P.O. Box 97, SB306
Perry, Ohio 44081

Mr. James R. Williams, Chief of
Staff
Ohio Emergency Management Agency
2825 West Granville Road
Worthington, Ohio 43085