

NOTICE OF DEVIATION

Wisconsin Electric Power  
Company  
Point Beach Nuclear Plant -  
Units 1 and 2

Docket Nos. 50-266; 50-301  
Licenses No. DPR-24; No. DPR-27


During an NRC inspection conducted on April 20 through 24, 1992, a deviation from a commitment contained in your January 16, 1991 response to GL 89-04, Position 8, was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Action", 10 CFR Part 2, Appendix C, (1991), the deviation is listed below:

Your response to Position 8 of GL 89-04 stated that inservice testing procedures were revised to include a sign-off to document an operability determination, following testing.

Contrary to the above, as of April 24, 1992, several procedures were identified which did not require an operability determination sign-off (266/92008-02(DRS); 301/92008-02(DRS)).

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region III, in writing within 30 days of the date of this Notice, the reason(s) for the deviation, the corrective steps which have been taken and the results achieved, the corrective steps which will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Glen Ellyn, Illinois  
this 28th day of May, 1992

  
\_\_\_\_\_  
H. J. Miller, Director  
Division of Reactor Safety