

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p><i>E</i> D. Required containment atmosphere radioactivity monitor inoperable.</p> <p><u>AND</u></p> <p>Required containment air cooler condensate flow rate monitor inoperable.</p>	<p><i>E</i> D.1 Restore required containment atmosphere radioactivity monitor to OPERABLE status.</p> <p><u>OR</u></p> <p><i>E</i> D.2 Restore required containment air cooler condensate flow rate monitor to OPERABLE status.</p>	<p>30 days</p> <p>30 days</p>
<p><i>F</i> F. Required Action and associated Completion Time not met.</p>	<p><i>F</i> F.1 Be in MODE 3.</p> <p><u>AND</u></p> <p><i>F</i> F.2 Be in MODE 5.</p>	<p>6 hours</p> <p>36 hours</p>
<p><i>G</i> <u>leakage detection systems</u></p> <p><i>F.</i> All required monitors inoperable.</p>	<p><i>G</i> F.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.15.²X Perform CHANNEL CHECK of the required containment atmosphere radioactivity monitor.</p>	12 hours
<p>SR 3.4.15.1 Perform CHANNEL CHECK of containment normal sumps level and reactor cavity sump level monitors.</p>	(continued) 12 hours

LCV-0603-E

9602050253 960130
PDR ADOCK 05000424
P PDR

~~W08 STS~~

3.4-41

Rev. 0, 09/28/92

Vault Units 1 and 2

LCV-0603-E

For the purpose of this Condition, the leakage detection systems consist of the three systems described below in items a, b and c, respectively:

a. the containment normal sump level and reactor cavity sump monitors, BASES

b. one containment atmosphere radioactivity monitor (gaseous or particulate); and

c. either the containment air cooler condensate flow rate or a containment atmosphere gaseous or particulate radioactivity monitoring system not taken credit for in item b.

F F
~~F.1~~ and ~~F.2~~ (continued)

required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

G
~~F.1~~

leakage detection systems

With all required ~~monitors~~ inoperable, no automatic means of monitoring leakage are available, and immediate plant shutdown in accordance with LCO 3.0.3 is required.

SURVEILLANCE REQUIREMENTS

SR 3.4.15.1 and SR 3.4.15.2

These SRs

SR 3.4.15.1 requires the performance of a CHANNEL CHECK of the required containment atmosphere radioactivity monitor. The check gives reasonable confidence that the channel is operating properly. The frequency of 12 hours is based on instrument reliability and is reasonable for detecting off normal conditions.

are

and containment sump monitors

³
SR 3.4.15.2

SR 3.4.15.2 requires the performance of a COT on the required containment atmosphere radioactivity monitor. The test ensures that the monitor can perform its function in the desired manner. The test verifies the alarm setpoint and relative accuracy of the instrument string. The frequency of ~~3~~ days considers instrument reliability, and operating experience has shown that it is proper for detecting degradation.

L92 WOG-09
C4

⁴
SR 3.4.15.2, DSR 3.4.15.4, and SR 3.4.15.5

These SRs require the performance of a CHANNEL CALIBRATION for each of the RCS leakage detection instrumentation channels. The calibration verifies the accuracy of the instrument string, including the instruments located inside containment. The frequency of 18 months is a typical refueling cycle and considers channel reliability. Again, operating experience has proven that this frequency is acceptable.

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.13</p> <p style="text-align: right;">(8b)</p> <p style="text-align: right;">KW and KVAR</p> <p>-----NOTES-----</p> <p>1. Momentary transients outside the load and power factor ranges do not invalidate this test.</p> <p>21 X This Surveillance shall not be performed in MODE 1 or 2. However</p> <p>X 2. Credit may be taken for unplanned events that satisfy this SR.</p> <p>-----</p> <p>8b Verify each DG operating at a power factor of 0.9 operates for ≥ 24 hours:</p> <p>a. For ≥ 20 hours loaded \geq 5250 ⁷⁶⁰⁰ kW and \leq 5500 ⁷⁷⁰⁰ kW; and</p> <p>b. For the remaining hours of the test loaded \geq 4500 ⁶⁸⁰⁰ kW and \leq 5000 ⁷⁰⁰⁰ kW.</p> <p>and operating as close as practicable to 3730 KVAR</p> <p>LCV-0603-E</p>	<p>BW06-05-C1</p> <p>18 months</p> <p>while maintaining voltage $\leq 4330V$</p> <p>and operating as close as practicable to 3390 KVAR</p>
<p>SR 3.8.1.14</p> <p style="text-align: right;">(11.4)</p> <p>-----NOTES-----</p> <p>1. This Surveillance shall be performed within 5 minutes of shutting down the DG after the DG has operated ≥ 20 hours loaded \geq 4500 ⁶⁸⁰⁰ kW and \leq 5000 ⁷⁰⁰⁰ kW.</p> <p>Momentary transients outside of load range do not invalidate this test.</p> <p>2. All DG starts may be preceded by an engine prelude period.</p> <p>-----</p> <p>4330 Verify each DG starts and achieves, in \leq 10 ^{11.4} seconds, voltage \geq 3740 ⁴⁰²⁵ V, and \leq 4500 ⁶⁶⁰⁰ V and frequency \geq 58.8 ⁶⁶ Hz and \leq 61.2 ⁶⁶ Hz.</p>	<p>18 months</p>

(continued)

LCV-0603-E

2. KVAR load as close as practicable to 3730 KVAR while loaded ≥ 7600 KW and ≤ 7700 KW and 3390 KVAR while loaded ≥ 6800 KW and ≤ 7000 KW for the remaining hours of the test, while maintaining voltage ≤ 4330 V

BASES

SURVEILLANCE REQUIREMENTS

SR 3.8.1.14¹³ (continued)

KVAR load

The voltage limit of 4330v is required to prevent operation of any loads at or above the maximum design voltage.

possible, testing must be performed using a power factor of ~~≤ 0.9~~ . This power factor is chosen to be representative of the actual design basis inductive loading that the DG would experience. The load band is provided to avoid routine overloading of the DG. Routine overloading may result in more frequent teardown inspections in accordance with vendor recommendations in order to maintain DG OPERABILITY.

TSC

The 18 month Frequency is consistent with the recommendations of Regulatory Guide 1.108 (Ref. 9), paragraph 2.a.(3), takes into consideration unit conditions required to perform the Surveillance, and is intended to be consistent with expected fuel cycle lengths.

KVAR load

This Surveillance is modified by ~~three~~ two Notes. Note 1 states that momentary transients due to changing bus loads do not invalidate this test. Similarly, momentary power factor transients above the power factor limit will not invalidate the test. The reason for Note 2 is that during operation with the reactor critical, performance of this Surveillance could cause perturbations to the electrical distribution systems that could challenge continued steady state operation and, as a result, unit safety systems. Note 2 acknowledges that credit may be taken for unplanned events that satisfy this SR.

TSC

TSC

BWR-25-1

INSERT

SR 3.8.1.15¹⁴

11.4

This Surveillance demonstrates that the diesel engine can restart from a hot condition, such as subsequent to shutdown from normal Surveillances, and achieve the required voltage and frequency within ~~10~~ seconds. The ~~10~~ second time is derived from the requirements of the accident analysis to respond to a design basis large break LOCA. The 18 month Frequency is consistent with the recommendations of Regulatory Guide 1.108 (Ref. 9), paragraph 2.a.(5).

This SR is modified by two Notes. Note 1 ensures that the test is performed with the diesel sufficiently hot. The load band is provided to avoid routine overloading of the DG. Routine overloads may result in more frequent teardown inspections in accordance with vendor recommendations in

(continued)

TSC

BASES

ACTIONS (continued)

A.2

of RTP

state

A reduction of the Power Range Neutron Flux - High trip setpoints by ≥ 1% for each 1% by which F₀(Z) exceeds its steady state limit, is a conservative action for protection against the consequences of severe transients with unanalyzed power distributions. The Completion Time of 8 hours is sufficient considering the small likelihood of a severe transient in this time period and the preceding prompt reduction in THERMAL POWER in accordance with Required Action A.1

LCV-0603-E

(in % RTP)
(value of K₄)

A.3

Reduction in the Overpower ΔT trip setpoints by ≥ 1% for each 1% by which F₀(Z) exceeds its limit, is a conservative action for protection against the consequences of severe transients with unanalyzed power distributions. The Completion Time of 72 hours is sufficient considering the small likelihood of a severe transient in this time period, and the preceding prompt reduction in THERMAL POWER in accordance with Required Action A.1.

A.4

Verification that F₀(Z) has been restored to within its limit, by performing SR 3.2.1.1 prior to increasing THERMAL POWER above the limit imposed by Required Action A.1, ensures that core conditions during operation at higher power levels are consistent with safety analyses assumptions.

B.1

limit

transient
transient

If it is found that the maximum calculated value of F₀(Z) that can occur during normal maneuvers, F₀(Z), exceeds its specified limits, there exists a potential for F₀(Z) to become excessively high if a normal operational transient occurs. Reducing the AFD by ≥ 1% for each 1% by which F₀(Z) exceeds its limits within the allowed Completion Time of 2 hours, restricts the axial flux distribution such that even if a transient occurred, core peaking factors are not exceeded. INSERT FOR REQUIRED ACTION B.1 BASES

PSC

(Ref. 5)

(continued)

BASES

SURVEILLANCE
REQUIREMENTS

SR 3.8.3.4 (continued)

intended to reflect the lowest value at which the ^{five} starts can be accomplished. (PI-9060, PI 9061, PI-9064, PI-965) PSE

The 31 day Frequency takes into account the capacity, capability, redundancy, and diversity of the AC sources and other indications available in the control room, including alarms, to alert the operator to below normal air start pressure.

SR 3.8.3.5

Microbiological fouling is a major cause of fuel oil degradation. There are numerous bacteria that can grow in fuel oil and cause fouling, but all must have a water environment in order to survive. Removal of water from the fuel storage tanks once every 31 days eliminates the necessary environment for bacterial survival. This is the most effective means of controlling microbiological fouling. In addition, it eliminates the potential for water entrainment in the fuel oil during DG operation. Water may come from any of several sources, including condensation, ground water, rain water, and contaminated fuel oil, and from breakdown of the fuel oil by bacteria. Frequent checking for and removal of accumulated water minimizes fouling and provides data regarding the watertight integrity of the fuel oil system. The Surveillance Frequencies are established by Regulatory Guide 1.137 (Ref. 2). This SR is for preventive maintenance. The presence of water does not necessarily represent failure of this SR, provided the accumulated water is removed during performance of the Surveillance.

PSC
INSERT
new
SR 3.8.3.6

SR 3.8.3.7

Draining of the fuel oil stored in the supply tanks, removal of accumulated sediment, and tank cleaning are required at 10 year intervals by Regulatory Guide 1.137 (Ref. 2), paragraph 2.f. ~~This SR also requires the performance of the ASME Code, Section XI (Ref. 8), examinations of the tanks.~~ To preclude the introduction of surfactants in the fuel oil system, the cleaning should be accomplished using sodium hypochlorite solutions, or their equivalent, rather than

LCV-0603-E

(continued)

BASES

SURVEILLANCE REQUIREMENTS

7

SR 3.8.3.7 (continued)

soap or detergents. This SR is for preventive maintenance. The presence of sediment does not necessarily represent a failure of this SR, provided that accumulated sediment is removed during performance of the Surveillance.

REFERENCES

1. FSAR, Section 9.5.4.2.
2. Regulatory Guide 1.137.
3. ANSI N195-1976, Appendix B.
4. FSAR, Chapter 16.
5. FSAR, Chapter 15.
6. ASTM Standards: D4052-81; D975-81; D4176-82; D1522-79; D2622-82; D2276, Method A. -7B PSC
7. ASTM Standards, D975, Table 1.
8. ~~ASME, Boiler and Pressure Vessel Code, Section XI.~~ LCV-0603-E
Deleted

WOG-13-11

The SR is modified by a note that excepts the performance of this SR when the associated DG is required OPERABLE by LCO 3.8.2. This exception is consistent with the SR performance exceptions in LCO 3.8.2 for SRs that might impact the OPERABILITY of the DGs.

9. Southern Company Services Calculation number X4C2403V10, Emergency Diesel Generator Fuel Oil Storage Technical Specification Values.
10. Southern Company Services Calculation number X4C2403V11, Emergency Diesel Generator Lube oil Inventory Technical Specification Values.
11. Southern Company Services Calculation number X4C2403V09, Emergency Diesel Generator Starting Air Pressure Technical Specification Value.

CHAPTER 3.7 PLANT SYSTEMS

INSERT 28 FOR CST LCO BASES PAGE B 3.7- 34

LCV-0603-E

In order for a single CST to meet the LCO requirements stated above, design modifications are required. ~~The design modifications are planned for each unit, during 1996, to allow alignment of the AFW pumps mini-flow lines to the CST to which the pump suction is aligned. Prior to the implementation of the design modification, LCO 3.7.6a shall be applicable. Prior to completion of the design modification the volume of water required to satisfy the safety analyses for a unit is 420,000 gallons. LCO 3.7.6a requires an unmodified unit to maintain both CSTs OPERABLE with a combined safety-related volume of $\geq 420,000$ gallons. In addition, LCO 3.7.6a requires the CST that supplies the AFW pumps to contain a safety-related volume of $\geq 340,000$ gallons. The volume specified for the CST supplying the AFW System is based on the need to ensure sufficient time exists for the operator action required to switch the AFW pump suction supply to the other CST. If the combined safety-related volume or the safety-related volume required for the AFW supply is not as specified, LCO 3.7.6a contains Actions to restore the volume(s) to within limit or to place the unit in a MODE where the CSTs are no longer required OPERABLE. LCO 3.7.6a is no longer required and may be deleted when both units have completed the required modifications.~~

5.5 Programs and Manuals (continued)

5.5.10 Secondary Water Chemistry Program

7a

This program provides controls for monitoring secondary water chemistry to inhibit SG tube degradation and ~~low pressure turbine disc stress corrosion cracking~~. The program shall include:

- a. Identification of a sampling schedule for the critical variables and control points for these variables;
- b. Identification of the procedures used to measure the values of the critical variables;
- c. Identification of process sampling points; ~~which shall include monitoring the discharge of the condensate pumps for evidence of condenser in leakage;~~
- d. Procedures for the recording and management of data;
- e. Procedures defining corrective actions for all off control point chemistry conditions; and
- f. A procedure identifying the authority responsible for the interpretation of the data and the sequence and timing of administrative events, which is required to initiate corrective action.

8

5.5.11 Ventilation Filter Testing Program (VFTP)

A program shall be established to implement the following required testing of Engineered Safety Feature (ESF) filter ventilation systems at the frequencies specified in ~~[Regulatory Guide]~~, and in accordance with ~~[Regulatory Guide 1.52, Revision 2x and ASME N510-1989, and AG 1]~~.

1980

- a. Demonstrate for each of the ESF systems that an in-place test of the high efficiency particulate air (HEPA) filters shows a penetration and system bypass $\leq 0.05\%$ when tested in accordance with ~~[Regulatory Guide 1.52, Revision 2, and ASME N510-1989]~~ at the system flowrate specified below $\pm 10\%$.

LCV-0603-E

1980

ESF Ventilation System



Flowrate



(CREFS)

Control Room Emergency Filtration System 19,000 CFM
Piping Penetration Area Filtration and Exhaust System (PPAFES) (continued)
15,560 CFM

5.5 Programs and Manuals

5.5.11 Ventilation Filter Testing Program (VFTP) (continued)

9a

- b. Demonstrate for each of the ESF systems that an in place test of the charcoal adsorber shows a penetration and system bypass $\leq 10.051\%$ when tested in accordance with Regulatory Guide 1.52, Revision 2, and ASME N510-1989 at the system flowrate specified below $\pm 10\%$.

1980




LCV-0603-E

8a

- c. Demonstrate for each of the ESF systems that a laboratory test of a sample of the charcoal adsorber, when obtained as described in Regulatory Guide 1.52, Revision 2, shows the methyl iodide penetration less than the value specified below when tested in accordance with ASTM D3803-1989 at a temperature of $\geq 30^{\circ}\text{C}$ and greater than or equal to the relative humidity specified below.

or equal to



Reviewer's Note: Allowable penetration = $[100\% - \text{methyl iodide efficiency for charcoal credited in staff safety evaluation}] / (\text{safety factor})$
 Safety factor = [5] for systems with heaters.
 = [7] for systems without heaters.

9

- d. Demonstrate for each of the ESF systems that the pressure drop across the combined HEPA filters, the prefilters, and the charcoal adsorbers, is less than the value specified below when tested in accordance with Regulatory Guide 1.52,

and CREFS cooling coils

(continued)