



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

May 28, 1992

Docket No. 52-002

APPLICANT: Combustion Engineering, Inc. (ABB-CE)
PROJECT: CE SYSTEM 80+
SUBJECT: MEETING ON APRIL 30, 1992, REGARDING THE MODIFIED ELECTRICAL
DISTRIBUTION SYSTEM FOR SYSTEM 80+

On April 30, 1992, a public meeting was held between representatives of the Nuclear Regulatory Commission (NRC) staff and ABB-CE regarding a modification to the System 80+ electrical distribution system. A list of the attendees at the meeting is provided in Enclosure 1. ABB-CE's presentation material is provided in Enclosure 2. The last two pages of Enclosure 2 pertain to the modified electrical distribution system. The other pages provide historical and background information.

ABB-CE stated that the modified distribution system design would be submitted by May 8, 1992. This would include new drawings and marked-up pages for CESSAR-DC. The switchyard designs shown are conceptual designs for an interface requirement. The Electric Power Research Institute (EPRI) Design Requirements Document requires the feed to the safety busses to be normally from the unit auxiliary transformer and fast transfer to the reserve transformers for safety buses. The diesel generator is connected to the safety buses through two breakers in series. The diesel generator output breakers are manual and normally closed. The drawing in Enclosure 2 was corrected at the meeting to designate these breakers as normally closed.

The NRC provided comments on the ABB-CE responses to requests for additional information (RAI) as follows:

RAI 430-2 ABB-CE is to confirm that the inspections, tests, analyses, and acceptance criteria (ITAAC) will ensure a non-class IE failure does not cause adverse effects on class IE components and distribution system.

RAI 430.28 Remove the caveat, "if necessary."

RAI 430.29 This response conflicts with response to 430.19.

020123

NRC FILE CENTER COPY

9206020302 920528
PDR ADOCK 05200002
A PDR

Handwritten: 1703
11

May 28, 1992

- RAI 430.30 ITAAC must demonstrate that adequate time is available to take corrective action for any by-passed diesel generator trip that could result in diesel generator failure.
- RAI 430.31 ABB-CE must provide analysis to show that the loading sequence intervals are acceptable.
- RAI 430.32 Clarify the number of pumps needed. Also, can the containment spray pump be started at any time after its normal sequence when other loads are sequencing on?

Perform a failure effects and modes analysis (FEMA) to ensure that failure of any a-c bus or d-c bus does not result in a plant transient and simultaneous loss of single failure protection in any safety-related system.

- RAI 430.25 How many UV relays are on each bus? What is actuation logic used? Describe any co-ordination needed.
- RAI 430.26 Are there different sequencers for offsite and onsite power sources?
- RAI 430.34 Expand response to include d-c motors.
- RAI 430.35 Elaborate on single failure protection for valve indication (diversity).
- RAI 430.36 Statement must be augmented to show that penetrations can withstand maximum fault current vs. time.
- RAI 430.37 Specify continuous rating plus margin for the combustion turbine.
- RAI 430.38 Words about 0.8 being a non-conservative power factors assumption are wrong.
- RAI 430.40 ABB-CE must make a positive response about providing surge arrestors for dry-type transformers.
- RAI 430.42 Why run control and power cables in a tray with a barrier? Check cable tray fill criteria.
- RAI 430.43 Item 2 clarify the use of breakers as isolation devices.
- RAI 430.45 Remove claim that solid state relays do not drift.
- RAI 430.47 Item 4 was not responded to.

NRC indicated other comments would be given over the telephone at a later date. NRC asked ABB-CE to ensure that all TMI items were addressed. ABB-CE was also asked to ensure that all emergency lighting fixtures were seismic Category I.

May 28, 1992

ABB-CE indicated that they would respond with mark-ups of CESSAR-DC, revised drawings and augmented responses to RAI's as soon as possible.

Original Signed By:

Thomas V. Wambach, Project Manager
Standardization Project Directorate
Associate Directorate for Advanced Reactors
and License Renewal
Office of Nuclear Reactor Regulation

Enclosures:

1. List of Attendees
2. ABB-CE Presentation

DISTRIBUTION:

Docket File	PDST R/F	DCrutchfield	WTravers
NRC PDR	RPierson	JNWilson	TMurley/FMiraglia, 12G18
TWambach	JMoore, 15B18	ACRS (10)	EJordan, 3701
PShea	OChopra, 7E4	CMcCracken, 8D1	GGrant, EDO

OFC:	LA:PDST	PM:PDST	SC:PDST
NAME:	PShea <i>PS</i>	TWambach:sg	JNWilson
DATE:	05/27/92	05/27/92	05/28/92

OFFICIAL RECORD COPY:
DOCUMENT NAME: MTSUM430.TW

Combustion Engineering, Inc.

Docket No. 52-002

cc: Mr. C. B. Brinkman, Acting Director
Nuclear Systems Licensing
Combustion Engineering, Inc.
1000 Prospect Hill Road
Windsor, Connecticut 06095-0500

Mr. C. B. Brinkman, Manager
Washington Nuclear Operations
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. Stan Ritterbusch
Nuclear Systems Licensing
Combustion Engineering, Inc.
1000 Prospect Hill Road
Post Office Box 500
Windsor, Connecticut 06095-0500

Mr. Daniel F. Giessing
U. S. Department of Energy
NE-42
Washington, D.C. 20585

Mr. Steve Goldberg
Budget Examiner
725 17th Street, N.W.
Washington, D.C. 20503

Mr. Raymond Ng
1776 Eye Street, N.W.
Suite 300
Washington, D.C. 20006

Mr. Mark McCabe
U.S. Department of Justice/EAG
555 4th Street, N.W.
Room 11-809
Washington, D.C. 20001

ATTENDEE LIST
ELECTRICAL DISTRIBUTION
APRIL 30, 1992


<u>NAME</u>	<u>ORGANIZATION</u>
THOMAS V. WAMBACH	NRC/NRR/PDST
OM P. CHOPRA	NRC/NRR/DST
MARK D. CERALDI	DE&S
J. F. STONER, JR.	DE&S
BRIAN R. HAY	DE&S
BILL FOX	DE&S
S. DAUBRENE	MPR
JOHN TROTTER	EPRI
RICK TURK	ABB-CE

SYSTEM 80+™

ELECTRICAL DISTRIBUTION SYSTEM PROPOSAL

DISCUSSION MEETING

ABB-CE OFFICES
ROCKVILLE, MARYLAND
APRIL 30, 1992



Amendment I
December 21, 1990



ONSITE POWER SYSTEM ONE-LINE


Figure

8.1-1

ACRS POLICY ISSUES

TWO POWER SOURCES TO NON-SAFETY BUSES SHOULD BE PROVIDED IN ORDER TO AVOID MINIMIZE RELIANCE ON ON NATURAL CIRCULATION AND THE SAFETY SYSTEMS FOR CORE COOLDOWN. (NRC RAI 430.9)

OFFSITE POWER SHOULD BE PROVIDED DIRECTLY TO THE SAFETY BUSES TO AVOID VOLTAGE AND POWER TRANSIENTS AND TO SEGREGATE SAFETY BUSES FROM NONSAFETY BUSES. CLASS 1E POWER SHOULD NOT HAVE TO TRANVERSE NONSAFETY BUSES TO THE SAFETY BUSES. (NRC RAI 430.10)




SYSTEM 80+ ELECTRICAL DISTRIBUTION ARRANGEMENT


- **FOUR CLASS 1E BUSES**
 - Supports Building General Arrangements For Quadrant Separation Of Safety Systems
 - Minimizes Cabling
 - Supports Mechanical Systems (e.g., Four SI Pumps)

- **FOUR 13.8 KV NON-SAFETY BUSES AND UNIT AUXILIARY TRANSFORMERS**
 - Based On Plant Loads
 - Required To meet Voltage Drop/Dip And Fault Duty
 - Supports Mechanical Systems (e.g., Four RCPs)

System 80+




ELEVATION 50+0 BASEMAT



NOTE: THIS DRAWING IS TO BE USED FOR THE LAYOUT AND CONNECTIONS OF THE BUS AND TO BE USED FOR THE WIRING OF THE TRANSFORMER.

* LOCKED OPEN BREAKER OR BREAKER MUST BE RE-ARMED BY SAFETY CIRCUIT

Figure 11.2-1 PWR Electrical System Configuration Page 11.2-5



SK41491

DIVISION 11

DIVISION 1

ELECTRICAL DISTRIBUTION SYSTEM BASES

ONE GENERATOR CIRCUIT BREAKER

THREE UNIT MAIN STEPUP TRANSFORMERS WITH ONE INSTALLED SPARE TRANSFORMER

TWO UNIT AUXILIARY TRANSFORMERS WITH ONE INSTALLED SPARE TRANSFORMER

TWO RESERVE TRANSFORMERS, EACH WITH MINIMUM CAPABILITY TO SUPPLY:

- A) THE MOST CONSERVATIVE POWER REQUIREMENTS OF ITS ASSOCIATED CLASS 1E BUSES, AND
- B) THE MOST CONSERVATIVE POWER REQUIREMENTS OF ITS ASSOCIATED PERMANENT NONSAFETY BUS, AND
- C) POWER REQUIREMENTS FOR AT LEAST ONE REACTOR COOLANT PUMP AND ITS SUPPORT LOADS.

4.16 KV PERMANENT NONSAFETY AND 4.16 KV SAFETY BUSES RECEIVE NORMAL POWER FROM THE UNIT AUXILIARY TRANSFORMERS. PER EPRI GUIDANCE (VOLUME II, CHAPTER 11, SECTION 4.2.2), ON LOSS OF UNIT AUXILIARY TRANSFORMER FAST TRANSFER TO RESERVE TRANSFORMER OCCURS. FAST TRANSFER WILL NOT OCCUR ON LOCA/LOOP. MANUAL TRANSFER OF 4.16 KV SAFETY BUSES TO RESERVE TRANSFORMERS IS AN OPTION, SHOULD FAILURE OCCUR IN PERMANENT NONSAFETY BUS.