

2

PACIFIC GAS AND ELECTRIC COMPANY

PG&E +

DIABLO CANYON POWER PLANT
P.O. Box 56 • Avila Beach, California 93424 • (805) 595-7351

R.C. THORNBERRY
PLANT MANAGER

August 3, 1984


Office of Management Information
and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

RE: Docket No. 50-275
License No. DPR-76
Monthly Operating Report for July, 1984

Gentlemen:

Enclosed are the completed monthly operating report forms for Diablo Canyon Unit 1 for July 1984. This report is submitted in accordance with Section 6.9.1.10 of our Technical Specifications. Please note that in last month's Operating Data Report, the "Gross Thermal Energy Generated" was inadvertently given in megawatt days rather than megawatt hours.

Sincerely,


R. C. THORNBERRY

RCT:jhr

Enclosures

cc Mr. John B. Martin, Regional Administrator
Region V - USNRC

8409130263 840803
PDR ADDCK 05000275
R PDR

DC0044 1

IE24
1/1

MONTHLY NARRATIVE REPORT
OF OPERATION
AND MAJOR MAINTENANCE EXPERIENCE

This report describes the operating and major maintenance experience for the month of July, 1984. This narrative report was prepared by the plant staff and is submitted in accordance with Section 6.9.1.10 of the Plant Technical Specifications.

On July 24, 1984, a low power natural circulation test was performed for operator training qualification.

There is no significant major safety-related maintenance to report.

No challenges to the PORV's or safety valves have been made.

On May 25, 1984, minor changes were made to the Environmental Radiological Monitoring Procedure. The changes consist of the assignment of responsibilities for documentation and application of corrective actions and the addition of more sample points to Table 6 "Summary of Cross Checks Program with State of California". The addition of more sample points to the Cross Checks Program was in response to an agreement with the State of California.

No changes have been made in the Offsite Dose Calculation Procedure, or any radioactive waste treatment systems.