



International Agreement Report

TRAC-PF1 Code Assessment Using OECD LOFT LP-FP-1 Experiment

Prepared by
F. J. Barbero

Centro de Investigaciones Energeticas
Medioambientales y Tecnologicas
Consejo de Seguridad Nuclear
Madrid, Spain

**Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555**

April 1992

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

Published by
U.S. Nuclear Regulatory Commission

NOTICE

This report was prepared under an international cooperative agreement for the exchange of technical information.* Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

Superintendent of Documents
U.S. Government Printing Office
P.O. Box 37082
Washington, D.C. 20433-7082

and

National Technical Information Service
Springfield, VA 22161

NUREG/IA-0050
ICSP-LP-FP-1



International Agreement Report

TRAC-PF1 Code Assessment Using OECD LOFT LP-FP-1 Experiment

Prepared by
F. J. Barbero

Centro de Investigaciones Energeticas
Medioambientales y Tecnologicas
Consejo de Seguridad Nuclear
Madrid, Spain

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

April 1992

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

Published by
U.S. Nuclear Regulatory Commission

NOTICE

This report documents work performed under the sponsorship of the Consejo De Seguridad Nuclear of Spain. The information in this report has been provided to the USNRC under the terms of an information exchange agreement between the United States and Spain (Technical Exchange and Cooperation Agreement Between the United States Nuclear Regulatory Commission and the Consejo De Seguridad Nuclear of Spain in the field of reactor safety research and development, November 1985). Spain has consented to the publication of this report as a USNRC document in order that it may receive the widest possible circulation among the reactor safety community. Neither the United States Government nor Spain or any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, or any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

ABSTRACT

Document resumes the final calculations of the thermal-hydraulic aspects of the OECD LOFT-LP-FP-1 experiment, with emphasis in those related with the assessment of the TRAC-PF1 code.

LOFT LP-FP-1 experiment was carried out at the LOFT facility in INEL, sponsored by the OECD.

Code used for this simulation was TRAC-PF1/Mod 1 (version 11.0) running on a CDC Cyber 830 (O.S. NOS-BE).

TABLE OF CONTENTS

1. INTRODUCTION	1
2. FACILITY AND TEST	4
2.1 System configuration	4
2.2 Test description	8
3. INPUT MODEL AND NODALIZATION	23
3.1 Code	23
3.2 Nodalization	25
4. RESULTS	39
4.1 Steady state	39
4.2 Transient	40
4.2.1 Exit flows	41
4.2.2 Initial quenches	43
4.2.3 Heat-up	45
4.2.4 T/H conditions during rod rupture period	47
4.2.5 Combined injection	48
5. RUN STATISTICS	82
6. CONCLUSIONS	85
7. REFERENCES	86
List of Figures	87
List of Tables	88
APENDIX A. LOFT system instrumentation	90

FOREWORD

This report represents one of the assessment application calculations submitted in fulfilment of the bilateral agreement for cooperation in thermalhydraulic activities between the Consejo de Seguridad Nuclear of Spain (CSN) and the United States Nuclear Regulatory Commission (US-NRC) in the form of Spanish contribution to the International Code Assessment and Applications Program (ICAP) of the US-NRC whose main purpose is the validation of the TRAC and RELAP system codes.

The Consejo de Seguridad Nuclear has promoted a coordinated Spanish Nuclear Industry effort (ICAP-SPAIN) aiming to satisfy the requirements of this agreement and to improve the quality of the technical support groups at the Spanish Utilities, Spanish Research Establishments, Regulatory Staff and Engineering Companies, for safety purposes.

This ICAP-SPAIN national program includes agreements between CSN and each of the following organizations:

- Unidad Eléctrica (UNESA)
- Unión Iberoamericana de Tecnología Eléctrica (UITESA)
- Empresa Nacional del Urano (ENUSA)
- Centro de Investigaciones Energéticas y Medioambientales (CIEMAT)
- TECNATOM
- LOFT-ESPAÑA

The program is executed by 12 working groups and a generic code review group and is coordinated by the "Comité de Coordinación". This committee has approved the distribution of this document for ICAP purposes.

1. INTRODUCTION

The fission products release test LP-FP-1 was conducted on Dec 19, 1984. The first trial to conduct the test on Dec 12 had failed because of a defect in the position indicator of the hot leg QOBV (Quick Opening Blowdown Valve). The test was terminated by the PPS (Plant Protection System) action at about 10 s and the transient ended at 50 s. This test is designated as LP-FP-1A.

The thermal-hydraulic transient of the test LP-FP-1 has been initiated by the reactor scram and opening of the QOBV's with one second delay. This experiment simulates large break LOCA in the cold leg with delayed ECC injection to allow pin rupture and fission products release.

LP-FP-1 was specified to be similar to LOFT experiment L2-5 and OECD LOFT experiments LP-O2-6 and LP-LB-1, except for initial primary pump operation, closure of the BLCL valve and ECCS operation for core recovery and fuel cladding quench.

From the thermal-hydraulic point of view, the following objectives were considered achievable:

- Determine system thermal-hydraulics and core thermal response for initial and boundary conditions similar to a large break design basis LOCA leading to and limited to fission product release from the fuel cladding gap region.
- Determine the fission product retention effectiveness of the ECCS operating in a mode representative of a German

PWR ECCS in nominal (best estimate) conditions for combined hot leg and cold leg injection.

During the conduct of FP-1, most of the water in the accumulator B line was unintentionally injected into the upper plenum during the blowdown. This water distorted the thermal behaviour of the core and delayed the burst of the pressurized fuel pins by more than 200 s. Also more than 60 % of the rods that were planned to burst, remained intact. the thermal-hydraulic conditions in the core at the time of fission product release are far less definite than was expected. In order to be able to analyse the test results and to carry out post-test calculations using advanced thermal hydraulic codes, one has to know the amount and the rate of water injected.

We have selected a history for this unexpected injection, based on previous studies. We have run a simulation of 400 s, covering blowdown, heat-up and reflood phases in order to compare the obtained results with the data measured along the experiment, both hydraulic and thermal variables.

A brief description of the LOFT facility, system configuration for LP-FP-1 experiment and test evolution are included in Section 2, together with initial conditions and operational set points.

Section 3 contains the input model for TRAC-PF1 code and nodalization details.

In Section 4, results obtained are checked against the measured data for a set of important parameters showing main physical phenomena that occurred during the experiment.

Run statistics in different regions of the transient are shown in Section 5.

Conclusions and recommendations arising from the study are resumed in Section 6.

Appendix A resumes the instrumentation nomenclature and location for the LOFT system, related with the assessment.

2. FACILITY AND TEST DESCRIPTION

2.1 System configuration

The LOFT facility was designed to simulate the major components and system responses of a commercial PWR during a LOCA. The experimental assembly includes five major subsystems which have been instrumented in such a way that the system variables can be measured and recorded during a LOCA simulation. The subsystems include:

- Reactor vessel
- Intact loop
- Broken loop
- Blowdown suppression tank (BST)
- ECC system

Complete information on the LOFT system is provided in ref [1].

The arrangement of the major LOFT components is shown in Figs 2.1 and 2.2. The intact loop simulates three loops of a commercial four-loop PWR and contains a steam generator, two primary coolant pumps in parallel, a pressurizer, a venturi flowmeter and connecting piping.

The broken loop consists of a hot and a cold legs, each of which are connected to the reactor vessel and the BST header. Primary coolant pump and steam generator simulators were installed in the broken loop hot leg to provide the flow resistance normally represented by these components in a

commercial PWR. Each broken leg contains a quick-opening blowdown valve, a recirculation line, an isolation valve, an orifice to represent the break plane, and connecting piping. The recirculation lines establish a small flow through the broken loop to maintain hot fluid conditions in these loops which otherwise are stagnant prior to initiation of the experiment.

The LOFT reactor vessel, shown in Figure 2.3 has an annular downcomer, a lower plenum, lower core support plates, a nuclear core and an upper plenum. The downcomer is connected to the cold legs of the intact and broken loops and the upper plenum is connected to the hot legs.

The core consists of 1300 enriched uranium fuel rods arranged in five square and four triangular fuel assemblies. The fuel rods were designed to commercial PWR specifications except that they are only 1.68 m long and several fuel rods have special instrumentation. Twenty-four fuel rods were enriched to 6 % (wt) U235, and twenty-two of these were pre-pressurized at cold conditions to 2.41 MPa. The other two fuel rods were unpressurized and were designed to be easily removed for PIE. All other fuel rods in the core were unpressurized and enriched to 4 % (wt) U235. Fig 2.4 shows the fuel cladding thermocouple locations and Fig 2.5 shows all the central fuel assembly instrumentation, as well as the locations of the two fuel rods which were removed for PIE. Fig 2.6 shows the location for the thermocouples in the upper plenum. Nomenclature and location of the instruments may be seen in Appendix A.

The ECCS in FP-1 was designed to simulate the hot leg and cold leg ECC injection rates representative of the ECCS operation in a KWU 1300 Mwe reference PWR under nominal conditions. As mentioned, injection have to be delayed to allow fuel rupture and fission product release and transport in a vapour environment. Accumulator A was rooted to the intact loop cold leg (Fig 2.2) and was used to inject ECC scaled to the reference PWR best estimate cold leg accumulators and LPIS injection based on power scaling (1:100).

Accumulator B was rooted to the upper plenum (Fig 2.2) near the top of the center fuel assembly through a special piping configuration convenient to the LOFT system and not related to the reference PWR. Accumulator B was designed to inject ECC scaled to the reference PWR.

As the injection line enters the pressure vessel, it penetrates through the central fuel module and branches in the upper structure (see Fig 2.7). At station 203.17 (3.44 m) above reactor vessel bottom and about 42 cm above the top of fuel pins, 6 reflood injection nozzles are positioned to inject inside the flow shroud in the central fuel module. At station 191.82 (about 13 cm above the top of fuel pins) another 8 reflood nozzles are positioned in such a way as to inject outside the flow shroud and towards the peripheral elements. Details may be found in reference [2].

Accumulator B is connected to the pressure vessel by three lines. Injection in the hot leg, in downcomer or in the upper plenum can be activated. Direct injection in the downcomer is

only activated in case of PPS as happened in LP-FP-1A. The same lines are also used by the low pressure injection system (LPIS). See design of the injection line in Fig 2.8.

The upper plenum injection valve CV-P120-54 which is very near to the pressure vessel was then opened about 90 s before the test while the far valve CV-P120-33 was kept close. This means that the whole line between that valve and the nozzles in the upper plenum was subjected to the system pressure of 14.77 MPa during a period of 90 s before the test.

No accumulator blowdown and no venting of the primary system were performed after the failed experiment and no precautions were taken to prevent nitrogen injection. The injection line of accumulator B included large amount of nitrogen before system pressurization in the transient phase of FP-1. This nitrogen was then compressed to system pressure during the 90 s after opening CV-P120-54 and the gas bubble was moved towards the accumulator B, behind the flowmeter FE-P120-33.

The LOFT steam generator, located in the intact loop, is a vertical U-tube-design steam generator. Operation of the secondary coolant system approximates that of a commercial PWR.

2.2 Test description

LP-FP-1 was defined to consist of four distinct phases which were designated as: fuel preconditioning, pretransient, transient and postransient. The four phases were continuous and had specific beginning and ending definitions.

The purpose of the fuel preconditioning phase, in conjunction with the pretransient phase, was to subject the 24.6 % (wt) enriched fuel rods in the new center assembly to the minimum required burnup condition of 1175 MWD/MTU prior to conducting the transient. This burnup is equivalent to power operation at a maximum linear heat generation rate of 52.2 Kw/m for 20 days on the enriched fuel rods. The preconditioning phase started at the begining of plant heatup prior to power operation and ended with termination of power operation after the calculated burnup fraction had been achieved. An additional period of preconditioning beyond that required for minimum burnup occurred after the first attempt of conducting the experiment. The delay of one week resulted in three more days of power operation, reaching 1417 MWD/MTU.

The pretransient phase consisted of a reactor shutdown interval of approximately five days, followed by a power operation interval. The final plant preparations were completed during the reactor shutdown interval. The power operation interval established the required minimum decay heat level (86 % of DH in commercial PWR fuel rods after one year of at 52 Kw/m), and the initial conditions for conducting the experiment. The requirement to build up the short lived

fission product inventory of 40 Equivalent Fission Product Hours was achieved by 70 %. The pretransient phase started at the termination of power operation in the preconditioning phase and ended with initiation of the transient by a reactor scram.

The transient phase of the experiment started with reactor scram, followed by the opening of the QOBV's and ended at the initiation of the closure of the broken loop hot leg (BLHL) QOBV. The BLCL-QOBV was closed at 68 s to ensure that positive core vapour flow existed for the transport of fission products, released from the fuel rod gap, along the intended path for fission product measurements. The unplanned injection of water in the upper plenum due to the expansion of non-condensable gases in the injection line from accumulator B have caused a delay in pin rupture, core reflood and system recovery, which commenced at 344 s instead of the expected value of 100 s on a peak cladding temperature trip of 1037 K in the peripheral fuel assemblies was accomplished with cold leg and upper plenum accumulator ECC injection. The maximum cladding temperature measured in the central fuel assembly was 1210 K.

The final (postransient) phase consisted of a 12 h time from the closure of the BLHL-QOBV, for measuring the redistribution of fission product inventory in gas and liquid in the BST and PCS.

The initial conditions are specified in Table 2.1 together with the measured system conditions immediately prior to the

transient phase of LP-FP-1. The operational setpoints specified are listed in Table 3 together with the measured values. Differences between specified and operational setpoints reflect in some cases the time elapsed between operator action and system response.

* As shown in Table 2.2, the break apertures was taken as the initiation time of the experiment. The reactor was scrammed one second prior to the initiation of blowdown. This was done for avoiding early departure from nucleate boiling (DNB) on the 6 % fuel rods which would lead to excessive cladding temperatures early in the transient. The blowdown was initiated by opening the QOBVs and the pumps were turned off and decoupled from their flywheels within 1 s.

The PCS quickly depressurized to saturation pressure in the upper plenum, broken hot and cold legs by 0.1, 1.1 and 3.5 s, respectively. A bottom-up partial core quench occurred between 6 and 7 s, followed at 12 to 18 s by a total top-down quench of the central fuel assembly. The lower part of some of the peripheral fuel rods did not completely quench at this time. This total top-down quench was the 1st indication that the upper plenum injection line was leaking. The unplanned injection of water in the upper plenum doesn't influence the pressure history.

The cold leg QOBV was closed by 68 s, forcing all break flow out the cold leg and core flow from bottom to top. A sustained heatup of most (not all) of the core started at 90 s, resulting in the rupture of some of the enriched fuel

rods beginning at 325 s. The ECCS was initiated at 344 s and the entire core was quenched by 365 s. A 12 h postexperiment sampling period followed and the experiment was then terminated with plant cleanup and sample removal for PIE.

TABLE 2.1. Initial conditions for experiment LP-FP-1

	Specified Value ^(a)	Measured Value
<u>PRIMARY COOLANT SYSTEM</u>		
Core delta T (K)	14.4 ± 0.1	
Primary system pressure (hot leg) (MPa)	14.95 ± 0.1	14.77 ± 0.07 ^(b) (-1.2 %)
Hot leg temperature (K)	577 ± 1.1	577.6 ± 0.8
Cold leg temperature (K)		563.2 ± 1.1
Mass flow intact loop (kg/s)	479 ± 19	486.7 ± 2.5 ^(b) (+1.6 %)
Boron concentration (ppm)		612 ± 15
Primary coolant pump injection (both pumps) (L/s)	0.127 ± 0.016	0.126 ± 0.003
<u>REACTOR VESSEL</u>		
Power level (MW)	38 ± 1	37.0 ± 1.2 ^(b) (-2.6 %)
Maximum linear heat generation rate (kW/m)	~52	51.2 ± 3.6
Control rod position /above full-in position) (m)	1.37 ± 0.01	1.38 ± 0.002
<u>STEAM GENERATOR</u>		
Secondary system pressure (MPa) .		6.41 ± 0.08
Water level (m) ^(c)	0.19 ± 0.05	0.15 ± 0.06 ^(b) (-21 %)
<u>PRESSURIZER</u>		
Liquid volume (m ³)		0.66 ± 0.02
Steam volume		0.27 ± 0.02
Water temperature (K)		616.2 ± 5.8
Pressure (MPa)		14.73 ± 0.11
Liquid level (m)	1.12 ± 0.1	1.23 ± 0.04 ^(b) (+9.8 %)
<u>BROKEN LOOP</u>		
Cold leg temperature (K)		561.4 ± 1.5
Hot leg temperature (K)		564.8 ± 1.8
... / ...		

... / ...

	Specified Value ^(a)	Measured Value
<u>SUPPRESSION TANK</u>		
Liquid level (m)	1.27 ± 0.127	1.52 ± 0.06 ^(b) (+19.6 %)
Gas volume (m ³)		47.90 ± 2.11
Water temperature (K)		354.4 ± 3
Pressure (gas space) (kPa)		99.5 ± 3
Boron concentration (ppm)		3898 ± 15
<u>EMERGENCY CORE COOLING SYSTEM</u>		
Borated water storage tank tem- perature (K)	303 ± 3	303.4 ± 7
Accumulator A liquid level (m) ..	2.15 ± 0.03	2.11 ± 0.01 ^(b) (-1.8 %)
Accumulator A stardpipe position (above inside bottom of tank) (m)		0.4 ± 0.03
Accumulator A pressure (MPa)	4.14 ± 0.17	4.30 ± 0.06 ^(b) (+3.8 %)
Accumulator A liquid tempera- ture (K)	303 ± 3	300 ± 6 ^(b) (-0.99 %)
Accumulator B liquid level (m) ..	2.1 ± 0.03	2.08 ± 0.01 ^(b) (-0.9 %)
Accumulator B pressure (MPa)	4.15 ± 0.17	4.26 ± 0.06 ^(b) (+2.8 %)
Accumulator B liquid tempera- ture (K)	303 ± 3	308 ± 6 ^(b) (+1.6 %)

(a) If no value is listed, none was specified.

(b) These values were out of specification.

(c) Steam generator liquid level referenced to 2.95 m (116 in.) above top
of tube sheet.

TABLE 2.2. Operational setpoints

Event	Specified (s)	Actual (s)
Reactor scram	1.0 ± 0.025	-0.99 ± 0.01
QOBV open	0	0
Primary pumps turned off	1.25 ± 0.25	0.91 ± 0.01
FPMS isolation valve opened	29 ± 2	29.2 ± 0.1
BLCL QOBV closed	49 ± 5	62.5 ± 0.1
FPMS incore isolation valves closed ^(a)	341	340.8 ± 0.05
Accumulator A & B injection started ^(b)	347 ± 1	344.3 ± 0.05
FPMS BLHL isolation valve closed ^(c)	371 ± 2	371.7 ± 0.05
Accumulator injection stopped ^(d)	507 ± 1	506.5 ± 0.5
HPIS injection starts ^(d)	507 ± 1	515.8 ± 0.5
BLHL QOBV closed ^(e)	<527	535 ± 1
QOBV isolation valves closed ^(f)	>527	695 ± 1

- (a) Defined as when 3 peripheral thermocouples measured 1037 K (1408 °F).
- (b) 5 to 7 s after FPMS incore isolation valves closed.
- (c) 30±2 s after FPMS incore isolation valve closure.
- (d) 160 s after accumulator injection initiation.
- (e) Within 20 s after accumulator injection termination.
- (f) After closure of BLHL QOBV.




Figure 2.1. Axonometric representation of LOFT system




Figure 2.2. Emergency Core Cooling System




Figure 2.3. Loft reactor vessel

• Recorded on PLSS only - low frequency
 ■ Recorded on DAS/DDAPS - high frequency




Figure 2.4. Fuel cladding thermocouples in core





Figure 2.5. Central fuel assembly instrumentation



*Station numbers are a dimension of relative elevation within the DTI. They are assigned in increments of 100, starting from 300.00 at the reactor vessel flange edge. The symbols used are defined in the legend.

Figure 2.6. Upper plenum thermocouples




Figure 2.7. Accumulator B upper head injection




Figure 2.8. Accumulator B injection line

3. INPUT MODEL AND NODALIZATION

3.1 Code

Code used was TRAC-PF1/Mod 1 (version 11.0), installed on CDC Cyber 830.

The Transient Reactor Analysis Code (TRAC serie P) is an advanced best-estimate code for handling PWR accidents, having the capability to make a 3-D model in the reactor vessel. Code uses full two-fluid model with two-steps numerics in the one-dimensional components and may also handle a noncondensable gas field.

TRAC has the capability to treat the following physical phenomena:

1. ECC downcomer penetration and bypass, including the effects of countercurrent flow and hot walls
2. Lower plenum refill with entrainment and phase separation effects
3. Bottom-flood and falling-film reflood quench fronts
4. Multidimensional flow patterns in the core and plenum regions
5. Pool formation and countercurrent flow at the upper core support plate region
6. Pool formation in the upper plenum
7. Steam binding

8. Average rod and hot rod cladding temperature histories
9. Alternate ECC injection systems, including hot leg and upper lead injection
10. Direct injection of subcooled ECC water, without artificial mixing zones
11. Critical flow (choking)
12. Liquid carryover during reflood
13. Metal-water reaction
14. Water-hammer effects
15. Wall friction losses
16. Horizontal stratified flow, including reflux cooling

Code has been used without any modification in models or components. No multiplicative factor for minimum stable film boiling temperature (MSFBT) has been introduced.

3.2 Nodalization

Nodalization of the LOFT system for the FP-1 test may be seen in Figures 3.1 to 3.6 and Table 3.1.

Input deck for determining the plant steady state (actually a first processing by TRAC), is in Table 3.2.

Reactor vessel is modelled as three-dimensional due to the non-homogeneous phenomena registered during the experiment. 3-inner rings represent the core and the 4th downcomer, which extends from level 3 to level 11. Core covers levels 4 to 8 and loops insert at level 11.

First ring simulates the central (11 x 11) fuel assembly and around, a zircaloy shroud. Second and third rings are the internal parts of the peripheral bundles. Vessel is nodalized in 192 cells.

Bypasses have been introduced in the nodalization for getting a better calculation of core liquid fraction (underestimated in pretest calculations). Description and calculations of these bypasses may be found in reference [3]:

- 4 bypasses connecting lower and upper plena, carrying 4.7 % of the flux through the intact loop in the steady state.
- 3 bypasses from downcomer to lower plenum, carrying 4.1 % of the above mentioned flux.

The existence of 1300 rods in the core was simulated using 18 "theoretical" TRAC rods:

- 12 standard rods, representing 4 % enriched fuel rods, one per internal cell.
- 4 rods with peak factor 1.25, simulate the 24 - 6 % fuel rods, one per cell in the central ring.
- 1 rod in cell 8 with peak factor 1.094
- 1 rod in cell 12 with peak factor 1.236

Rod axial dynamic renodalization factor is fixed in a value of 11, instead the initially selected of 60, due to high running times.

Decay heat used has been obtained from the previous power and burn-up histories and may be seen in Table 3.3.

Figure 3.4 shows the intact loop nodalization, including pressurizer, primary side of SG and ECCS with the roots of LPI and HPI systems:

- Accumulator A has been simulated as a PIPE component instead an ACCUM component for avoiding calculation time. Flow rates correspond to those of a 1300 MW scaled KWU reactor.
- Cold leg is fractioned in several cells for helping follow condensation when the accumulator begins to inject.
- Pressurizer has been simulated also as a PIPE for the same reason as before. FILL connected at the upper end represents a relief valve.

Steam generator secondary side is modelled as a STGEN component, including secondary downcomer, main steam line and steam control valve (see Figure 3.5).

water loop is shown in Fig 3.6, where secondary sides of EFB represent Reflood Assist Bypass Valve, connecting both SG, PC, and pump, which includes simulators of steam generator and pump, is nodalized in detail but the cold leg has been defined using the minimum number of nodes, due to the TRAC ability for modelling the choked flow.

Accumulator B has been nodalized as 12 independent FILLs (one for each cell) rooted on the vessel axial node 9, where the upper head injector is located. Each FILL has the same injection history (see Fig 3.7 and Table 3.4) but different weights. History has been defined to be azimuthally symmetric but non-homogeneous from one ring to another. During the blow-down and heatup phases, these weights are:

Ring	Weight	per cell
1	0.33	0.0825
2	0.67	0.1675
3	0.	0.

Planned injection from 345 s on, follows the measured data from accumulators and the corresponding weights are:

Ring	Weight	per cell
1	0.20	0.05
2	0.34	0.085
3	0.46	0.115

Unexpected injection history from accumulator B line has been selected through several parametric studies from different authors and from the data registered by thermocouples

such as TE-5UP-004 (see Fig 3.8), guide tubes and flowmeter FE-P120-31. Main characteristics of the selected injection were:

- Bulk of mass injection starts at 16 s, being preceded of a slight mass flow of coolant.
- Duration of this injection expands up to 100 s.
- Mass flow doesn't cease during the heatup phase.
- A second injection peak exists at 270 s.
- Total unplanned mass water injected is 400.5 Kg.

Trips defined in TRAC to simulate the events occurred during the experiment, were:

t(s)	Event	Components
0.	SCRAM	50
1.	QOBVs aperture	32, 43
2.	Pumps disconnect	4, 5
63.5	QOBV (BLHL) closes	43
345.	Reflood begins	15

Accumulator B and BREAKS are inhibited during the plant steady state calculations. When this state is reached, code starts the transient using restart data and the input deck in Table 3.5.

TABLE 3.1. Nodalization elements of LOFT system

	Component Number	Description	Number of Cells	
			Primary	Secondary
Intact Loop	1	Hot leg--TEE	8	3
	2	Steam generator--STGEN	10	5
	3	Steam generator to pump piping--TEE	3	3
	4	Pump--PUMP	2	-
	5	Pump--PUMP	2	-
	6	Pump discharge--TEE	2	1
	7	Cold leg--TEE	9	1
	8	Pressurizer--PRIZER	3	-
Steam Generator Secondary Vessel	21	Header-TEE	2	1
	22	Downcomer--TEE	4	1
	23	Exit valve--VALVE	6	-
	24	Water inlet--FILL	-	-
	25	Steam exit--BREAK	-	-
Intact Vessel	50	Vessel		
		Axial levels	12	
		Radial segments	4	192
		Azimuthal sectors	4	
Broken Loop	31	Hot leg--TEE ^(a)	26	3
	41	Cold leg--TEE ^(a)	2	2
	32	Hot leg break--BREAK	-	-
	42	Cold leg break--BREAK	-	-
	43	Cold leg break--VALVE	4	-
Emergency Core Cooling Systems	12	HPI connection and piping--TEE.	1	1
	13	LPI connection and piping--TEE.	1	1
	14	Accumulator check valve--VALVE.	2	-
	15	Accumulator-ACCUM	3	-
	16	HPI--FILL	1	1
Upper Plenum	81-92	Upper plenum connections, Cells 1 through 12, Vessel Level 9--PIPE	-	-
ECCS	61-72	Upper plenum fills--FILL	-	-

(a) Secondary sides of hot and cold broken loops represent reflood assist bypass lines.

TABLE 3.3. Decay heat in LP-FP-1

t(s)	DH (MW)	t(s)	DH (MW)
0.	37.	4.	1.987
0.3	32.425	6.	1.875
0.9	9.875	8.	1.792
1.28	5.514	10.	1.726
1.38	3.990	15.	1.605
1.40	3.299	20.	1.518
1.46	2.996	30.	1.396
1.52	2.648	40.	1.309
1.59	2.332	60.	1.136
1.61	2.271	100.	1.070
2.	2.155	200.	0.950
3.	2.062	300.	0.840
		10.E4	0.053

TABLE 3.4. Unplanned injection history

t(s)	Mass flow rate (Kg/s)	Integrated flow (Kg)
0.	0.	0.
0.45	1.0	2.9
1.	0.	6.5
2.	0.67	6.8
16.	0.67	16.2
38.	7.2	102.8
40.	5.9	115.9
100.	0.	292.9
175.	0.5	311.6
255.	0.5	351.7
265.	0.	354.2
271.	1.8	359.6
277.	0.5	366.5
345.	0.5	400.5




Figure 3.1. Section of LOFT reactor






Figure 3.2. Vessel nodalization



— — — TRAC fluid cell boundaries
 - - - LOFT core fuel bundle boundaries

Figure 3.3. Simulated rods location




Figure 3.4. Intact loop nodalization




Figure 3.5. Steam generator secondary side nodalization




Figure 3.6. Broken loop nodalization




Figure 3.7. Unexpected injection history




Figure 3.8. TE-5UP-004 measurements

4. RESULTS

4.1 Steady state

Plant steady state conditions have been determined after 52 s of "pseudo-transient" for starting the transient phase calculations, based on the referred input model.

Table 4.1 resumes the final values for a representative set of variables, compared with the equivalent measured ones. The agreement is good in general, except in the case of the steam generator dome pressure, which shows a minor convergence rate. The main consequence of this fact is to have a slightly higher temperature in the intact loop (maintaining differences between hot and cold legs), without influence on the transient evolution.

Convergence criteria used (also in transient) have been:

- Inner convergence : 5.OE-6
- Outer convergence : 5.OE-4
- Steady state convergence : 1.OE-5
- Maximum number of iterations in vessel : 50
- Maximum number of outer iterations : 10
- Maximum number of steady state iterations : 25

Total calculation time for this 52 s of pseudo-transient has been 89400 s of CPU.

4.2 Transient

We analyze in this chapter, results obtained after simulating 400 s of transient, compared with measured data along the experiment. In the case of hydraulic variables, comparison is done between registered data and the variable calculated in the TRAC node related to the detector actual location. For cladding temperatures, code provides information at fixed rod heights; measurements for each thermocouple is compared with the calculations in two adjacent levels and, in some cases, using a cosine law interpolation.

Analysis is mainly directed to explain the asymmetry in the damaged rods distribution and to determine vessel thermal-hydraulic conditions during the fuel rod rupture period (325-345 s), in connection with fission products generation and transport.

Start time of simulation begins at scram time in order to take into account its effects on the plant thermal-hydraulic state, mainly on rod temperatures. From simulation start point through the instant of QOBV apertures, cladding temperatures decrease remarkably, while hydraulic variables remain nearly constant.

4.2.1. Exit flows

When QOBVs open, system pressure drops suddenly due to the subcooled flow through the breaks. Code slightly overestimates ($\sim 7\%$) system pressure up to 16 s, when becomes lower than the observed one, partly because of the unplanned injection existence. The final pressure in the blowdown phase is well calculated (see Fig 4.1).

Figures 4.2 to 4.5 show mass flow rates through the loops, and figures 4.6 to 4.9 the corresponding densities.

Sudden aperture of QOBVs in the broken loop drives the fluid, initially subcooled, to flow out at high velocity, higher in the cold leg, a way with a lower resistance. As pressure continues decreasing, fluid in the broken loop suffer saturation conditions, reaching critical velocity and reducing the mass flow rate. Simultaneously in the intact loop, flow decreases but at lower rate so there is a net positive mass inventory in vessel, causing a bottom-up quench, starting at 4.5-5 s in simulation time (1 s less in real experiment time) (see Fig 4.10 for CORE).

Mass flow rate in the ILHL shows a good agreement with FR- PG-205 detector measurements up to 7 s, when code calculates a back flow from the pressurizer and steam generator. Total mass implied in this flow is about 500 Kg in 18 s, which causes a top-down quench. Fig 4.6 is a plot of the density in ILHL showing two peaks, one for each mentioned back flows (pressurizer and steam generator). First peak is underestimated and delayed, but the second one is simulated properly.

In the ILCL, there is no reference data, because detectors have been removed in this experiment.

Agreement of mass flow rates in BLHL with experimental data is exceptionally good, matching the peaks caused by the mentioned quenches.

Code underestimates the mass flow rate in the BLCL during the initial phase, causing a greater mass inventory and, consequently, a greater pressure as Fig 4.1 has showed (always in the range of the experimental data uncertainties).

Vessel liquid fraction for upper plenum, core and lower plenum may be seen in Fig 4.10, where all the referred initial hydraulic effects can be observed in timing and relative magnitude.

4.2.2 Initial quenches

Loss of coolant and depressurization have as a direct consequence the interruption of fission processes and a drastic fall in the capability of cooling the fuel rods, from now on producing only decay heat.

Figures 4.11 to 4.14 show the evolution of cladding temperatures for the simulated 6 % fuel rods 13, 14, 15 and 16, at heights 0., 0.305, 0.533, 0.762, 1.219 and 1.676 m, during the blowdown phase. Fig 4.15 to 4.18 show, for the same rods and heights, the evolution in the whole transient (blowdown, heatup and reflood phases).

The explanation of the behaviour in cladding temperatures, can be derived from the comparison between this TRAC calculated variables and the corresponding measurements, such as in figures 4.19 and 4.20.

Code calculates an initial rod dry-out beginning at about 3 s (depending on the level). This first heat-up brings cladding temperatures up to the minimum stable film boiling temperature (MSFBT) or beyond, for almost the whole rod surface. A first (bottom-up) quench stops the rise in temperatures in the bar, but isn't able to destroy the film, as the experiment has showed.

After this slight cooling, temperature grows again (in film boiling regime) through the second quench (top-down at 16 s), which rewets all the bar, remaining yet in the same heat transfer mode, while experimental data show a second quench dropping the cladding temperature to saturation. Code predicts

a maximum temperature 2 or 3 s earlier than in the experiment.

Thermocouples remain at saturation several second, but a third dry-out occurs, irregular in timing and magnitude. An unexpected injection, actually non-homogeneous and asymmetric ends this phase. Code responds to the simulated injection only decreasing slowly cladding temperatures and, in some cases (as the 4 % fuel rods in central ring and 6 % fuel rods in cell 3) quenching the whole rod and getting the saturation temperature in the surface, when the MSFBT is reached, but in times delayed up to 40 s, compared with the measured in the experiment.

4.2.3 Heat-up

After the blowdown phase and under the effects of a decreasing unexpected injection, calculated cladding temperatures for rewetted rods begins to departure from nucleate boiling in time very near to the observed. Several thermocouples - (such as SG08 or SI05) undergoes particular quench situations reaching the DNB point very late. Code, of course, cannot predict these special cases because simulated injection is defined to be symmetric.

DNB point is exceptionally well matched in rods SG08, SI11, SE09 and 4C14, all of them starting from saturation.

Calculated mean heating rate, from DNB to reflood point, for 6 % fuel rods is about 3 K/s at peak power elevation, being 4-5 K/s a typical value for the initial rate. Calculated values are very near to measured data.

In those cases when cladding is in film boiling regime, the slope is nearly the same or lower, but starting at temperatures 200-300 K higher (see figure 26).

The effects of a second peak of injected water at 270 s, which provides about 12 Kg of coolant, are seen as a little decrease of 10-15 K in cladding temperatures. Actually, this was distributed in a very chaotic way, such as several thermocouples showed (including those in guide tubes).

Heat-up follows steadily from this point through the simultaneous injection from accumulators A and B at 345 s.

Table 4.2 resumes the maximum cladding temperatures reached in the TRAC simulated rods at peak power elevation (27 inch). Marked values correspond to those rods which remain in film boiling regime during the whole transient. Fig 4.23 to 4.25 show the behaviour of those instrumented 6 % fuel rods which ruptured, compared with the corresponding TRAC calculations. In the case of 5G11, the agreement is exceptionally good, because of heat-up starts from saturation.

For peripheral rods (Fig 4.26), when the simulated rod has descended from film boiling regime, the fitting in the final heat-up phase is sucessful.

Thermocouples cited above, show sucessful fits between calculations and measured data along the final heat-up phase. In the case of 5G08 (4 % enriched fuel rod), predicted cladding temperature is lower than the registered during the final heat-up phase, so it's possible that the actual temperacure in central element during the rod rupture period were slightly higher than the calculated one. This comment is derived from only one 4 % enriched rod and must be seen as an hypothesis.

4.2.4. T/H conditions during rod rupture period

Results from TRAC shows that all the hydraulic variables were nearly constant during the period in which, eight 6 % fuel rods ruptured (325-345 s).

- A small quantity of water from accumulator B line was falling over the element during this phase as some detectors showed (see Fig 3.8 for TE-5UP-004). We are feeding the system with 0.5 Kg/s of coolant in this period, which flows down among the rods, vaporizing partly.

Tables 4.3 to 4.4 resume the mean (ring averaged) vapor and liquid behaviour during the rod rupture period, when eight 6 % fuel rods failed. Fig 4.27 shows the flow patterns (also during rupture period, when 8 - 6 % fuel rods failed. Figure averaged per ring) through the vessel.

One may see two possible and alternative paths for the generated fission products, both starting at peak power elevation (where there is a stagnation point) through BLHL:

- Ascending from this point to the upper plenum
- Descending from peak power elevation to the lower plenum and then, ascending through the peripheral bundles in ring 3.

Vapor in the upper plenum has a very asymmetric behaviour (Fig 4.28 and 4.29), which may be explained by the presence of the hot legs. Those cells near to the cold legs have near identical values.

In second ring (inner parts of peripheral bundles), vapor is nearly stagnant during this period.

4.2.5. Combined injection

From 345 s on, both accumulators inject coolant for system recovery. Injection caused dramatic oscillations in all plant variables, except on cladding temperatures which drop steadily to the moment when the MSFBT is reached and the film is destroyed. Quenching is nearly instantaneous but happens with a great delay respect to the measured final quench times. Enriched fuel rods (6 %) doesn't have completed the rewetting phase at 400 s in TRAC calculations.

Some other characteristics of the reflood period are:

- Core liquid fraction rise from 0. to 0.8 at a rate of 4 Kg/s (see figure 4.30).
- Vapor temperature in the core, decreases at a rate of about 6.5 K/s near the peak power elevation.
- Cooling rates for cladding temperatures are about:
 - 7 K/s for 4 % enriched fuel rods in central element.
 - 10 K/s for 6 % enriched fuel rods in central element.
 - 10 K/s for 4 % enriched fuel rods in peripheral elements.

TABLE 4.1. Plant calculated steady state

	Measured	TRAC/PF1
Hot leg pressure (Mpa)	14.77 + 0.07	14.87
Hot leg temperature (K)	577.6 + 0.8	581.6
Cold leg temperature (K)	563.2 + 1.1	567.2
Mass flow in loop (Kg/s)	486.7 + 2.5	487.5
Steam generator secondary pressure (Mpa)	6.41 + 0.08	6.77
Pressurizer pressure (Mpa)	14.73 + 0.11	14.85
Pressurizer temperature (K)	616.2 + 5.8	614.3
Broken loop cold leg temperature (K)	561.4 + 1.5	562.0
Broken loop hot leg temperature (K)	564.8 + 1.8	565.0

TABLE 4.2. Maximum cladding temperatures during
rod rupture phase

	4% Rod	T(K)	6% Rod	T(K)
Ring 1	1	1025	13	1254*
	2	1018	14	1238*
	3	1018	15	1167
	4	1048	16	1192
Ring 2	5	1076*		
	6	1173*		
	7	1165*		
	8	1176*		
Ring 3	10	950		
	11	933		
	12	940		
	13	952		

TABLE 4.3. Vapor axial velocity (m/s) in central ring during rod rupture phase

LEVEL	CELL			
	1	2	3	4
4	-0.75	-0.61	-0.71	-1.36
5	-0.41	-0.30	-0.39	-0.71
6	0.03	0.01	0.03	0.02
7	0.73	0.52	0.70	1.33
8	1.08	0.89	1.06	1.35

TABLE 4.4. Liquid axial velocity (m/s) in central ring during rod rupture phase

LEVEL	CELL			
	1	2	3	4
4	-3.60	-3.60	-3.60	-3.60
5	-3.51	-3.53	-3.51	-3.50
6	-3.45	-3.47	-3.45	-3.40
7	-3.35	-3.39	-3.35	-3.28
8	-3.26	-3.29	-3.26	-3.22

TABLE 4.5. Vapor temperature (K) in central ring during rod rupture phase

LEVEL	CELL			
	1	2	3	4
4	502	498	499	548
5	628	621	625	666
6	640	636	637	660
7	598	596	597	617
8	498	491	497	522




Figure 4.1. Upper plenum pressure

This page intentionally left blank.




Figure 4.2. intact loop hot leg (cell 3)




Figure 4.3. Intact loop cold leg (cell 2) mass flow




Figure 4.4. Broken loop cold leg (cell 1) mass flow




Figure 4.5. Broken loop hot leg (cell 3) mass flow




Figure 4.6. Intact loop hot leg (cell 2) density





Figure 4.7. Intact loop cold leg (cell 2) density

69



FIGURA

Figure 4.8. Broken loop cold leg (cell 1) density




Figure 4.9. Broken loop test log (cell 3) density




Figure 4.10. Vessel liquid fraction




Figure 4.11. Simulated 6 % rod 13 at several heights during blowdown phase




Figure 4.12. Simulated 6 % rod 14 at several heights during blowdown phase




Figure 4.13. Simulated 6 % rod 15 at several heights during blowdown phase




Figure 4.14. Simulated 6 % rod 16 at several heights during blowdown phase




Figure 4.15. Simulated 6 % rod 13 at several heights during the whole transient




Figure 4.16. Simulated 6 % rod 14 at several heights during the whole transient




Figure 4.17. Simulated 6 x rod 15 at several heights during the whole transient




Figure 4.18. Simulated 6 % rod 16 at several heights during the whole transient




Figure 4.19. Comparison with thermocouple 5E07 (blowdown)




Figure 4.20. Comparison with thermocouple SE07 (transient)




Figure 4.21. Cladding temperatures calculated for 5G08
(4 % fuel rod in central element)




Figure 4.22. Cladding temperatures calculated for SG08
(4 % fuel rod in central element)




Figure 4.23. Cladding temperatures calculated for SG11
(@ 1 ruptured fuel rod)




Figure 4.24. Cladding temperatures calculated for 5111
(6 % ruptured fuel rods)




Figure 4.25. Cladding temperatures calculated for SF09
(6 % ruptured fuel rod)




Figure 4.26. Cladding temperatures calculated for fuel rods in peripheral bundles





Figure 4.26. Cladding temperatures calculated for fuel rods in peripheral bundle 2






Figure 4.28. Vapor axial velocity (m/s) from level 10 to 11 during rod rupture phase




Figure 4.29. Vapor radial velocity (m/s) in level 11 during rod rupture phase




Figure 4.30. Liquid fraction in core

5. RUN STATISTICS

In the nodalization defined we have used the following number of cells:

- Vessel and core 192
- Intact loop 54
- Broken loop 37
- Steam generator
(secondary side) 19

Total number of cells = 302

Minimum and maximum time steps selected were:

Range (s)	DTMIN (s)	DTMAX (s)
0 - 1	1.E-5	1.E-3
1 - 5	1.E-5	1.E-2
5 - 345	1.E-5	1.E-1

These maximum values haven't been reached in any phase as may be seen in Fig 5.1, where the time step evolution along the transient is shown.

Figure 5.2 reflects the cumulative CPU time used in calculating the transient. Clearly, we can distinguish two phases according to the time steps selected by the code:

Phase	Range (s)	Number steps	CPU time (s)	RS
Blowdown & Heat-up	0 - 345	21500	624E3	96.1
Reflood	345 - 400	16000	576E3	119.2

The last column, named RS, represents the calculated run statistics (CPU time in ms per cell and time step) in units of ms/(cell*step).

Machine used for this calculation was CDC Cyber (operating system NOC-BE) with reserved Core Memory = 376500 and Extended Memory = 500.




Figure 5.2. Accumulated CPU time




Figure 5.1. Time step evolution

6. CONCLUSIONS

1. Good agreement exists between calculated and experimental hydraulic variables during the blowdown, like pressure, mass flow rates and densities.
2. TRAC-PF1 cannot simulate observed initial quenches and final quench time. If these delays were consequence of an incorrect value of MSFBT, introducing a multiplicative correcting factor greater than 1.12 in the correlation for MSFBT (only for the FP-1 case), the experimental quench time can be reproduced.
3. Good agreement is found between calculated and measured cladding temperatures for the 4 % enriched rods in central fuel assembly.
4. Those simulated 6 % fuel rods which suffer quench during the blowdown phase (such as rod 15 in TRAC, close to ILCL), show the best fitting with thermocouple data. For the remaining 6 % and peripheral rods, higher temperatures are calculated in film boiling transfer regime.
5. Three-dimensional behaviour is calculated, although unplanned upper plenum injection was defined to be azimuthally symmetric within each ring.
6. Flow patterns during rod rupture period show two possible paths for fission products in a non-dry phase.

7. REFERENCES

1. REEDER, D.L., 1978. LOFT System and Test Description. NUREG/CR-0247, TREE-1208.
2. Upper reactor vessel and ECC tube thermal-hydraulic analysis. 1984. EG&G OECD LOFT-I-14-5093.
3. Internal LOFT reactor vessel core bypass flows. 1981. EG&G LO-17-81-044.
4. BERTA, V.T., CORYEL, E.W., 1984. OECD LOFT Project Experiment Specification Document Fission Product Experiment LP-FP-1. OECD-LOFT-T-3702.
5. ADAMS J.P. et al., 1985. Quick Look Report on OECD-LOFT Experiment LP-FP-1. OECD-LOFT-T-3704. (and Experimental Data Tapes).
6. TRAC-PF1/Mod 1. An Advanced Best Estimate Computer Code for Pressurized Water Reactor Thermo-hydraulic Analysis. NUREG/CR-3858.
7. CORYELL, E.W. and GLAESER, H.G., 1984. Best estimate prediction for OECD LOFT Project Fission Product Experiment LP-FP-1. OECD-LOFT-T-3703.
8. CODDINGTON, P., 1987. FP-1 Accumulator Blowdown Calculations. Experts Meeting on LP-FP-1 Analysis. Garching.
9. WAHBA, A.B., 1987. The Fission Product Experiment FP-1 and Status of the Analysis. Experts Meeting on FP-1 Analysis. Garching.

LIST OF FIGURES

- Figure 2.1. Axonometric representation of LOFT system
Figure 2.2. Emergency Core Cooling System
Figure 2.3. Loft reactor vessel
Figure 2.4. Fuel cladding thermocouples in core
Figure 2.5. Central fuel assembly instrumentation
Figure 2.6. Upper plenum thermocouples
Figure 2.7. Accumulator B upper head injection
Figure 2.8. Accumulator B injection line
Figure 3.1. Section of LOFT reactor
Figure 3.2. Vessel nodalization
Figure 3.3. Simulated rods location
Figure 3.4. Intact loop nodalization
Figure 3.5. Steam generator secondary side nodalization
Figure 3.6. Broken loop nodalization
Figure 3.7. Unexpected injection history
Figure 3.8. TE-SUP-004 measurements
Figure 4.1. Upper plenum pressure
Figure 4.2. Intact loop hot leg (cell 3) mass flow
Figure 4.3. Intact loop cold leg (cell 2) mass flow
Figure 4.4. Broken loop cold leg (cell 3) mass flow
Figure 4.5. Broken loop hot leg (cell 1) mass flow
Figure 4.6. Intact loop hot leg (cell 3) density
Figure 4.7. Intact loop cold leg (cell 2) density
Figure 4.8. Broken loop cold leg (cell 3) density
Figure 4.9. Broken loop hot leg (cell 1) density
Figure 4.10. Vessel liquid fraction
Figure 4.11. Simulated 6 % rod 13 at several heights during blowdown phase

LIST OF TABLES

- Table 2.1. Initial conditions for experiment FP-1
- Table 2.2. Operational setpoints for experiment FP-1
- Table 3.1. Nodalization elements of LOFT system
- Table 3.2. Input deck listing for steady state
- Table 3.3. Decay heat for experiment FP-1
- Table 3.4. Unplanned injection history
- Table 3.5. Input deck listing for transient
- Table 4.1. Plant calculated steady state
- Table 4.2. Maximum cladding temperatures during rod rupture phase.
- Table 4.3. Vapor axial velocity (m/s) in central ring during rod rupture phase
- Table 4.4. Liquid axial velocity (m/s) in central ring during rod rupture phase
- Table 4.5. Vapor temperature (K) in central ring during rod rupture phase
- Table A.1. Nomenclature for LOFT instrumentation

- Figure 4.12. Simulated 6 % rod 14 at several heights during blowdown phase
- Figure 4.13. Simulated 6 % rod 15 at several heights during blowdown phase
- Figure 4.14. Simulated 6 % rod 16 at several heights during blowdown phase
- Figure 4.15. Simulated 6 % rod 13 at several heights during the whole transient
- Figure 4.16. Simulated 6 % rod 14 at several heights during the whole transient
- Figure 4.17. Simulated 6 % rod 15 at several heights during the whole transient
- Figure 4.18. Simulated 6 % rod 16 at several heights during the whole transient
- Figure 4.19. Comparison with thermocouple 5E07 (blowdown)
- Figure 4.20. Comparison with thermocouple 5E07 (transient)
- Figure 4.21. Cladding temperatures calculated for 5G08 (4 % fuel rod in central element)
- Figure 4.22. Cladding temperatures calculated for 5G08 (4 % fuel rod in central element)
- Figure 4.23. Cladding temperatures calculated for 5G11 (6 % ruptured fuel rod)
- Figure 4.24. Cladding temperatures calculated for 5I11 (6 % ruptured fuel rod)
- Figure 4.25. Cladding temperatures calculated for 5E09 (6 % ruptured fuel rod)
- Figure 4.26. Cladding temperatures calculated for fuel rods in peripheral bundles
- Figure 4.27. Flow patterns in vessel during rupture phase
- Figure 4.28. Vapor axial velocity (m/s) from level 10 to 11 during rod rupture phase
- Figure 4.29. Vapor radial velocity (m/s) in level 11 during rod rupture phase
- Figure 4.30. Liquid fraction in core
- Figure 5.1. Time step evolution
- Figure 5.2. Accumulated CPU time

APENDIX A. LOFT system instrumentation

This section resumes the instrumentation nomenclature and location in the LOFT facility, contained in reference [5].

Figures show locations for the main instrumentation used for the FP-1 thermal-hydraulic study.

All experimental data plotted in this document are identified using the instrumentation nomenclature explained in Table A.1, which is also used for the related variables. The DIRC report resumed, shows the qualified and failed data in the experiment, recorded at 50 samples per second, except in the cases which are noted.

TABLE A.1. Nomenclature for LOFT instrumentation

Designation for the different types of transducers

RPE - Pump speed	FE - Coolant flow
PE - Pressure transducer	DE - Densitometer
PdE - Differential pressure	ME - Momentum flux
LE - Coolant level	FT - Flow rate
PS - Pressure switch	TC - Fuel centerline
TE - Thermocouple	

Designation of systems

PC - Primary coolant intact	LP - Lower plenum
BL - Broken loop	ST - Dowcomer stalk
RV - Reactor vessel	UP - Upper plenum
P120 - Emergency core coolant system	P128 - Primary coolant addition and control

Designation for Core instrumentation

Transducer location (inches from bottom) -----

Fuel assembly row -----

Fuel assembly column -----

Fuel assembly number -----

Transducer type -----

TF-3B11-28




Figure A-1. LOFT Major Components




Figure A-2. LOFT Piping Schematic with Instrumentation

Process instrumentation for the containment vessel (not shown) includes containment pressure (PT-P139-41, 42 and 43), containment temperature (TE-T55-2), and hydrogen concentration (AH2E-T55-1,2,3). Specific instrumentation for the pressurizer and steam generator is found on their respective drawings in this set.




Figure A-3 LOFT Intact Loop Process
Instrumentation





Figure A-4. LOFT Intact Loop Experimental Thermal-Hydraulic instrumentation



IHEI-AC-11-4-308

Figure A-5. Instrument Locations - Broken Loop Differential Pressure Measurements

85/02/01
15:52:31

FP-1 FINAL DIRE QUALIFICATION REPORT

EFFECTIVE DATE: 01/09/85
REVISION: FINAL
SYSTEM: LOOP FP-1

MEASUREMENT IDENTIFICATION		DESCRIPTION	QUAL DATE	STATUS	QUALIFYING STATEMENT(S)
CV-P004-008	VALVE POS-FEEDWATER FLOW CONTROL		01-03-87	QUALIFIED	
CV-P004-010	VALVE POS-SCS STEAM FLOW CONTROL		12-31-84	QUALIFIED	
CV-P004-090	MAIN STEAM BYPASS VALVE		01-03-85	QUALIFIED	
CV-P004-091	MAIN FEED BYPASS VALVE		12-31-84	QUALIFIED	
CV-P138-001	VALVE POS-BROKEN LOOP CL 008A		01-03-85	QUALIFIED	
CV-P138-015	VALVE POS-BROKEN LOOP HL 008A		12-31-84	QUALIFIED	
CV-P138-070A	VALVE POS-BROKEN SYSTEM RASH CH A	12-31-84	QUALIFIED		
DE-BL-001A	CHORDAL DENSITY-BROKEN SYSTEM RASH CH B	12-31-84	QUALIFIED		
DE-BL-001B	CHORDAL DENSITY-BROKEN LOOP CL	01-03-85	QUALIFIED		
DE-BL-001C	CHORDAL DENSITY-BROKEN LOOP CL	01-03-85	QUALIFIED	TO 6.5 SEC OND S	
DE-BL-002A	CHORDAL DENSITY-BROKEN LOOP HL	01-03-7	QUALIFIED	TO 6.5 SEC OND S	
DE-BL-002B	CHORDAL DENSITY-BROKEN LOOP HL	01-03	QUALIFIED	TO 6.5 SEC OND S	

85/02/01
15.52.31

FP - FINAL DISC QUALIFICATION REPORT
15.52.31

EFFECTIVE DATE: 01/30/85
REVISION: F16A1
SYSTEM LOGIC FP-1

MEASUREMENT QUALIFICATION	DESCRIPTION	QUAL DATE	QUAL STATUS	QUALIFYING STATEMENT(S)
DE-BL-002C	CHORDAL DENSITY-BROKEN LOOP HL	01-09-85	QUALIFIED	TO 65 SECONDS
DE-BL-002D	GROSS GAMMA AVG/BROKEN LOOP HL	01-29-85	QUALIFIED	TO 60 DATA ONLY, 80 SAMPLES PER SECOND DATA
DE-BL-105	AVERAGE DENSITY-BROKEN LOOP CL	01-11-85	QUALIFIED	AFTER 13 SECONDS, SPURIOUS SPINES
DE-BL-205	AVERAGE DENSITY-BROKEN LOOP HL	01-11-85	QUALIFIED	TO 65 SECONDS
DE-PC-001A	CHORDAL DENSITY-INTACT LOOP CL	01-08-85	QUALIFIED	SPURIOUS SPINES
DE-PC-001B	CHORDAL DENSITY-INTACT LOOP CL	01-08-85	QUALIFIED	SPURIOUS SPINES
DE-PC-001C	CHORDAL DENSITY-INTACT LOOP CL	01-08-85	QUALIFIED	SPURIOUS SPINES
DE-PC-002A	CHORDAL DENSITY-INTACT LOOP HL	01-09-85	QUALIFIED	DE-PC-001B USED FOR BACKGROUND CORRECTION
DE-PC-002B	CHORDAL DENSITY-INTACT LOOP HL	01-09-85	QUALIFIED	TO 65 SECONDS
DE-PC-002C	CHORDAL DENSITY-INTACT LOOP HL	01-09-85	FAILED	
DE-PC-002D	GROSS GAMMA AVG/INTACT LOOP HL	01-29-85	QUALIFIED	TO 60 DATA ONLY
DE-PC-101	AVERAGE DENSITY - INTACT LOOP CL	01-11-85	QUALIFIED	
DE-PC-225	WEIGHTED AVG DENSITY CL HL	01-11-85	QUALIFIED	TO 65 SECONDS

05/02/01
13:52:34

FP-1 FINAL DIRC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/85
REVISION: FINAL
SYSTEM: LOCE FP-1

MEASUREMENT DESCRIPTION	QUAL. DATE	STATUS	QUALIFYING STATEMENT
FP-PC-002A QUALITY-INTACT LOOP HOT LEG BOTTOM CL-09-85 QUALIFIED			UNIDIRECTIONAL
FP-PC-002B QUALITY-INTACT LOOP HOT LEG MIDDLE 01-09-85 QUALIFIED			UNIDIRECTIONAL
FP-PC-002C QUALITY-INTACT LOOP HOT LEG TOP 01-09-85 QUALIFIED			UNIDIRECTIONAL
FP-PC-002 AVERAGE VELOCITY - INTACT LOOP HL 01-27-85 QUALIFIED			UNIDIRECTIONAL
FP-1ST-001 VELOCITY DOWNSIDE STALK 1 LOWER 01-09-85 QUALIFIED			UNIDIRECTIONAL
FP-1ST-002 VELOCITY DOWNSTREAM STALK 1 LOWER 01-18-85 QUALIFIED			UNIDIRECTIONAL
FP-1ST-002 VELOCITY-FAS ABOVE UPPER END BOX 01-09-85 QUALIFIED			UNIDIRECTIONAL
FP-BL-105 AVERAGE FLOWRATE, BROKEN LOOP CL 01-18-85 QUALIFIED			TO 65 SECONDS
FP-BL-205 AVERAGE FLOWRATE, BROKEN LOOP HL 01-27-85 QUALIFIED			TO 420 SECONDS, MASS FLOW AFTER 65 SECONDS BASED ON STEAM DENSITY
FP-PC-205 MASS FLOW RATE HL OBJECTS 01-27-85 QUALIFIED			TO 22 SECONDS. 3 DRAG DISC SUBSTITUTED FOR C DRAG DISC IN CALCULATION
FP-P004-012 FLOWRATE-STEAM FLOW CONDUIT 2A 01-03-85 QUALIFIED			INITIAL CONDITIONS ONLY
FP-P004-090 VOLUMETRIC FLOW STEAM TRANSMIC # 01-03-85 QUALIFIED			
FP-P004-091 VOLUMETRIC FLOW SECONDARY 01-03-85 QUALIFIED			

03/02/01
15-32-31

FP-1 FINAL DINC QUALIFICATION REPORT

EFFECTIVE DATE: 01/03/05
REVISION: FINAL
SYSTEM: LOCS FP-1

MEASUREMENT IDENTIFICATION	MEASUREMENT DESCRIPTION	QUAL DATE	UAL STATUS	QUALIFYING STATEMENT(S)!
FI-P004-72-A	FLOWATE-LCS FLOWMETER	01-09-05	QUALIFIED	INITIAL CONDITION ONLY
FI-P004-72-C	FLOWATE-LCS PNEUMATIC	01-09-05	QUALIFIED	INITIAL CONDITIONS ONLY
FI-P120-072	FLOWRATE-LPIS PUMP & DISCHARGE	01-03-05	QUALIFIED	NO OTHER MEASUREMENT FOR DIRECT COMPARISON
FI-P120-085	FLOWRATE-LPIS PUMP & DISCHARGE	01-03-05	QUALIFIED	NO OTHER MEASUREMENT FOR DIRECT COMPARISON
FI-P128-085	FLOWRATE-HPI'S PUMP & DISCHARGE	01-09-05	QUALIFIED	NO OTHER MEASUREMENT FOR DIRECT COMPARISON
FI-P128-104	FLOWRATE-HPI'S PUMP & DISCHARGE	01-09-05	QUALIFIED	NO OTHER MEASUREMENT FOR DIRECT COMPARISON
FI-P139-27-1	FLOWRATE-INFACT LOOP COOLANT	01-08-05	QUALIFIED	INITIAL CONDITION ONLY
FI-P139-27-2	FLOWRATE-INFACT LOOP COOLANT	01-08-05	QUALIFIED	INITIAL CONDITION ONLY
FI-P139-27-3	FLOWRATE-INFACT LOOP COOLANT	01-08-05	QUALIFIED	INITIAL CONDITION ONLY
FI-P141-022	FLOWRATE-TOTAL PCC	01-03-05	QUALIFIED	NO OTHER MEASUREMENT FOR DIRECT COMPARISON
LO-P139-006	LIQUID LEVEL-PRESSURIZER CH A	12-31-04	QUALIFIED	INITIAL CONDITIONS ONLY
LO-P139-007	LIQUID LEVEL-PRESSURIZER CH B	12-31-04	QUALIFIED	INITIAL CONDITIONS ONLY
LO-P139-008	LIQUID LEVEL-PRESSURIZER CH C	12-31-04	FAILED	

870270
15.52±31

FP-1 FINAL QIRC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/85
REVISION: FINAL
SYSTEM: LOC FP-1

MEASUREMENT IDENTIFICATION	DESCRIPTION	QUAL DATE	STATUS	QUALIFYING STATEMENT	INITIAL AND FINAL CONDITIONS ONLY
LEPDE-SV-101	Liquid Level-Assay	01-18-85 QUALIFIED		01-18-85 QUALIFIED	INITIAL AND FINAL CONDITIONS ONLY
LE-ECC-01A	ACCUMULATOR A LIQUID LEVEL	01-11-85 QUALIFIED		NO OTHER MEASUREMENT FOR DIRECT COMPARISON	
LE-1F10	COOLANT LEVEL-FUEL ASSY 1 LOC F10	01-03-85 QUALIFIED		FAILED STINGS - 1, 4, 5, 6, 7, 8, 9, 11, 13, 16, 18	
LE-1ST-001	COOLANT LEVEL-INSTR STALK 1 UP	12-27-84 QUALIFIED		FAILED STINGS - 1, 2, 3, 4, 5, 7, 11, 16, 18, 19	
LE-3F10	COOLANT LEVEL-FUEL ASSY 3 LOC F10	12-27-84 QUALIFIED		FAILED STINGS - 1, 2, 3, 4, 5, 7, 11, 16, 18, 19	
LE-3UP-001	COOLANT LEVEL-UPPER PLenum	01-03-85 QUALIFIED		FAILED STINGS - 1, 2, 3, 4, 5, 6, 7, 8	
LE-SUP-001	COOLANT LEVEL-UPPER PLenum	12-27-84 QUALIFIED		FAILED STING - 17	
LI-T-P120-030	Liquid Level-Accumulator B	01-11-85 QUALIFIED		NO OTHER MEASUREMENT FOR DIRECT COMPARISON	
LI-D-P138-033	Assy Dens Curr B	01-18-85 QUALIFIED		INITIAL AND FINAL CONDITIONS ONLY	
LI-D-P138-050	Assy Dens Curr Y	01-18-85 QUALIFIED		INITIAL AND FINAL CONDITIONS ONLY	

05/02/01
15.52.31

FP-1 FINAL DIAC QUALIFICATION REPORT

EFFECTIVE DATE: 01/06/05
REVISED: FINAL
SYSTEM: LOCB FP-1

MEASUREMENT IDENTIFICATION
DESCRIPTION
QUAL STATUS
DATE
QUALIFYING STATEMENT(S):

LI-P004-000A STEAM GENERATOR LEVEL 01-18-05 QUALIFIED

LI-P004-042 CONDENSATE RECEIVER LEVEL 12-31-04 QUALIFIED

LI-P007-08A STEAM GEN LEVEL, MEDIUM RANGE 01-14-04 QUALIFIED

LI-P130-033 LIQUID LEVEL, 100% A 01-14-05 QUALIFIED

LI-P130-058 LIQUID LEVEL-BOTT B 01-18-05 QUALIFIED

ME-SL-001A HIGH FLUX, SL-1, MIDDLE, HIGH RANGE 01-18-05 QUALIFIED TO 6.5 SECONDS

ME-SL-001B HIGH FLUX, SL-1, MIDDLE, TOP, HIGH RANGE 01-18-05 QUALIFIED TO 6.5 SECONDS

ME-SL-001C HIGH FLUX, SL-1, TOP, HIGH RANGE 01-18-05 QUALIFIED TO 6.5 SECONDS

ME-SL-001 D AVERAGE HIGH FLUX, BROKEN LOOP CL 01-18-05 QUALIFIED TO 6.5 SECONDS

ME-SL-002A MEDIUM FLUX-BROKEN LOOP HL BOTTOM 01-18-05 QUALIFIED

ME-SL-002B MEDIUM FLUX-BROKEN LOOP HL MIDDLE 01-18-05 QUALIFIED

ME-SL-002C HIGH FLUX-BROKEN LOOP HL TOP 01-18-05 QUALIFIED

ME-SL-002 D AVERAGE HIGH FLUX, BROKEN LOOP HL 01-18-05 QUALIFIED

05/02/01
15.22.31

FPM FINAL QIRC QUALIFICATION REPORT

EFFECTIVE DATE: 01/10/85
REVISION: FINAL
SYSTEM: LOCE FPM-1

MEASUREMENT IDENTIFICATION	DESCRIPTION	QUAL DATE	QUAL STATUS	QUALIFYING STATEMENT(S)
ME-PC-002A	MOMENTUM FLUX-INTACT LOOP HL EDITION 01-22-85 QUALIFIED			10 22 SECONDS
ME-PC-002B	MOMENTUM FLUX-INTACT LOOP HL MIDDLE 01-22-85 QUALIFIED			10 22 SECONDS
ME-PC-002C	MOMENTUM FLUX-INTACT LOOP HL TOP	01-18-85	FAILED	
ME-15T-002	AVE ADVENTUR FLUX-INTACT LOOP HL	01-22-85	QUALIFIED	10 22 SECONDS. 0 DBAC DISC SUBSTITUTION FOR C DBAC DISC IN CALCULATION
ME-15T-001	MOMENTUM FLUX-INSTR STAK 1 DC	01-22-85	FAILED	
ME-15T-002	MOMENTUM FLUX-INSTR STAK 1 DC	01-22-85	FAILED	
ME-SUP-002	MOMENTUM FLUX-PAS AB UPPER END SON	01-22-85	QUALIFIED	UNTIL 10 24% AND AFTER 70 SECONDS UNC COMPENSATED TEMPERATURE SENSITIVITY BETWEEN 10 & 70 SECS.
ME-ZHO-B-26	NEUTRON DETECTOR IN CORE FAB2	12-31-84	QUALIFIED	
ME-ZHO-B-26	NEUTRON DETECTOR IN CORE FAB4	12-31-84	QUALIFIED	
ME-040-B-26	NEUTRON DETECTOR IN CORE FAB6	12-31-84	QUALIFIED	
PCB-81-003	DELTIA P-BL GOLD LEG SPIN PLANE	01-03-85	QUALIFIED	
POE-BL-008	DELTIA P-BL ACROSS SPIN PLANE	01-03-85	QUALIFIED	
POE-SV-001	SUPPRESSION VESSEL LEVEL	01-18-85	QUALIFIED	INITIAL AND FINAL CONDITIONS ONLY

85702701
15-52-31

FP-1 FINAL DIFC QUALIFICATION REPORT

EFFECTIVE DATE: 01/20/85
REVISIONS: FINAL
SYSTEM: LOCE FP-1

REFERENCE	TEST REQUIREMENT DESCRIPTION	QUAL DATE	QUAL STATUS	QUALIFING STATEMENTS
P0E-SV-002	SUPPRESSION VESSEL LEVEL	01-08-85	QUALIFIED	INITIAL AND FINAL CONDITION IS ONLY
P01P139-27-1	INTACT LOOP MASS FLOW DELTA P	01-08-85	QUALIFIED	INITIAL CONDITION ONLY, THENS THEREAFTER
P01P139-27-2	INTACT LOOP MASS FLOW DELTA P	01-08-85	QUALIFIED	INITIAL CONDITION ONLY, THENS THEREAFTER
P01P139-27-3	INTACT LOOP MASS FLOW DELTA P	01-08-85	QUALIFIED	INITIAL CONDITION ONLY, THENS THEREAFTER
P0T-P004-072	DIFF PRESS FRESHWATER FLOW UNIFICE	01-08-85	QUALIFIED	INITIAL CONDITIONS ONLY
P0T-P139-03UA	DELTA PRIMARY COOLANT PUMP	01-03-85	QUALIFIED	INITIAL CONDITIONS ONLY
P0T-P139-0308	DELTA P - INTACT LOOP 36	01-08-85	QUALIFIED	INITIAL CONDITION ONLY, THENS THEREAFTER
P0T-P139-030	DELTA P - REACTOR VESSEL	01-03-85	QUALIFIED	UNIDIRECTIONAL
P1-E-81-001	PRESSURE-BROKEN LOOP COOLANT	12-27-84	QUALIFIED	
P1-E-81-002	PRESSURE-BROKEN LOOP HOT LEG	12-27-84	QUALIFIED	
P1-E-C-002	PRESSURE-INTACT LOOP HOT LEG	12-27-84	QUALIFIED	
P1-E-C-005	PRESSURE-INTACT LOOP REF.	12-27-84	QUALIFIED	
P1-E-C-006	PRESSURE-INTACT LOOP REF.	12-27-84	QUALIFIED	

85-027-01
15-22-31

CP-1 FINAL DIRC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/85
REVISION: FINAL
SYSTEM: LOCB FP-1

MEASUREMENT	DESCRIPTION	QUAL	DATE	STATUS	QUALIFYING STATEMENT(S)
PS-5F04-SW	PRESSURE SWITCH FA #5	01-11-85	QUALIFIED	SWITCH ACTIVATES AT 800 INTERNAL PRESSURE OF 450 +/-20 PSI	
PS-5G12-SW	PRESSURE SWITCH FA #5	01-11-85	QUALIFIED	SWITCH ACTIVATES AT 800 INTERNAL PRESSURE OF 450 +/-20 PSI	
PS-5I05-SW	PRESSURE SWITCH FA #5	01-11-85	QUALIFIED	SWITCH ACTIVATES AT 800 INTERNAL PRESSURE OF 450 +/-20 PSI	
PS-5A12-SW	PRESSURE SWITCH FA #5	01-11-85	QUALIFIED	SWITCH ACTIVATES AT 800 INTERNAL PRESSURE OF 450 +/-20 PSI	
PI-P004-N10A	PRESSURE-SC1 ID INCH LINE FROM 56	12-27-84	QUALIFIED		
PI-P004-U22	CONDENSATE RECEIVER PRESSURE	12-27-84	QUALIFIED		
PI-P004-Q34	PRESSURE-SC5 FEEDWATER	12-27-84	QUALIFIED		
PI-P004-Q85	PRESSURE-SC5 12 INCH CONDENSER IN	12-27-84	FAILED		
PI-P120-Q29	PRESSURE-ECCS ACCUMULATOR A	12-27-84	QUALIFIED		
PI-P128-043	PRESSURE-ECCS ACCUMULATOR A	01-10-85	QUALIFIED		
PI-P128-102	AC-P-48 DISCHARGE PRESS	01-09-85	FAILED		
PI-P128-103	AC-P-48 DISCHARGE PRESS	01-09-85	QUALIFIED		

05/02/01
15-52-33

FP-1 FINAL DIFCQ QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/93
REVISONS: FINAL
SYSTEM: LDC8 FP-1

IDENTIFICATION	MEASUREMENT DESCRIPTION	TEST DATE	QUALIFIED	QUALIFYING STATEMENT(S)	
				GATE	STATUS
PT-P138-055	PRESSURE-051 VAPOR SPACE CH A	01-03-89	QUALIFIED		
PT-P138-056	PRESSURE-051 VAPOR SPACE CH B	01-03-89	QUALIFIED		
PT-P138-057	PRESSURE-051 VAPOR SPACE CH C	01-03-89	QUALIFIED		
PT-P139-002	PRESSURE-INITIAL LOOP HOT LEG CH A	12-31-84	QUALIFIED		RESPONSE LIMITED DURING THE SUB COOLED BLOWDOWN
PT-P139-003	PRESSURE-INITIAL LOOP HOT LEG CH B	12-31-84	QUALIFIED		RESPONSE LIMITED DURING THE SUB COOLED BLOWDOWN
PT-P139-004	PRESSURE-INITIAL LOOP HOT LEG CH C	12-31-84	QUALIFIED		RESPONSE LIMITED DURING THE SUB COOLED BLOWDOWN
PT-P139-041	PRESSURE CONTAINMENT CHAN A	12-27-84	FAILED		
PT-P139-042	PRESSURE CONTAINMENT CHAN B	12-27-84	QUALIFIED		
PT-P139-043	PRESSURE CONTAINMENT CHAN C	12-27-84	QUALIFIED		
PT-P139-031	PRESSURE-PRESSURIZER			12-27-84	QUALIFIED
RE-1-77-2A2	MIS-POWER RANGE CHANNEL A LEVEL			01-11-85	QUALIFIED
RE-1-77-2A2	MIS-POWER RANGE CHANNEL B LEVEL			01-11-85	QUALIFIED
RE-1-77-3A2	MIS-POWER RANGE CHANNEL C LEVEL			01-11-85	QUALIFIED

05/02/01
15:52:31

RPT-FINAL DIRE QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/05
REVISION: FINAL
SYSTEM LOGIC FG-1

MEASUREMENT IDENTIFICATION	MEASUREMENT DESCRIPTION	QUAL DATE	STATUS	QUALIFYING STATEMENT(S)
RPT-PC-001	PUMP SPEED-PRIMARY COOLER	12-31-04	QUALIFIED	AFTER 5 SECONDS

RPT-PC-002	PUMP SPEED-PRIMARY COOLER	12-31-04	QUALIFIED	< 31-84 QUALIFIED
RPT-CR02-TC	RUD POS-KOD 2 TURNS COUNTER	12-31-04	QUALIFIED	FOR SCRAM EVENT TIME ONLY
RPT-CR04-TC	RUD POS-KOD 4 TURNS COUNTER	12-31-04	QUALIFIED	FOR SCRAM EVENT TIME ONLY
RPT-CR06-TC	RUD POS-KOD 6 TURNS COUNTER	12-31-04	QUALIFIED	FOR SCRAM EVENT TIME ONLY
RPT-CR08-TC	RUD POS-KOD 8 TURNS COUNTER	12-31-04	QUALIFIED	FOR SCRAM EVENT TIME ONLY
RPT165-51-10	GROSS GAMMA 51 SAMPLE SYSTEM	01-22-05	QUALIFIED	TRNG DATA ONLY
RPT165-52-10	GROSS GAMMA 52 SAMPLE SYSTEM	01-22-05	FAILED	
RPT165-53-10	GROSS GAMMA 53 SAMPLE SYSTEM	01-22-05	QUALIFIED	S-3 SAMPLE SYSTEM BLOCKED
RPT165-54-10	GROSS GAMMA 54 SAMPLE SYSTEM	01-22-05	QUALIFIED	TRNG DATA ONLY
SP-BL-001B	SAT PRESSURE BURNIN LOOP CL	01-08-05	QUALIFIED	
SP-BL-002B	SAT PRESSURE BURNIN CCP HL	01-08-05	QUALIFIED	
SP-PC-002B	SATURATION PRESS-INITIAC LOOP HL	01-08-05	QUALIFIED	

85/02/01
15.52.31

FP-1 FINAL DIRC QUALIFICATION REPORT

EFFECTIVE DATE: 01/01/85
REVISONS: FINAL
SYSTEM: LOC8 FP-1

MEASUREMENT IDENTIFICATION	QUAL DATE	STATUS	QUALIFYING STATEMENT:
			QUAL
SATURATION PRESSURE, STEAM GUN, #10 01-08-85		QUALIFIED	

SP-36-004 SATURATION PRESSURE-STRUCTURAL STALK I 01-08-85 QUALIFIED

SP-151-005 SATURATION PRESSURE, UPPER P. ENGIN 01-08-85 QUALIFIED

SI-8L-001 SAT TEMPERATURE BROKEN LOOP CL 01-08-85 QUALIFIED

SI-8L-002 SAT TEMPERATURE BROKEN LOOP HL 01-08-85 QUALIFIED

SI-PC-002 SATURATION TEMP, CONTACT LOOP, CL 01-08-85 QUALIFIED

SI-PO04-0102 SATURATION TEMP - SCS SC 10 IN LINE 01-08-85 QUALIFIED

TC-3003-27 TEMP FUEL CENTERLINE#1A#1B 27W 12-27-84 FAILED

TC-5010-27 TEMP FUEL CENTERLINE#1A#1B 27 01-03-85 QUALIFIED FAILED FREI-LAGE TEST

TE-8L-001A COOLANT TEMP-BROKEN LOOP CL BOTTOM 12-27-84 QUALIFIED POSSIBLE NOT WALL EFFECTS

TE-8L-001B COOLANT TEMP-BROKEN LOOP CL TOP 12-27-84 QUALIFIED POSSIBLE NOT WALL EFFECTS

85202/01
15052031

FP-1 FINAL DIRE QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/05
REVISION: FINAL
SYSTEM: LOCE FP-1

MEASUREMENT IDENTIFICATION	DESCRIPTION	QUAL DATE	STATUS	QUALIFYING STATEMENT(S)
TE-PL-0028	COOLANT TEMP-INTACT LOOP HL MIDDLE	12-27-04	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-PL-002C	COOLANT TEMP-BREAK LOOP HL TOP	12-27-04	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-PL-002A	TEMP-INTACT LOOP HL BOTTOM	12-27-04	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-PL-002B	TEMP-INTACT LOOP HL MIDDLE	12-27-04	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-PL-002C	TEMP-INTACT LOOP HL TOP	12-27-04	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-P004-054	COMPENSATE RECEIVER TEMP	12-27-04	QUALIFIED	
TE-P120-001	Liquid TEMP-BEST	12-27-04	QUALIFIED	
TE-P120-41	Liquid TEMP-ECCS ACCUM A	01-03-05	QUALIFIED	INITIAL CONDITIONS ONLY
TE-P120-102	Liquid TEMP-ECCS LPIZ HL & OUTLET	12-27-04	QUALIFIED	
TE-P139-019	TEMPERATURE-PRESURIZED VAPOR	12-31-04	QUALIFIED	INITIAL CONDITIONS ONLY
TE-P139-020	TEMPERATURE-PRESURIZER LIQUID	12-31-04	QUALIFIED	INITIAL CONDITIONS ONLY
TE-P139-029	COOLANT TEMP-INTACT LOOP COLD LEG	12-27-04	QUALIFIED	INITIAL CONDITIONS ONLY
TE-P139-78-2	TEMPERATURE-INTACT LOOP COLD LEG	12-27-04	QUALIFIED	INITIAL CONDITIONS ONLY

85/02/01
15.52x31

FFP-1 FINAL DIRC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/85
REVISION: FINAL
SYSTEM: LOCB FPP-1

MEASUREMENT IDENTIFICATION		DESCRIPTION	QUAL	DATE	STATUS	QUALIFYING STATEMENT(S)
TE-P139-32-1		PRIMARY COOLANT WPT LOG TEMP CHAN A 12-2-84	QUALIFIED			INITIAL CONDITIONS ONLY
TE-P141-004		PCCS HEAT EXCH M. TEMP		12-27-84	QUALIFIED	
TE-P141-005		WATER TEMP-COLD LEG OF ACC LOADS		12-27-84	QUALIFIED	
TE-S6-001A	COOLANT TEMP-1L 56 INLET PLUM		01-03-85	QUALIFIED		Possible heat wall effects
TE-S6-001	COOLANT TEMP-1L 56 INLET PLUM		12-31-84	FAILED		
TE-S6-002A	COOLANT TEMP-1L 56 OUTLET PLUM		12-27-84	QUALIFIED		Possible heat wall effects
TE-S6-002	COOLANT TEMP-1L 56 OUTLET PLUM		12-27-84	QUALIFIED		Possible heat wall effects
TE-S6-003	Liquid TEMP-5C5 56 DOWNCENTER		12-27-84	FAILED		
TE-S6-004	Liquid TEMP-5C5 56 DOWNCENTER		12-27-84	QUALIFIED		
TE-S4-001	Liquid TEMP-851 STAIN 1-107-2		12-27-84	QUALIFIED		
TE-S4-006	Liquid TEMP-851 STAIN 1-107-7		12-27-84	QUALIFIED		
TE-S4-007	Liquid TEMP-851 STAIN 2-107-2		12-27-84	QUALIFIED		
TE-S4-011	Liquid TEMP-851 STAIN 2-39-0		12-27-84	QUALIFIED		

05/02/01
15:52:31

FP-1 FINAL, DIRE QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/95
REVISION: FINAL
SYSTEM: LOGE 1P-1

MEASUREMENT IDENTIFICATION	DESCRIPTION	QUAL DATE	QUAL STATUS	QUALIFYING STATEMENT*
TE-54-012	Liquid Temp-Sat 77deg F-14.7	12-27-84	QUALIFIED	
TE-1011-002	Temperature-Coolant Ambient	12-27-84	QUALIFIED	No other measurement for direct comparison
TE-1011-030	Temp-Cladding/Fal Pin All 30 in.	01-22-85	QUALIFIED	Sample rate is 2.9 samples per second
TE-1010-037	Temp-Cladding/Fal Pin 810 ft 1 in.	01-22-85	QUALIFIED	Sample rate is 2.9 samples per second
TE-1011-028	Temp-Cladding/Fal Pin 811 22 in.	01-22-85	QUALIFIED	Sample rate is 2.9 samples per second
TE-1011-032	Temp-Cladding/Fal Pin 811 32 in.	01-22-85	QUALIFIED	Sample rate is 2.9 samples per second
TE-1C11-021	Temp-Cladding/Fal Pin C11 21 in.	01-22-85	QUALIFIED	Sample rate is 2.9 samples per second
TE-1C11-039	Temp-Cladding/Fal Pin C11 39 in.	01-22-85	QUALIFIED	Sample rate is 2.9 samples per second
TE-1F07-015	Temp-Cladding/Fal Pin F19 19 in.	01-22-85	QUALIFIED	Sample rate is 2.9 samples per second
TE-1F07-026	Temp-Cladding/Fal Pin F7 26 in.	01-22-85	QUALIFIED	Sample rate is 2.9 samples per second
TE-1S1-001	Coolant Temp-Rv Instr Stalk 1 DC	12-27-84	QUALIFIED	Possible hot wall effects
TE-1S1-002	Coolant Temp-Rv Instr Stalk 1 DC	12-27-84	QUALIFIED	Possible hot wall effects
TE-1S1-003	Coolant Temp-Rv Instr Stalk 1 DC	12-27-84	QUALIFIED	Possible hot wall effects

05/02/01
15:52:31

FP-1 FINAL DISC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/89
REVISIONS FINAL
SYSTEM LOG: FP-1

MEASUREMENT IDENTIFICATION
MEASUREMENT
DESCRIPTION
DATE
STATUS
QUALIFYING STATEMENT(S)

FE-15Y-004	COOLANT TEMP-RU INSTR STAK 1 DC	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-005	COOLANT TEMP-RU INSTR STAK 1 DC	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-006	COOLANT TEMP-RU INSTR STAK 1 DC	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-007	COOLANT TEMP-RU INSTR STAK 1 LP	12-27-84	FAILED	
FE-15Y-008	COOLANT TEMP-RU INSTR STAK 1 LP	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-009	COOLANT TEMP-RU INSTR STAK 1 LP	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-010	COOLANT TEMP-RU INSTR STAK 1 LP	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-011	COOLANT TEMP-RU INSTR STAK 1 LP	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-012	COOLANT TEMP-RU INSTR STAK 1 LP	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-013	COOLANT TEMP-RU INSTR STAK 1 LP	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-014	COOLANT TEMP-RU INSTR STAK 1 DC	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-015	COOLANT TEMP-RU INSTR STAK 1 DC	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-016	COOLANT TEMP-UPPER END SDA	12-27-84	QUALIFIED	Possible hot wall effects
FE-15Y-017	COOLANT TEMP-UPPER END SDA	12-31-84	QUALIFIED	Possible hot wall effects

5/02/01
15.32.31

FP-1 FINAL DISC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/93
REVISED: FINAL
SYSTEM: LOC2 FP-1

MEASUREMENT IDENTIFICATION	MEASUREMENT DESCRIPTION	QUAL DATE	STATUS	QUALIFYING STATEMENT(S)
TE-1UP-005	COOLANT TEMP-IN DIT FE-1UP-1	12-27-84	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-1UP-006	TEMP-SUPPORT COLUMN FAIL	12-27-84	QUALIFIED	
TE-1UP-007	METAL TEMP-SUPPORT COLUMN FAIL	12-27-84	QUALIFIED	
TE-2FO-043	TEMP-CLADDING/FAZ PIN F15 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-2FO-012	TEMP-CLADDING/FAZ PIN F0 32 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-2FO-026	TEMP-CLADDING/FAZ PIN F9 26 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-2614-011	TEMP-CLADDING/FAZ PIN 614 31 IN.	12-27-84	QUALIFIED	
TE-2614-010	TEMP-CLADDING/FAZ PIN 614 30 IN.	12-27-84	QUALIFIED	
TE-2614-045	TEMP-CLADDING/FAZ PIN 614 45 IN.	12-27-84	QUALIFIED	
TE-2H02-020	TEMP-CLADDING/FAZ PIN H2 28 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-2H13-021	TEMP-CLADDING/FAZ PIN H13 21 IN.	12-27-84	QUALIFIED	
TE-2H13-049	TEMP-CLADDING/FAZ PIN H13 49 IN.	01-03-84	QUALIFIED	

05/02/01
15.52.31

FP-1 FINAL DIRE CLASSIFICATION REPORT

EFFECTIVE DATE: 05/30/85
REVISION: FINAL
SYSTEM: LOCA FP-1

MEASUREMENT IDENTIFICATION	MEASUREMENT DESCRIPTION	QUAL STATUS	QUALIFYING STATEMENT
TE-2H14-028	TEMP-CLADDING/FAZ P/M 26 IN.	12-27-84 QUALIFIED	

TE-2H14-032 TEMP-CLADDING/FAZ P/M 32 IN. 12-27-84 QUALIFIED

TE-2H15-026 TEMP-CLADDING/FAZ P/M 36 IN. 12-27-84 QUALIFIED

TE-2H15-041 TEMP-CLADDING/FAZ P/M 38 1/2 IN. 12-27-84 QUALIFIED

TE-2H14-021 TEMP-CLADDING/FAZ P/M 24 1/2 IN. 12-27-84 QUALIFIED

TE-2H14-039 TEMP-CLADDING/FAZ P/M 34 3/4 IN. 12-27-84 QUALIFIED

TE-2LP-001 COOLANT TEMP-LOWER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-2LP-002 COOLANT TEMP-LOWER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-2LP-003 COOLANT TEMP-LOWER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-2LP-001 COOLANT TEMP-UPPER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-2LP-002 COOLANT TEMP-UPPER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-2LP-003 COOLANT TEMP-UPPER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-2UP-004 METAL TEMP-SUPPORT COLUMN FAZ 12-27-84 QUALIFIED

05/02/01
15.52±.31

FP-1 FINAL DIRC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/85
REVISION: FINAL
SYSTEM: LOCE FP-1

MEASUREMENT IDENTIFICATION	DESCRIPTION	QUAL DATE	STATUS	QUALIFYING STATEMENT
TE-2UP-005	METAL TEMP-SUPPORT COLUMN FAZ	12-27-84	QUALIFIED	
TE-3A11-030	TEMP-CLADDING/FAZ PIN A11 30 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-3B11-028	TEMP-CLADDING/FAZ PIN B11 28 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-3M11-032	TEMP-CLADDING/FAZ PIN B11 32 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-3C11-021	TEMP-CLADDING/FAZ PIN C11 21 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-3C11-019	TEMP-CLADDING/FAZ PIN C11 39 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-3F07-026	TEMP-CLADDING/FAZ PIN F7 26 IN.	01-22-85	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-3UP-001	COOLANT TEMP-UPPER END BOX	12-27-84	QUALIFIED	Possible hot wall effects
TE-3UP-006	METAL TEMP-SUPPORT COLUMN FAZ	12-27-84	QUALIFIED	
TE-3UP-008	TEMP-COOLANT LIT ABOVE FAZ	12-27-84	QUALIFIED	Possible hot wall effects
TE-3UP-010	TEMP-COOLANT LIT ABOVE FAZ	12-27-84	QUALIFIED	Possible hot wall effects
TE-3UP-011	TEMP-COOLANT LIT ABOVE FAZ	12-27-84	QUALIFIED	Possible hot wall effects
TE-3UP-012	TEMP-COOLANT LIT ABOVE FAZ	12-27-84	QUALIFIED	Possible hot wall effects

5/02/01
5.92-31

F91-FINAL DIRC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/99
REVISION: FINAL
SYSTEM: DCR F91

MEASUREMENT IDENTIFICATION	DESCRIPTION	QUAL	DATE	STATUS	QUALIFYING STATEMENT(S)
TE-3UP-014	TEMP-COOLANT LIT ABOVE FA3	12-27-94	QUALIFIED	POSSIBLE HOT WALL EFFECTS	
TE-3UP-015	TEMP-COOLANT LIT ABOVE FA3	12-27-94	QUALIFIED	POSSIBLE HOT WALL EFFECTS	
TE-3UP-016	TEMP-COOLANT LIT ABOVE FA3	12-27-94	QUALIFIED	POSSIBLE HOT WALL EFFECTS	
TE-4E08-045	TEMP-CLADDING/FA4 PIN 68 42 IN.	01-22-95	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND	
TE-4F07-015	TEMP-CLADDING/FA4 PIN 77 15 IN.	01-22-95	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND	
TE-4F08-032	TEMP-CLADDING/FA4 PIN 89 32 IN.	01-22-95	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND	
TE-4G08-021	TEMP-CLADDING/FA4 PIN 68 21 IN.	12-27-94	QUALIFIED		
TE-4G14-011	TEMP-CLADDING/FA4 PIN 61A 11 IN.	12-27-94	QUALIFIED		
TE-4G14-030	TEMP-CLADDING/FA4 PIN 61A 30 IN	12-27-94	FAILED		
TE-4G14-045	TEMP-CLADDING/FA4 PIN 61A 45 IN.	12-27-94	QUALIFIED		
TE-4H13-015	TEMP-CLADDING/FA4 PIN 61B 15 IN.	12-27-94	QUALIFIED		
TE-4H13-037	TEMP-CLADDING/FA4 PIN 61B 37 IN.	12-27-94	QUALIFIED		

07/02/01
1502-32

FP-1 FINAL DIRC QUALIFICATION REPORT

EFFECTIVE DATE: 01/06/05
REVISED: FIRST
SYSTEM: I-DCB FP-1

MEASUREMENT IDENTIFICATION	DESCRIPTION	QUAL DATE	STATUS
TE-5C10-032	TEMP-GUIDE TUBE FAS LOC C10 32 IN	12-27-04	QUALIFIED
TE-5E03-032	TEMP-GUIDE TUBE FAS LOC E9 32 IN	12-27-04	QUALIFIED
TE-5E07-026	TEMP-CLADDING/FAS PIN E7 76 IN	12-27-04	QUALIFIED
TE-5E07-032	TEMP-CLADDING/FAS PIN G1 32 IN	12-27-04	QUALIFIED
TE-5E07-039	TEMP-CLADDING/FAS PIN E7 30 IN	12-27-04	QUALIFIED
TE-5E07-043	TEMP-CLADDING/FAS PIN E7 43 IN	12-27-04	QUALIFIED
TE-5E09-003	TEMP-CLADDING/FAS PIN E9 9 IN	12-27-04	QUALIFIED
TE-5E09-010	TEMP-CLADDING/FAS PIN E9 10 IN	12-27-04	QUALIFIED
TE-5E09-016	TEMP-CLADDING/FAS PIN E9 16 IN	12-27-04	QUALIFIED
TE-5E09-021	TEMP-CLADDING/FAS PIN E9 21 IN	12-27-04	QUALIFIED
TE-5F03-043	TEMP-GUIDE TUBE FAS LOC F3 43 IN	12-27-04	QUALIFIED
TE-5F13-060	TEMP-GUIDE TUBE FAS LOC F13 60 IN	12-27-04	QUALIFIED
TE-5G05-027	TEMP-CLADDING/FAS PIN G9 27 IN	01-03-05	QUALIFIED

03/02/01
12-02-31

FP-1 FINAL DISC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/01
REVISION: FINAL
SYSTEM: LOC-FP-1

MEASUREMENT DEFINITION	DESCRIPTION	QUALIFICATION STATEMENT(s)	
		QUAL DATE	STATUS
TE-5608-006	TEMP-CLADDING/FAS PIN 66 & IN	12-27-84	QUALIFIED
TE-5608-012	TEMP-CLADDING/FAS PIN 66 12 IN	12-27-84	QUALIFIED
TE-5608-029A	TEMP-CLADDING/FAS PIN 68 29 IN	12-27-84	QUALIFIED
TE-5608-029B	TEMP-CLADDING/FAS PIN 68 29 IN	12-27-84	QUALIFIED
TE-5611-027	TEMP-CLADDING/FAS PIN 611 27 IN	12-27-84	QUALIFIED
TE-5611-027	TEMP-CLADDING/FAS PIN 611 27 IN	12-27-84	QUALIFIED
TE-5613-045	TEMP-GAUGE TUBE FAS 1.0K J13 45 IN	12-27-84	QUALIFIED
TE-5607-048	TEMP-CLADDING/FAS PIN K7 48 IN	12-27-84	FAILED
TE-5607-055	TEMP-CLADDING/FAS PIN K7 55 IN	12-27-84	QUALIFIED
TE-5607-060	TEMP-CLADDING/FAS PIN K7 60 IN	12-27-84	QUALIFIED
TE-5607-065	TEMP-CLADDING/FAS PIN K7 65 IN	12-27-84	QUALIFIED
TE-5609-021	TEMP-CLADDING/FAS PIN K9 21 IN	12-27-84	QUALIFIED

05/02/01
15.52+31

FP-1 FINAL GIRC QUALIFICATION REPORT

EFFECTIVE DATE: 07/30/89
REVISED: Final
SYSTEM: IGC8 FP-1

MEASUREMENT IDENTIFICATION
DESCRIPTION
QUAL STATUS
DATE
QUALIFYING STATEMENT(S)

TE-5R04-026 TEMP-CLADDING/FAS PIN RP 26 IN 12-27-84 QUALIFIED

TE-5R09-032 TEMP-CLADDING/FAS PIN RP 32 IN 12-27-84 QUALIFIED

TE-5R09-039 TEMP-CLADDING/FAS PIN RP 39 IN 12-27-84 QUALIFIED

TE-5R08-032 TEMP-GUIDE TUBE FAS LOC A 32 IN 12-27-84 QUALIFIED

TE-5R06-045 TEMP-GUIDE TUBE FAS LOC NO 45 IN 12-27-84 QUALIFIED

TE-5R01-066 TEMP-GUIDE TUBE FAS LOC NO 1M 12-27-84 QUALIFIED

TE-SUP-004 COOLANT TEMP-UPPER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-SUP-005 COOLANT TEMP-UPPER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-SUP-006 COOLANT TEMP-UPPER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-SUP-007 COOLANT TEMP-UPPER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-SUP-008 COOLANT TEMP-UPPER END BOX 12-27-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-SUP-011 COOLANT TEMP-UPPER END BOX 12-31-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

TE-SUP-012 COOLANT TEMP-UPPER END BOX 12-31-84 QUALIFIED POSSIBLE HOT WALL EFFECTS

05/02/01
15.52.31

FP-1 FINAL DIRC QUALIFICATION REPORT

EFFECTIVE DATE: 03/30/95
REVISIONS: FINAL
SYSTEM: LDC & FPC

MEASUREMENT IDENTIFICATION	MEASUREMENT DESCRIPTION	QUAL DATE	STAB/D	QUALIFYING STATEMENT
TE-SUP-021	COOLANT TEMP-UPPER END BOX	12-27-94	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-SUP-022	COOLANT TEMP-UPPER END BOX	12-27-94	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-SUP-171A	METAL SURFACE TEMPERATURE UPPER END	12-27-94	QUALIFIED	
TE-SUP-171B	METAL SURFACE TEMPERATURE UPPER END	12-27-94	QUALIFIED	
TE-SUP-194	METAL SURFACE TEMPERATURE UPPER END	12-27-94	QUALIFIED	
TE-SUP-212	METAL SURFACE TEMPERATURE UPPER END	12-31-94	QUALIFIED	
TE-SUP-250	METAL SURFACE TEMPERATURE UPPER END	12-27-94	QUALIFIED	
TE-6E08-045	TEMP-CLADDING/FAB PIN 68 45 IN.	01-22-95	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-6F07-037	TEMP-CLADDING/FAB PIN FT 37 3IN.	01-22-95	QUALIFIED	SAMPLE RATE IS 2.5 SAMPLES PER SECOND
TE-6F09-041	TEMP-CLADDING/FAB PIN 41 3IN.	01-03-94	QUALIFIED	
TE-6F14-011	TEMP-CLADDING/FAB PIN 614 11 IN.	12-27-94	QUALIFIED	
TE-6G14-030	TEMP-CLADDING/FAB PIN 614 30 IN.	12-27-94	QUALIFIED	

15.2.31

FP-1 FINAL DIREC QUALIFICATION REPORT

EFFECTIVE DATE: 01/30/82
REVISION: Final
SYSTEM: LOGIC FP-1

MEASUREMENT IDENTIFICATION	TEST SENSIMENT DESCRIPTION	QUAL DATE	STATUS	QUALIFYING STATEMENT
TE-614-045	TEMP-CLADDING/FAB PIN 614 45 IN.	01-05-83	QUALIFIED	
TE-6113-015	TEMP-CLADDING/FAB PIN 6113 15 IN.	12-27-84	QUALIFIED	
TE-6113-037	TEMP-CLADDING/FAB PIN 6113 37 IN.	12-27-84	QUALIFIED	
TE-6114-028	TEMP-CLADDING/FAB PIN 6114 28 IN.	12-27-84	QUALIFIED	
TE-6114-032	TEMP-CLADDING/FAB PIN 6114 32 IN.	12-27-84	QUALIFIED	
TE-6115-026	TEMP-CLADDING/FAB PIN 6115 26 IN.	01-05-85	QUALIFIED	
TE-6116-021	TEMP-CLADDING/FAB PIN 6116 21 IN.	12-27-84	QUALIFIED	
TE-6116-039	TEMP-CLADDING/FAB PIN 6116 39 IN.	12-27-84	QUALIFIED	
TE-611P-001	COLD ANT TEMP-LOWER END BOX	12-27-84	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-611P-002	COLD ANT TEMP-LOWER END BOX	12-27-84	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-611P-001	COLD ANT TEMP-UPPER END BOX	12-27-84	QUALIFIED	POSSIBLE HOT WALL EFFECTS
TE-611P-002	COLD ANT TEMP-UPPER END BOX	12-27-84	QUALIFIED	POSSIBLE HOT WALL EFFECTS

85/02/01
15.52±31

FP-1 FINAL DINC QUALIFICATION REPORT

EFFECTIVE DATE: 01/36/85
REVISIONS: FINAL
SYSTEM: LOCB FP-1

MEASUREMENT IDENTIFICATION	DESCRIPTION	QUALIFICATION STATEMENT	
		QUAL DATE	STATUS
16-6UP-003	COOLANT TEMP-UPPER END 804	12-27-84	QUALIFIED POSSIBLE HOT WALL EFFECTS
16-6UP-004	METAL TEMP-SUPPORT COLUMN FAS	12-27-84	QUALIFIED
16-6UP-005	METAL TEMP-SUPPORT COLUMN FAS	12-27-84	QUALIFIED
17-F004-004	Liquid TEMP-SCS FEEDWATER	12-27-84	QUALIFIED
17-F120-062	Liquid TEMP-TCS CL INJECT POINT	01-03-85	QUALIFIED NO SPHERE LIMITED
17-F139-032	COOLANT TEMP-IMPACT - OCP NO 1 LG	12-27-84	QUALIFIED INITIAL CONDITIONS ONLY
17-F139-033	COOLANT TEMP-IMPACT LDOP NOT LEG	12-27-84	QUALIFIED INITIAL CONDITIONS ONLY
17-F139-034	COOLANT TEMP-IMPACT LDOP NOT LEG	12-27-84	QUALIFIED INITIAL CONDITIONS ONLY

TABLE 3.2. Input deck listing for plant steady state

23 4 1 0
 *

 * UPT-PRTSTATEST LP=FP=1 STEADY STATE DECK FOR TRAC-PRT1/MOD1
 * DATA BASED ON L2+0 DECK FROM LARS FOR TRAC-PRT1/MOD1 AND DN
 * L9H1 DECK FROM AERONAUTRITH, CHANGED TO FP=1, AUGUST 85
 * CHANGES ALREADY IN TRAC-PRT1-DECK: UPPER PLENUM ECOS, INNER CORE
 * RING FLOWAD,7 (FLUX SHRINK) & LOCAL VALVE
 * ADDITIONAL CHANGES: CORE 131 MM LAKER
 * HOT PODS IN CELL 1+2+3+4+8+12
 * BYPASS UPPR PLENUM + UPPER PLENUM => 4 TERS (PATH 1+2+6) GUIDE TUBES
 * BYPASS UPPR PLENUM + DOWNCOMER => FAIR IN LEVEL 11 (PATH 3+4+5+6)
 * BYPASS FAIR (INCREASED)
 * OP3AR, RDX => RING AREA
 * ENVIRONMENTAL HEAT LOSSES, HTC DUTY PLUS PIPING = 6.6 W/M²K
 * PRESSURIZER = 2.0 W/M²K
 * SG SEC. SIDE = 1.6 W/M²K
 *
 * CHANGES INCORPORATED 1988.87
 * PCS E/FY RESISTANCE REDUCED, RESISTANCE ADDED FOR +CORE, CORE+CORE+UP
 * FAU-FAY FRICTION FACTORS USED FOR PCS, FRICCO NOT ALLOWED
 * CHANGES TO VESSEL FLUID VOLUME AND FLOW AREA FRACTIONS
 * CHANGES IN VESSEL HEAT SLABS
 * NFR RESET TO 1
*

*

* NAMELIST DATA
* ICDPTS 1CFLW=2, CHB12=1.0, CHM22=0.84, NOAIR=0, ICENDM3=1, NLT=18,
* IMEP=3, NF=0.1=2,
1743

* CONTROL CARDS*****
*
*
* 0 2.0
* 1 0 *NNDMP# 53 *NNJUN# 63 1 *MCC 01
* 5+P=4 5.UE=6 1.UE=5 1.UE=1 1 *MCC 02
* 10 50 25 1 *MCC 03
* MTSV# 3 *NTDRY# 0 *NTCF# 0 *NTRPR# 10 *NTCP# 1 *MCC 04
* 4 *MCC 05
*
* 1 2 3 4 55 *COMP
* 5 7 8 93S *COMP
* 23 24 25 *COMP
* 11 12 13S *COMP
* 14 15 16 17 31S *COMP
* 32 41 42 50 43S *COMP
* 31 32 33 34 65S *COMP
* 55 67 68 69 40S *COMP
* 71 72 61 52 63S *COMP
* 54 55 66 57 68S *COMP
* 53 70 71 72 101S *COMP
* 102 103 104E *COMP

* PROBLEMS VARIOUS DATA*****
* IDSY 15VN ILLN ILCON1 ILCON2 9 PROBLEM TIME SV01
* 1 0 0 0 0 * PROBLEM TIME SV01
* 2 25 50 100S 400S 9 ROD TEMPERATURE SV02
* 3 71 12 2 0 9 RPI'S PRESSURE SV03

* CONTROL BLOCK DATA*****
* NTSE 4TCT NTSF NTDP NTSD 0 *TRIP DI
*
* TRIP 2 = EOC RPIS (16)
*
* IDTP 15RT ISRT ISET ITST IDSG
* 2 2 0 1 1 *TRIP02
* 0.0 517.0 *TRIP02
* 0.0 0.0 *TRIP02
* 0 0 *TRIP02
*
* TRIP 3 = EOC LPIS (17) (LNUO LEG ACCUMULATOR)

3	6	9	1	1	*TRIP03 *TRIP03 *TRIP03 *TRIP03
	0.0	346.0			
	0.0	0.0			
	0	0			
* TRIP 4 = PUMPS (4 & 5)					
4	2	0	1	1	*TRIP04 *TRIP04 *TRIP04 *TRIP04
	0.0	2.00			
	0.0	0.0			
	0	0			
* TRIP 5 = STEAM GENERATOR FEEDWATER (24)					
5	2	0	1	1	*TRIP05 *TRIP05 *TRIP05 *TRIP05
	0.0	1.0E+5			
	0.0	0.0			
	0	0			
* TRIP 5 = FCC LINE VALVE (14)					
6	4	0	1	1	*TRIP06 *TRIP06 *TRIP06 *TRIP06
	0.0	10000.0			
	0.0	0.0			
	0	0			
* TRIP 7 = STEAM LINE VALVE (23)					
7	2	0	1	1	*TRIP07 *TRIP07 *TRIP07 *TRIP07
	0.0	0.0			
	0.0	0.0			
	0	0			
* TRIP 1010 1. PLENUM INJECTION SYSTEM (61 815 72)					
1010	2	0	1	1	*TRIP1010 *TRIP1010 *TRIP1010 *TRIP1010
	0.0	1.0E+5			
	0.0	0.0			
	0	0			
* TRIP 100 = REACTOR SURFACE VESSEL (50)					
100	2	0	1	1	*TRIP100 *TRIP100 *TRIP100 *TRIP100
	0.0	1.0E+5			
	0.0	0.0			
	0	0			
* TRIP 101 = REFLCOOL FINL-MESH TRIP FOR VESSEL (50)					
101	2	0	1	1	*TRIP101 *TRIP101 *TRIP101 *TRIP101
	0.0	1.0E+5			
	0.0	0.0			
	0	0			
* TRIP 200 = BROKEN LOOP COLD LEG VALVE (43)					
200	2	0	1	1	*TRIP200 *TRIP200 *TRIP200 *TRIP200
	0.0	63.5			
	0.0	0.0			
	0	0			
*****COMPONENT DATA*****					
* NOTE THAT COMPONENT #, SUBSYSTEM AND TRIP NUMBERS ARE GIVEN.					
* 1. TEE	1	1+2+10			INTACT-LOOP HOT LEG
* 2. STGEN	2	2+3 - P 22+25 + S EXTERNAL			STEAM GENERATOR
* 3. VALVE	23	21+23,24 - S INTERNAL 22+26 7			STEAM-LINE VALVE

	0	2	4	6	8	
	0	0	0	0	0	*CN03
	0.14222	0.03571	6.0	5.0	300.0	*CN04
	300.0	0.0	0.0	1.0E20	1.0	*CN05
	0.0	0.0	1.0E20	1.0		*CN06
*						*CN07
*						*CN08
*	SIDE TUBE					
*						
	0	3	10	0		*CN09
	0	0	0	0	0	*UN10
	0.0233005	0.0086968	6.0	5.0	300.0	*CN11
	300.0	0.0	0.0	1.0E20	1.0	*CN12
	0.0	0.0	1.0E20	1.0		*UN13
*						*CN14
*	MATL TUBE					
*						
P	2 7.83555E+1	4.92503E+1	7.75839E+15		*DX	
	1.19419E+0	9.55752E+1	4.17249E+15			
F	2.25924E+1F					
P	2 5.09932E+2	3.20423E+2	5.04812E+25		*YJL	
	5.05917E+2	5.52749E+2	3.13808E+25			
F	5.21981E+2F					
P	5 5.34253E+2	5.34253E+2	5.34253E+25		*FA	
	A.34253E+2	5.16000E+2E				
	0.0F 5	0.0	7.52500E+25		*FRIC YSL=HL FF=-0.28	
	0.0	1.70400E+1E			*FRIC HL=SG FF=0.1704	
	0.0310R 5	0.0	7.52500E+25		*FRIC REV	
	0.0	1.70400L+1E			*FRIC REV	
P	8 0.0	5.84737E+1E			*GRAY	
P	7 2.84000E+1	2.84000E+1	2.56300E+1E		*HD	
F	0E				*ICFLG	
F	1F				*NPF	
F	0.0F				*AL_P	
F	0.0F				*YL	
F	0.0F				*YY	
F	578.4E				*TL	
F	515.0F				*TY	
F	148.4E+5F				*P	
F	0.0F				*PA	
F	0.0F				*QP3PP	
F	7E				*MATID	
F	573.0F				*TH	
					*CDNC	
					*S	
					*PQWTB1	
					*PQWRF1	
					*QP3TR1	
					*QP3RF1	
*						
*	SIDE TUBE					
*						
	2.14984E+0	2.64277E+0	2.22169E+0E		*DX	
	3.11487E-3	3.59537E-3	5.70588E-3E		*YJL	
P	3 1.44922E-3	5.73212E-3E			*FA	
	1.65249E-1	5.50315E-3P 2	4.66877E-3E		*FRIC	
F	1.65298E-1	5.50315E-3R 2	4.66877E-3E		*FRIC REV	
F	5.45100E-1R 2	0.0	6.04100E-1E		*GRAY	
P	3 4.20355E-2	8.54304E-2E			*HD	
	0E				*ICFLG	
F	1F				*NPF	
F	0.0F				*AL_P	
F	0.0F				*YL	
F	0.0F				*YY	
F	578.4E				*T	
F	515.0F				*TY	
F	148.4E+5F				*P	
F	0.0F				*PA	
F	0.0F				*QP3PP	

P 77
S 1034LF

*MKT11
*TH
*CDYC
*S
*PDKT02
*PDKRF1
*QP3TB1
*QP3RF1

*-----
* TO MAKE THIS DATA CONSISTENT AT JUNCTION 2
* THE FOLLOWING CHANGES HAVE BEEN MADE
* FRIIC 3 CHANGED FROM 0.1183 TO 0.19258
* GFRV 1 CHANGED FROM 0.4237 TO 0.582737
* THE NEW VALUES ARE GIVEN IN COMPONENT 1 FROM TRAC-P02 LB1 DECK
*

STCEN	2	2 STEAM GENERATOR	9	4CN	02
*	10	4	3	*	4CN
*	9	2	3	*	4CN
*	0	25	22	*	4LN
*	0	0	0,000000	*	4CN
*	0	5	-	*	4LN
*	17	4	-	*	4LN
S,10540E-3	1,24460E-3	-	-	*	4LN
PIPE	5	0	-	*	SECONDARY PIPE 20
TEE	4	1	-	*	DOWNCOMER TEE 22
TEE	6	1	-	*	STEAM DOME TEE 21
*-----*PRIMARY SIDE					
2,63500E+1F03	5,56950E+1	9,63600E+1E	-	*	4DX
3,72500E+1F03	5,57500E+2	3,79500E+13	-	*	4VNL
5,15000E+2F03	1,51100L+1	5,16000E+2F	-	*	4FA
0,17040	F02	0,000000	0,186100F	*	4FRIC
0,17040	F04	0,000000	0,186100F	*	4FRIC P KE
0,582737	004	1,000000	0,332000R04	-1,000000	-0,711600F
2,55300E+1F04	1,02110L+2	2,56000E+1E	-	*	4URAY
F	0F	-	-	*	4HD
F	1F02	1	1E	*	4ICFLG
F	0,000000F	-	-	*	4NFF
F	0,000000F	-	-	*	4ALP
F	0,000000F	-	-	*	4YL
1U9	567,500000	552,80000L	-	*	4YY
1U9	567,500000	552,80000E	-	*	4TL
F	14,8400E+1F	-	-	*	4TV
F	0,000000F	-	-	*	4P
*	-	-	-	*	4PA
*-----*SECONDARY SIDE					
24	21	0	20	*	PIPE 20
R03	5,58950E+1	1,11150E+0E	-	*	4UX
R04	4,43562E+1	9,97863L+1E	-	*	4VNL
*	2,18842E+1F03	7,79615L+1F02	8,37762E+1F	*	4FA
*	7,000000F05	0,000000E	-	*	4FRICF
*	2,000000F05	0,000000E	-	*	4FRICK
*	0,000000F05	1,000000E+0E	-	*	4URAY
R05	5,35000E+3	1,06910L+0E	-	*	4HD
F	0F	-	-	*	4ICFLG
F	1E	-	-	*	4NFF
R04	0,000000	0,258500E	-	*	4ALP
F	0,000000F	-	-	*	4YL
F	0,000000E	-	-	*	4YY
F	540,000000F	-	-	*	4TL
F	540,000000F	-	-	*	4TV
F	5,4100E+6F	-	-	*	4P
F	0,000000F	-	-	*	4PA
*	-	-	-	-	-
23	24	25	22	*	TEE 22
R02	7,41000E-1	1,70585E+0	5,58950E+1E	*	4DX
R02	3,82365E-1	3,73532E-1	1,24544E+1E	*	4VNL
R02	5,15342E+1F03	2,18898E+1E	-	*	4FA
R04	0,000000	2,000000E	-	*	4FRICF
R04	0,000000	2,000000F	-	*	4URAY
*	3,37524E+1F03	-1,000000	0,000000F	-	-
R02	2,54000E+1F02	1,01600E+1	5,35000E+3F	*	4ICFLG

2
 4
 1F
 1,000000U 0.776734E02 0.00000UF *ICFLG P
 0.000000E *NFF P
 0.000000E *ALP P
 0.000000E *VYL P
 541.571343E *VYV
 541.571343E *TL
 5.4100E+6E *TV P
 0.000000F *P
 0.000000 0.000000F *PA P
 2.000000F
 1.42145E+2F *DX S
 8.10732E-3F *YOL S
 0.000000F *FA S
 0.000000F *FRICF S
 0.000000F *FRICR S
 1.01500E+1F *GRAY S
 UF *HD S
 1F *ICFLG S
 0.000000UF *NFF S
 0.000000E *ALP S
 0.000000F *VYL S
 525.00000UE *VYV S
 525.000000F *TL S
 6.4100F+5E *TV S
 0.000000F *P S
 *PA S
 *-----
 21 22 23 21 *TEE 21
 F 1.11157E+0F *DX P
 9.07867E-1 1.23445E+0F *YOL P
 9.97767E-1 1.58704E+0 4.63242E-2F *FA P
 0.000000 1.0000E+30 2.44600E+1E *FRICF P
 0.000000 1.0000E+30 2.44600E+1F *FRICR P
 F 1.000000F *GRAY P
 R02 1.05917E+0 2.46900E+1L *HD P
 GE *ICFLG P
 1F *NFF P
 1.000000F *ALP P
 0.000000E *VYL P
 0.000000F *VYV P
 541.571343E *TL P
 541.571343E *TV P
 6.4100E+6F *P P
 0.000000F *PA P
 0.000000 0.000000F *DX S
 7.41000E+1E *YOL S
 3.82966E+1E *FA S
 5.15347E-1F *FRICF S
 0.000000E *FRICR S
 0.000000F *GRAY S
 -3.37525E+5F *HD S
 2.54000E+1E *ICFLG S
 GE *NFF S
 1E *ALP S
 1.000000F *VYL S
 0.000000F *VYV S
 F 0.000000E *TL S
 541.571343E *TV S
 541.571343E *P S
 6.4100E+6E *PA S
 0.000000F *-----
 IFAT STRUCTURES
 R08 0R05 0R06 2UR04 22R02 21E *ICMP
 2 3 4 5 6 *ICELL
 7 6 45
 R03 1R02 1U5 4R02 4R02 5 *ICELL
 1 4 3 *ICELL
 1 2 3 *ICELL
 2 3E
 R08 2UR05 UR06 2UR04 DR02 UE *ICMP

1	2	3	4	5	6	7
R02	0	10E02	05			*UCELU
	4E03	3	2	15		*UCELU
R04	1P02	0E				*UCELU
R24	12825	8E03	6E06	45		*KATG
R18	1P18	4F				*KATG
R08	5.12540E+3	0.6685800	5.12540E+3	12.000000	0.685800	*RADIG
	5.12540E+3R04	0.644525K02	0.571500R06	0.711200E		*RADIG
R08	1.24467E+3	0.088900	5.18435E+3	0.031750	0.088700	*TH
	5.18435E+3R06	0.012700UR06	0.053875E			*TH
#	0.000000E					*UPPS
R32	541.571343R12	6.7.500000E+0	552.320000R48	541.571343E		*TH04
F	0.000000F					*HILS
F	0.000000E					*HIVG
F	0.000000E					*TILS
F	0.000000F					*TIYG
R08	33.84995E	1.388600	17.287714	0.738780	1.388500	*WAIS
	17.287714R04	2.304050	2.550813	2.849253	2.214537	*WAIS
	3.311234	7.827232	2.542411	4.956850	4.407864E	*WAIS
R08	0.000000R02	1.500000	0.000000R02	1.500000R05	0.000000	*PHOLG
R08	1.500000F					*PHOLG
R08	0.000000R02	1.500000	0.000000R02	1.500000R05	0.000000	*PHOLG
R08	1.500000F					*PHOLG
R08	0.000000R02	305.370000	0.000000R02	305.370000R06	0.000000	*TOLG
R08	305.370000F					*TOLG
R08	0.000000R02	305.370000	0.000000R02	305.370000R06	0.000000	*TOVG
R08	305.370000F					*TOVG
R08	42.162876	1.568606	38.228926	0.738783	1.568604	*WAUG
	38.228926R04	2.349460	2.719942	2.911549	2.382671	*WAUG
	3.567533	8.206045	2.735352	5.343793	4.742394E	*WAUG

* DATA CHANGED TO AGREE WITH CONTROL LOGIC IN FP+1

* VALVE IS OPEN UNTIL TRIP COMES ON
 * THEN VALVE IS CLOSED USING A TABLE (TIME,RELATIVE POSITION)
 * TRIP 7 , SV 1

VALVE	23	23 STEAM LINE VALVE			
6	0	22	26	7	*UN 02
1	0	3	5	0	*CN 03
7	1	6	0	0	*UN 04
0	0				*UN 06
1.0E+20	0.0	0.0	1.0		*UN 07
0.1214	0.0151	1.6	1.5	305.37	*UN 08
305.37	4.53292E+2	0.242900	0.451		*CN 09
F	5.01191F				*DX
F	2.32147E+1F				*VOL
F	4.63247E+2F				*FA
	0.2446 R04	0.0	5.44	0.0E	*FR1CF
	0.2445 R24	0.0	6.4	0.0E	*FPICK
	1.0 R06	0.0E			*GRAY
F	3.2429E				*HD
R04	0	1	UF		*ICFLU
F	1E				*NFF
F	1.0	E			*ALP
F	0.0	E			*YL
F	0.0	E			*VV
F	541.571343E				*TL
F	541.571343F				*TV
R08	6.4900E+6	2.1500E+6E			*P
F	0.0	E			*PA
	0.0	0.451	1.0	0.4115	*VMTB1
	2.0	0.350	5.0	0.1665	*VMTB1
	7.5	0.0	1000.0	0.0E	*VMTB1

 * MODIFIED TO AGREE WITH FP+1 DATA
 * CONSTANT MASS FLOW UNTIL TRIP ON
 * THEN MASS FLOW READ FROM A TABLE (TIME,MASS FLOW)

F 1210 5 5 1

FILL

	24	24 STEAM GENERATOR FEEDWATER	
25	0	0	*CN 02
5	1	5	*LN
0.0	1.0E20	0.0	*CN ..
2.0	1.62146E+2	0.0	482.0 *CN 05
57.*E+5	0.0	12.800	482.0 *CN 06
1.0	1.0	0.0	*LN 09
0.0	12.800	1.0	*VHTB
2.0	0.8101	2.67	*VHTB
0.0,	0.0001	0.005	*VHTB

BREAK

	25	25 STM GEN SEC BRK	
26	0	3	1
5.011910	0.232198	1.0	488.0 21.5E5 *CN 04
+ 0.0	0.0	1.0E20	21.5F5 0.0 *CN 05

TEE

	3	3 PUMP SUCTION	
2	4	7	0.0 *ICRHF 1 *CN02

MAIN TUBE

	0	3	4	5	0	
0	0	0	0	0	0	*CN03
0.14203	0.03571	6.0	5.0	300.0	0	*CN04
300.0	0.0	0.0	1.0E20	1.0	0	*CN05
0.0	0.0	1.0E20	1.0	0	0	*CN06
						*CN07
						*CN08

SIDE TUBE

	0	3	3	0	
0	0	0	0	0	*CN09
0.14203	0.03571	6.0	6.0	300.0	*CN10
300.0	0.0	0.0	1.0E20	1.0	*CN11
0.0	0.0	1.0E20	1.0	0	*CN12
					*CN13
					*CN14

MAIN TUBE

4.35000E-1	1.80340E+0	5.35000E+1E	*DX
2.74575E-2	1.14380E+1	2.74675E+2E	*YDL
3.55131E+2P	2.634249E-2	3.55131E+2E	*FA
0.0F			*FRICE
0.0F			*FRICR
-5.25590E-1	-5.52200E+1	5.52200E+1S	*GRAY
5.76590E+1F			
2.15910E+1P	2.2.84174E+1	2.15910E+1E	*HJ
0E			*ICFLG
1E			*NFF
0.0E			*ALP
0.0E			*Y_
0.0E			*YY
564.3E			*TL
515.0E			*TY
148.4E+5E			*P
0.0E			*PA
0.0E			*OPPP
7E			*MATID
573.0E			*TN
			*C3YC
			*S
			*PDWTB1
			*PDARF1
			*OP3TBL
			*OP3RF1

SIDE TUBE

F	1.71311E+03	2.114700E-17		*DX
F	7.74710E-2	4.00000E-2	5.00481E-25	*VJL
F	2.534240E-2	6.87143E-2	5.16000E-26	*FA
F	3.0	1.80100E-16		*FRIC FF=0.1861
F	3.0	1.80100E-16		*FRIC KEY
F	0.0	6.74400E-1	1.00000E+05	*GRAY
	7.11500E-16			
F	2.294174E-1	2.45787E-1	2.55000E-1F	*HJ
F	0F			*ICFLG
F	1E			*NFF
F	0.0E			*A_P
F	0.0E			*VL
F	0.0F			*VV
F	564.3F			*TL
F	515.0E			*TV
F	148.4E+5E			*P
F	0.0E			*PA
F	* 0.0E			*OPPP
F	7E			*MATIC
F	593.0E			*TH
				*CONE
				*S
				*PQWTBL
				*PQWRF1
				*QP3TBL
				*QP3RF1

PUMP			4	4 PUMP NU. 2	
	2	4	4	6	7
#10400	1	U	2	1	1
	4	U	0	0	0
	3	U	0	0	0
D.10795	0.02868		6.0	6.0	300.0
300.0	1.42		1.3.0	0.0	
941.54	500.0		0.315	614.0	369.561
363.50	0.0		1.0E20	1.0	0
0.0	0.0		1.0E20	1.0	

* OPTION FOR LIGHT PUMP DATA
*

*	2				*CN11
*					
*	ARPAV DATA CARDS				
F	1.35213E+0E				*DX
F	4.95548E+2E				*VJL
F	3.65131E+2E				*FA
F	0.0E				*FRICF
F	0.0E				*FRICR
F	5.75530E+1R 2	0.0E			*GRAY
F	2.15910E-1E				*HJ
F	0E				*ICFLG
F	1	0	1E		*NFF
F	0.0F				*A_P
F	0.0	5.77	0.0E		*VL
F	0.0	5.77	0.0E		*VV
F	564.3F				*TL
F	515.0E				*TV
F	148.4E+5E				*P
F	0.0F				*PA
F	0.0E				*OPPP
F	7E				*MATIC
F	593.0E				*TH
					*CONE
					*S
					*PMPTR
					*PMPRF
					*QP3TB
					*QP3RF

* TEE 12 9-11 12 TUBE NAME AS CURRENTLY
* EXISTING FOR THE JUNCTION NUMBERS IN LNUZ

PUMP
2 4 6 8 10 PUMP Nbr 1
#CN02
#CN03
#CN04
#CN05
#CN06
#CN07
#CN08
#CN09
#CN10

* OPTION FOR LNUZ PUMP DATA

* * * * * #CN11

* AIRBY DATA C4K05

L 1.35213E+0E #DX
R 6.75548E-2E #VOL
R 3.65131E-2F #PA
F 0.0F #FRICF
F 0.0E #FRICR
F 6.25547E-19 Z 0.0E #GRAY
P 2.15391D-1E #H2
F 0F #ICFLG
F 1 0 1E #NRF
F 0.0E #ALP
F 0.0 6.77 0.0E #V_#V
F 0.0 5.7 0.0E #VV
F 5.643E #TL
F 5.152E #TV
F 148.4E+5F #P
F 0.0E #PDA
F 0.0F #OPPP
F 7F #MATID
F 5.7340F #TA
#C0NC
#S
#PRPTR
#PRPRI
#QP3TP
#OP3RF

TEE 2 4 6 8 10 PUMP DISCHARGE #CN02

MAJN TJB#
0 2 7 8 0 #C_3
0 0 0 0 0 #CN04
#10795 0.02858 6.0 6.0 300.0 #CN05
300.0 0.0 0.0 1.0E20 1.0 #CN06
0.0 0.0 1.0E20 1.0 #CN07
#CN08

* SIDE TJB#

0 1 6 0 #CN09
0 0 0 0 0 #CN10
#10795 0.02858 6.0 6.0 300.0 #CN11
300.0 0.0 0.0 1.0E20 1.0 #CN12
0.0 0.0 1.0E20 1.0 #CN13
#CN14

* MAJN TJB#

1.30817E+0 1.11760E+0E #DX

	4.7E53.7E+2	1.6E11/4.5E+2	FVJL
R	2.3E51.31E+2F	1.6E3E2.49E+2F	*FA
R	0.0	U+UF	*FRIC PS+CL FF+0.12
R	0.0	U+UE	*FRIC REV FF+0.12 ?
R	0.0+P		*GRAY
R	2.2E159.15E+1	2.8E174E+11	*HD
R	UE		*I2FLG
R	1E		*NRP
R	0.0F		*ALP
R	0.0E		*VL
R	0.0F		*VV
R	5E4+3E		*TL
R	6E5+0E		*TV
R	1.6E+4E+5E		*P
R	0.0E		*PA
R	0.0E		*OPPP
R	+7E		*MATID
R	5.0E+0E		*TH
			*CDNC
			*S
			*PDWTR1
			*PDWRF1
			*QP3TB1
			*QP3RF1

* SIDE TUBE

	4.9E2E5E+1E		*DX
R	2.9E3+4E+2F		*VJL
R	3.4E51.31E+2F		*FE
R	0.0F		*FRICF
R	0.0F		*FRICR
R	0.0E		*GRAY
R	2.15E+1E		*HD
R	DE		*I2FLG
R	1F		*NFF
R	0.0E		*ALP
R	0.0F		*VL
R	0.0E		*VV
R	5E4+3E		*TL
R	6E5+0E		*TV
R	1.6E+4E+5E		*P
R	0.0E		*PA
R	0.0F		*OPPP
R	+7E		*MATID
R	5.0E+0E		*TH
			*CDNC
			*S
			*PDWTR1
			*PDWRF1
			*QP3TB1
			*QP3RF1

TEE 7 7 INTACT+LOOP COLD LEG
5 4 7 U+O *ICHEP 1 *CN02

* MAIN TUBE

	0	9	8	9	0	*CN03
	0	0	0	0	0	*CN04
	0.14209	0.23571	6.0	6.0	300.0	*CN05
	300.0	0.0	0.0	1.0E20	1.0	*CN06
	0.0	U+O	1.0E20	1.0		*CN07
						*CN08

* SIDE TUBE

	0	1	14	0		*UN09
	0	0	0	0	0	*CN10
						*CN11

* 14011800 14011800 14011800
14011800 14011800 14011800
14011800 14011800 14011800

* MAIN TUBE

*
23 9.181457 P3 0.2735245 E 3.4555867 F FOX
23 0.274232 P3 0.3144116 R3 2.4295143 E #VSL
23 0.0534749 E
0.20 PB 0.0 3.20225 E #FRICL CL-VSL FF#0.202
0.20 RR 0.0 0.0 F #FRICL VSL-CL FF#0.266
23 0.0 1.0 #GRAY
23 0.244174 F #H3
23 0.0 #ICFLG
23 1.0 #NFF
23 0.0 CF #ALP
23 0.0 JE #VL
23 0.0 DE #VV
23 5.64E33 #TL
23 5.15E33 #TV
23 148.4E4SF #P
23 0.0 CF #PA
23 0.0 DE #OPPP
23 0.0 #MATID
23 0.0 #TA
23 5.73E18 #CONE
23 #S
23 #PDTB1
23 #PDWRF1
23 #OP3TR1
23 #OP3RF1

***** ***** ***** ***** ***** ***** ***** ***** ***** *****
* NOTE THAT VALUES ARE CHANGED FOR FP+1 DECK (HEAT TRANSF., WALL-FLIUID)

*
PRISER 5 8 PRESSURIZER
3 4 93 10 7 #CN02
#15448 1 0 0.0 #CN03
0.4342 0.075 2.0 2.0 300.0 #CN04
3.242 0.0 0.0 0.0 0.0 #CN05

*
* 12DAY DATA

1.11700E+1 1.11700E+1 2.02207E+1P 704
 1.24417E+1 5.30000L+1 1.27700E+2L 8VOL
 8 3 4.55253E+1 5.73212E+38 8FA
 8 3 0.0 4.56877E+35 8FKJLF
 8 3 0.0 4.56877E+35 8FRICR
 8 3 -1.0000E+0 5.510410L+18 8GRAY
 8 3 8.48367E-1 8.54354E+46 8H2
 8 OF 8ICFLG
 8 1E 8NPF
 8 0.7174 0.0000 0.0E 8SLP
 8 0.0E 8VL
 8 0.0F 8VV
 8 614.3F 8TL
 8 614.3F 8TY
 8 148.4E+5 148.361E+5 148.223E+5E 8P
 8 0.0F 8PS
 8 = 0.0E 8OPPP
 8 7F 8MATIO
 8 614.3F 8TA
 8 0.0E 8CNC
 8 S

* CONSTANT VELOCITY - SET TO ZERO

FILL 43 93 PRESSURISER OUTLET
 43 1 0 *CN02
 0.0 1.0E20 0.0 0.0 *CN03
 4.654E+1 2.4414E+2 0.0 0.0 550+3 *CN04
 148.4E+5 0.0 0.0 0.0 550+3 *CN05
 *CN06
 *CN07
 *CN08
 *CN09
 *CN10

* CONSTANT VELOCITY - SET TO ZERO

FILL 11 11 ACCUMULATOR TOP
 11 1 0 *CN02
 0.0 1.1E20 0.0 0.0 *CN03
 0.555 0.4E7 0.0 0.0 300+0 *CN04
 63.0E5 43.0E5 0.0 0.0 300+0 *CN05
 *CN06
 *CN07
 *CN08
 *CN09
 *CN10

* NOTE THAT NODES=0 GIVING NO WALL-FLUID HEAT TRANSFER

TEE 1 12 12 ECC LINE + HP15
 0 0 7 0.0 0 *CN02
 * MAIN TUBE
 *
 0 1 15 14 0 *CN03
 0.0E6625 0.0134874 0.0 5.0 300+0 *CN04
 300+0 0.0 0.0 1.0E20 1.0 *CN05
 *CN06
 *CN07
 *CN08

* SIDE TUBE

*
 0 1 18 0 *CN09
 0.0E6625 0.0134874 0.0 5.0 300+0 *CN10
 300+0 0.0 0.0 1.0E20 1.0 *CN11
 *CN12
 *CN13
 *CN14

```

* MAIN TUBE
E
E   1.03300E+0F          *DX
E   6.99320E+3E          *VOL
E   6.99320E+3F          *FA
E       0.0      0.4941    6     *FRICF
E       0.0      0.4941    F     *FRICR
E       0.0F               *GRAY
E   8.73252E+2F          *HD
E       UF                *ICFLG
E       1E                *NFF
E       0.0F               *ALP
E       0.0F               *VL
E       0.0E               *VV
E       450.0F              *TL
E       615.0E              *TY
E   148.4E+5F             *P
E       0.0F               *PA
E       0.0F               *QPPP
E       0.0F               *MATID
E       0.0F               *TH
E       0.0F               *CJYC
E       0.0F               *S
E       0.0F               *PDWTB1
E       0.0F               *PDWRF1
E       0.0F               *QP3TB1
E       0.0F               *QP3RF1

* SIDE TUBE
E
E   5.00000E+0F          *DX
E   6.53355E-3F          *VOL
E   9.07132E+4E          *FA
E       0.0E               *FRICF
E       0.0E               *FRICR
E       0.0F               *GRAY
E   3.39852E+2E          *HD
E       UF                *ICFLG
E       1E                *NFF
E       0.0E               *ALP
E       0.0E               *VL
E       0.0E               *VV
E       450.0F              *TL
E       615.0E              *TY
E   148.4E+5F             *P
E       0.0E               *PA
E       0.0E               *QPPP
E       0.0E               *MATID
E       0.0E               *TH
E       0.0E               *CJYC
E       0.0E               *S
E       0.0E               *PDWTB1
E       0.0E               *PDWRF1
E       0.0E               *QP3TB1
E       0.0E               *QP3RF1

*****  

* NOTE THAT NODES=0 GIVING NO WALL-FLUID HEAT TRANSFER  

*  

TEE      1        0        13        13 ECC LINE = LP15  

        7        0        0.0        0          *CN02  

*  

* MAIN TUBE
*  

        0        1        15        15        0          *CN03
        0.7435625  0.0134874  0.0        5.0        300.0          *CN04
        300.0        0.0        0.0        1.0E20        1.0          *CN05
                                                *CN06
                                                *CN07
                                                *CN08

```

5	6	7	8	9	10	11
6	7	8	9	10	11	12
3	4	5	6	7	8	9
200.0	100.0	50.0	25.0	12.5	6.25	3.125
4.35625E+2	1.34674E+2	6.0	3.0	1.5	0.75	0.375
300.0	5.547E+2	2.636E+1	1.318E+1	6.59E+0	3.295E+0	1.647E+0

* 6 EKRAY DATA

F	1.07227E+0E				*DX
F	2.61555E+2E				*VJL
F	3.28522E-4E	2	5.54700E+2E		*FA
D	0.013521	0.006551	44.5155	E	*FRICF
D	0.014521	0.006551	44.5155	E	*FRICR
F	-1.0E-2		0.0E		*GRAY
F	2.04520E-1E	2	2.63500E+1E		*HJ
F	0E				*ICFLG
F	1E				*NFF
F	0.0E				*ALP
F	0.0F				*YL
F	307.2		400.0E		*TV
F	525.6		615.0E		*P
F	43.0E+5		148.4E+5E		
F	0.0F				

0.0	1.0	10000.0	1.0	E	

* NOTE THAT VALUES=0 GIVING NO WALL-FLUID HEAT TRANSFER
 * UNKNOWN VALUES FOR RADII'S AND THICKNESS OF PIPE

PIPE		15		15 ACCUMULATOR	
3	0	11	17	0	*CN02
1	0	1	0		*CN03
					*CN04
					*CN05
1.0	0.1	0.0	0.0	300.0	*CN06
300.0	0.0	0.0	1.0E20	1.0	*CN07
					*CN08

* 6 APPAY DATA

F	0.5A5	0.95lb	1.12500E-2E		*DX
F	0.707	1.166	1.40771E-2E		*VJL
F	3.1.25133E+0	3.26522E-2E			*FA
R	3	0.0	0.013521	E	*FRICF
R	3	0.0	0.013521	E	*FRICR
F	-1.0E				*GRAY
R	3.1.25954E+0	2.04520E-1E			*HJ
F	0F				*ICFLG
F	1E				*NFF
F	1.0	0.0E			*ALP
F	0.0E				*YL
F	0.0E				*VV
F	307.2E				*TL
F	307.2E				*TV
F	43.0E5		E		*P
F	43.0E5	R2	0.0	E	*PA
					*OPPP

*SHALT
 *TIA
 *CUND
 *S
 *PDXTR1
 *PDXRF1
 *PDXTR1
 *PDXRF1

* USES TRIP 2 AND SIGNAL VARIABLE 3
 * CONSTANT VELOCITY UNTIL TRIP 0 ON THE PRESSURE-VELOCITY TABLE
 *

FILL	15	15 HPIS INJECTION				
18	7	0				*CN02
2	3	0	0	0		*CN03
0.0	1.0E20	0.0	0.0	0.0		*CN04
5.0	4.53556E-3	0.0	0.0	307.2		*CN05
1.0E+5	0.0	0.0	0.0	307.2		*CN06
						*CN07
						*CN08
1.0	1.0					*CN09
						*CN10

*
 * FILL TABLE = (PRESSURE,VELOCITY)
 * THIS IS FOR L2=3,LB=1 AND FP=1
 *

1.0000E+0	1.76554	0.85013E+5	1.765545	*VNTB
83.588E+5	0.73564	1000.0E+5	0.735648	

* USES TRIP 2 AND SIGNAL VARIABLE 1
 * CONSTANT MASS FLOW UNTIL TRIP 0 ON THE TIME-MASS TABLE
 *

FILL	17	17 LCCL ACCUMULATOR & INJECTION				
19	8	0				*CN02
3	1	-13	0	0		*CN03
0.0	1.0E20	0.0	0.0	0.0		*CN04
1.0	5.98920E-3	0.0	0.0	303.0		*CN05
41.4E+5	0.0	0.0	0.0	303.0		*CN06
						*LN07
						*CN08
1.0	1.0					*CN09
						*CN10

*
 * FILL TABLE = (TIME,MASS FLOW)
 * R7K FP=1
 *

0.0	0.0	0.2	3.0 5	*VNTB
2.0	10.8	4.0	13.8 5	
6.0	15.6	8.0	15.8 5	
12.0	15.3	16.0	14.5 5	
28.0	13.6	52.0	11.0 5	
69.0	2.4	70.0	0.0 5	
1000.0E	0.0E			
78.0	9.6	100.0	8.5 5	
136.0	7.0	145.0	7.4 5	
1000.0	7.4E			

* REMOVED AS USED IN L2/3 DECK FOR TRAC-PF1(M3011)
 * TCHF=1
 *

TEE		31	31 BROKEN-LOOP HOT LEG			
2	4	7	0.0	1		*CN02
* MAIN TUBE						
0	26	31	32	0		*CN03
0	0	0	0	0		*CN04
5.16203	6.003571	6.0	6.0	300.0		*LN05
						*CN06

1.0000	0.0000	0.0000	1.0000	1.0000	1.0000
0.0000	0.0000	1.0000	1.0000		
# SIDE FLOW					
2	3	6.3	9		
3	0	0	0	3	
0.10725	0.02858	6.0	6.0	300.0	
300.0	0.0	0.0	1.00E20	1.0	
0.0	0.0	1.00E20	1.0		
# DATA FLOW					
2 3 6.468298E+1	7.125780E+1	4.67490E+1	5.58510E+1	1.98750E+05	*DX
2 3 1.07720E+0	1.98750E+0	5.10290E+1	5.46290E+1	4.86280E+15	*UX
2 3 7.54010E+1	1.71450E+1	3.00000E+1	2.79400E+1R 2	2.11840E+15	*UX
F4 0.19717	0.24922	0.244476	0.815976 E		
#					
2 3 4.246070E+2	4.724800E+3	3.75790E+3	4.550330E+3	1.96860E+15	*YOL
2 3 1.125300E+1	1.769600E+1	4.37280E+3	4.26350E+3	3.17150E+35	*YOL
2 3 2.730000E+2	1.850000E+2	1.840000E+2	6.85060E+3R 2	1.76670E+35	*YOL
F4 0.0015574	0.002472	0.00204498	0.04239448 E		
#					
2 3 4.362500E+2	1.37130E+2R 3	0.36470E+3P 3	1.91410E+2R 3	8.36470E+35	*FA
5.342500E+2R 2	3.46240E+3	5.34250E+25			*FA
F5 8.35470E+3P1	5.14560L+2E				*FA
#					
0.0	0.0	2.21151E+1	2.39561E+1	2.54000E+1	0.05 *FRICF
7.72000L+3P 3	1.40000E+2	1.93000E+2R 3	0.0	1.90000E+15	*FRICF
1.72000E+1	1.14000E+1R 2	0.0	4.39700E+2R4	0.05 *FRICF	
2.518333R 0.347732	0.0				*FRICF
0.035	E 2 2.21151E+1	2.39561E+1	2.54000E+1	0.05 *FRICR	
7.72000L+3R 3	1.40000E+2	1.93000E+2R 3	0.0	1.40000E+15	*FRICR
1.72000E+1	1.14000E+1R 2	0.0	4.39700E+2R4	0.05 *FRICR	
0.018403R 0.347732	0.0				*FRICR
#					
P 0	0.0	6.21372L+1R 2	1.00000E+0	0.0R 6=1.00000E+05	*GPAY
-6.453554E+1P 2	0.0	2.91528E+15			*GPAY
R 5 1.00000E+0	0.4692407	R3	0.0E		*GPAY
#					
2 3 2.84000L+1	1.43000E+1R 3	1.03000E+1R 3	1.75000E+2R 3	1.03000E+15	*HD
2 3 2.84000E+1P 2	1.14000E+2	2.84000E+15			*HD
R 2 1.03200E+1P1	2.57200E+1E				*HD
#					
P25	0	2	UF		*ICFLG
F	1F				*NFF
F	0.0F				*ALP
F	0.0E				*YL
F	0.0E				*YY
#					
2 2 5.65500E+2	5.55120E+2	5.64770E+2	5.54650E+2	5.64070E+25	*TL
5.62730E+2	5.62000E+2	5.51280E+2	5.59930E+2	5.59590E+25	*TL
5.53220E+2	5.56840E+2	5.58720E+2	5.58600E+2	5.58400E+25	*TL
5.58210E+2	5.58070E+2	5.57920E+2	5.57800E+2	5.57670E+25	*TL
5.57555E+2	5.57420E+25				*TL
5.57270E+2	5.57100E+2	5.56760E+2E			*TL
#					
F	615.0F				*TV
F	148.4E+5F				*P
F	0.0F				*PA
F	0.0E				*QPPP
F	7F				*MATID
#					
2 8 5.65500E+2P 4	5.65120L+2R 4	5.64770E+2P 4	5.64450E+2K 4	5.64070E+25	*TH
2 4 5.62730E+2P 4	5.62000L+2P 4	5.61280E+2R 4	5.57930E+2K 4	5.59590E+25	*TH
2 4 5.53220L+2P 4	5.55890E+2K 4	5.58720E+2R 4	5.58600E+2R 4	5.58400E+25	*TH
2 4 5.58210E+2P 4	5.58070L+2R 4	5.57920E+2R 4	5.57800E+2R 4	5.57670E+25	*TH
2 4 5.57555E+2P 4	5.57420L+2S				*TH
2 4 5.57270E+2P 4	5.57100E+2R 4	5.56760E+2E			*TH

*LOND
*S
*POWTB1
*POWRF1
*UP3TB1
*UP3RF

*
* SIDE TUBE
*

1.38700E+0	8.14000E-1	5.10440E+0E	*DX
5.40000E-2	3.14000E-2	1.38700E-1E	*YDL
3.3.8800E-2	3.33000E-03E		*FA
0.0	0.0E		*FRICF
0.0	0.0E		*FRICR
0.0	2.24200E-1	1.91200E-15	*GRAY
0.0E			
1.2.22300E-1	65.200E-3E		*HD
0E			*ICFLG
1E			*NFF
0.0E			*ALP
0.0E			*VU
0.0E			*VV
5E5.5E			*TL
515.5E			*TV
148.4E+5F			*P
0.0E			*PA
0.0E			*OPPP
7E			*HATID
565.5E			*TD
			*C3NC
			*S
			*POWTB1
			*POWRF1
			*UP3TB1
			*UP3RF1

*
* CONSTANT VELOCITY = SET TO ZERO
*

FILL 32 32 BROKEN-HOT-LEG TERMINAL

32	1	0		*CN02
0.0	1.0E20	0.0	0.0	*CN03
0.815975	0.0423448	0.0	0.0	*CN04
148.4E+5	0.0	0.0	0.0	*CN05
				*CN06
				*CN07
				*CN08
				*CN09
				*CN10

*
* REVERSED AS USED IN L2/3 DECK FOR TRAC-PF1(MOD1)
* TCHF=1

TEE 2 4 41 41 BROKEN-LOOP COLD LEG TEE

2	4	41	0.0	1	*CN02
0	0	41	4.6	0	*CN03
0	0	0	0	0	*CN04
0.14209	0.03571	6.0	6.0	300.0	*CN05
300.0	0.0	0.0	1.0E20	1.0	*CN06
0.0	0.0	1.0E20	1.0		*CN07
					*CN08

*
* SIDE TUBE

0	2	43	0		*CN09
0	0	0	0	0	*CN10
0.10735	0.02685	6.0	5.0	300.0	*CN11
					*CN12

* SIDE FIRE

	5	1	14	0		*CN09 *CN10 *CN11 *CN12 *CN13 *CN14
5.31E-024	0.0071374	0.0	0.0	0.0	300.0	
300.0	0.0	0.0	1.0E20	1.0		

* MAIN TURF

	9.35953E+0F				RDX
	1.015552E+1F				*VOL
F	9.54705E+2	5.98920E-3F			*PA
F	4.051E5	0.0E			*FRICF
F	4.951E5	0.0E			*FRICR
F	0.0E				*GRAY
F	2.43505E+1	8.73792E-2F			*HO
F	UF				*ICFLG
F	1E				*NPF
F	0.0E				*A_P
F	0.0F				*V_L
F	0.0F				*V_V
F	400.0E				*T_L
F	615.0F				*T_V
F	1.48E4E+5F				*P
F	0.0E				*PA
					*QPPP
					*MATID
					*TA
					*CONC
					*S
					*PDHTB1
					*PDHRRF1
					*OP3TR1
					*OP3RF1

* SIDE FIRE

	1.0E				RDX
F	8.73920E-3F				*VOL
F	8.73920E-3E				*PA
F	0.0F				*FRICF
F	0.0E				*FRICR
F	0.0E				*GRAY
F	8.73252E-2F				*HO
F	0F				*ICFLG
F	1E				*NPF
F	0.0F				*A_P
F	0.0F				*V_L
F	0.0E				*V_V
F	400.0E				*T_L
F	615.0E				*T_V
F	1.48E4E+5F				*P
F	0.0F				*PA
					*QPPP
					*MATID
					*TA
					*CONC
					*S
					*PDHTB1
					*PDHRRF1
					*OP3TR1
					*OP3RF1

* VALVE IS CONTROLLED BY TRIP 5.

*

VALVE	14	14_ECC_WIRE = CHECK VALVE
2	0	17
		18

*CN02

100,0	W+J	0+J	1,0H20	1+J	10013	
0+0	U+U	1,0E20	1+0		*CN14	
* MAIN TUBE						
R2	0,80774			E	*DX	
F2	0,0312674			E	*VOL	
R3	0,053425			L	*FA	
R2	0,0	1,047	0,030579	E	#FRIC VSL-BLCL -0,17	
F2	0,1291	1,047	0,030579	E	#FRIC BLCL-VSL 0,129	
F	0,0	F			*GRAY	
R3	0,224			E	*HD	
R3	0		E		*ICFLG	
F	1F				*NPF	
F	0,0E				*ALP	
F	0,0E				*VL	
F	=	0,0E			*VV	
	550,95	502,40		L	*TL	
F	515,38E				*TY	
F	148,4E+5E				*P	
F	0,0E				*PA	
F	0,0E				*QPPP	
F	7F				*MATID	
	550,9	501,01	R2	561,03	562,535	*TW
	502,51	R2	502,58E			*TW
* SIDE TUBE						
	8,85000E-1	7,28340E+0E			*DX	
	3,03300E-2	2,76800E-1E			*VOL	
R2	0,038R	3,3300E-03E			*FA	
R2	0,0	0,0E			*FRICF	
R2	0,0	0,0E			*FTICR	
R2	0,0	1,09000E-1	0,0E		*AV	
R2	2,22300E-1	55,700E-3E			I	
C	UF				*ICFLG	
F	15				*VZF	
F	0,0F				*ALP	
F	0,0F				*VL	
F	0,0E				*VV	
F	553,33	502,88 E			*T,	
F	515,1E				*TY	
F	148,4E+5F				*P	
F	0,0F				*PA	
C	0,0E				*QPPP	
F	7E				*MATID	
F	553,38				*TW	
* CONC						
					*S	
					*POWTR1	
					*POWRF1	
					*QP3TB1	
					*QP3RF1	

*-- TRIP 200

VALVE	43	43	BROKEN-LOOP	COLD	LEJ	VALVE	
4	4	44	42	7			*CN02
0	0	3	2	0			*CN03
200	1	-4	0	0			*CN04
2	0	0	0	0			*CN05
0	0						*CN06
1,0E+20	11,0		0,0	0,0			*CN07
1,47093E+01	3,5710E+02		6,0	6,0	3,00E+02		*CN08

31040 1.387E+000 1.227E+000 1.0 1.0 2.0 *CN10

*
* ARRAY DATA
*

348077E-00	5113081	1.14803E-00	1.02230	0.0	0.0	0.0	0.0	*DX
0.0512576	0.00500142	0.32623801	0.0472489					*VOL
14053325	0.013875	0.0083097	0.02352	0.05195				*PA
24210879	0.0	0.1515	0.0460103	0.1717				*FRICF
2.030579	0.0	0.1515	0.0460103	0.1717				*FRICR
F	0.0							*GRAY
	0.284	0.13292	0.1032	0.17305	0.6572			*HD
F	0	2	R2	0				*ICFLG
F	1							*NFF
F	0.0							*ALP
F	0.0							*VAL
F	0.0							*VV
F	554.53	553.72	551.91	550.36				*TL
F	516.38							*TV
F	148.48E+5							*P
F	0.0							*PA
F	0.0							*PPP
F	?							*RATTI
F	554.47	554.0	552.0	551.0				*TW
F	554.47	554.0	552.0	551.0				*CONC
F	0.0	2.5	0.55					*S
F	0.0	0.0	1000.0	0.0			E	*VTB1
								*VTB1
								*VTB2
								*VRF
								*QP3TB
								*QP3RF

* CONSTANT VELOCITY = SET TO ZERO
*
*

FIL1	42	42	42 BROKEN-COLD-LEG TERMINAL					
	42	1	0					*CN02
								*CN03
	0.0	1.0E20	0.0	0.0				*CN04
	1.02235	0.0472489	0.0	0.0	550.3			*CN05
	148.48E+5	0.0	0.0	0.0	550.3			*CN06
								*CN07
								*CN08
								*CN09
								*CN10

*
*
* PIPE
*

PIPE	81	81	81 UPPER PLENUM INJECTION PIPE	7				
	1	0	81	81				*CN102
	0	0	0	0				*CN03
	3.505200E+02	3.555000E-03	0.	0.				*CN04
	3.072000E+02	0.0	0.0	1.0E20	1.0			*CN05
								*CN06
								*CN07
								*CN08

*
* ARRAY DATA
*

F	2.5000E+00E							*DX
F	2.4124E+03E							*VOL
F	0.6497E+04E							*PA
F	0.	E						*FRICL
F	0.	E						*FRICR
F	1.0000E+00E							*GRAY
F	3.5052E+02E							*HD
F	0.	E						*ICFLU
F	1.	E						*NFF
F	5.9573E+06E							*ALP
F	0.							*VAL

F 7. 7.7732E+02F * VV
 F 5.1531F+02F * TL
 F 1.5120F+07F * TV
 F 0.0 E * P
 * PA
 * QPPP
 * MATID
 * TW
 * CONC
 * S
 * POWTB1
 * PDURF1
 * QP3TH1
 * UP3RF1

FILL 61 51 UPPER PLENUM INJECTION
 A: 8 0 * CN02
 1010 1 21 0 0 * CN03
 0.0 1.0E20 0.0 0. 3.080000E+02 * CN04
 2.500000E+00 2.412430E+03 0. 0. * CN05
 4.140000E+05 0. 0. * CN06
 * CN07
 * CN08
 * CN09
 * CN10

3.0E25
 0.0 0.0 1.0 0.05 * VMTB
 30.0 7.2 40.0 5.25
 78.0 0.0 100.0 0.05
 200.0 0.67 255.0 0.705
 260.0 0.0 266.0 1.805
 272.0 0.50 345.0 0.505
 347.0 31.0 352.0 30.05
 358.0 20.0 353.0 18.25
 375.0 16.9 400.0 10.05
 445.0 4.0 450.0 0.05
 1000.0 0.0E

PIPE 82 82 UPPER PLENUM INJECTION PIPE
 1 0 82 82 7 * CN02
 0 0 0 0 * CN03
 * CN04
 * CN05
 * CN06
 * CN07
 * CN08

* ARRAY DATA
 *
 F 2.5000F+04F * Dx
 F 2.4124E-03F * VDL
 F 9.6497F-04E * FA
 F 0. F * FRIC
 F 0. E * FRIC
 F 1.0000E+00E * GRAY
 F 3.5052E-02F * HD
 F 0. E * ICFLG
 F 1E * NFF
 F 1.8330E-06F * ALP
 D. -1.2684E-05E * VL
 D. -1.2684E-05E * VV
 F 5.9792F+02F * TL
 F 5.1535F+02F * TV
 F 1.5200F+07F * P
 F 0.0 E * PA
 * QPPP
 * MATID

* T8
 * PUL
 * S
 * PDWTR1
 * PDWRP1
 * QP3TB1
 * QP3RF1

*

F124 N6 52 UPPER PLENUM INJECTION

	62	0	0	0	0	0	0
1010	4	21	0	0			
0.0	1.0E20		0.0				
2.80000E+00	2.412430E+03	0.		0.		3.080000E+02	
41.40000E+05	0.	0.					

*

0.43825

	0.0	0.0	1.0	0.05	* VMTB
79.0	7.2	40.0	5.95		
78.0	0.0	100.0	0.05		
270.0	0.67	255.0	0.725		
270.0	0.0	256.0	1.825		
272.0	0.49	345.0	0.505		
367.0	31.0	352.0	30.05		
378.0	20.0	363.0	18.25		
375.0	16.9	400.0	10.05		
445.0	4.0	450.0	0.05		
1000.0	0.0E				

*

PIPE #3 83 UPPER PLENUM INJECTION PIPE

	1	0	63	R3	7	PCH02
0	0	0	0	0		

3.405200E+02 3.555500E+03 0. 0. 0. 3.072000E+02 *CNO5

3.457200E+02 0.0 0.0 1.0E20 1.0 *CNO7 *CNO8

*

* ARRAY DATA

F 2.50000E+00F *DX
 F 2.41244E+03F *VUL
 F 2.5497E+04E *FA
 F 0. E *FRIC
 F 0. E *FRIC
 F 1.00000E+00F *GRAY
 F 3.5052E+02F *HU
 F 0. E *ICFLG
 F 1F *HFF
 F 2.6250E+06F *ALP
 F 0. -1.2657E+05E *YL
 F 0. -1.2657E+05E *YY
 F 5.0791E+02E *TU
 F 6.1575E+02E *TY
 F 1.5120E+07F *P
 F 0.0 E *PA
 F QPPP *MATTU
 F TH *TW
 F CONC *S
 F PDWTR1 *PDWRP1
 F QP3TB1 *QD3RF1

FILL

63	63	53	UPPER PLENUM INJECTION		
1010	1	21	0	0	
0.0			0.0		*CNU2
2.500000E+00	2.412430E+03	0.			*CNU3
41.40000E+05	0.	0.			*CNU4

3.0825

0.0	0.0	1.0	0.05	*VHTB
78.0	7.4	40.0	5.95	
78.0	0.0	100.0	0.05	
220.0	0.67	255.0	0.705	
250.0	0.0	256.0	1.805	
278.0	0.50	345.0	0.505	
347.0	31.0	382.0	30.05	
358.0	20.0	383.0	18.25	
375.0	16.9	400.0	10.05	
445.0	4.0	450.0	0.05	
1000.0	0.0E			

PIPE

1	84	84	84	UPPER PLENUM INJECTION PIPE
0	0	0	0	
3.505200E-02	3.555000E-03	0.	0.	
3.072000E+02	0.0	0.0	1.0E20	3.072000E+02
				*CNU2
				*CNU3
				*CNU4
				*CNU5
				*CNU6
				*CNU7
				*CNU8

ARRAY DATA

2.5000E+00F			*FX
2.4124F+03E			*YUL
2.6437E+04E			*FA
0.	E		*FRIC
0.	F		*FRIC
1.0330E+00E			*GR&V
3.5052F+02E			*HD
0	E		*ICFLG
	1E		*NFF
2.5303F+05F			*ALP
0.	-1.2758E-05E		*VL
0.	-1.2758E-05E		*VV
8.9791E+02E			*TL
5.1536E+02E			*TV
1.5220F+07F			*P
0.0	F		*PA
			*UPPP
			*HATIU
			*TW
			*CNC
			*S
			*FOWTE1
			*POwRF1
			*QP3TH1
			*QP3RF1

FILL

64	64	54	UPPER PLENUM INJECTION		
1010	1	21	0	0	
0.0	1.0E20	0.0			*CNU2

3.452525E+01 2.401243E+03 0.4 0.4 3.083000E+02 * CNU5
 41.40000E+05 0.0 0.0 * CNU6
 * CNU7
 * CNU8
 * CNU9
 * CNU10
 0.00025
 0.0 0.0 1.0 0.05 * VMTB
 38.0 7.0 40.0 5.95
 78.0 0.0 100.0 0.25
 270.0 0.67 255.0 0.705
 270.0 0.0 266.0 1.825
 272.0 0.50 345.0 0.505
 347.0 31.0 352.0 30.05
 378.0 20.0 363.0 18.25
 375.0 10.9 400.0 10.05
 445.0 4.0 450.0 0.05
 = 1000.0 0.0E

PIPE 85 85 UPPER PLENUM INJECTION PIPE
 1 0 65 85 7 * CNU2
 0 0 0 0 * CNU3
 * CNU4
 * CNU5
 3.405200E+02 3.455000E+03 0.4 0.4 3.072000E+02 * CNU6
 3.077200E+02 0.0 0.0 1.0E20 1.0 * CNU7
 * CNU8

6
 6 APPENDY DATA
 6
 E 2.5000F+00F * DX
 F 2.6126F+03F * VUL
 F 2.6497F+04F * FA
 F 0.0 F * FRIC
 E 0.0 F * GRAY
 F 1.0000F+00E * HU
 F 3.5052F+02F * ICFLG
 F 0.0 E * NFF
 F 1F * ALP
 E 4.7080F+06F * VL
 D. -1.2637E+05E * VV
 D. -1.2637E+05E * TL
 E 4.0731F+02F * TY
 F 5.1537E+02F * P
 F 1.5203F+07F * PA
 F 0.0 F * UPPP
 * MAT10
 * ETW
 * CONC
 * S
 * POWTB1
 * POWRF1
 * UP3TB1
 * QP3RF1

6
 6 APPENDY DATA
 6
 FILL 65 65 65 UPPER PLENUM INJECTION * CNU2
 65 8 0 0 * CNU3
 1010 1 21 0 0 * CNU4
 0.0 1.0E20 0.0 0.0 3.080000E+02 * CNU5
 2.500000E+00 2.412430E+03 0.4 0.4 * CNU6
 41.40000E+05 0.0 0.0 * CNU7
 * CNU8
 * CNU9
 * CNU10
 0.1675
 0.0 0.0 1.0 0.05 * VMTB

78.0	74.0	92.0	5.75
75.0	80.0	100.0	7.05
770.0	0.67	255.0	0.725
240.0	0.0	266.0	1.805
272.0	0.50	345.0	0.525
347.0	31.0	352.0	30.05
358.0	20.0	363.0	18.25
375.0	16.4	400.0	10.05
445.0	4.0	450.0	0.05
1000.0	0.0E		

*

*

PIPE
1 86 86 7 *CNU02
0 0 0 *CNU03
*CNU04
*CNU05
*CNU06
*CNU07
*CNU08

3.505200F+02 3.55500JF+01 0. 0. 3.072000E+02
3.572000F+02 0.0 0.0 1.0E20 1.0

*
* AERAS: DATA
*

2.4000F+00F			* DX
2.4124E+03F			* YUL
2.4697F+04E			* FA
0.0			* FRI
0.0			* FKIC
1.0000E+00E			* GRAY
3.5032E+02E			* HD
0.0	E		* ICFLG
	1E		* HFF
5.33957E+06E			* ALP
0.	-1.2615E+05E		* VL
0.	-1.2615E+05E		* VV
5.9791F+02E			* TL
5.1538E+02E			* TV
1.5204E+07E			* P
0.0	E		* PA
			* QPPP
			* MATID
			* TW
			* CONC
			* S
			* POWTBI
			* POWRF1
			* UP3TA1
			* QP3R

*

*

FILL 56 56 56 56 56 56 56
66 8 0 0 0 0 0 0
1010 1 21 0 0 0 0 0
0.0 1.0E20 0.0 0.0 0.0 0.0 0.0 0.0
2.500000F+00 2.412430E+03 0. 0. 0. 0. 0. 0.
41.40000F+05 0. 0. 0. 0. 0. 0. 0.
0.1575

0.0 0.0 1.0 0.05 * YMTR
38.0 7.2 40.0 5.75
78.0 0.0 100.0 0.25
270.0 0.67 255.0 0.705
240.0 0.0 266.0 1.805
272.0 0.50 345.0 0.505
347.0 31.0 352.0 30.05
358.0 20.0 363.0 18.25

3.445E+00	1.0E+00	400.0	10.05
4.45E+00	4.0	450.0	0.05
10.0E+00	0.0E+00		

PIPE 87 87 UPPER PLENUM INJECTION PIPE
 1 0 67 87 7 *CNU2
 0 0 0 0 *CNU3
 *CNU4
 *CNU5
 $3.4505200E+02$ $3.4555000E+03$ 0. 0. $3.072000E+02$ *CNU6
 $3.072000E+02$ 0.0 0.0 1.0E20 1.0 *CNU7
 *CNU8

* SPRAY DATA
 -
 X $2.5000E+00F$ *DX
 Y $2.4124E+03F$ *VOL
 Z $2.5697E+04F$ *PA
 S 0. E *FRIC
 N 0. F *FRIC
 R $1.0000E+00E$ *GRAY
 T $3.45052E+02E$ *HD
 E 0. F *ICFLG
 E 1E *HFF
 F $4.9541E-06F$ *ALP
 D. $+1.20RCE+05E$ *YL
 D. $+1.20RCE+05E$ *VV
 F $6.0720E+02E$ *TL
 F $6.1537E+02E$ *TV
 F $1.5203E+07E$ *P
 F 0.0 E *PA
 *OPPF
 *SHATI0
 *TW
 *CONC
 *S
 *PORTAL
 *POWERF1
 *QP3TB1
 *UP3RF1

FILL 67 67 UPPER PLENUM INJECTION
 67 6 0 *CNU2
 1010 1 21 0 0 *CNU3
 0.0 1.0E20 0.0 *CNU4
 $2.500000E+00$ $2.412430E+03$ 0. 0. $3.080000E+02$ *CNU5
 $41.40000E+05$ 0. 0. *CNU6
 *CNU7
 *CNU8
 *CNU9
 *CNU10

0.0 0.0 1.0 0.05 *YMTB
 38.0 7.2 40.0 5.95
 78.0 0.0 100.0 0.05
 200.0 0.67 255.0 0.725
 200.0 0.0 255.0 1.825
 272.0 0.50 345.0 0.505
 347.0 31.0 352.0 30.05
 358.0 20.0 363.0 18.25
 375.0 10.9 400.0 10.05
 445.0 4.0 450.0 0.05
 1000.0 0.0E+00

PIPE 88 88 UPPER PLENUM INJECTION PIPE

1	.	58	88	?	CNU2
0	0	0	0		CNU3
					CNU4
3.505200F+02	3.555000E+01	0.	0.		CNU5
3.072000E+02	0.0	0.0	1.0E20	1.0	CNU6
					CNU7
					CNU8
*					
*	ARRAY DATA				
F	2.6000F+00F				* DX
F	2.41245E+03F				* VOL
F	9.6427E+00F				* FA
F	0.				* FRIC
F	0.				* FRIC
F	1.0000F+00F				* GBBV
F	3.5052F+02F				* HD
F	0.	E			* ICFLC
F	1F				* IFF
F	4.67215E-06F				* ALP
D		-1.2745E-05E			* VL
D		+1.2745E-05E			* VV
F	8.0720F+02F				* TL
F	6.1537F+02F				* TV
F	1.5203F+02F				* P
F	0.0	E			* PA /
					* QPPP
					* MATIU
					* TW
					* CONC
					* S
					* РОНТВ1
					* ИОРВФ1
					* QR3TV1
					* УР3RF1
*					
*	*****				
*	FILL	68	58 UPPER PLENUM INJECTION		
	50	8	0		CNU2
	1010	1	21	0	CNU3
	0.0	1.0E20	0.0		CNU4
	2.500000F+00	2.412430E+03	0.		CNU5
	41.40000F+05	0.	0.		CNU6
					CNU7
					CNU8
					CNU9
					CNU10
*					
*	0.1675				
	0.0	0.0	1.0	0.05	* VMTR
	38.0	7.2	40.0	5.95	
	78.0	0.0	100.0	0.05	
	270.0	0.47	255.0	0.725	
	260.0	0.0	265.0	1.825	
	272.0	0.40	345.0	0.505	
	347.0	31.0	242.0	30.05	
	358.0	20.0	363.0	18.25	
	375.0	16.9	400.0	10.05	
	445.0	9.0	450.0	0.05	
	1000.0	0.0E			
*					
*	*****				
*	PIPE	84	89 UPPER PLENUM INJECTION PIPE		
	1	0	59	89	CNU2
	0	0	0	0	CNU3
					CNU4
					CNU5
	3.505200F+02	3.555000E+03	0.		CNU6
	3.072000F+02	0.0	0.0	1.0E20	CNU7
					CNU8

E 6485E-0576
 E 2.4720E+00E
 E 2.4125E+03E
 E 9.6492E+04E
 E 7.
 E 7.
 E 1.03300E+00E
 E 3.5352E+02E
 E 0.
 E 1E
 E 1.2584E+5LE
 D₁ -1.2674E+02E
 D₂ -1.2674E+02E
 E 3.9735E+32E
 E 4.537E+02E
 E 1.5223E+07E
 E 0.
 E E

 PIPE 64 59 UPPER PLENUM INJECTION 0.000000000000000E+00
 64 0 0 0 0 0 0 UN02
 1010 1 21 0 0 UN03
 0.0 1.0E20 0.0 0.0 0.0 0.0 UN04
 2.500000E+00 2.412630E+03 0.
 41.40000E+05 0. 0. 0. 0. 0. 0. UN05
 UN06
 UN07
 UN08
 UN09
 UN10
 0.0000 0.00 1.0 0.05 VM18
 70.0 7.0 40.0 5.95
 75.0 0.0 100.0 0.05
 200.0 0.67 255.0 0.705
 250.0 0.0 266.0 1.805
 272.0 0.50 345.0 0.505
 347.0 31.0 352.0 30.05
 368.0 20.0 353.0 10.25
 375.0 16.9 400.0 10.05
 445.0 4.0 450.0 0.05
 1000.0 0.0E0

 PIPE 90 90 UPPER PLENUM INJECTION PIPE 0.000000000000000E+00
 1 0 70 90 7 UN02
 0 0 0 0 UN03
 UN04
 UN05
 3.505200E-02 3.555000E+03 0.
 3.072000E+02 0.0 0.0 1.0E20 1.0 UN06
 UN07
 UN08

 E ARRAY DATA
 E
 E 2.5000E+10E
 E 2.4124E+03E
 E 9.6492E+04E
 E 7.

E 0
 F 1.0250E+00F * FXTL
 F 3.5052E+02F * GRAV
 F 0.0 * HD
 F 1.7754E+06F * ICFLG
 D. -1.25115E+05E * NFF
 D. -1.2506E+05E * ALP
 F 5.0784E+02F * VL
 F 5.1538E+02F * VV
 F 1.5206E+07F * TL
 F 0.0 * TV
 F 0.0 * P
 F 0.0 * PA
 F 0.0 * SUPPP
 F 0.0 * MATID
 F 0.0 * TIV
 F 0.0 * CONC
 F 0.0 * S
 F 0.0 * PONTF1
 F 0.0 * POWRF1
 F 0.0 * UP3TB1
 F 0.0 * UP3RF1
 *

 *
 FILE 70 70 UPPER PLENUM INJECTION
 70 8 0 * UND2
 1010 1 21 0 0 * CHN03
 0.0 1.0E20 0.0 * CHN04
 2.500000E+00 2.412430E+03 0.0 0.0 3.080000E+02 * CHN05
 41.40000E+05 0.0 0.0 * CHN06
 *
 0.0000
 0.0 0.0 1.0 0.05 * VMTB
 98.0 7.2 40.0 5.95
 78.0 0.0 100.0 0.05
 210.0 0.67 255.0 0.705
 250.0 0.0 266.0 1.805
 272.0 0.60 345.0 0.505
 347.0 31.0 352.0 30.05
 358.0 20.0 363.0 18.25
 375.0 16.9 400.0 10.05
 445.0 4.0 450.0 0.05
 1000.0 0.0F *
 *

 *
 PIPE 91 91 UPPER PLENUM INJECTION PIPE
 1 0 71 91 7 * CHN02
 0 0 0 0 * CHN03
 * CHN04
 * CHN05
 * CHN06
 * CHN07
 * CHN08
 *
 3.505200E+02 3.555000E+03 0.0 0.0 3.072000E+02 *
 3.072000E+02 0.0 0.0 1.0E20 1.0 *
 *
 * AKRAY DATA
 *
 F 2.5000E+00F * DX
 F 2.4124E+03E * VOL
 F 3.6497E+04F * FA
 F 0.0 * FRIC
 F 0.0 * FRIC
 F 1.0250E+00F * GRAV
 F 3.5052E+02F * HD
 F 0.0 * ICFLG
 F 1.7754E+06F * NFF
 D. -1.0107E+05F * ALP
 F 0.0 * VL

E 8.07342E+02E *1.0E-27E+02E
 E 8.1537E+02E
 F 1.5203E+02E
 E 0.0 E

E VV
 E TL
 E TV
 E P
 E PA
 E QPPP
 E MATID
 E TW
 E CONC
 E S
 E PDRHTB1
 E PDRHRE1
 E UP3TB1
 E UP3RF1

E *****
 E

FILL 71 71 UPPER PLENUM INJECTION
 71 0 0 0 0 0
 1010 1 21 0 0 0
 0.0 1.0E20 11.0 0 0 0
 2.500000E+00 2.412430E+03 0.0 0.0 3.050000E+02
 41.40000E+05 0.0 0.0 0.0 0.0 0.0

E CNU2
 E CNU3
 E CNU4
 E CNU5
 E CNU6
 E CNU7
 E CNU8
 E CNU9
 E CNU10

0.0000
 0.0 0.0 1.0 0.05 * VHTB
 38.0 7.2 40.0 5.95
 78.0 0.0 100.0 0.05
 200.0 0.67 250.0 0.725
 250.0 0.0 260.0 1.805
 272.0 0.50 345.0 0.505
 347.0 31.0 352.0 30.25
 378.0 20.0 363.0 18.25
 375.0 10.9 400.0 19.05
 465.0 4.0 450.0 0.05
 1070.0 0.0E

E *****
 E

PIPE 42 92 UPPER PLENUM INJECTION PIPE
 1 0 72 92 0 0
 0 0 0 0 0 0

E CNU2
 E CNU3
 E CNU4
 E CNU5
 E CNU6
 E CNU7
 E CNU8

E APRAY DATA
 E

F 2.5000E+00E E DX
 F 2.4124E+03E E YUL
 F 9.5497E+04E E FA
 F 0.0 E FRIC
 F 0.0 E FRIC
 F 1.0000UF+00F E GRAY
 F 3.5052E+02E E HD
 F 0.0 E ICFLG
 F 1F E NFR
 F 4.1450F+06F E ALP
 F 0.0 -1.2557E+05E E VL
 F 0.0 -1.2557E+05E E VV
 F 5.07355E+02E E TL
 F 8.1537E+02E E TV
 F 1.5202E+02E E P
 F 0.0 E PA
 E QPPP
 E MATID

* FW
 * QDNC
 * S
 * QDWT01
 * QDWRF1
 * QUP3TB.
 * QUP3RF1

*

 *
 FILL 72 72 UPPER PLIUM INJECTION
 72 8 0 *CN02
 1013 1 21 0 0 *CN03
 0.0 1.0E20 0.0 *CN04
 2.50000E+00 2.412430E+03 0.0 0.0 3.08000E+02 *CN05
 4.14000E+05 0.0 0.0 *CN06
 *
 0.0000

0.0 0.0 1.0 0.05 * VMTB
 38.0 7.2 40.0 5.95
 78.0 0.0 100.0 0.05
 245.0 0.87 255.0 0.705
 250.0 0.0 260.0 1.805
 272.0 0.40 345.0 0.505
 347.0 31.0 352.0 30.05
 358.0 20.0 363.0 18.25
 375.0 18.9 400.0 10.05
 445.0 4.0 450.0 0.05
 1000.0 0.0F

*

 *
 TEE 101 101 CORE BYPASS

* JCELL	NUDES	HAT	CUST	ICHE	
3	4	7	0.0	1	*CN02

* MAIN TUBE

* ICUN11	NCELL1	JUN1	JUN2	IPDH1	
0	5	101	102	0	*CN03
* IDPT11	IDPSV1	NQFT01	NQPSV1	NQPRF1	
0	0	0	0	0	*CN05
* RADT11	TH1	HOUTL1	HOUTV1	TOUTL1	
0.00174	0.04	0.0	0.0	300.0	*CN06
* TDUTV1	PH1N1	PWDF1	PPWMX1	PWSCL1	
300.0	0.0	0.0	1.0E20	1.0	*CN07
* DPT11	DPUFF1	PUPMX1	QPSCL1		
0.0	0.0	1.0E20	1.0		*CN08

* SIDE TURF

* ICUN02	NCELL2	JUN3	IPDH2		
0	1	102	0	*CN09	
* IDPT02	IDPSV2	NQFT02	NQPSV2	NQPRF2	
0	0	0	0	0	*CN11
* RADT02	TH2	HOUTL2	HOUTV2	TOUTL2	
0.00175	0.04	0.0	0.0	300.0	*CN12
* TDUTV2	PH1N2	PWDF2	PPWMX2	PWSCL2	
300.0	0.0	0.0	1.0E20	1.0	*CN13
* DPT02	DPUFF2	PUPMX2	QPSCL2		
0.0	0.0	1.0E20	1.0		*CN14

* MAIN TUBE

R 2	0.0	0.46R 2	0.97E	*DX1
R 2	2.824E+03	1.693E+03R 2	3.573E+03E	*Y3L1
	1.295E+03R 4	5.033E+03	1.295E+03E	*F4L1
F	0.0F			*FRIC1F

* 1.0E-03F 4 1.44E+02 3.4R0F+03F *FR411.E
 * 1.0E-04 0 LE *H01
 * 1F *JDFL01
 * 0.0F *KALP1
 * 0.0F *KV1
 * 0.0F *VV1
 * 5.93*0E *T_1
 * 5.15*UF *TV1
 * 148.4E+5F *P1
 * 0.0 *PA1
 * 0.0E *OPPP1
 * 7F *MAT1D1
 * 5.70*0F *TA1

 * SIDE TURF

 * 0.0*0E *DK2
 * 2.742F+04F *V0L2
 * 1.041E+03F *FA2
 * 0.0E *FRICZF
 * 0.0F *FRICZB
 * 0.0F *GRAY2
 * 0.00391E *HD2
 * 0 LE *ICPL02
 * 1F *NFF2
 * 0.0F *ALP2
 * 0.0E *V_2
 * 0.0F *VV2
 * 5.93*0F *T_2
 * 5.15*UF *TV2
 * 148.4E+5E *P2
 * 0.0E *PA2
 * 0.0F *OPPP2
 * 7E *MAT1D2
 * 5.70*0F *TA2

 * TEE JCELL NODES 102 102 CORE PYPASS
 * 3 4 7 CUST IC4F 1 *CN02

 * MAIN TURF

 * ICUM01 NCCELL1 JUN1 JUN2 IP0H1 *CN03
 * 0 5 102 106 0
 * IQPTR1 IQPSV1 HQPTB1 HQPSV1 HQPRF1 *CN05
 * 0 0 0 0 0
 * RADIN1 TH1 HUUTL1 HUUTV1 TOJTL1
 * 0.00174 0.04 0.0 0.0 300.0 *CN06
 * TOUTV1 PW1H1 PW0FF1 PWMMX1 PWSCLL1
 * 300.0 0.0 0.0 1.0E20 1.0 *CN07
 * QPIV1 QP0FF1 RQPMX1 QPSCL1
 * 0.0 0.0 1.0E20 1.0 *CN08

 * SIDE TURF

 * IC0N02 NCCELL2 JUN3 IP0W2 *CN09
 * 0 1 110 0
 * IQPTR2 IQPSV2 HQPTB2 HQPSV2 HQPRF2 *CN11
 * 0 0 0 0 0
 * RADIN2 TH2 HUUTL2 HUUTV2 TOJTL2
 * 0.00195 0.04 0.0 0.0 300.0 *CN12
 * TOUTV2 PW1H2 PW0FF2 PWMMX2 PWSCLL2
 * 300.0 0.0 0.0 1.0E20 1.0 *CN13
 * QPIV2 QP0FF2 RQPMX2 QPSCL2
 * 0.0 0.0 1.0E20 1.0 *CN14

```

* MAIN TUBE
*
2 3      0.0           0.46E-2       0.27E          #DX1
2 2  2.2207E+03    1.623E+03E-2   3.570E+03E          #YDL1
1.225E+03E-4  6.030E+03            1.295E+03E          #FA1
F      0.0E
F      0.0E
F      1.0E
3.480E+03E-4  1.44E+02       3.480E+03E          #H21
1.0E-4        0             1E               #ICFLG1
F      1E
F      0.0E
F      0.0E
F      0.0E
F      5.93E+0E
F      6.15E+0E
F      1.48E+5E
F      0.0E
F      0.0E
F      7E
F      5.70E+0E
F

```

* SIDE TUBE

```

U.050E          #DX2
2.742E+04F     #YDL2
1.041E+03F     #FA2
F      0.0E
F      0.0E
F      0.0E
F      3.0E391E
F      0             1E               #ICFLG2
F      1E
F      0.0E
F      0.0E
F      0.0E
F      5.93E+0E
F      6.15E+0E
F      1.48E+5E
F      0.0E
F      0.0E
F      7E
F      5.70E+0F
F

```

```

***** BYPASS ****
TIP      103      103      CORE BYPASS
*      JCELL      NODES      MAT      CUST      ICHE
*      3          4          7          0.0          1          #CNO2

```

* MAIN TUBE

```

* ICUN01      NCCELL1      JUN1      JU42      IPJW1
*      0          5          103      107      0          #CNO3
*      12PTR1      12PSV1      NUPTR1      NQPSV1      NQPRF1
*      0          0          0          0          0          #CNO5
*      RADIV1      TH1      HUUTL1      HOUTV1      TOUTL1
*      0.00174      0.04      0.0      0.0      300.0      #CNO6
*      TRJTV1      PWIN1      PHOFF1      RPWMX1      PWSCL1
*      300.0      0.0      0.0      1.0E20      1.0      #CNO7
*      OPIV1      OPOFF1      ROPMX1      QPSCL1
*      0.0      0.0      1.0E20      1.0      #CNO8

```

* SIDE TUBE

```

* ICUN02      NCCELL2      JUN3      IPOW2
*      0          1          111      0          #CNO9
*      12PTR2      12PSV2      NUPTR2      NQPSV2      NQPRF2
*      0          0          0          0          0          #CNO11
*      RADIV2      TH2      HUUTL2      HOUTV2      TOUTL2

```

* 7.72175 7.74 0.42 7.72 3.7042 7.7117
 * 1.02742 0.112 0.011742 0.55246 0.5117
 * 3.0042 0.42 0.42 1.0620 1.42 0.413
 * 0.1142 0.011742 0.011742 0.0502 0.0502 0.0414
 * 0.42 0.42 1.0620 1.42 0.413
 *
 * MAIN TUBE
 *
 P 2 0.46 0.46R 2 0.47E 0DX1
 P 7 2.4204F+03 1.593E+03P 2 3.5705+03F 0VOL1
 1.295T+03P 4 6.030E+03 1.295+03F 0FA1
 C 0.0F 0FRIC1
 C 0.0E 0FRIC1
 E 1.3F 0GRAY1
 3.480T+03P 4 1.44E+02 3.480E+03E 0H01
 1E 4 0 1E 0ICFLG1
 N -1F 0NPF1
 N 0.0F 0ALP1
 N 0.0E 0VU1
 P 0.0F 0VV1
 S 593+0F 0TL1
 S 615+0F 0TV1
 F 148.4E+5F 0P1
 P 0.0F 0PA1
 P 0.0E 0OPPP1
 F 7E 0MATID1
 R 570+0F 0TA1
 *
 * SIDE TUBE
 *
 0.050E 0DX2
 2.742E+04F 0VOL2
 1.041F+03E 0FA2
 P 0.0E 0FRIC2
 P 0.0F 0FRIC2
 C 0.0F 0GRAY2
 F 3.00391E 0H02
 0 1E 0ICFLG2
 F 1E 0NPF2
 F 0.0E 0ALP2
 P 0.0F 0VU2
 S 593+0F 0VV2
 S 615+0F 0TL2
 F 148.4E+0F 0TV2
 P 0.0E 0P2
 P 0.0F 0PAZ
 C 7F 0OPPP2
 F 570+0E 0MATID2
 R 570+0E 0TA2

 *
 TEE 104 104 CORE BYPASS
 * JCELL NODES MAT DUST 10HR
 3 4 7 0.0 1 0CN02
 *
 * MAIN TUBE
 *
 * ICUM01 NCELL01 JUN1 JUN2 IPOW1
 0 5 104 108 0 0CN03
 * IOPTR1 IOPSY1 NUPTB1 NOPSY1 NOPRF1
 0 0 0 0 0 0CN05
 * RADIN1 TH1 HOUTL1 HOUTY1 TOULL1
 0.00174 0.04 0.0 0.0 300.0 0CN06
 * TOUTV1 FRIN1 FWOFF1 RPWMX1 PWSDL1
 300.0 0.0 0.0 1.0E20 1.0 0CN07
 * DPIN1 0.0 0.0 0.0 0.0 1.0E20 1.0 0CN08
 *
 * SIDE TUBE
 *

*	170412	102LLZ	3UN3	1PUKZ	
*	3	1	112	0	*UN09
*	15PTR2	12P5V2	NUPTBZ	NQPRV2	
*	3	3	3	3	*CN11
*	RAD192	T42	MUUTLZ	HUUTV2	TUUTLZ
*	2470126	3.04	0.0	0.0	370.0
*	TMUTV2	R1N1Z	PHEFFLZ	KPMXHZ	PASCLLZ
*	300.0	0.0	0.0	1.0E20	1.0
*	2PTV2	2P0FF2	KUPMXZ	QP5LLZ	
*	0.0	0.0	1.0E20	1.0	*CN14

* MAIN TUBE

*	2	0.0L	0.40R 2	0.97E	*DX1
*	2	1.228E+03	1.673E+03R 2	3.570E+03E	*VOL1
*		1.6225E+03R 4	5.533E+03	1.295E+03E	*F&1
F		0.0F			*FRIC1
F		0.0R			*FRIC1
F		1.0F			*GRAV1
F		3.480E+03R 4	1.44E+02	3.480E+03E	*H01
F		1E 4	0	1E	*ICFLG1
F		1E			*NFF1
F		0.0F			*P1
F		0.0F			*V1
F		0.0E			*VV1
F		503.0E			*T1
F		615.0F			*TV1
F		148.4E+5E			*P1
F		0.0F			*PA1
F		0.0F			*OPPP1
F		7E			*MAT1D1
F		570.0E			*TH1

* SIDE TUBE

*		0.050F			*DX2
F		2.742E+04F			*VOL2
F		1.041E+03E			*F&2
F		0.0E			*FRIC2
F		0.0F			*FRIC2
F		0.0F			*GRAV2
F		3.0033E			*H02
F		0	1E		*ICFLG2
F		1F			*NFF2
F		0.0E			*ALP2
F		0.0E			*V2
F		0.0F			*VV2
F		503.0E			*TL2
F		615.0F			*TV2
F		148.4E+5E			*P2
F		0.0E			*PA2
F		0.0E			*OPPP2
F		7E			*MAT1D2
F		570.0E			*TH2

* - NZMAX SET TU 60 FROM 50

* THE FOLLOWING ARRAYS HAVE BEEN REPLACED BY FP=1 VALUES
* TAKEN FROM TRAC-HD2(MODULE) ANALYSIS

* - CPOWR
* - RPKF
* - ZPKTR
* - RADRO
* - PRHTP
* - NF&X
* - PGAPT

VESSEL 50 50 VESSEL

* BASED ON /P021A74.L2+3/091/L2+31ND WITH FOLLOWING MODIFICATIONS:

* OCT 1982, PTG
* + INCORPORATE DISTRIBUTED HEAT SLABS
* + CHANGE INITIAL HSTNCS FROM 5x3 X TU 570 < TO HELP INHIBIT
* FLUID BOILING AT START OF STEADY STATE RUN
* + MINOR CHANGE TO LEVEL 3 DOWNCOMER FAULT AND Z ETO .3751

* OCT 1983, PTG
* + REVISE AXIAL POWER SHAPE PER PC L TK

* AUG 1984, GLS
* + REVISE ELEVATION OF CLOKES 0.13 M LOWER

* SEP 1984, JABIRCHLEY
* + INCLUDE FRICTION FACTOR VALUES FOR ENTRY INTO, THROUGH
* AND EXIT FROM LOKE
* REVISE FLUID VOLUME AND AREA FRACTIONS

* NBSX5 12 #1UCLX# 4 #N1S5X# 4 #1UCSR# 28 #IVSSBF# 0 *CARD 2
* #1UCUR 12 #1UCLX# 2 #1UCH# 3 #1CPU# 8 #1CRL# 3 *CARD 3
* #1CRR# 3 #1UCSP# 0 #1UCSP# 0 #1UHP# 0 #1CDHC# 0 *CARD 4
* #NFFAS 0 #NFFAS# 0 #NFFAS# 0 #NVENT# 0 0 *CARD 5
* #TRPAT# 7 #1DCLX# 0 #1UDCL# 0 #NRTS# 0 0 *CARD 6

* #TRPAT# 100 #1XPW5V# 1 #NKPWATB# 25 #NRPW5V# 0 #NRPWRF# 0 *CARD 7
* #1ZPWT# 0 #1ZPWT# 1 #NZPWTB# 1 #NZPWT# 0 #NZPWF# 0 *CARD 8
* #TRFTR# 101 #NMWWT# 1 #NFCI# 1 #NFCIL# 1 #NZMAX# 60 *CARD 9

* #RADIUS# 16 #NUDESY# 10 #NUDHS# 4 #INHSMX# 1 *CARD 10
* #REACTR 0, #NEUTR# 0 #RPNDF# 1.E20 #RRPWHX# 1.E30 #RPHSCL# 1.0 *CARD 11
* #PPDR# 1E37.0E5#ZPWH# 0, #ZPWH# 0 #ZPWHX# 0 *CARD 12
* #SHFLV# 0, #FLD# 0, #PURAT# 1.336 #FUCKAC# 0.7 #HGARD# 1.0E+3 *CARD 13
* #DTXHT(11)*4.0 #DTXHT(21)*50, #DTXHT# 1.0E-3 *CARD 14

* #SKIPPER# *CARD 15
* #SKIPPER# *CARD 16
* #SKIPPER# *CARD 17

*
0.527 0.727 1.2485 0.2
1.553 1.7815 0.2
2.010 2.467 0.9245 0.2
3.400 4.8465 0.2
5.130 5.900E 0.2
0.105 0.231 0.324 0.470E #RADIUS
1.573794377 3.141592654 4.712388981 6.283135308E #THETA

* VESSEL SOURCE LEXDS

11	10	3	1	#ILHI
11	15	3	9	#ILCL
11	12	3	31	#BLHL
11	13	3	41	#BLCL
11	9	=2	105	#BYP5
11	6	=2	105	#BYP5
11	11	=2	107	#BYP5
11	8	=2	108	#BYP5
9	1	2	81	#UPINJ
9	2	2	82	#UPINJ
9	3	2	83	#UPINJ
9	7	2	84	#UPINJ
9	8	2	85	#UPINJ
9	9	2	87	#UPINJ
9	10	2	88	#UPINJ
9	11	2	89	#UPINJ
9	12	2	90	#UPINJ
8	8	3	91	#UPINJ
8	10	3	92	#UPINJ
			109	#BYP5
			110	#BYP5

	11	3	111	*BYPS
R	14	3	112	*BYPS
J	4	2	101	*HYP5
J	10	2	102	*HYP5
J	11	2	103	*HYP5
J	12	2	104	*HYP5
0.755	0.460	0.4655		*DROPWR
0.775	0.4945			*DROPWR
1.016	1.060E-3	0.000E		*DROPWR

THE FOLLOWING DATA IS FOR FH=1

R 4	1.4866E-4	1.2039E-4	0.7245E		*CDWR
	1	2	3	45	*IDR00
	8	12E			*IDR00
R 4	1.2803	1.0939	1.2355E		*RPKF
*IDUMMA1# 1.05					*ZPWTB
0.1500	1.2541	1.4586E-5			*ZPWTB
1.4995	1.0337	0.0477E			*ZPWTB
R 4	33.102E-4	127.1R 4	154.6E		*PDX
	0.0	7.7442E-4	1.5484E-35		*RADRD
2.3235E-3	3.0479E-35				*RADRD
3.3725E-3	4.6470E-3	4.7420E-35			*RADRD
5.0528E-3	5.3540E-3E				*RADRD
R 5	1	3R 2	2E		*MATRD
	0.0	37.0E6	0.3	32.425E6	S *RPWTB
	0.4	9.6748E6	1.28	5.5142E6	S *RPWTB
	1.38	3.9836E6	1.40	3.2385E6	S *RPWTB
	1.46	2.4956E6	1.52	2.6480E6	S *RPWTB
	1.59	2.3320E6	1.61	2.2712E6	S *RPWTB
	2.0	2.1547E6	3.0	2.0515E6	S *RPWTB
	4.0	1.9873E6	5.0	1.8751E6	S *RPWTB
	10.0	1.7919E6	10.0	1.7251E6	S *RPWTB
	15.0	1.6047E6	20.0	1.5183E6	S *RPWTB
	30.0	1.3462E6	40.0	1.3285E6	S *RPWTB
	60.0	1.1357E6	100.0	1.0700E6	S *RPWTB
	200.0	0.9500E6	300.0	0.8400E6	S *RPWTB
	1000000.	5.2560E4 E			*RPWTB

F	1E				*NFAX
F	0.0E				*FPU02
F	0.03E				*FTD
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
9.81010E-1	0.0	1.01030E-2	1.78300E-3	0.0	*GMIX
7.09910E-3	0.05				*GMIX
P	1.0E				*GMLES
P 4	2.4100E+6	K B	2.1200E+5 E		*PGAPT

XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
ASHA				0*3024	7	8
ASHA				5*0*5	5	5
VASH				5*0*0	6	6
VASH				5*0*0	4	5

LEVEL 7						
Nde				30*0	2	
Nde				140*4656	3	
NLN				593*04	3	
NLN				515*04	3	
AVLN-R				30*0	3	
AVLN-Z				0*0P	3	
AVLN-T				0*0P	2	
AVLN-R				0*0	2	
AVLN-Z				0*06	3	
AVLN-T				0*0	2	
AVLN-A				0*0	2	
AVLN-Y				0*0E	3	
AMATIIS				39	3	
MATIIS				570*0E	5	
ASHSTIN				0*1E	3	
ASHD-R				0*1E	3	
ZH-D-Z				3*1	2	
*HOD-T				3*1	2	
*HOD-R				0*1P	3	
EP-A-R				1*0F	3	
EP-A-Z				1*0E	3	
EP-A-T				1*0E	3	
AVOL				1*11E	5	
ACP2V-R				1*10E	5	
ACP2V-Z				0*0P	5	
ACP2V-T				0*0P	5	
ACP2L-R				30*0	6	
ACP2L-Z				30*0	6	
ACP2L-T				30*0	6	
XSH*	S260*C	580*0	0*075	0*0		
XSH*	S260*C	580*0	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
XSH*	S260*C	0*085	0*075	0*0		
ASHA				3*960*1	4	5
ASHA				5*160*0	4	5
VASH				5*380*0	4	5
VASH				5*700*0	4	5

LEVEL 1					
ACLENV				30*0	2
PSLNV				20*0	2
PLAUL				3*0	2

F	0.0	0.075	0.085	0.0925	*H5X
F	0.0	0.075	0.085	0.0925	*H5X
F	0.0	0.075	0.085	0.0925	*H5X
F	0.0	0.075	0.085	0.0925	*H5X
F	0.0	0.075	0.085	0.0925	*H5X
F	0.0E				*CFZL-T
F	0.0E				*CFZL-Z
F	0.0E				*CFZL-R
F	0.0E				*CFZY-T
F	0.0E				*CFZY-Z
F	0.0E				*CFZY-R
F	1.118E				*VOL
F	1.0F				*FA-T
R12	+4090 R 4	+582E			*FA-Z
R8	1.0 R 4	1.0 P 4	0.0 E		*FA-R
F		+1F			*HD-T
F		+1F			*HD-Z
F		+1E			*HD-R
F		570.0F			*HSTN
F		6F			*HATHS
F		0.0F			*ALPN
F		0.0E			*VVN-T
F		0.0F			*VVN-Z
F		0.0E			*VVN-R
F		0.0F			*VLN-T
F		0.0E			*VLN-Z
F		0.0F			*VLN-R
F		615.0F			*TVN
F		573.0E			*TLN
F		148.4E5E			*PN
F		0.0F			*PAN
*					
*	LEVEL 3				
*					
R 6	0.1341 S				*HSA
R 4	0.5150 S				*HSA
P 4	0.6676 S				*HSE
R 4	2.1207 E				*HSA
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.005	0.010	0.01535	*H5X
	0.0	0.025	0.035	0.0405	*H5X
	0.0	0.025	0.035	0.0405	*H5X
	0.0	0.025	0.035	0.0405	*H5X
	0.0	0.025	0.035	0.0405	*H5X
F	0.0F				*CFZL-T
R12	5.5R 4	0.0E		*FF=5.5	*CFZL-Z
F	0.0F				*CFZL-R
F	0.0E				*CFZY-T
R12	5.5R 4	0.0E		*FF=5.5	*CFZY-Z
F	0.0F				*CFZY-R
R12	.656R 4	0.582E			*VOL
R12	.7P 4	+582F			*FA-T
R12	0.448P 4	+582E			*FA-Z
R8	0.7 R 4	0.0 P 4	0.0 E		*FA-R
R12	1.27F-1R 4	0.100E			*HD-T
R12	1.22E-1P 4	0.100E			*HD-Z
R12	1.22E-2P 4	0.100E			*HD-R
F	570.0F				*HSTN
F	6E				*HATHS
F	0.0F				*ALPN

*		*.1			*VVV-T
c		0.0F			*VVV-Z
c		0.0F			*VVV-R
r		0.0F			*VLN-T
r		0.0F			*VLN-Z
r		0.0E			*VLN-R
c		515.0F			*TVN
c		593.0F			*TLN
F		148.4F5E			*PN
r		0.0E			*PAN

LEVEL 4

R 4		0.0 S			*HSA
R 4		0.0 S			*HSA
R 4		5.1703 S			*HSA
R 4		+ 1.7410 E			*HSA
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.025	0.035	*0.0405
		0.0	0.025	0.035	*0.0405
		0.0	0.025	0.035	*0.0405
		0.0	0.025	0.035	*0.0405
F		0.0F			*CFZL-T
P12		0.6F	0.0E		*CFZL-Z
F		0.0F			*CFZL-R
F		0.0F			*CFZY-T
P12		0.8F	0.0E		*CFZY-Z
F		0.0E			*CFZY-R
R12		+978R 4	+582E		*YUL
R12		0.251R 4	-582E		*FA-T
R12		0.448R 4	+582E		*FA-Z
R4		0.074	0.251R4	0.0E	*FA-R
P12		1.22E-2R 4	0.100E		*HD-T
P12		1.22E-2R 4	0.100E		*HD-Z
P12		1.22E-2R 4	0.100E		*HD-R
R		570.0E			*HSTN
F		6F			*MATHS
R		0.0E			*ALPN
R		0.0F			*VVN-T
F		0.0F			*VVV-Z
F		0.0E			*VVN-R
R		0.0E			*VLN-T
F		0.0E			*VLN-Z
F		0.0F			*VLN-R
F		515.0E			*TVN
F		593.0F			*TLN
F		148.4F5E			*PN
R		0.0E			*PAN

LEVEL 5

R 4		0.0 S			*HSA
R 4		0.0 S			*HSA
R 4		0.1273 S			*HSA
P 4		0.9277 S			*HSA
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX
		0.0	0.050	0.050	*HSX

*CFC2Y-R									
*CFC2Y-T									
*CFC2Y-U									
*CFC2Y-V									
*CFC2Y-W									
*CFC2Y-X									
*CFC2L-R									
*CFC2L-T									
*CFC2L-U									
*CFC2L-V									
*CFC2L-W									
XSH*	3040°C	560°0	520°0	0°0					
XSH*	5040°C	560°0	520°0	0°0					
XSH*	5040°C	560°0	520°0	0°0					
XSH*	5040°C	560°0	520°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSH*	5540°C	090°0	060°0	0°0					
XSHA					1826.0	6.8			
XSHA					5.6212	6.3			
XSHA					5.0	6.0			
XSHA					5.0	6.0			

9-75837

24	0.000	0.000	0.000	0.000	*HSA-R
R12	1.22E+2R 4	0.100E			*HD-T
R12	1.22E+2R 4	0.100E			*HD-Z
R12	1.22E+2R 4	0.100E			*HD-R
R	570.0F				*HSTN
F	6E				*MATHS
F	0.0F				*ALPN
F	0.0E				*VYN-T
F	0.0E				*VYN-Z
F	0.0F				*VYN-R
F	0.0F				*VLYN-T
F	0.0E				*VLYN-Z
F	0.0E				*VLYN-R
F	615.0E				*TVN
F	593.0E				*TLN
F	148.4E5E				*PN
F	0.0F				*PAN

9 LEVEL 7

F 4	0.0 5				*HSA
F 4	0.0 5				*HSA
F 4	0.2552 5				*HSA
F 4	1.9518 3				*HSA
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.050	0.050	0.06655	*HSX
	0.0	0.025	0.035	0.0405	*HSX
	0.0	0.025	0.035	0.0405	*HSX
	0.0	0.025	0.035	0.0405	*HSX
	0.0	0.025	0.035	0.0405	*HSX
	0.0	0.025	0.035	0.0405	*HSX
F	0.0F				*CFZL-T
R12	0.6E	0.0E			*CFZL-Z
F	0.0E				*CFZL-R
F	0.0E				*CFZY-T
C12	0.6F	0.0E			*CFZY-Z
F	0.0F				*CFZY-R
R12	4.72E 4	5.82E			*VOL
R12	0.2E1R 4	5.82E			*FA-T
R12	0.448R 4	5.84E			*FA-Z
R4	0.0R4	0.251R4	0.0R4	0.0E	*FA-R
R12	1.22E-2R 4	0.100E			*HD-T
R12	1.22E+2R 4	0.100E			*HD-Z
R12	1.22E+2R 4	0.100E			*HD-R
R	5.0E				*HSTN
F	6E				*MATHS
F	0.0F				*ALPN
F	0.0E				*VYN-T
F	0.0E				*VYN-Z
F	0.0E				*VYN-R
F	0.0E				*VLYN-T
F	0.0E				*VLYN-Z
F	0.0F				*VLYN-R
F	615.0E				*TVN
F	593.0E				*TLN
F	148.4E5E				*PN
F	0.0E				*PAN

9 LEVEL 9

2 4	0.0 5				*HSA
-----	-------	--	--	--	------

E S 0+0 S PHSA
 R 4 0.7552 S PHSA
 S 4 1.8518 E PHSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 0+0E0 0+0E0 0+0E655 *HSA
 0.0 0+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 0+0E0 0+0E0 0+0E655 *HSA
 0.0 0+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 0+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 0+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 0+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 0+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 J+0E0 0+0E0 0+0E655 *HSA
 0.0 0+0E0 0+0E0 0+0E655 *HSA
 E 0+0F PHZL-T
 R12 0+6F 0+0E PHZL-Z
 F 0+0E PHZL-R
 F 0+0F *CFZV-T
 R12 0+6F 0+0E *CFZV-Z
 S 0+0F *CFZV-R
 R12 478P 4 +582E *VOL
 R12 0.251P 4 +582E *FA-T
 R12 0.446P 4 +582E *FA-Z
 R4 0+0P4 0+25184 0+0R4 0+0E *FA-R
 R12 1.27E-2P 4 0+100E 0+0E *HD-T
 F12 1.27E-2P 4 0+100E 0+0E *HD-Z
 S12 1.27E-2P 4 0+100E 0+0E *HD-R
 c 570+0F *HSTN
 c 6F *MATHS
 c 0+0F *ALPH
 c 0+0F *VAN-T
 c 0+0E *VAN-Z
 c 0+0E *VAN-R
 F 0+0F *VLN-T
 S 0+0F *VLN-Z
 S 0+0F *VLN-R
 R 515+0E *TAN
 S 503+0. *TLN
 c 148.4E5F *RN
 F 0+0E *RAD

 LEVEL 2
 R 4 0.2100 S PHSA
 S 4 0.9060 S PHSA
 S 4 0.5172 S PHSA
 S 4 1.9370 E PHSA
 0.0 +00250 +00500 +00715 *HSX
 0.0 +02000 +03000 +03415 *HSX
 0.0 +025 +035 +040 S *HSX
 0.0 +025 +035 +040 S *HSX
 0.0 +025 +035 +040 S *HSX
 0.0 +025 +035 +040 E *HSX
 c 0+0F *CFZL-T
 R 4 0+0F 4 1.28K 4 0+58 4 0+0E *CFZL-Z

C	7.0E					*CFZL-T
F	0.0T					*CFZY-T
R 4	0.0P 4	LCK 4	0.0P 4	0.0E		*CFZY-Z
S	0.0F					*CFZY-R
R12	0.875P 4	.715E				*VOL
F12	0.375P 4	.500E				*FA-T
R 4	0.75P 4	U.375R 4	0.5820E			*FA-Z
R 3	0.375W 4	0.0	0.0			*FA-R
R12	1.22E+2R 4	0.100E				*HD-T
R12	1.22E+2R 4	0.100E				*HD-Z
F12	1.22E+2R 4	0.100E				*HD-R
F	570.0E					*HSTN
F	0E					*MATHS
F	0.0E					*ALPN
F	0.0E					*VVN-T
F	0.0T					*VVN-Z
F	0.0F					*VVN-R
F	0.0E					*VLN-T
F	0.0F					*VLN-Z
F	0.0F					*VLN-R
F	515.0E					*TVN
F	593.0E					*TLN
F	148.4F5E					*PN
F	0.0E					*PN
S						
S	LEVEL 10					
S						
R 4	1.0940 S					*HSX
R 4	4.2018 S					*HSX
R 4	1.7744 S					*HSX
R 4	5.0840 S					*HSX
	0.0	0.0010	.002	0.03045		*HSX
	0.0	0.0010	.002	0.03045		*HSX
	0.0	0.0010	.002	0.03045		*HSX
	0.0	0.0010	.002	0.03045		*HSX
	0.0	0.0010	.002	0.03045		*HSX
	0.0	0.0010	.002	0.03045		*HSX
	0.0	0.0010	.002	0.03045		*HSX
	0.0	0.0010	.002	0.03045		*HSX
	0.0	0.0010	.002	0.03045		*HSX
	0.0	0.0200	.030	0.34105		*HSX
	0.0	0.0200	.030	0.34105		*HSX
	0.0	0.0200	.030	0.34105		*HSX
	0.0	0.0200	.030	0.34105		*HSX
	0.0	0.0200	.030	0.34105		*HSX
	0.0	0.0250	.035	0.40005		*HSX
	0.0	0.0250	.035	0.40005		*HSX
	0.0	0.0250	.035	0.40005		*HSX
	0.0	0.0250	.035	0.4000E		*HSX
F	0.0F					*CFZL-T
F	0.0F					*CFZL-Z
S	0.0T					*CFZL-R
F	0.0F					*CFZY-T
F	0.0E					*CFZY-Z
F	0.0E					*CFZY-R
R12	0.885P 4	.715E				*VOL
F 4	1.0P 4	0.0R 4	.7150E			*FA-T
R 4	0.85P 4	0.0R 4	.2505			*FA-Z
	0.981	0.444	0.981	0.449E		*FA-R
R8 0.0	R4 0.0 R4 0.0	E				*HD-T
R12	1.22E+2R 4	0.100E				*HD-Z
R12	1.22E+2R 4	0.100E				*HD-R
R12	1.22E+2R 4	0.100E				*HSTN
F	570.0E					*MATHS
F	0E					*ALPN
F	0.0E					*VVN-T
F	0.0F					*VVN-Z
F	0.0F					*VVN-R
F	0.0F					*VLN-T
F	0.0F					*VLN-Z
F	0.0F					*VLN-R

XSH*	S014105	030*	0020*	0*0
XSH*	S014105	030*	0020*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
XSH*	S003045	200*	0100*	0*0
Ash*				0*0
Ash*				0*0
AHSA			0.74265	6 8
AHSA			2.23715	6 8
AHSA			3.58275	6 8

YEAR 12

NA*			0*0	
Nd			148.4353	
NTL*			533.30	
NTN			30.514	
VAL-H-L*			30*0	
VAL-N-L*			30*0	
VAL-H-T			30*0	
VAL-N-H			30*0	
VAL-N-A			30*0	
VAL-H-T			30*0	
VAL-PN			30*0	
WATHS			30*0	
WATIN			30*0	
WHD-B		300*	570.5	
Z-HD-Z		300*	1.222.1	
I-HD-I		300*	1.222.1	
EPA-E		300*	1.222.1	
EPA-E-L		300*	0.366.6	
EPA-I		300*	334.5	
EAPL		300*	334.6	
ECP2A-R		300*	0.391.6	
ECP2A-L		300*	0.391.6	
ECP2A-T		300*	0.391.6	
ECP2L-R		300*	30*0	
ECP2L-L		300*	30*0	
ECP2L-T		300*	30*0	
XSH*	S0060*	030*	0.570*	0*0
XSH*	S0060*	030*	0.570*	0*0
XSH*	S0060*	030*	0.570*	0*0
XSH*	S0060*	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S014105	030*	0.570*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
XSH*	S00600*	200*	0.0010*	0*0
Ash*			1.95511	7 3
Ash*			5.40671	7 8
Ash*			5.15281	7 4
Ash*			5.6912	7 3

YEAR 11

HAd*			30*0	
HAd			35.36455	
HAd			40.4646	
HAd			51.11	

0.0	*0250	*030	*03410S	*HSX
1.0	*0250	*030	*03410S	*HSX
2.0	*0250	*035	*0400S	*HSX
3.0	*0250	*035	*0400S	*HSX
4.0	*0250	*035	*0400S	*HSX
5.0	*0250	*035	*0400S	*HSX
6.0	*0250	*035	*0400E	*HSX
7.0	0.0F			*CFZL-T
8.0	0.0F			*CFZL-Z
9.0	0.0F			*CFZL-R
E	0.0E			*CFZY-T
F	0.0E			*CFZY-Z
E	0.0F			*CFZY-R
R12	1.885P 4	0.000E		*YDL
R12	0.375P 4	0.000E		*FA-T
R12	0.000F 4	0.000E		*FA-Z
R8	0.385 K4 0.0 F4 0.0 E			*FA-R
R12	1.22E+2P 4	0.100E		*HD-T
R12	1.22E+2P 4	0.100E		*HD-Z
F12	1.22E+2P 4	0.100F		*HD-R
F	570.0E			*HSTN
F	0.0F			*MATHS
F	0.0E			*ALPN
F	0.0F			*VVN-T
F	0.0F			*VVN-Z
F	0.0F			*VVN-R
F	0.0E			*VLN-T
F	0.0F			*VLY-Z
F	0.0F			*VLN-R
F	615.0F			*TYN
F	593.0F			*TLN
F	149.4F5F			*PN
F	0.0F			*SPAN

PUN DATA

0.0F		*BURN 1
559.0F		*ROTY 1
0.0F		*BURN 2
557.0F		*ROTY 2
0.0F		*BURN 3
559.0F		*ROTN 3
0.0F		*BURN 4
559.0F		*ROTN 4
0.0F		*BURN 5
559.0F		*ROTN 5
0.0F		*BURN 6
559.0E		*ROTY 6
0.0E		*BURN 7
559.0F		*ROTY 7
0.0F		*BURN 8
559.0E		*ROTN 8
0.0E		*BURN 9
559.0F		*ROTN 9
0.0F		*BURN10
559.0F		*ROTN10
0.0E		*BURN11
559.0E		*ROTN11
0.0E		*BURN12
559.0E		*ROTN12
0.0E		*BURN13
559.0E		*ROTN13
0.0E		*BURN14
559.0E		*ROTN14
0.0E		*BURN15
559.0E		*ROTN15
0.0F		*BURN16
559.0E		*ROTN16
0.0F		*BURN17
559.0E		*ROTN17
0.0F		*BURN18

2 7.7 7
***** THE STEP DATA *****
E 1.0E+5 1.0E+0 3.0E+1 1.0E+1
1.0E+5 1.0E+0 0.1E-1 1.0E+1
5.0E+0 1.0E-1 1.0E+0 1.0E+0
+1.e7

TABLE 3.5. Input deck listing for transient

LUFT-PLST-TEST LP=FP=1 TRANSIENT DECK FOR TRAC-HPF1/MOD1
 * RESTART FROM THERM LAST RELOAD OF STEADY STATE RUN
 * AXFACS AND ACCUMULATOR OF ACTIVES.
 * BREAK CONDITIONS TAKEN FROM STEADY STATE.

 *
 ******NAMELIST DATA*****
 S1N0PTS INFLOW=4, WHM12=1, U+, CHM22=0, B4+, NUAIR=0+, IUEDM3=1+, VLT=18,
 IMPR4+, YHRL1=2
 *PND
 *****MAIN CONTROL CARDS*****
 + -1 0.000000 0.000000 *MCC 01
 + 0 1 PNCMP* 53 PNUJN* 53 1 *MCC 02
 5.0E+4 5.0E+6 1.0E+5 1.0E+1 *MCC 03
 10 50 25 *MCC 04
 SYRSV* 3 PNTCH* 0 PNTCH* 0 PNTRP* 10 PNTCP* 1 *MCC 05
 *
 1 2 3 4 55 *COMP
 5 7 8 935 *COMP
 23 24 255 *COMP
 11 12 135 *COMP
 14 15 16 17 315 *COMP
 32 41 42 50 435 *COMP
 81 82 83 84 855 *COMP
 85 87 88 89 905 *COMP
 71 42 61 62 635 *COMP
 54 55 56 57 685 *COMP
 59 70 71 72 1015 *COMP
 102 103 104E *COMP
 *****SIGNAL VARIABLE DATA*****
 0
 *****CONTROL BLOCK DATA*****
 *****TRIP DATA*****
 0 0 0 0 0 *TRIP DI
 *****COMPONENT DATA*****
 *
 *****BREAK DATA*****
 BREAK 32 22 BROKEN-HUT-LEG TERMINAL
 32 1 3 1 0 *CNO2
 0 1 17 ~ 0 *CNO3
 0.875075 0.0423448 0.0 615.3 150.1E5 *CNO4
 0.0 0.0 1.0E20 0.0 0.0 *CNO5
 * 1.0 1.0 1.0 1.0 1.0 *CNO6
 3.0 150.1E5 1.0 150.1E5 5 PPT8 *CNO7
 1.0191 1.0E55
 2.0 1.81E5 3.0 1.61E5 5
 7.0 1.71E5 21.0 2.79E5 5
 24.4 2.88E5 74.8 2.60E5 5
 140.0 2.61E5 269.0 2.60E5 5
 285.0 2.85E5 357.0 2.645E5 5
 381.0 2.674E5 401.0 2.88E5 5
 457.0 3.08E5 500.0 3.09E5 5
 * 2.0 3.5E5 6.0 2.3E3 5
 * 33.0 3.6E5 53.0 3.34E5 5
 * 70.0 3.17E5 100.0 3.0E5 5
 * 310.0 2.7E5 500.0 2.7E5 5
 *****BREAK DATA*****
 BREAK 42 42 BROKEN-COLD-LEG TERMINAL
 42 1 3 1 0 *CNO2
 0 1 17 0 0 *CNO3
 1.022750 0.0472489 0.0 615.5 150.4E5 *CNO4
 0.0 0.0 1.0E20 0.0 0.0 *CNO5
 * 1.0 1.0 1.0 1.0 1.0 *CNO6
 * 1.0 1.0 1.0 1.0 1.0 *CNO7

8.1 1.0E5 1x1 1.0E4E5 S DATA
1.7131 .JLDS
2.0 1.61E3 3.0 1.51E5 S
2.3 1.71E5 2.3 2.79E5 S
2.4 2.88E5 7.0 2.40E5 S
1.0 2.61E3 26.0 2.60E5 S
2.5 2.65E5 35.0 2.645E3 S
2.1 2.694E5 40.0 2.56E5 S
4.5 2.0 500.0 3.08E5 E
* 2.0 3.5E5 6.0 2.3E5 S
* 3.0 3.6E5 53.0 3.34E5 S
* 7.0 3.17E3 1.0E11 3.0E5 S
* 31.0 2.7E5 500.0 2.7E5 E

END
***** TIME STEP DATA *****
1.0E-5 5.0E-3 1.0 10.0
1.0 0.2 2.0 0.5
1.0E-5 1.0E-2 5.0 10.0
1.0 0.5 2.0 1.0
1.0E-5 0.1 345.0 10.0
5.0 0.5 5.0 5.0
* 1.0E-5 1.0E-2 500.0 10.0
* 5.0 0.5 5.0 5.0
-1.0

NRC FORM 335
12-89
NRCM 1102
3201, 3202

U.S. NUCLEAR REGULATORY COMMISSION

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

2. TITLE AND SUBTITLE

TRAC-PF1 Code Assessment Using OECD LOFT LP-FP-1 Experiment

1. REPORT NUMBER
(Assigned by NRC Addl Vol., Suppl., Errr.,
and Addendum Numbers, if any.)

NUREG/IA-0050
ICSP-LP-FP-1

3. DATE REPORT PUBLISHED

MONTH	YEAR
-------	------

April	1992
-------	------

4. FIN OR GRANT NUMBER
A4682

5. AUTHOR(S)

F.J. Barbero

6. TYPE OF REPORT

7. PERIOD COVERED (inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Centro de Investigaciones Energeticas
Medioambientales y Tecnologicas
Consejo de Seguridad Nuclear
Madrid, Spain

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

This report assesses thermal-hydraulic aspects of LOFT LP-FP-1 experiment making use of TRAC-PF1/MOD1. LP-FP-1 experiment studies the system thermal-hydraulic and core thermal response for initial and boundary conditions similar to a large-break design basis LOCA leading to fission product release from the fuel cladding gap region. It also assesses the fission product retention effectiveness of the PWR-ECCS in best estimate conditions.

12. KEY WORDS/DESCRIPTORS (list words or phrases that will assist researchers in locating the report.)

ICAP Program
TRAC-PF1/MOD1
LP-FP-1 Experiment

13. AVAILABILITY STATEMENT

Unlimited

14. SECURITY CLASSIFICATION

(This Page)
Unclassified

(This Report)

Unclassified

15. NUMBER OF PAGES

16. PRICE

THIS DOCUMENT WAS PRINTED USING RECYCLED PAPER

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

SPECIAL FOURTH CLASS RATE
POSTAGE AND FEES PAID
USNRC
PERMIT NO. G-67

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

120555134531 1 JAN 15
US NRC-OADM
DIN FOIA & PUBLICATIONS SVCS
TPC-PDR-NURFG
P-211
WASHINGTON DC 20555