

PDR

7590-01

CORRECTION TO BIWEEKLY NOTICE  
ENTERGY OPERATIONS, INC.  
GRAND GULF NUCLEAR STATION, UNIT 1  
DOCKET NO. 50-416

On October 16, 1991, the Federal Register published the "Biweekly Notice Applications and Amendments to Operating Licenses Involving No Significant Hazards Considerations." On page 51925, for the Grand Gulf Nuclear Station, Unit 1 (application dated September 11, 1991) the first paragraph should read as follows: "The proposed amendment would modify Table 3.3.4.1-2 of the Grand Gulf Nuclear Station, Unit 1 Technical Specifications (TS) to increase the Trip Setpoint and Allowable Value for the Anticipated Transient Without Scram (ATWS) Recirculation Pump Trip System from 1095 psig to 1126 psig and from 1102 psig to 1139 psig, respectively."

Dated at Rockville, Maryland, this 28th day of October, 1991.

FOR THE NUCLEAR REGULATORY COMMISSION

*Paul W. O'Connor*

Paul W. O'Connor, Project Manager  
 Project Directorate IV-1  
 Division of Reactor Projects - III, IV and V  
 Office of Nuclear Reactor Regulation

9206050066 911028  
 PDR ADOCK 05000416  
 P PDR

*DF02 1/0*