This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the staff on this date.

Facility: Consumers Power Co. Palisades Nuclear Plant

Covert, MI 49043

Docket No: 50-255

Licensee Emergency Classification: Notification of an Unusual Event

Alert

Site Area Emergency General Emergency Not Applicable

Subject:

SHUTDOWN TO REPAIR AUXILIARY FEEDWATER PUMP

The unit was shut down on September 8, 1984, after the steam-driven auxiliary feedwater pump was found to be inoperable during a routine surveillance test. The pump tripped repeatedly on overspeed. The shutdown was required by the plant's Technical Specification when the pump could not be returned to service. The plant had been operating at 19 per cent power.

The licensee declared an Unusual Event at 12:05 a.m. (EDT), on September 9, 1984. The Unusual Event classification was terminated at 8:10 p.m., (EDT), September 9, 1984 when the plant was placed in cold shutdown.

The licensee has determined that both the turbine throttle valve and the overspeed governor will need to be repaired. The length of the outage has not been determined

The State of Michigan will to notified.

Region III (Chicago) was initially notified of the pump problem at 10:16 p.m. (EDT). September 8, 1984. This information is current as of 11 a.m., September 10, 1984.

Air Rights 1:39

of Shafer

8409140096 840910 PDR I&E PNO-III-84-072 PDR

DISTRIBUTION:

H. St. 1.39 Chairman Palladino Comm. Roberts

Comm. Asselstine Comm. Bernthal

Comm. Zech SECY

ACRS CA

PDR

Applicable Resident Site 2:03 Regions I 14, II 143, IV 153, V 2.00 Licensee (Corporate Office) 2:04

MNBB 1,36

ED0

PA

MPA

ELD

Phillips 2,17 IE

OIA

MAIL: INPO : 09 NSAC 2:07

ADM: DMB DOT: Trans Only

Willste 1.34

NMSS

RES