



**GPU Nuclear Corporation**  
Post Office Box 388  
Route 9 South  
Forked River, New Jersey 08731-0388  
609 971-4000  
Writer's Direct Dial Number:

September 7, 1984

Mr. James Lombardo  
U.S. Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Bethesda, MD 20014  
Mail Stop No. 314

Dear Mr. Lombardo

Subject: Oyster Creek Nuclear Generating Station  
Docket No. 50-219  
Technical Specification Change Request 127  
Request for Additional Information

This letter is a follow-up to our telephone conversation with Mr. J. Singh of the NRC on September 5, 1984. As discussed with Mr. Singh, the limit switches on the Reactor Building crane are redundant and diverse. The setting of these switches will be required as outlined in the GPU Nuclear procedure being developed specifically for handling the TN-9 spent fuel shipping casks. This procedure will also specify the use of a "GO-NO GO" gauge as outlined in our submittal of August 28, 1984.

Very truly yours,

Michael W. Laggart  
Manager, BWR Licensing

MWL:SDM:dam

8409140149 840907  
PDR ADOCK 05000219  
P PDR

*A001*  
*1/0* Add: James Lombardo