

February 1, 1996

Mr. Donald F. Schnell
Senior Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

SUBJECT: CHANGES TO THE CALLAWAY TECHNICAL SPECIFICATION BASES
(TAC NOS. M94271, M94272, AND M94273)

Dear Mr. Schnell:

By letters dated July 30, 1991, April 13, 1993, and January 19, 1994, you transmitted changes to the Callaway Technical Specification Bases. Some of the changes identified in these letters have been made in response to subsequent license amendment submittals. The enclosed Bases pages incorporate the remaining changes. If you have any questions, please contact me at (301) 415-1362.

Sincerely,

Original signed by:
Kristine M. Thomas, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Revised Technical
Specification Bases

cc w/encl: See next page

DISTRIBUTION

Docket File	OGC, 015B18	CGrimes
PUBLIC	WBateman	JKilcrease, Region IV
PDIV-2 Reading	JRoe	RJones
EGAI	JDyer, RIV	
ACRS	KThomas	
EPeyton	LHurley, RIV	
BJohnson, RIV	GHill (2)	

DOCUMENT NAME: TSBASES.LTR

OFC	LA:PD4-2	SRXB	PM:PD4-2
NAME	EPeyton	RJones	KThomas:pk
DATE	12/29/95	1/30/96	2/1/96

OFFICIAL RECORD COPY

9602090138 960201
PDR ADOCK 05000483
P PDR

NUC FILE CENTER COPY

RF01
1/1

February 1, 1996

Mr. Donald F. Schnell
Senior Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

SUBJECT: CHANGES TO THE CALLAWAY TECHNICAL SPECIFICATION BASES
(TAC NOS. M94271, M94272, AND M94273)

Dear Mr. Schnell:

By letters dated July 30, 1991, April 13, 1993, and January 19, 1994, you transmitted changes to the Callaway Technical Specification Bases. Some of the changes identified in these letters have been made in response to subsequent license amendment submittals. The enclosed Bases pages incorporate the remaining changes. If you have any questions, please contact me at (301) 415-1362.

Sincerely,

Original signed by:
Kristine M. Thomas, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Revised Technical
Specification Bases

cc w/encl: See next page

DISTRIBUTION

Docket File	OGC, 015B18	CGrimes
PUBLIC	WBateman	JKilcrease, Region IV
PDIV-2 Reading	JRoe	RJones
EGA1	JDyer, RIV	
ACRS	KThomas	
EPeyton	LHurley, RIV	
BJohnson, RIV	GHill (2)	

DOCUMENT NAME: TSBASES.LTR

OFC	LA:PD4-2	SRXB	PM:PD4-2
NAME	EPeyton	RJones	KThomas:pk
DATE	12/29/95	1/10/96	2/1/96

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 1, 1996

Mr. Donald F. Schnell
Senior Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

SUBJECT: CHANGES TO THE CALLAWAY TECHNICAL SPECIFICATION BASES
(TAC NOS. M94271, M94272, AND M94273)

Dear Mr. Schnell:

By letters dated July 30, 1991, April 13, 1993, and January 19, 1994, you transmitted changes to the Callaway Technical Specification Bases. Some of the changes identified in these letters have been made in response to subsequent license amendment submittals. The enclosed Bases pages incorporate the remaining changes. If you have any questions, please contact me at (301) 415-1362.

Sincerely,

Kristine M. Thomas

Kristine M. Thomas, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Revised Technical
Specification Bases

cc w/encl: See next page

cc w/encl:

Professional Nuclear
Consulting, Inc.
19041 Raines Drive
Derwood, Maryland 20855

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Mr. H. D. Bone
Supervising Engineer,
Site Licensing
Union Electric Company
Post Office Box 620
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission
Resident Inspector Office
8201 NRC Road
Stedman, Missouri 65077-1302

Mr. G. L. Randolph, Vice President
Nuclear Operations
Union Electric Company
P.O. Box 620
Fulton, Missouri 65251

Manager - Electric Department
Missouri Public Service Commission
301 W. High
Post Office Box 360
Jefferson City, Missouri 65102

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavilion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Mr. Ronald A. Kucera, Deputy Director
Department of Natural Resources
P.O. Box 176
Jefferson City, Missouri 65102

Mr. Neil S. Carns
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
P.O. Box 411
Burlington, Kansas 66839

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
6267 Delmar Boulevard
University City, Missouri 65130

Mr. Lee Fritz
Presiding Commissioner
Callaway County Court House
10 East Fifth Street
Fulton, Missouri 65151

Mr. Alan C. Passwater, Manager
Licensing and Fuels
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Mr. J. V. Laux, Manager
Quality Assurance
Union Electric Company
Post Office Box 620
Fulton, Missouri 65251

2.1 SAFETY LIMITS

BASES

2.1.1 REACTOR CORE

The restrictions of this safety limit prevent overheating of the fuel and possible cladding perforation which would result in the release of fission products to the reactor coolant. Overheating of the fuel cladding is prevented by restricting fuel operation to within the nucleate boiling regime where the heat transfer coefficient is large and the cladding surface temperature is slightly above the coolant saturation temperature.

Operation above the upper boundary of the nucleate boiling regime could result in excessive cladding temperatures because of the onset of departure from nucleate boiling (DNB) and the resultant sharp reduction in heat transfer coefficient. DNB is not a directly measurable parameter during operation and therefore THERMAL POWER and Reactor Coolant Temperature and Pressure have been related to DNB. This relation has been developed to predict the DNB flux and the location of DNB for axially uniform and non-uniform heat flux distributions. The local DNB heat flux ratio, DNBR, defined as the ratio of the heat flux that would cause DNB at a particular core location to the local heat flux, is indicative of the margin to DNB.

The DNB design basis is as follows: there must be at least a 95 percent probability that the minimum DNBR of the limiting rod during Condition I and II events is greater than or equal to the DNBR limit of the DNB correlation being used (the WRB-2 correlation for VANTAGE 5 fuel in this application). The correlation DNBR limit is established based on the entire applicable experimental data set such that there is a 95 percent probability with 95 percent confidence that DNB will not occur when the minimum DNBR is at the DNBR limit (1.17 for the WRB-2 correlation).

In meeting this design basis, uncertainties in plant operating parameters, nuclear and thermal parameters, and fuel fabrication parameters are considered statistically such that there is at least a 95% probability with 95% confidence level that the minimum DNBR for the limiting rod is greater than or equal to the DNBR limit. The uncertainties in the above plant parameters are used to determine the plant DNBR uncertainty. This DNBR uncertainty, combined with the correlation DNBR limit, establishes a design DNBR value which must be met in plant safety analyses using values of input parameters without uncertainties. For Callaway, the design DNBR values are 1.33 and 1.34 for thimble and typical cells, respectively, for VANTAGE 5 fuel. In addition, margin has been maintained by meeting safety analysis DNBR limits of 1.61 and 1.69 for thimble and typical cells, respectively, for VANTAGE 5 fuel.

The curves of Figure 2.1-1 show the loci of points of THERMAL POWER, Reactor Coolant System pressure and average temperature below which the calculated DNBR is no less than the design DNBR value or the average enthalpy at the vessel exit is less than the enthalpy of saturated liquid.

SAFETY LIMITS

BASES

2.1.1 REACTOR CORE (Continued)

The curves are based on a measured nuclear enthalpy rise hot channel factor, $F_{\Delta H}^N$, as specified in the Core Operating Limits Report (COLR), and a reference cosine with a peak of 1.55 for axial power shape. An allowance is included for an increase in $F_{\Delta H}^N$ at reduced power based on the equation given in the COLR.

These limiting heat flux conditions are higher than those calculated for the range of all control rods fully withdrawn to the maximum allowable control rod insertion assuming the axial power imbalance is within the limits of the $f_1(\Delta I)$ function of the Overtemperature trip. When the axial power imbalance is not within the tolerance, the axial power imbalance effect on the Overtemperature ΔT trips will reduce the setpoints to provide protection consistent with core safety limits.

2.1.2 REACTOR COOLANT SYSTEM PRESSURE

The restriction of this safety limit protects the integrity of the Reactor Coolant System (RCS) from overpressurization and thereby prevents the release of radionuclides contained in the reactor coolant from reaching the containment atmosphere.

The reactor vessel, pressurizer, and the RCS piping and valves are designed to Section III of the ASME Code for Nuclear Power Plants which permits a maximum transient pressure of 110% (2735 psig) of design pressure. The Safety Limit of 2735 psig is therefore consistent with the design criteria and associated Code requirements.

The entire RCS is hydrotested at greater than or equal to 125% (3110 psig) of design pressure to demonstrate integrity prior to initial operation.

REACTIVITY CONTROL SYSTEMS

BASES

MODERATOR TEMPERATURE COEFFICIENT (Continued)

The most negative MTC value, equivalent to the most positive moderator density coefficient (MDC), was obtained by incrementally correcting the MDC used in the FSAR analyses to nominal operating conditions. These corrections involved: (1) a conversion of the MDC used in the FSAR accident analyses to its equivalent MTC, based on the rate of change of moderator density with temperature at RATED THERMAL POWER conditions, and (2) adding margin to this value to account for the largest difference in MTC observed between an EOL, all rods withdrawn, RATED THERMAL POWER condition and an envelope of those most adverse conditions of moderator temperature and pressure, rods inserted to their insertion limits, axial power skewing, and xenon concentration that can occur in normal operation within Technical Specification limits and lead to a significantly more negative EOL MTC at RATED THERMAL POWER. These corrections transformed the MDC value used in the FSAR accident analyses into the limiting End of Cycle Life (EOL) MTC value. The 300 ppm surveillance limit MTC value represents a conservative value (with corrections for burnup and soluble boron) at a core condition of 300 ppm equilibrium boron concentration and is obtained by adding an allowance for burnup and soluble boron concentration changes to the limiting EOL MTC value.

The Surveillance Requirements for measurement of the MTC at the beginning and near the end of the fuel cycle are adequate to confirm that the MTC remains within its limits since this coefficient changes slowly due principally to the reduction in RCS boron concentration associated with fuel burnup.

3/4.1.1.4 MINIMUM TEMPERATURE FOR CRITICALITY

This specification ensures that the reactor will not be made critical with the Reactor Coolant System average temperature less than 551°F. This limitation is required to ensure: (1) the moderator temperature coefficient is within its analyzed temperature range, (2) the trip instrumentation is within its normal operating range, (3) the pressurizer is capable of being in an OPERABLE status with a steam bubble, and (4) the reactor vessel is above its minimum RT_{NDT} temperature.

3/4.1.1.5 CORE REACTIVITY

When measured core reactivity is within $\pm 1\% \Delta k/k$ of the predicted value at steady state thermal conditions, the core is considered to be operating within acceptable design limits. Since deviations from the limit are normally detected by comparing predicted and measured steady state RCS critical boron concentrations, the difference between measured and predicted values would be approximately 100 ppm (depending on the boron worth) before the limit is reached. These values are well within the uncertainty limits for analysis of boron concentration samples, so that spurious violations of the limit due to uncertainty in measuring the RCS boron concentration are unlikely.

The acceptance criteria for core reactivity ($\pm 1\% \Delta k/k$ of the predicted value) ensures plant operation is maintained within the assumptions of the safety analyses.

INSTRUMENTATION

BASES

3/4.3.3.5 REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the Remote Shutdown System ensures that sufficient capability is available to permit shutdown and maintenance of HOT SHUTDOWN of the facility from locations outside of the control room and that a fire will not preclude achieving safe shutdown. The Remote Shutdown System transfer switches, power circuits, and control circuits are independent of areas where a fire could damage systems normally used to shutdown the reactor. This capability is required in the event control room habitability is lost and is consistent with General Design Criteria 3 and 19 and Appendix R of 10 CFR Part 50.

3/4.3.3.6 ACCIDENT MONITORING INSTRUMENTATION

The OPERABILITY of the accident monitoring instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables following an accident. This capability is consistent with the recommendations of Regulatory Guide 1.97, Revision 2, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant Conditions During and Following an Accident," December 1980, and NUREG-0737, "Clarification of TMI Action Plan Requirements," November 1980, as clarified in FSAR Appendix 7A.

CONTAINMENT SYSTEMS

BASES

3/4.6.1.4 INTERNAL PRESSURE

The limitations on containment internal pressure ensure that: (1) the containment structure is prevented from exceeding its design negative pressure differential with respect to the outside atmosphere of 3.0 psig, and (2) the containment peak pressure does not exceed the design pressure of 60 psig during steam line break conditions.

The maximum peak pressure expected to be obtained from a steam line break event is 48.1 psig. The limit of 1.5 psig for initial positive containment pressure will limit the total pressure to 49.6 psig, which is less than design pressure and is consistent with the safety analyses.

3/4.6.1.5 AIR TEMPERATURE

The limitations on containment average air temperature ensure that the overall containment average air temperature does not exceed the initial temperature condition assumed in the safety analysis for a steam line break accident. Measurements shall be made at all listed locations, whether by fixed or portable instruments, prior to determining the average air temperature.

3/4.9 REFUELING OPERATIONS

BASES

3/4.9.1 BORON CONCENTRATION

The limitations on reactivity conditions during REFUELING ensure that: (1) the reactor will remain subcritical during CORE ALTERATIONS, and (2) a uniform boron concentration is maintained for reactivity control in the water volume having direct access to the reactor vessel. The limitation on K_{eff} of no greater than 0.95 is sufficient to prevent reactor criticality during refueling operations. The locking closed of the required valves during refueling operations precludes the possibility of uncontrolled boron dilution of the filled portions of the Reactor Coolant System via the CVCS blending tee. This action prevents flow to the RCS of unborated water by closing all automatic flow paths from sources of unborated water. Administrative controls will limit the volume of unborated water which can be added to the refueling pool for decontamination activities in order to prevent diluting the refueling pool below the limits specified in the LCO. These limitations are consistent with the initial conditions assumed for the boron dilution incident in the safety analyses.

3/4.9.2 INSTRUMENTATION

The OPERABILITY of the Source Range Neutron Flux Monitors ensures that redundant monitoring capability is available to detect changes in the reactivity condition of the core.

3/4.9.3 DECAY TIME

The minimum requirement for reactor subcriticality prior to movement of irradiated fuel assemblies in the reactor vessel ensures that sufficient time has elapsed to allow the radioactive decay of the short-lived fission products. This decay time is consistent with the assumptions used in the fuel handling accident radiological consequence and spent fuel pool thermal-hydraulic analyses.

3/4.9.4 CONTAINMENT BUILDING PENETRATIONS

The requirements on containment building penetration closure and OPERABILITY ensure that a release of radioactive material within containment will be restricted from leakage to the environment. The OPERABILITY and closure restrictions are sufficient to restrict radioactive material release from a fuel element rupture based upon the lack of containment pressurization potential while in the REFUELING MODE.

The OPERABILITY of this system ensures the containment purge penetrations will be automatically isolated upon detection of high radiation levels within containment. The OPERABILITY of this system is required to restrict the release of radioactive materials from the containment atmosphere to the environment.

The restriction on the setpoint for GT-RE-22 and GT-RE-33 is based on a fuel handling accident inside the Containment Building with resulting damage to one fuel rod and subsequent release of 0.1% of the noble gas rod activity, except for 0.3% of the Kr-85 rod activity. The setpoint concentration of $5E-3$ $\mu\text{Ci/cc}$ is equivalent to approximately 150 mR/hr submersion dose rate.