

ENCLOSURE 1

NOTICE OF VIOLATION

GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station

Docket No. 50-219
License No. DPR-16

During an NRC inspection conducted March 29, 1992, through May 2, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, (1992), the violation is listed below:

Technical Specification 6.8.1 requires that written procedures shall be established, implemented, and maintained that meet or exceed the requirements of Regulatory Guide (Reg Guide) 1.33, revision 2, "Quality Assurance Program Requirements (Operation)." Reg Guide 1.33, Appendix A requires that procedures be written for surveillance testing of the containment spray system.

Station procedure 604.4.007, revision 13, "Containment Spray and Emergency Service Water System 1 Pump Operability and Inservice Test," step 6.20, requires the containment spray and emergency service water (ESW) pumps to be secured if inservice testing (IST) is not required to be performed.

Contrary to the above, on April 20, 1992, the control room operator failed to implement procedure 604.4.007 in that the containment spray and ESW pumps were not secured when performance of IST was not required before proceeding to the next step in the procedure. As a result of this action the system was aligned to spray the containment when the operator placed the system control switch in the AUTO 1 position and approximately 825 gallons of water were sprayed into the containment.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, GPU Nuclear Corporation is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region I, and a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Where good cause is shown consideration will be given to extending the response time.

Dated at: King of Prussia, PA
this 2d day of Jun 1992

OFFICIAL RECORD COPY

9206090045 920602
PDR ADDCK 05000219
Q PDR