

ADMINISTRATIVE CONTROLS

ORGANIZATION

RECORDS

6.2.3.4 Records of activities performed by the ISEG shall be prepared, maintained, and forwarded each calendar month to the Vice President - Nuclear Safety Assessment and Support. |

6.2.4 SHIFT TECHNICAL ADVISOR

Normally, the Shift Technical Advisor (STA) shall be a dedicated position. If, however, a dedicated STA cannot be provided on a shift, then the Assistant Station Shift Supervisor (ASSS) shall function in a dual role (SRO/STA) and assume the duties of the Shift Technical Advisor (STA) when the Emergency Plan is activated in OPERATIONAL CONDITIONS 1, 2 or 3. The STA shall provide advisory technical support to the Shift Supervisor in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to safe operation of the unit. The STA (and the ASSS, when fulfilling the role of the STA) shall have a bachelor's degree in a physical science, engineering, or a Professional Engineer's license issued by examination, and shall have received specific training in the response and analysis of the unit for transients and accidents, and in unit design and layout, including the capabilities of instrumentation and controls in the control room.

6.3 FACILITY STAFF QUALIFICATIONS

Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI/ANS 3.1-1978 for comparable positions, except for the Manager Radiation Protection who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975.

6.4 TRAINING

A retraining and replacement training program for the unit staff shall be maintained under the direction of the Manager Training, shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI/ANS 3.1-1978 and 10 CFR 55, and shall include familiarization with relevant industry operational experience. A training program for the Fire Brigade shall be maintained under the direction of the Manager Training and the Supervisor - Fire Protection Nuclear and shall meet or exceed the requirements of Appendix R to 10 CFR 50.

9602120266 960207
PDR ADOCK 05000410
P PDR