

February 8, 1996

Mr. T. C. McMeekin  
Vice President, McGuire Site  
Duke Power Company  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078

SUBJECT: EVALUATION OF THE SECOND 10-YEAR INTERVAL INSPECTION PROGRAM PLAN  
REQUEST FOR RELIEF FOR MCGUIRE NUCLEAR STATION, UNIT 1  
(TAC NO. M91457)

Dear Mr. McMeekin:

The NRC staff, with technical assistance from its contractor, the Idaho National Engineering Laboratory (INEL), has reviewed and evaluated the information provided by your letter dated January 20, 1995, related to the second 10-year interval inservice inspection (ISI) program plan request for relief for the McGuire Nuclear Station, Unit 1. The NRC staff concluded that your proposed alternative, to perform the Code-required VT-3 visual examination of the reactor pressure vessel interior at the end of Cycle 10 refueling outage, is authorized pursuant to 10 CFR 50.55a(a)(3)(ii). The NRC staff's evaluation and conclusions are contained in the enclosed Safety Evaluation.

Sincerely,  
Original signed by:

Eugene V. Imbro, Acting Director  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-369

Enclosure: As stated

cc w/encl: See next page

Distribution:

Docket File	RZimmerman	VNurses	EMerschhoff, RII
PUBLIC	SVarga	OGC	RCrlenjak, RII
PDII-2 RF	JZwolinski	GHill(2)	WRussell/FMiraglia
LWiens	ACRS	LBerry	GTracy

DOCUMENT NAME: G:\MCGUIRE\MCG91457.RR

OFFICE	DRPE/PD22/LA	DRPE/PD22/PM	OGC	DRPE/PD22/D
NAME	L. BERRY	V. NURSES	M. Young	E. Imbro
DATE	1/18/96	1/19/96	1/25/96	2/7/96
COPY	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY

9602120302 960208  
PDR ADOCK 05000369  
Q PDR

NRC FILE CENTER COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

February 8, 1996

Mr. T. C. McMeekin  
Vice President, McGuire Site  
Duke Power Company  
12700 Hagers Ferry Road  
Huntersville, North Carolina 23078

SUBJECT: EVALUATION OF THE SECOND 10-YEAR INTERVAL INSPECTION PROGRAM PLAN  
REQUEST FOR RELIEF FOR MCGUIRE NUCLEAR STATION, UNIT 1  
(TAC NO. H91457)

Dear Mr. McMeekin:

The NRC staff, with technical assistance from its contractor, the Idaho National Engineering Laboratory (INEL), has reviewed and evaluated the information provided by your letter dated January 20, 1995, related to the second 10-year interval inservice inspection (ISI) program plan request for relief for the McGuire Nuclear Station, Unit 1. The NRC staff concluded that your proposed alternative, to perform the Code-required VT-3 visual examination of the reactor pressure vessel interior at the end of Cycle 10 refueling outage, is authorized pursuant to 10 CFR 50.55a(a)(3)(ii). The NRC staff's evaluation and conclusions are contained in the enclosed Safety Evaluation.

Sincerely,

A handwritten signature in black ink, appearing to read "E. Imbro".

Eugene V. Imbro, Acting Director  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-369

Enclosure: As stated

cc w/encl: See next page

Mr. T. C. McMeekin  
Duke Power Company

McGuire Nuclear Station

cc:

Mr. Paul R. Newton  
Duke Power Company, PB05E  
422 South Church Street  
Charlotte, North Carolina 28242-0001

County Manager of Mecklenburg County  
720 East Fourth Street  
Charlotte, North Carolina 28202

Mr. J. E. Snyder  
Regulatory Compliance Manager  
Duke Power Company  
McGuire Nuclear Site  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078

J. Michael McGarry, III, Esquire  
Winston and Strawn  
1400 L Street, NW.  
Washington, DC 20005

Senior Resident Inspector  
c/o U. S. Nuclear Regulatory  
Commission  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078

Mr. Peter R. Harden, IV  
Account Sales Manager  
Westinghouse Electric Corporation  
Power Systems Field Sales  
P. O. Box 7288  
Charlotte, North Carolina 28241

Dr. John M. Barry  
Mecklenburg County  
Department of Environmental  
Protection  
700 N. Tryon Street  
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director  
Department of Environmental,  
Health and Natural Resources  
Division of Radiation Protection  
P. O. Box 27687  
Raleigh, North Carolina 27611-7687

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of  
Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Mr. G. A. Copp  
Licensing - EC050  
Duke Power Company  
526 South Church Street  
Charlotte, North Carolina 28242

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW. Suite 2900  
Atlanta, Georgia 30323

Elaine Wathen, Lead REP Planner  
Division of Emergency Management  
116 West Jones Street  
Raleigh, North Carolina 27603-1335