

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard
Vice President Plant Operations

February 3, 1996

WO 96-0020

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Reference: Letter WO 95-0187 Dated December 20, 1995, from
O. L. Maynard, WCNO, to USNRC
Subject: Docket No. 50-482: Additional Change to Technical
Specifications 3/4.6.1.1 and 3/4.6.1.3 to Incorporate
Option B of 10 CFR 50, Appendix J

Gentlemen:

This letter provides an additional change to the proposed technical specification changes submitted by the Reference in an application for amendment to Facility Operating License No. NPF-42 for the Wolf Creek Generating Station (WCGS). This additional change is being submitted, in response to conversations on January 25, 1996, with the NRC Project Manager for WCGS.

The Reference submitted a license amendment request which proposed to revise Technical Specification 3/4.6.1.1, "Containment Integrity," and 3/4.6.1.3, "Containment Air Locks," and to add Technical Specification 6.8.4i, "Containment Leakage Rate Testing Program." These proposed revisions implement the new performance based leakage rate testing program as permitted by 10 CFR 50, Appendix J. The Reference also proposed a revision to Technical Specification 1.7e, "Containment Integrity," to reference Technical Specification 4.6.1.1.c instead of Technical Specification 4.6.1.1.d since the technical specification would be renumbered by the proposed changes addressed above. An additional change to Technical Specification 1.7e is being proposed based on discussions with the Project Manager to identify that the containment leakage rates determined by Specification 4.6.1.1.c are within limits. Specification 4.6.1.1.c refers to the Containment Leakage Rate Testing Program in Section 6.8.4i for the leakage rate limits.

The conclusions of the Safety Evaluation and No Significant Hazards Consideration Determination provided in the Reference remain valid.

In accordance with 10 CFR 50.91, a copy of this information, with the attachment, is being provided to the designated Kansas State official.

9602120304 960208
PDR ADOCK 05000482
P PDR


P.O. Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831

An Equal Opportunity Employer M/F/HG/VET

Ad 17
11

If you have any questions concerning this matter, please contact me at (316) 364-8831, extension 4450, or Mr. Richard D. Flannigan, at extension 4500.

Very truly yours,



Otto L. Maynard

OLM/jra

Attachment: I - Revised Technical Specification Change

cc: G. W. Allen (KDHE), w/a
L. J. Callan (NRC), w/a
W. D. Johnson (NRC), w/a
J. F. Ringwald (NRC), w/a
J. C. Stone (NRC), w/a

STATE OF KANSAS)
) SS
COUNTY OF COFFEY)

Otto L. Maynard, of lawful age, being first duly sworn upon oath says that he is Vice President Plant Operations of Wolf Creek Nuclear Operating Corporation; that he has read the foregoing document and knows the content thereof; that he has executed that same for and on behalf of said Corporation with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.



BY *Otto L. Maynard*
Otto L. Maynard
Vice President
Plant Operations

SUBSCRIBED and sworn to before me this 8TH day of FEBRUARY, 1996.

Mary E. Gifford.
Notary Public

Expiration Date 12/09/1999