



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

SEQUOYAH NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 218  
License No. DPR-77

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated December 8, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 218, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 45 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebdon, Director  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: February 7, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 218

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

Revise the Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page is identified by the captioned amendment number and contain marginal lines indicating the areas of change.

REMOVE

3/4 6-16a

INSERT

3/4 6-16a

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- b. By verifying, that on recirculation flow, each pump develops a differential pressure of greater than or equal to 143 psid at greater than or equal to 4750 gpm when tested pursuant to Specification 4.0.5. | R84
  - c. At least once per 18 months during shutdown, by:
    - 1. Verifying that each automatic valve in the flow path actuates to its correct position on a Containment Pressure High-High test signal.
    - 2. Verifying that each spray pump starts automatically on a Containment Pressure High-High test signal.
  - d. At least once per 10 years by performing an air or smoke flow test through each spray header and verifying each spray nozzle is unobstructed. |
- 4.6.2.1.2 Each RHR spray train shall be demonstrated OPERABLE: | R73
- a. Per surveillance requirements 4.5.2.b.2 and 4.5.2.f.3; |
  - b. At least once per 10 years by performing an air or smoke flow test through each spray header and verifying each spray nozzle is unobstructed. | R73



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-328

SEQUOYAH NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 208  
License No. DPR-79

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated December 8, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 208, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance, to be implemented within 45 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hedden, Director  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications

Date of Issuance: February 7, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 208

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Revise the Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page is identified by the captioned amendment number and contain marginal lines indicating the areas of change.

REMOVE

3/4 6-16a

INSERT

3/4 6-16a

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- b. By verifying that on recirculation flow, each pump develops a differential pressure of greater than or equal to 143 psid at greater than or equal to 4750 gpm when tested pursuant to Specification 4.0.5. | R71
  - c. At least once per 18 months during shutdown, by:
    - 1. Verifying that each automatic valve in the flow path actuates to its correct position on a Containment Pressure High-High test signal.
    - 2. Verifying that each spray pump starts automatically on a Containment Pressure High-High test signal.
  - d. At least once per 10 years by performing an air or smoke flow test through each spray header and verifying each spray nozzle is unobstructed. |
- 4.6.2.1.2 Each RHR Spray train shall be demonstrated OPERABLE: | R61
- a. Per surveillance requirements 4.5.2.b.2 and 4.5.2.f.3; |
  - b. At least once per 10 years by performing an air or smoke flow test through each spray header and verifying each spray nozzle is unobstructed. | R61