



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to, Post Office Box 767
Chicago, Illinois 60690

September 4, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: LaSalle County Station Unit 2
Reactor Scram on Low Control Rod
Drive Pump Discharge Pressure
Modification
NRC Docket No. 50-374

- References (a): NPF-18 License Condition 2.C.(7) Low Pressure in Pump Discharge of the Control Rod Drive.
- (b): FSAR Section 4.6.2 pages 4.6-9, 26, 31.
- (c): FSAR Section 7.2 pages 7.2-8, 10, 65, 65a, 65n, 65c, 92, 93, Figure 7.2-5.
- (d): SSER #2 4.6.2, Control Rod System.
- (e): SSER #7 7.2 Control Rod Drive Low Changing Pressure Scram.
- (f): Telecon with Dr. A. Bournia et. al. on August 15, 1984.

Dear Mr. Denton:

The following is in response to a discussion between the NRC and CECO in the conference call of August 15, 1984 (reference (f)), and provides clarification on the subject of automatic reactor scram from Control Rod Drive low charging pressure.

The purpose of the CRD low charging pressure scram is to assure that there is adequate pressure in the charging header to accomplish CRD rod insertion into the core. An automatic reactor scram from CRD low charging pressure has been interlocked with the reactor mode switch.

The reactor mode switch activates this interlock when the mode switch is placed into the refuel or start-up position only. A new alarm has been installed on the main control room annunciator (Hathaway) indicating CRD charging water pressure - low. With the mode switch in refuel or start-up, a reactor scram will occur within 10 secs. of this alarm, should the header charging pressure remain below the setpoint.

8409180083 840904
PDR ADOCK 05000374
P PDR

8001
1/0

September 4, 1984

The automatic reactor scram on CRD low charging pressure is not activated when the reactor mode switch is placed into the run position because the accumulators are not necessary for rod insertion at vessel operating pressure. The auto-scrام is also not activated in the shutdown mode since no control rods may be withdrawn in this mode.

Should vessel operating pressure decrease when in the run mode, MSIV closure will initiate at greater than or equal to 854 psig and within 1 second of the beginning of closure of these valves, reactor scram and control rod insertion will occur. At this point, assuming low accumulator or header pressure exists, there will be sufficient vessel pressure for control rod insertion.

From the above discussion, it has been shown that the automatic scram on CRD low header pressure is not a necessary function when operating in the run mode. Portions of IEEE-279 require that if a protective action has been bypassed or deliberately rendered inoperative, this fact should be indicated in the control room. Since the auto-scrام function on low CRD header pressure is not a required action in the run mode, we believe there is no need to annunciate in the main control room when this function is not active.


During our review of this subject in the LaSalle FSAR, we determined that the installation description of the four new pressure transmitters needs clarification. The FSAR presently indicates that the four new pressure transmitters are attached to two pressure taps on header downstream of the CRD pumps. The actual plant installation of these four new pressure transmitters is connected to individual process taps (four separate process taps to the charging header).

Applicable portions of the LaSalle FSAR will be revised to correct and clarify the interlocks and annunciation associated with this SCRAM logic at the next annual update.

Please direct any questions you may have concerning this matter to this office.

One signed original and fifteen copies of this letter are provided for MRC use.

Very truly yours,



J. G. Marshall
Nuclear Licensing Administrator

lm

cc: A. Bournia - NRR
Resident Inspector - LSCS