DCS No: 50443920605 Date: June 5, 1992

PRELIATINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE-PNO-I-92-28

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility:	Licensce Emergency Classification:
North Atlantic Energy Service Co. Seabrook Nuclear Station New Hampshire DN 50-443	Notification of Unusual Even Alert Site Area Emergency General Emergency X Not Applicable

Subject: OFFSITE FIRE NEAR SEABROOK STATION

One June 5, 1992, at about 10:00 a.m., a fire started in a trailer at the Rockingham Fireworks Company. The fire was located approximately one mile west of the Seabrook Station, just outside the owner controlled area. The licensee learned about the fire at about 10:10 a.m., based on a report from a security guard at the North Gate. Based on the guard's observations from his location near the scene, there was no indication of an explosion, however, he did report that he heard what sounded to be firecrackers going off. The fire was extinguished at 10:30 a.m. by the local Fire Department. One individual suffered minor injuries.

The fire had no impact on the plant. Smoke from the fire was blowing away from the site and had no affect on the transmission lines. During the fire the licensee provided backup emergency equipment to the scene, however, it was not required. Additionally, the licensee monitored the status of the fire via phone link between the access control point at the North Gate and the main control room.

The licensee has not made a press release.

Region I Public Affairs is prepared to respond to media inquiries.

The State of New Ham-shire and the Commonwealth of Massachusetts were informed.

CONTACT: William Lazarus (FTS) 346-5231

9206120166 920605 PDR 1&E PNO-I-92-028 PDR

2

DISTRIBUTION:						
OWFN Chairman Selin		MNBB AEOD	L-St-	NL RES	Mail:	ADM:DMB DOT:Trans only
Comm.	Curtiss	IRM OIG	PDR		NRC Ops	
OCA OGC	EDO NMSS NRR OE	Phillips ACRS				
	OSP	Regional Offices		RI Resider	nt Office	3.30 pm
		EWW OIG		Licensee:		3: 33/0
		0.0		Lateriace,	(Reactor I	licensees)

Region I Form 83 (Rev. July 1991)