



**ENTERGY**

Entergy Operations, Inc.  
P.O. Box 8  
Greene LA 70066  
Tel: 504-739-6774

**R. F. Burski**  
Director  
Nuclear Safety  
Waterford 3

W3F1-92-0169  
A4.05  
QA

June 10 1992

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Subject: Waterford 3 SES  
Docket No. 50-382  
License No. NPF-38  
Withdrawal of Technical Specification Bases Change Request

Gentlemen:

The purpose of this letter is to withdraw a Technical Specification Bases Change Request, originally submitted per Louisiana Power and Light (LP&L) letter no. W3P88-1810, dated October 6, 1988. In that letter, LP&L requested an update to Waterford 3 Technical Specification Bases 3/4.3.1 and 3/4.3.2 concerning main feedwater isolation valve (MFIV) response tests. On April 17, 1990, LP&L furnished additional information to the NRC in letter no. W3P90-0222. The latter correspondence discussed the adjustment to the MFIV closure times and explained that the bases change was requested for clarification of the relationship between full flow and zero flow closure times, with respect to technical specification requirements.

Entergy Operations, Inc. is currently in the process of reevaluating vendor supplied information furnished in support of the previously submitted bases change. As such, Entergy will withdraw the previously submitted bases change. Following completion of the reevaluation, Waterford 3 will submit a separate bases change or a technical specification revision, if deemed appropriate.

Please note that this information was discussed with a member of your staff in a telecon on March 19, 1992. Should you have any questions or comments regarding this withdrawal, please contact B.R. Loetzerich at (504) 739-6636.

Very truly yours,

RFB/BRL/ssf

cc: R.D. Martin (NRC Region IV), D.L. Wigginton (NRC-NRR),  
R.B. McGehee, N.S. Reynolds, NRC Resident Inspectors Office,  
Administrator Radiation Protection Division (State of Louisiana),  
American Nuclear Insurers

9206120346 920610  
PDR ADOCK 05000382  
P PDR

A001  
1/0