

June 13, 1995

Mr. George A. Hunger, Jr.
Director-Licensing, MC 62A-1
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, PA 19087-0195

SUBJECT: PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 (TAG NO. 91928)

Dear Mr. Hunger:

The Commission has issued the enclosed Amendment No. 206 to Facility Operating License No. DPR-44 for the Peach Bottom Atomic Power Station, Unit No. 2. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated March 30, 1995, as supplemented by letter dated May 26, 1995.

This amendment revises TS Section 4.7.D.1.b(1) by adding a footnote to exempt the High Pressure Coolant Injection motor-operated valve MO-2-23-015 from quarterly stroke testing requirements until refueling outage 2R011.

You are requested to inform the staff when you have implemented the provision of this amendment. This request affects nine or fewer respondents and therefore, is not subject to the Office of Management and Budget review under PL 96-511.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's BiWeekly Federal Register Notice.

Sincerely,
/s/

Joseph W. Shea, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-277

- Enclosures: 1. Amendment No. 206 to License No. DPR-44
- 2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION:

Docket File	MO'Brien	CGrimes	JColaccino
PUBLIC	JShea	FCherny	NGilles
PDI-2 Reading	OGC	ACRS(4)	
SVarga	OPA	OC/LFDCB	
JZwolinski	GHill(2)	CAnderson, RGN-I	
JStolz	JZimmerman	FCherny	

OFC : PDI-2/LA : PDI-2/PM : PDI-2/PM : EMEB/SC : OGC : PDI-2/D :
 NAME : MO'Brien : JZimmerman:rb:JShea : FCherny : JStolz :
 DATE : 6/1/95 : 6/1/95 : 6/1/95 : 6/1/95 : 6/6/95 : 6/13/95 :

9602160053 950613
PDR ADOCK 05000277
PDR

9602160053

JFOJ
1/1



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

June 13, 1995

Mr. George A. Hunger, Jr.
Director-Licensing, MC 62A-1
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, PA 19087-0195

SUBJECT: PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 (TAC NO. 91928)

Dear Mr. Hunger:

The Commission has issued the enclosed Amendment No. 206 to Facility Operating License No. DPR-44 for the Peach Bottom Atomic Power Station, Unit No. 2. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated March 30, 1995, as supplemented by letter dated May 26, 1995.

This amendment revises TS Section 4.7.D.1.b(1) by adding a footnote to exempt the High Pressure Coolant Injection motor-operated valve MO-2-23-015 from quarterly stroke testing requirements until refueling outage 2R011.

You are requested to inform the staff when you have implemented the provision of this amendment. This request affects nine or fewer respondents and therefore, is not subject to the Office of Management and Budget review under PL 96-511.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's BiWeekly Federal Register Notice.

Sincerely,

A handwritten signature in black ink, appearing to read "Joseph W. Shea", written over a white background.

Joseph W. Shea, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-277

Enclosures: 1. Amendment No. 206 to
License No. DPR-44
2. Safety Evaluation

cc w/encls: See next page

Mr. George A. Hunger, Jr.
PECO Energy Company

Peach Bottom Atomic Power Station,
Units 2 and 3

cc:

J. W. Durham, Sr., Esquire
Sr. V.P. & General Counsel
PECO Energy Company
2301 Market Street, S26-1
Philadelphia, Pennsylvania 19101

Mr. Rich R. Janati, Chief
Division of Nuclear Safety
Pennsylvania Department of
Environmental Resources
P. O. Box 8469
Harrisburg, Pennsylvania 17105-8469

PECO Energy Company
ATTN: Mr. G. R. Rainey, Vice President
Peach Bottom Atomic Power Station
Route 1, Box 208
Delta, Pennsylvania 17314

Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

PECO Energy Company
ATTN: Regulatory Engineer, A4-5S
Peach Bottom Atomic Power Station
Route 1, Box 208
Delta, Pennsylvania 17314

Public Service Commission of Maryland
Engineering Division
Chief Engineer
6 St. Paul Centre
Baltimore, MD 21202-6806

Resident Inspector
U.S. Nuclear Regulatory Commission
Peach Bottom Atomic Power Station
P.O. Box 399
Delta, Pennsylvania 17314

Mr. Richard McLean
Power Plant and Environmental
Review Division
Department of Natural Resources
B-3, Tawes State Office Building
Annapolis, Maryland 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. John Doering, Chairman
Nuclear Review Board
PECO Energy Company
965 Chesterbrook Boulevard
Mail Code 63C-5
Wayne, Pennsylvania 19087

Mr. Roland Fletcher
Department of Environment
201 West Preston Street
Baltimore, Maryland 21201

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

A. F. Kirby, III
External Operations - Nuclear
Delmarva Power & Light Company
P.O. Box 231
Wilmington, DE 19899